State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II – Skill Sheet Index

1/10/11

SS#	Skill Sheet Title	NFPA 1001 Objectives Addressed 2008 Edition
5.1.1.2A	Donning Personal Protective Clothing	5.1.2.1, 5.1.2.1(3)(C), 6.3.1(B), 6.3.2(B)
5.1.2.1A	Donning SCBA	5.1.2.1, 5.1.2.1(3)(C), 6.3.1(B), 6.3.2(B)
5.1.2.1B	Doffing SCBA	5.1.2.1, 5.1.2.1(3)(C), 6.3.1(B), 6.3.2(B)
6.2.1A	Complete a Basic Incident Report	6.2.1, 6.2.1(A)(B)
6.2.2A	Communicate the Need for Assistance	6.2.2, 6.2.2(A)(B)
6.3.1A	Foam Stream Application	6.3.1, 6.3.1(A)(B)
6.3.1B	Open Pans of Combustible Liquids	6.3.1, 6.3.1(A)(B)
6.3.1C	Open Liquid Fires	6.3.1, 6.3.1(A)(B)
6.3.2A	Interior Attack – Grade Level	6.3.2, 6.3.2(A)(B), 6.2.2, 6.2.2(A)(B)
6.3.2B	Interior Attack – Above Grade	6.3.2, 6.3.2(A)(B), 6.2.2, 6.2.2(A)(B)
6.3.2C	Interior Attack – Below Grade	6.3.2, 6.3.2(A)(B), 6.2.2, 6.2.2(A)(B)
6.3.3A	Flammable Gas Cylinder	6.3.3, 6.3.3(A)(B)
6.3.4A	Preserve Evidence of Cause and Origin	6.3.4, 6.3.4(A)(B)
6.4.1A	Vehicle Extrication	6.4.1, 6.4.1(A)(B)
6.4.1B	Crib and Shore Vehicle	6.4.1, 6.4.1(A)(B)
6.4.2A	Rescue Team Assistance	6.4.2, 6.4.2(A)(B), 6.4.1, 6.4.1(A)(B)
6.5.1A	Private Dwelling Inspection	6.5.1, 6.5.1(A)(B)
6.5.2A	Prepared Program Presentation	6.5.2, 6.5.2(A)(B)
6.5.2B	Preparation of Documentation	6.5.2, 6.5.2(A)(B)
6.5.3A	Prepare a Pre-Incident Survey	6.5.3, 6.5.3(A)(B)
6.5.4A	Portable Power Plant Maintenance	6.5.4, 6.5.4(A)(B)
6.5.4B	Power Tool Selection	6.5.4, 6.5.4(A)(B), 6.4.1, 6.4.1(A)(B)
6.5.5A	Annual Service Test	6.5.5, 6.5.5(A)(B)

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **5.1.1.2A**	**Primary Task:**	**Donning Personal Protective Clothing**	
Objective(s) : 5.1.2.1, 5.1.2.1 (3)(c), 6.3.1(B), 6.3.2(B)	NFPA Standard: 1001	Candidate #	

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	* Don boots / trousers with suspenders on shoulders		
2	Dons hood (if applicable), extending around neck under coat or ear flaps down		
3	* Fastens coat completely with collar up and neck tab secured		
4	* Dons helmet, chin strap secured under chin		
5	* Dons gloves		
6	* Dons PPE completely within one minute		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **4**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **5.1.2.1A**	**Primary Task:**	**Donning Self Contained Breathing Apparatus (SCBA)**	
Objective(s) : 5.1.2.1, 5.1.2.1(3)(c), 6.3.1(B), 6.3.2(B)	NFPA Standard: 472	Candidate #	

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	* Wears full protective clothing properly		
2	* Checks that cylinder is full (or at least 90%)		
3	* Opens cylinder fully		
4	Dons harness and connects waist straps		
5	Checks facepiece seal		
6	Turns on PASS Device (if applicable)		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **4**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **5.1.2.1B**	**Primary Task:**	**Doffing Self Contained Breathing Apparatus (SCBA)**	
Objective(s) : 5.1.2.1, 5.1.2.1(3)(c), 6.3.1(B), 6.3.2(B)	NFPA Standard: 472	Candidate #	

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	* Deactivate Positive Pressure if Required		
2	Closes cylinder fully		
3	* Breathes off excess air, closes remaining valves (if applicable)		
4	Disconnect regulator from facepiece		
5	Removes facepiece, buckles and straps properly		
6	* Gently lowers unit to ground or case		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **4**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.2.1A**	**Primary Task:**	**Complete Basic Incident Report**	
Objective(s) : 6.2.1, 6.2.1(A)(B)		NFPA Standard: 1001	Candidate #

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	* Records department FDID, and incident number		
2	* Records number of personnel responding		
3	Records Officer in charge (OIC)		
4	Records name and address of occupant/owner		
5	* Records type of structure		
6	* Records type of incident		
7	* Records type of action taken		
8	Records damage estimate		
9	Records remarks/comments		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**6**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.2.2A**	**Primary Task:**	**Communicate the Need for Assistance**	
Objective(s) : 6.2.2, 6.2.2(A)(B)	NFPA Standard: 1001	Candidate #	

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	Describes alarm assignments based on department policy and procedures		
2	Demonstrates use of alerting procedures		
3	Demonstrates use of incident assignments		
4	Demonstrates fireground radio reporting procedures		
5	Demonstrates procedures for requesting additional response or resources		
6	Demonstrates radio traffic procedures		
7	* Demonstrates evacuation signal procedures		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **5**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.3.1A**	**Primary Task:**	**Foam Stream Application**	
Objective(s) : 6.3.1, 6.3.1(A)(B)		NFPA Standard: 1001	Candidate #

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	* Wears appropriate protective clothing properly		
2	* Assembles foam appliances and / or equipment		
3	* Matches nozzle to eductor		
4	Introduces eductor to foam concentrate		
5	Identifies fuel type (hydrocarbon or polar solvent)		
6	Sets the eductor metering valve to proper concentrate percentage rating		
7	Opens nozzle properly		
8	* Applies foam by demonstrating appropriate method as directed		
9	Establishes an adequate vapor suppression blanket		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **6**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.3.1B**	**Primary Task:**	**Fire Suppression – Open Pans of Combustible Liquids (with water)**	
Objective(s) : 6.3.1, 6.3.1(B)		NFPA Standard: 1001	Candidate #

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	* Wears approved full protective equipment with SCBA correctly		
2.	Describes the volume of water needed (extinguishment and reach)		
3	* Approaches liquid using wide fog patttrn		
4	* Avoids stepping into pools of fuel and fuel runoff		
5	Locates and operates shut-off valve (where applicable)		
6	Retreats using wide fog pattern		
7	Follows all safety precautions		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**5**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.3.1C**	**Primary Task:**	**Open Liquid Fires**	
Objective(s) : 6.3.1, 6.3.1(B)	NFPA Standard: 1001	Candidate #	

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	* Wears approved full protective equipment with SCBA correctly		
2	Selects appropriate nozzle		
3	Approaches fire, maintaining team communication		
4	Operates fog nozzle on approach (wide fog pattern, if applicable)		
5	* Opens nozzle fully		
6	Extinguishes fire		
7	Executes effective retreat with wide fog pattern		
8	Follows all safety precautions		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **6**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.3.2A**	**Primary Task:**	**Fire Suppression – Interior Attack at Grade Level**	
Objective(s) : 6.3.2, 6.3.2(A)(B), 6.2.2, 6.2.2(A)(B)	NFPA Standard: 1001	Candidate #	

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	* Wears full protecting clothing and SCBA correctly		
2	Advances hoseline properly from one of the following methods • Minuteman Load • Preconnected Flat Load with loops • Triple Layer Load		
3	* Clears remaining hose from hose bed and flakes out hoseline before advancing to fire area		
4	Calls for water		
5	* Bleeds air from line, adjusts nozzle pattern		
6	* Maintains communication with other team members		
7	Advances hose line into structure maintaining team and hoseline integrity		
8	Locates fire		
9	* Extinguishes fire using the appropriate attack method		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**4**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.3.2B**	**Primary Task:**	**Fire Suppression – Interior Attack Above Ground**
Objective(s) : 6.3.2, 6.3.2(A)(B), 6.2.2, 6.2.2(A)(B)	NFPA Standard: 1001	Candidate #

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	* Wears full protecting clothing and SCBA properly		
2	Advances hoseline properly from one of the following loads: • Minuteman Load • Preconnected Flat Load with loops • Triple-Layer Load		
3	* Clears remaining hose from hose bed and flakes out hoseline before advancing to fire area		
4	* Calls for water, bleeds air from line, adjusts nozzle pattern		
5	Maintains communication with other team members		
6	Ascends stairway quickly, properly and safely to avoid injury hazards		
7	Locates fire		
8	* Extinguishes fire using the appropriate attack method		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**4**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.3.2C**	**Primary Task:**	**Fire Suppression – Interior Attack Below Grade**	
Objective(s) : 6.3.2, 6.3.2(A)(B), 6.2.2, 6.2.2(A)(B)	NFPA Standard: 1001	Candidate #	

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	* Wears full protective equipment and SCBA properly		
2	Advances hoseline properly from one of the following loads:		
	• Minuteman Load		
	• Preconnected Flat Load with loops		
	• Triple Layer Load		
3	* Clears remaining hose from hose bed and flakes out hoseline before advancing to fire area		
4	* Calls for water, opens bail or throttle to bleed air, adjust nozzle pattern		
5	* Maintains communication with other team members		
6	Enters structure safely (per building conditions) maintains team and hoseline integrity		
7	* Descends stairway guickly, properly and safely to avoid injury hazards		
8	Locates fire		
9	* Extinguishes fire using the appropriate attack method		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**6**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.3.3A**	**Primary Task:**	**Flammable Gas Cylinder**	
Objective(s) : 6.3.3, 6.3.3(A)(B)		NFPA Standard: 1001	Candidate #

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	* Wears approved full protective equipment and SCBA correctly		
2	* Selects appropriate nozzle		
3	Approaches fire from a safe distance		
4	Demonstrates proper nozzle techinque (cooling cylinder)		
5	* Closes shutoff valve		
6	Applies additional agent to prevent re-ignition		
7	Executes proper and effective retreat		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **5**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.3.4A**	**Primary Task:**	**Preserve Evidence of Cause and Origin**	
Objective(s) : 6.3.4, 6.3.4(A)(B)	NFPA Standard: 1001	Candidate #	

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	* Wears appropriate protective clothing properly		
2	Locates potential fire origin		
3	* Identifies evidence that needs to be preserved		
4	* Demonstrates proper techniques for protecting evidence		
5	Recognizes possible cause		
6	Records findings (diagrams, sketches, camera, videos)		
7	Protects evidence and scene		
8	* Notifies investigating agency		
9	Documents activity log		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **6**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.4.1A**	**Primary Task:**	**Vehicle Extrication**	
Objective(s) : 6.4.1A, 6.4.1(A)(B)		NFPA Standard: 1001	Candidate #

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	* Wears approved full protective clothing (eye protection) correctly		
2	Secures scene		
3	Communicates potential hazards at incident		
4	Confirms vehicle is stabilized		
5	* Protects victim		
6	Communicates with victim		
7	* Follows all safety procedures		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **5**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.4.1B**	**Primary Task:**	**Crib and Shore Vehicle**	
Objective(s) : 6.4.1, 6.4.1(A)(B)	NFPA Standard: 1001	Candidate #	

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	* Wears approved full protective clothing properly		
2	Selects proper materials for cribbing		
3	Places pieces into psition safely		
4	* Checks stabilization		
5	* Proper lifting techniques when cribbing vehicle (back to vehicle)		
6	* Proper hand placement when cribbing vehicle		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **4**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.4.2A**	**Primary Task:**	**Rescue Team Assistance**	
Objective(s) : 6.4.2, 6.4.2(A)(B), 6.4.1, 6.4.1(A)(B)	NFPA Standard: 1001	Candidate #	

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	* Wears approved full protective clothing properly		
2	* Identifies and states application for various types of rescue tools upon request		
3	Retrieves various types of rescue tools upon request		
4	Establishes public barriers		
5	Indicates potential hazards		
6	Assists rescue teams as a member of a team upon request		
7	* Follows safety procedures		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **5**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.5.1A**	**Primary Task:**	**Private Dwelling Inspections**	
Objective(s) : 6.5.1, 6.5.1(A)(B)		NFPA Standard: 1001	Candidate #

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	* Have and wear appropriate identification, dresses in appropriate attire		
2	* Obtains permission from occupant		
3	Checks heating appliances		
4	Checks electrical distribution and appliances		
5	Checks cooking appliances		
6	Checks for smoking materials		
7	Checks attic and basement areas		
8	Checks yard and exterior areas		
9	Checks attached and detached buildings		
10	* Communicates findings to occupant/exit interview		
11	Follows proper procedures and record keeping		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **8**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.5.2A**	**Primary Task:**	**Presentation of a Prepared Program**
Objective(s) : 6.5.2, 6.5.2(A)(B)	NFPA Standard: 1001	Candidate #

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	* Selects lesson materials on safety-related topic for specific audience		
2	Wears appropriate attire for presentation		
3	Introduces self		
4	Introduces topic		
5	Presents lesson		
6	Provides correct answers to questions		
7	Summarizes lesson		
8	* Documents presentation for records		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **6**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.5.2B**	**Primary Task:**	**Preparation of Documentation**	
Objective(s) : 6.5.2, 6.5.2(B)		NFPA Standard: 1001	Candidate #

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	Identify program title		
2	Document participants by:		
	Name		
	Number		
3	Enter student evaluations		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **3**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.5.3A**	**Primary Task:**	**Prepare a Pre-Incident Survey**	
Objective(s) : 6.5.3, 6.5.3(A)(B)		NFPA Standard: 1001	Candidate #

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	Identifies department pre-plan format		
2	Records property name, address, owner, and emergency contact numbers accurately		
3	Reports occupancy type and capacity		
4	Identifies utilities present, shutoff methods and locations		
5	Reports type of construction		
6	Identifies building materials		
7	Identifies special hazards		
8	* Identifies fire protection system(s) present		
9	* Identifies alerting system present		
10	Draws appropriate annotated sketch(es) from pre-incident data		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **7**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.5.4A**	**Primary Task:**	**Portable Power Plant Maintenance**	
Objective(s) : 6.5.4, 6.5.4(A)(B)		NFPA Standard: 1001	Candidate #

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	Maintains / services properly		
2	Checks gas / fuel		
3	Checks Oil		
4	Starts unit properly		
5	Shuts down unit properly		
6	Demonstrates safety devices / equipment on the unit		
7	* Tags for damaged and / or documents service records		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **5**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.5.4B**	**Primary Task:**	**Power Tool Selection**	
Objective(s) : 6.5.4, 6.5.4(A)(B), 6.4.1, 6.4.1(A)(B)	NFPA Standard: 1001	Candidate #	

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	* Wears approved full protective clothing properly		
2	Selects proper tool for operation		
3	Completes all proper connections		
4	* Operates equipment properly including safety features		
5	* Tags for damaged equipment and / or documents for service records		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**4**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter II

Skill Sheet No. **6.5.5A**	**Primary Task:**	**Annual Service Test**	
Objective(s) : 6.5.5, 6.5.5(A)(B)		NFPA Standard: 1001	Candidate #

Performance Evaluation Sheet

Tasks:

		1st	2nd
1	* Wears appropriate protective clothing properly		
2	Verbalizes maximum allowable hose length for test based on current NFPA 1962 standard		
3	* Prepars hoseline and couplings for testing		
4	* Establishes safety barrier		
5	Tightens all connections		
6	Removes all air from hose lines		
7	* Verbalizes test pressure compliance based on current NFPA 1962 standard		
8	Verbalizes time limit for service test		
9	* Checks all couplings for hose separation		
10	* Records results of hose test		
11	Verbalizes removal of damaged equipment from service		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **8**

1/10/11

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.