

## Fire Fighter I Practical Skill Evaluation Sheets Index

SS#	Skill Sheet Title	NFPA 1001 Objectives Addressed 2008 Edition
5.1.1.2A	Don Personal Protective Equipment	5.1.2
5.1.1.2B	Tie Knots and Hoist Tools	5.1.2
5.1.1.2C	Select Rope and Tie Knots	5.1.2
5.1.1.2D	Secure with Rope	5.1.2
5.2.1A	Receive Notification of Reported Emergency or Business Call	5.2.1;5.2.1(A)(B);5.2.2;5.2.2(A)(B)
5.2.3A	Radio Procedures on the Fire Ground	5.2.3;5.2.3(A)(B)
5.3.1A.1	SCBA – Replacement of Cylinder (Station)	5.3.1;5.3.1(A)(B)
5.3.1A.2	SCBA -- Replacement of Cylinder (Fire Ground )	5.3.1;5.3.1(A)(B)
5.3.1B	Don SCBA	5.3.1;5.3.1(A)(B)
5.3.1C	SCBA – Ready for Immediate Use (Non-Fire Ground)	5.3.1;5.3.1(A)(B)
5.3.1D	Restricted Use of SCBA (Horizontal)	5.3.1;5.3.1(A)(B);5.3.9;5.3.9(A)(B)
5.3.1E	Restricted Use of SCBA (Vertical)	5.3.1;5.3.1(A)(B);5.3.9;5.3.9(A)(B)
5.3.1F	SCBA Failure Procedures	5.3.1;5.3.1(A)(B)
5.3.2A	Safely Mount, Ride, Dismount Apparatus	5.3.2;5.3.2(A)(B)
5.3.3A	Deploy Traffic and Scene Control Devices	5.3.3;5.3.3(A); 5.3.2;5.3.2(A)(B)
5.3.4A	Identify and Carry Tools	5.3.4;5.3.4(A)(B)
5.3.4B	Forcible Entry - Door	5.3.4;5.3.4(A)(B)
5.3.4C	Open Window (Non-Destructive)	5.3.4;5.3.4(A)(B)
5.3.4D	Forcible Entry – Partition Walls	5.3.4;5.3.4(A)(B)
5.3.5A.1	Action When Trapped/Disoriented with Hose	5.3.5;5.3.5(A)(B)
5.3.5A.2	Action When Trapped/Disoriented without Hose	5.3.5;5.3.5(A)(B)
5.3.6A	24' Extension Ladder – Carry, Raise, Extend (one person)	5.3.6;5.3.6(A)(B)
5.3.6B	24' Extension Ladder – Remove, lower (one person)	5.3.6;5.3.6(A)(B)
5.3.6C	24-28' Extension Ladder -- Carry, Raise, Extend (two person)	5.3.6;5.3.6(A)(B)
5.3.6D	24-28' Extension Ladder -- Remove, lower (two persons)	5.3.6;5.3.6(A)(B)
5.3.6E	14' – 20' Single Ladder – Carry, Raise (one person)	5.3.6;5.3.6(A)(B)
5.3.6F	14'-20' Single Ladder – Remove, lower (one person)	5.3.6;5.3.6(A)(B)
5.3.6G	35' Extension Ladder – Carry, Raise, Extend (three person)	5.3.6;5.3.6(A)(B)
5.3.6H	35' Extension Ladder – Remover, lower (three person)	5.3.6;5.3.6(A)(B)
5.3.7A	Fire Suppression – Vehicle Fires	5.3.7;5.3.7(A)(B)
5.3.8A	Fire Suppression – Class A Stack	5.3.8;5.3.8(A)(B)
5.3.8B	Fire Suppression – Dumpster/Storage	5.3.8;5.3.8(A)(B)
5.3.8C	Deploy Master Stream Device	5.3.8;5.3.8(A)(B)
5.3.9A	Rescue With SCBA – Obscured Visibility	5.3.9;5.3.9(A)(B);5.3.1;5.3.1(A)(B)
5.3.9B	Remove By Ladder (conscious person)	5.3.9;5.3.9(A)(B);5.3.6;5.3.6(A)(B)
5.3.9C	Remove By Ladder (unconscious person)	5.3.9;5.3.9(A)(B);5.3.6;5.3.6(A)(B)
5.3.9D	Conduct Primary Search	5.3.9;5.3.9(A)(B);5.3.1;5.3.1(A)(B)
5.3.9E	Conduct Secondary Search	5.3.9;5.3.9(A)(B);5.3.1;5.3.1(A)(B)

## Fire Fighter I Practical Skill Evaluation Sheets Index

SS#	Skill Sheet Title	NFPA 1001 Objectives Addressed 2008 Edition
5.3.9F	Drags (one person)	5.3.9;5.3.9(A)(B)
5.3.9G	Carries (two person)	5.3.9;5.3.9(A)(B)
5.3.10A.1	Fire Suppression – Interior Structure At Grade Level	5.3.10;5.3.10(A)(B)
5.3.10A.2	Fire Suppression – Interior Structure Above Grade Level	5.3.10;5.3.10(A)(B)
5.3.10A.3	Fire Suppression – Interior Structure Below Grade Level	5.3.10;5.3.10(A)(B)
5.3.10B.1	Advance Pre-Connected Flat Load	5.3.10;5.3.10(A)(B);5.3.8;8.3.8(A)(B)
5.3.10B.2	Advance Minuteman Load	5.3.10;5.3.10(A)(B);5.3.8;8.3.8(A)(B)
5.3.10B.3	Advance Triple-Layer Load	5.3.10;5.3.10(A)(B);5.3.8;8.3.8(A)(B)
5.3.10B.4	Advance Shoulder-Load Method (two person)	5.3.10;5.3.10(A)(B);5.3.8;8.3.8(A)(B)
5.3.10B.5	Advance Working Line Drag Method (two person)	5.3.10;5.3.10(A)(B);5.3.8;8.3.8(A)(B)
5.3.10C	Advance Hoseline	5.3.10;5.3.10(A)(B)
5.3.10D	Operate Charged Hoseline from Ground Ladder (two person)	5.3.6;5.3.6(A)(B); 5.3.10;5.3.10(A)(B)
5.3.10E	Use of Nozzle	5.3.10;5.3.10(A)(B);5.3.8;8.3.8(A)(B)
5.3.10F	Replace Burst Hose	5.3.10;5.3.10(A)(B)
5.3.10G	Add Length of Hose	5.3.10;5.3.10(A)(B)
5.3.10H	Couple/Uncouple Hose	5.3.10;5.3.10(A)(B)
5.3.10J	Remove Hose From Upper Floor	5.3.10;5.3.10(A)(B)
5.3.10K	Remove Hose to Minimize Water Damage	5.3.10;5.3.10(A)(B)
5.3.11A	Leg Lock on a Ground Ladder	5.3.11;5.3.11(A)(B);5.3.12;5.3.12(A)(B) 5.3.6;5.3.6(A)(B)
5.3.11B	Horizontal Ventilation – Clearing Window	5.3.11;5.3.11(A)(B);5.3.6;5.3.6(A)(B)
5.3.11C	Hydraulic Ventilation	5.3.11;5.3.11(A)(B)
5.3.11D	Negative-Pressure Ventilation	5.3.11;5.3.11(A)(B)
5.3.11E	Positive-Pressure Ventilation	5.3.11;5.3.11(A)(B)
5.3.12A.1	Deploy Roof Ladder	5.3.12;5.3.12(A)(B);5.3.6;5.3.6(A)(B)
5.3.12A.2	Lower and Remove Roof Ladder (two person)	5.3.12;5.3.12(A)(B);5.3.6;5.3.6(A)(B)
5.3.12B	Climb Ladder with Tool	5.3.12;5.3.12(A)(B); 5.3.11;5.3.11(A)(B)
5.3.12C	Determine Roof Integrity	5.3.12;5.3.12(A)(B)
5.3.12D.1	Flat Roof Ventilation	5.3.12;5.3.12(A)(B)
5.3.12D.2	Roof Ventilation – Pitched	5.3.12;5.3.12(A)(B)
5.3.13A	Expose Hidden Fire	5.3.13;5.3.13(A)(B);5.3.10;5.3.10(A)(B)
5.3.14A	Salvage Cover Deployment (two person)	5.3.14;5.3.14(A)(B)
5.3.14B	Construct a Catch-all (two person)	5.3.14;5.3.14(A)(B)
5.3.14C	Construct a Water Chute (two person)	5.3.14;5.3.14(A)(B)
5.3.14D	Route/Remove Water and Debris (vertical)	5.3.14;5.3.14(A)(B)
5.3.14E	Route/Remove Water and Debris (horizontal)	5.3.14;5.3.14(A)(B)
5.3.14F	Route/Remove Water and Debris (below grade)	5.3.14;5.3.14(A)(B)
5.3.14G	Close up Building	5.3.14;5.3.14(A)(B)

## Fire Fighter I Practical Skill Evaluation Sheets Index

SS#	Skill Sheet Title	NFPA 1001 Objectives Addressed 2008 Edition
5.3.14H	Separate/Remove Charred Material	5.3.14;5.3.14(A)(B);5.3.13;5.3.13(A)(B)
5.3.14J	Stop Water Flow from Sprinkler	5.3.14;5.3.14(A)(B)
5.3.15A	Static Source Drafting	5.3.15;5.3.15(A)(B)
5.3.15B	Hydrant to Pump Connection	5.3.15;5.3.15(A)(B)
5.3.15C.1	Hydrant Connection (forward lay)	5.3.15;5.3.15(A)(B)
5.3.15C.2	Hydrant Connection (reverse lay)	5.3.15;5.3.15(A)(B)
5.3.15D	Fire Department Connection	5.3.15;5.3.15(A)(B)
5.3.15E	Standpipe Operation	5.3.15;5.3.15(A)(B)
5.3.16A	Extinguish Class A Fire with Portable Extinguisher	5.3.16;5.3.16(A)(B)
5.3.16B	Extinguish Class B Fire with Portable Extinguisher	5.3.16;5.3.16(A)(B)
5.3.16C	Extinguish Class C Fire with Portable Extinguisher	5.3.16;5.3.16(A)(B)
5.3.17A	Safety Procedures for Lighting Equipment	5.3.17;5.3.17(A)(B)
5.3.18A	Control Utility Services	5.3.18;5.3.18(A)(B)
5.3.19A	Attack Ground Cover Fire	5.3.19;5.3.19(A)(B)
5.3.19B	Fill, Use and Maintain Backpack Pump or Vest	5.3.19;5.3.19(A)(B)
5.3.19C	Use of Hand Tools While Building a Fire Control Line	5.3.19;5.3.19(A)(B)
5.5.1A	Clean, Maintain, and Inspect Ground Ladders	5.5.1;5.5.1(A)(B)
5.5.1B	Daily/Monthly SCBA Inspection	5.5.1;5.5.1(A)(B)
5.5.1C	Salvage Cover Maintenance and Inspection	5.5.1;5.5.1(A)(B)
5.5.1D	Safety Rope Inspection and Bag Storage	5.5.1;5.5.1(A)(B)
5.5.2A	Hose Rolls and Loads	5.5.2;5.5.2(A)(B)
5.5.2B	Clean, Maintain, and Inspect Hose	5.5.2;5.5.2(A)(B)



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.1.1.2A</b>	<b>Primary Task:</b>	<b>Don Personal Protective Equipment</b>	
Objective(s) : 5.1.2	NFPA Standard:	1001	Candidate #	
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	*Dons boots / trousers with suspenders on shoulders			
2	Dons hood (if applicable), extending around neck under coat			
3	*Fastens coat completely with collar up and neck tab secured			
4	Dons gloves			
5	*Dons helmet, ear flaps down and chin strap secured under chin			
6	*Dons PPE completely within one minute			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>5</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.1.1.2B <b>Primary Task:</b> Tie Knots and Hoist Tools				
Objective(s) :	5.1.2	NFPA Standard: 1001	Candidate # <span style="border: 1px solid black; display: inline-block; width: 40px; height: 20px; vertical-align: middle;"></span>	
Performance Evaluation Sheet				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	*Selects correct rope			
2	Verbalizes correct knot for the task			
3	*Ties correct knots to hoist tools / hose			
4	Hoists tools / hose successfully			
5	Ties tag lines properly (when applicable)			
* Critical Task    Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>		Total number tasks candidate must complete to pass <b>4</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.1.1.2C</b>	<b>Primary Task:</b>	<b>Select Rope and Tie Knots</b>		
Objective(s) :	5.1.2	NFPA Standard:	1001	Candidate # <span style="border: 1px solid black; display: inline-block; width: 50px; height: 20px;"></span>	
<b>Performance Evaluation Sheet</b>					
<b>Tasks:</b>					
				<b>1st</b>	<b>2nd</b>
1	*Selects proper type, size and length of rope				
2	Ties Clove Hitch with overhand safety knot				
3	Ties Figure of Eight on a Bight with overhand safety knot				
4	Ties Becket (Sheet Bend) with two safety knots				
5	Ties Half Hitch				
6	Ties Single Figure of Eight with overhand safety knot				
* Critical Task		Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>	
				Total number tasks candidate must complete to pass <b>5</b>	

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #: 5.1.1.2D</b>		<b>Primary Task: Secure with Rope</b>	
Objective(s) : 5.1.2	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Selects correct rope		
2	Uses correct knot for selected object		
3	*Ties knot correctly		
4	*Secures object correctly		
* Critical Task      Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>	
		Total number tasks candidate must complete to pass	
		<b>3</b>	

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.2.1A	<b>Primary Task:</b> Receive Notification of Reported Emergency or Business Call		
<b>Objective(s) :</b> 5.2.1, 5.2.1(A), 5.2.1(B), 5.2.2, 5.2.2(A), 5.2.2(B)	<b>NFPA Standard:</b> 1001	<b>Candidate #</b>	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Answers phone, radio, and intercom in accordance with department's SOPs or other guidelines (name, dept name and state emergency)		
2	Obtains caller's name and address if possible		
3	Determines if caller has an emergency or business (non-emergency) call		
4	Focuses on obtaining pertinent information (location, type of incident)		
5	Repeats information back to caller		
6	Forwards information to proper authority (department SOPs)		
7	*Documents information completely and correctly		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>	
		Total number tasks candidate must complete to pass <b>5</b>	

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.2.3A	<b>Primary Task:</b> Radio Procedures on the Fire Ground															
Objective(s) : 5.2.3, 5.2.3(A),5.2.3(B)	NFPA Standard: 1001	Candidate # <span style="border: 1px solid black; display: inline-block; width: 50px; height: 20px; vertical-align: middle;"></span>														
<b>Performance Evaluation Sheet</b>																
<b>Tasks:</b>																
		<table border="1" style="float: right; border-collapse: collapse;"> <thead> <tr> <th style="width: 50px;">1st</th> <th style="width: 50px;">2nd</th> </tr> </thead> <tbody> <tr><td style="height: 20px;"></td><td style="height: 20px;"></td></tr> </tbody> </table>	1st	2nd												
1st	2nd															
1 *Identifies Unit ID (radio number, firefighter number, apparatus number based on SOP)																
2 Identifies intended receiver of message (other firefighter, Command, Dispatch)																
3 Depresses button and transmits message based on radio equipment (repeater)																
4 Voice is clear and audible																
5 Transmits concise message																
6 Awaits acknowledgment from intended receiver																
* Critical Task      Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>5</b>														

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.1A.1	<b>Primary Task:</b> SCBA – Replacement of Cylinder (Station)	
Objective(s) : 5.3.1, 5.3.1(A), 5.3.1(B)	NFPA Standard: 1001	Candidate # <span style="border: 1px solid black; display: inline-block; width: 50px; height: 20px;"></span>
<b>Performance evaluation sheet</b>		
<b>Tasks:</b>		
		1st    2nd
1	Removes unit from storage (case, mounting)	
2	Places unit on clean, level surface	
3	Confirms that cylinder valve is closed or bleeds pressure from hoses	
4	Disconnects high pressure coupling from cylinder	
5	Releases cylinder from harness assembly	
6	Checks integrity of replacement cylinder (damage, hydrostatic test date)	
7	*Ensures replacement cylinder is at least 90% full	
8	Places cylinder in harness, checks “O” ring integrity, and secures high pressure coupling	
9	Opens cylinder and checks for low air alarm activation	
10	*Compares gauges verifying within 100 psi and no leakage	
11	*Shuts off unit and bleeds pressure from hoses	
12	Returns unit to storage	
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>
		Total number tasks candidate must complete to pass <b>9</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*





State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.1B	<b>Primary Task:</b> Don SCBA		
Objective(s) : 5.3.1, 5.3.1(A), 5.3.1(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	*Wears full protective clothing properly		
2	*Checks that cylinder is full (or at least 90%)		
3	*Opens cylinder fully, communicates low air alarm activation		
4	*Compares gauges (within 100 psi)		
5	Dons harness assembly as directed, connects waist straps, tightens waist and shoulder straps		
6	Dons facepiece, tightens straps, checks seal		
7	Connects regulator to facepiece		
8	Activates PASS device (if manual)		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>6</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #: 5.3.1C</b>	<b>Primary Task: SCBA Ready for Immediate Use (Non-Fire Ground)</b>	
Objective(s) : 5.3.1, 5.3.1(A), 5.3.1(B)	NFPA Standard: 1001	Candidate # <span style="border: 1px solid black; display: inline-block; width: 50px; height: 20px; vertical-align: middle;"></span>
<b>Performance Evaluation Sheet</b>		
<b>Tasks:</b>		
	<b>1st</b>	<b>2nd</b>
1. *Checks that cylinder is full (or at least 90%)		
2. Checks operation of all gauges. Verifies that the difference between cylinder and regulator gauges does not exceed 100 psi		
3. Tests operation of low pressure alarm (to activate at 25% of cylinder volume)		
4. Checks all hose connections for abrasions and cracks		
5. Checks condition of facepiece for cracks, gasket and seal compromise		
6. Checks condition of harness and straps for burns, tears and fraying		
7. Checks operation of donning switch and bypass valves (if applicable to unit)		
8. Checks unit for cleanliness		
9. *Tests PASS device in accordance with manufacturer's specifications (integrated and manual devices)		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>
		Total number tasks candidate must complete to pass <b>7</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.1D	<b>Primary Task:</b> Restricted Use of SCBA (Horizontal)		
Objective(s) : 5.3.1, 5.3.1(A), 5.3.1(B), 5.3.9, 5.3.9(A), 5.3.9(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
<b>HORIZONTAL EGRESS (crawl space)</b>		<b>1st</b>	<b>2nd</b>
1	*Does not remove facepiece, regulator, or PPE		
2	Loosens shoulder straps and disconnects waist straps		
3	Checks floor for integrity		
4	Removes harness assembly and places unit on floor in front of self		
5	*Maintains contact with the regulator shoulder strap		
6	*Slides harness assembly forward through restricted area while maintaining contact with regulator shoulder strap		
7	Checks for floor integrity before proceeding through opening		
8	Exits restricted area, redons harness assembly, tightens all straps		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	
Total number tasks candidate must complete to pass			<b>6</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.1E	<b>Primary Task:</b> Restricted Use of SCBA (Vertical)		
Objective(s) : 5.3.1, 5.3.1(A), 5.3.1(B), 5.3.9, 5.3.9(A),5.3.9(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
<b>VERTICAL EGRESS (between wall studs)</b>		<b>1st</b>	<b>2nd</b>
1 *Does not remove facepiece, regulator, or PPE			
2 Loosens shoulder and waist straps			
3 Removes or loosens shoulder strap from the non-regulator side			
4 *Maintains contact with the regulator shoulder strap			
5 Slides harness assembly to underside of arm to reduce profile			
6 Checks for floor integrity			
7 *Side steps through restricted opening maintaining contact with regulator shoulder strap			
8 Exits the restricted area, redons the SCBA harness, tightens all straps			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>6</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.1F	<b>Primary Task:</b> SCBA Failure Procedures		
Objective(s) : 5.3.1, 5.3.1(A), 5.3.1(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1 *Notifies partner/Command			
2 Verbalizes techniques for conserving air			
3 Selects one of the following:			
• Demonstrates use of bypass/purge valve to conserve air <b>OR</b>			
• Verbalizes to partner the need to use buddy breathing system (if SCBA is equipped for buddy breathing)			
4 Verbalizes intent to leave the structure			
5 *Manually alarms/activates PASS device			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>4</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.2A	<b>Primary Task:</b> Safely Mount, Ride, Dismount Apparatus		
Objective(s) : 5.3.2, 5.3.2(A), 5.3.2(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Dons PPE before boarding apparatus		
2	Mounts apparatus safely		
3	*Applies seat belt and other safety devices		
4	Closes door or places safety bar in proper position (as applicable)		
5	Communicates with officer/driver indicating secure in seat		
6	Dismounts apparatus safely		
7	*Demonstrates safe dismount when apparatus approaches downed electrical wires		
8	Protects self against traffic hazards		
9	Demonstrates or verbalizes sure footed placement in wet or icy conditions		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>	
		Total number tasks candidate must complete to pass	
		<b>7</b>	

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.3A	<b>Primary Task:</b> Deploy Traffic and Scene Control Devices		
Objective(s) : 5.3.3, 5.3.3(A), 5.3.3(B), 5.3.2,5.3.2(A),5.3.2(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1 *Wears appropriate protective clothing required for task			
2 Establishes zone boundaries (size and shape of area and degree of hazard), based on instructions from IC			
3 Uses available equipment designed for traffic scene control			
4 Continues to monitor area safety and scene control			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>3</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.4A	<b>Primary Task:</b> Identify and Carry Tools		
Objective(s) : 5.3.4, 5.3.4(A), 5.3.4(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1 Wears full protective equipment properly			
2 Given several fire service hand or power tool(s) select and categorize:			
• cutting tool			
• prying tool			
• striking tool			
• multi-function tool			
3 *Demonstrates how to safely carry a pick-head axe			
4 Demonstrates how to safely carry a pike pole			
5 Demonstrates how to safely carry a flat-head axe and Halligan bar			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>4</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.4B	<b>Primary Task:</b> Forcible Entry – Door		
Objective(s) : 5.3.4, 5.3.4(A), 5.3.4(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly		
2	Identifies tools and carries them properly		
3	*Inspects door for safety concerns and hazards		
4	*Determines if door is locked		
5	Identifies door swing		
6	Identifies lock mechanism		
7	Based on door swing, positions tool and forces door		
8	Demonstrates securing of door to prevent closure		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>6</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.4C	<b>Primary Task:</b> Opening Window (Non-Destructive)		
Objective(s) : 5.3.4, 5.3.4(A), 5.3.4(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	*Wears full protective equipment properly		
2	Identifies window type		
3	Inspects window for safety hazards and locking mechanism		
4	Selects proper tool(s) to create window opening		
5	*Disengages or displaces lock mechanism and opens window		
6	Keeps window from closing		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>5</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.4D	<b>Primary Task:</b> Forcible Entry - Partition Walls																						
Objective(s) : 5.3.4, 5.3.4(A), 5.3.4(B)	NFPA Standard: 1001	Candidate # <span style="border: 1px solid black; display: inline-block; width: 40px; height: 20px; vertical-align: middle;"></span>																					
Performance Evaluation Sheet																							
<b>Tasks:</b>																							
		<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%;"></th> <th style="width: 25%; text-align: center;">1st</th> <th style="width: 25%; text-align: center;">2nd</th> </tr> </thead> <tbody> <tr><td>1 Wears full protective clothing properly</td><td></td><td></td></tr> <tr><td>2 *Checks wall for hazards</td><td></td><td></td></tr> <tr><td>3 Sounds wall</td><td></td><td></td></tr> <tr><td>4 Selects location for opening and makes a small opening</td><td></td><td></td></tr> <tr><td>5 Cuts properly to gain greater access</td><td></td><td></td></tr> <tr><td>6 *Sounds floor on other side before entering</td><td></td><td></td></tr> </tbody> </table>		1st	2nd	1 Wears full protective clothing properly			2 *Checks wall for hazards			3 Sounds wall			4 Selects location for opening and makes a small opening			5 Cuts properly to gain greater access			6 *Sounds floor on other side before entering		
	1st	2nd																					
1 Wears full protective clothing properly																							
2 *Checks wall for hazards																							
3 Sounds wall																							
4 Selects location for opening and makes a small opening																							
5 Cuts properly to gain greater access																							
6 *Sounds floor on other side before entering																							
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b> Total number tasks candidate must complete to pass <b>5</b>																					

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #: 5.3.5A.1 Primary Task: Action When Trapped/Disoriented with Hose</b>																											
Objective(s) : 5.3.5, 5.3.5(A), 5.3.5(B) NFPA Standard: 1001	Candidate # <span style="border: 1px solid black; display: inline-block; width: 50px; height: 20px;"></span>																										
<b>Performance Evaluation Sheet</b>																											
<b>Tasks:</b>																											
	<table border="1" style="float: right; border-collapse: collapse;"> <thead> <tr> <th style="width: 50px;">1st</th> <th style="width: 50px;">2nd</th> </tr> </thead> <tbody> <tr><td style="height: 20px;"></td><td style="height: 20px;"></td></tr> </tbody> </table>	1st	2nd																								
1st	2nd																										
1 Wears full protective clothing properly 2 Uses portable radio properly 3 *Manually alarms/activates PASS device 4 Controls breathing and maintains calm 5 Listens for noises or sounds 6 Searches the room and locates hose 7 Follows hose line and locates coupling 8 *Uses gloved hands to identify couplings for egress 9 *Moves along hoseline in correct direction for egress 10 *Notifies IC of location (outside of structure)																											
* Critical Task Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>																										
Total number tasks candidate must complete to pass	<b>7</b>																										

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #: 5.3.5A.2 Primary Task: Action When Trapped/Disoriented Without Hose</b>																							
Objective(s) : 5.3.5, 5.3.5(A), 5.3.5(B) NFPA Standard: 1001	Candidate # <span style="border: 1px solid black; display: inline-block; width: 50px; height: 20px;"></span>																						
<b>Performance Evaluation Sheet</b>																							
<b>Tasks:</b>																							
	<table border="1" style="float: right; border-collapse: collapse;"> <thead> <tr> <th style="width: 50px;">1st</th> <th style="width: 50px;">2nd</th> </tr> </thead> <tbody> <tr><td style="height: 20px;"></td><td style="height: 20px;"></td></tr> </tbody> </table>	1st	2nd																				
1st	2nd																						
1 *Wears full protective clothing properly 2 Uses portable radio properly 3 *Manually alarms/activates PASS device 4 Controls breathing and maintains calm 5 Listens for noises or sounds 6 Identifies exits 7 Searches for adequate escape route 8 Maintains orientation and stays low 9 *Exits room and structure safely 10 *Notifies IC of location (outside of structure)																							
* Critical Task      Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>																						
Total number tasks candidate must complete to pass <b>7</b>																							

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.6A	<b>Primary Task:</b> 24' Extension Ladder – Carry, Raise, Extend (one person)																																					
Objective(s) : 5.3.6, 5.3.6(A), 5.3.6(B)	NFPA Standard: 1001	Candidate # <span style="border: 1px solid black; display: inline-block; width: 50px; height: 20px;"></span>																																				
<b>Performance Evaluation Sheet</b>																																						
<b>Tasks:</b>																																						
		<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;"></th> <th style="width: 10%;">1st</th> <th style="width: 10%;">2nd</th> </tr> </thead> <tbody> <tr><td>1</td><td></td><td></td></tr> <tr><td>2</td><td></td><td></td></tr> <tr><td>3</td><td></td><td></td></tr> <tr><td>4</td><td></td><td></td></tr> <tr><td>5</td><td></td><td></td></tr> <tr><td>6</td><td></td><td></td></tr> <tr><td>7</td><td></td><td></td></tr> <tr><td>8</td><td></td><td></td></tr> <tr><td>9</td><td></td><td></td></tr> <tr><td>10</td><td></td><td></td></tr> <tr><td>11</td><td></td><td></td></tr> </tbody> </table>		1st	2nd	1			2			3			4			5			6			7			8			9			10			11		
	1st	2nd																																				
1																																						
2																																						
3																																						
4																																						
5																																						
6																																						
7																																						
8																																						
9																																						
10																																						
11																																						
1 Wears full protective equipment properly																																						
2 Carries ladder properly as directed																																						
3 *Verbalizes overhead safety hazards																																						
4 Places butt of ladder against the building foundation before raising																																						
5 *Raises ladder to building using flat raise																																						
6 *Extends fly using hand-over-hand method on halyard																																						
7 Ensures ladder pawls (dogs) are secured																																						
8 Pivots ladder																																						
9 Positions ladder for operations																																						
10 Checks climbing angle																																						
11 Secures fly section with halyard and safety knot																																						
* Critical Task      Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number Tasks candidate must complete to pass <b>9</b>																																				

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.6B	<b>Primary Task:</b> 24' Extension Ladder - Remove, Lower (one person)			
<b>Objective(s) :</b> 5.3.6, 5.3.6(A), 5.3.6(B)		<b>NFPA Standard:</b> 1001	<b>Candidate #</b> <span style="border: 1px solid black; display: inline-block; width: 50px; height: 20px;"></span>	
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	Wears full protective clothing properly			
2	*Verbalizes overhead safety hazards			
3	Releases knots of halyard from ladder			
4	Moves ladder to vertical position next to building			
5	Pivots ladder			
6	*Lowers fly section using hand-over-hand method on halyard			
7	Places butt of ladder against the building foundation before lowering			
8	*Controls lowering ladder to ground			
9	Carries ladder properly as directed			
10	Replaces ladder to original position on ground or apparatus			
* Critical Task      Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass	<b>7</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.6C	<b>Primary Task:</b>	<b>24'-28' Extension Ladder Carry, Raise, Extend (two person)</b>		
Objective(s) : 5.3.6, 5.3.6(A), 5.3.6(B)		NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet				
<b>Tasks:</b>				
<b>**TIP PERSON**</b>			<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly			
2	Carries ladder properly as directed			
3	*Verbalizes overhead safety hazards			
4	Places ladder on the ground			
5	*Raises ladder as directed			
6	*Extends fly using hand-over-hand method on halyard			
7	Ensures ladder pawls (dogs) are secured			
8	Positions ladder for operations			
9	Checks climbing angle			
		Total number tasks candidate must complete to pass	<b>7</b>	
<b>**BUTT PERSON**</b>			<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly			
2	Carries ladder properly as directed			
3	*Verbalizes overhead safety hazards			
4	Places ladder on the ground			
5	*Butts ladder to vertical position and maintains grasp on ladder			
6	Assists with maneuvering of ladder to building			
7	Secures fly section with halyard and safety knot			
* Critical Task Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>5</b>	

**Prevent or prohibit any unsafe acts.**  
**Contact the Chief Examiner at any time with any questions.**  
**Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**



## Fire Fighter I

<b>Skill Sheet #:</b>	5.3.6D	<b>Primary Task:</b>	24'-28' Extension Ladder- Remove, Lower (two person)		
<b>Objective(s) :</b>	5.3.6, 5.3.6(A), 5.3.6(B)	<b>NFPA Standard:</b>	1001 #	<b>Candidate</b>	
<b>Performance Evaluation Sheet</b>					
<b>**TIP PERSON**</b>				<b>1st</b>	<b>2nd</b>
1	Wears Personal Protective Equipment properly				
2	*Verbalizes overhead safety hazards				
3	Moves ladder to vertical from building				
4	Pivots ladder (if necessary)				
5	*Controls lowering ladder to the ground by maintaining hand contact with ladder				
6	Stabilizes ladder				
7	*On command from Butt Person, Tip Person will "Swing Out"				
8	Carries ladder as directed, replaces ladder to original position on ground or apparatus				
<b>**BUTT PERSON**</b>			Total number tasks candidate must complete to pass	<b>6</b>	
1	Wears Personal Protective Equipment properly				
2	Carries ladder as directed				
3	*Verbalizes overhead safety hazards				
4	Releases knots from halyard of ladder				
5	Moves ladder to vertical from building				
6	Pivots ladder (if necessary)				
7	*Lowers fly section, using hand-over-hand method on halyard				
8	*Butts ladder while ladder is being lowered to ground				
9	*Commands Tip Person to "Swing Out" before firefighter reaches the end of the ladder				
10	Carries ladder as directed, replaces ladder to original position on ground or apparatus				
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass	<b>7</b>	

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.6E	<b>Primary Task:</b> 14' to 20' Single Ladder Carry, Raise (one person)																	
<b>Objective(s) :</b> 5.3.6, 5.3.6(A), 5.3.6(B)	<b>NFPA Standard:</b> 1001	<b>Candidate #</b> <span style="border: 1px solid black; display: inline-block; width: 40px; height: 20px; vertical-align: middle;"></span>																
Performance Evaluation Sheet																		
<b>Tasks:</b>																		
		<table border="1" style="float: right; border-collapse: collapse;"> <thead> <tr> <th style="width: 50px;">1st</th> <th style="width: 50px;">2nd</th> </tr> </thead> <tbody> <tr><td style="height: 20px;"></td><td style="height: 20px;"></td></tr> </tbody> </table>	1st	2nd														
1st	2nd																	
1 Wears full protective equipment properly																		
2 Carries ladder properly as directed																		
3 *Verbalizes overhead safety hazards																		
4 *Places butt of ladder against the building foundation before raising																		
5 Raises ladder to building using flat raise																		
6 Positions ladder for operations																		
7 Checks climbing angle																		
* Critical Task      Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number Tasks candidate must complete to pass <b>5</b>																

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.6F	<b>Primary Task:</b> 14'-20' Single Ladder - Remove, Lower (one person)		
<b>Objective(s):</b> 5.3.6, 5.3.6(A), 5.3.6(B)	<b>NFPA Standard:</b> 1001	<b>Candidate #</b>	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Wears full protective clothing properly		
2	*Verbalizes overhead safety hazards		
3	Moves ladder to vertical position next to building		
4	*Places butt of ladder against the building foundation before lowering		
5	*Controls lowering ladder to ground		
6	Carries ladder properly as directed		
7	Replaces ladder to original position on ground or apparatus		
* Critical Task      Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>	
Total number tasks candidate must complete to pass			<b>5</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #: 5.3.6G Primary Task: 35' Extension Ladder Carry, Raise, Extend (three person)</b>			
Objective(s) : 5.3.6, 5.3.6(A), 5.3.6(B) NFPA Standard: 1001		Candidate # <span style="border: 1px solid black; display: inline-block; width: 50px; height: 20px;"></span>	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
<b>**BUTT PERSON**</b>			<b>1st</b>
			<b>2nd</b>
1	Wears full protective equipment properly		
2	Carries ladder properly as directed		
3	*Verbalizes overhead wires		
4	Places ladder on the ground		
5	*Butts ladder to vertical position and maintains grasp on ladder		
6	Assists with maneuvering of ladder to building		
7	Secures fly section with halyard and safety knot		
<b>**BEAM PERSONS**</b>			<b>5</b>
			<b>5</b>
1	Wears full protective equipment properly		
2	Carries ladder properly as directed		
3	*Verbalizes overhead safety hazards		
4	Places ladder on the ground		
5	*Raises ladder		
6	*Extends fly using hand-over-hand method on halyard		
7	Ensures ladder pawls (dogs) are secured		
8	Positions ladder for operations		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	<b>6</b>
			<b>6</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.6H</b>	<b>Primary Task:</b>	<b>35' Extension Ladder Remove, Lower (three person)</b>	
Objective(s) : 5.3.6, 5.3.6(A), 5.3.6(B)		NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
<b>**BUTT PERSON**</b>			<b>1st</b>	<b>2nd</b>
1	Wears Personal Protective Equipment properly			
2	*Verbalizes overhead safety hazards			
3	Releases knots from halyard of ladder			
4	Moves ladder to vertical from building			
5	Pivots ladder (if necessary)			
6	*Lowers fly section, using hand-over-hand method on halyard			
7	*Butts ladder while ladder is being lowered to ground			
8	*Commands Tip Person to "Swing Out" before firefighter reaches the end of the ladder			
9	Carries ladder as directed, replaces ladder to original position on ground or apparatus			
<b>**BEAM PERSONS**</b>			Total number tasks candidate must complete to pass <b>7</b>	
1	Wear Personal Protective Equipment properly			
2	*Verbalizes overhead safety hazards			
3	Moves ladder to vertical from building			
4	Stabilizes ladder			
5	Pivots ladder (if necessary)			
6	*Controls lowering ladder to the ground by maintaining hand contact with ladder			
7	*On command from Butt Person, Tip Person will "Swing Out"			
8	Carries ladder as directed, replaces ladder to original position on ground or apparatus			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	
			Total number tasks candidate must complete to pass <b>6</b>	

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
COMMISSION ON FIRE PREVENTION AND CONTROL  
**Fire Fighter I**



**Prevent or prohibit any unsafe acts.  
Contact the Chief Examiner at any time with any questions.  
Remember, you are an evaluator, not a trainer...**

***IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.***



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.7A	<b>Primary Task:</b> Fire Suppression – Vehicle Fires		
Objective(s) : 5.3.7, 5.3.7(A), 5.3.7(B).	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	*Wears full protective equipment and SCBA properly		
2	Approaches fire from appropriate direction		
3	Verbalizes crew is protected for hazards		
4	*Advances to extinguish ground fire and under vehicle with appropriately-sized handline		
5	Facilitates suppression and overhaul by gaining access to all compartments with hand tools		
6	Uses effective fire stream techniques to minimize water damage and runoff		
7	Maintains crew integrity and communication		
8	Notifies Dispatch and/or Command that fire is under control		
9	*Extinguishes remaining fire		
10	Verbalizes the initiation origin/cause investigation given department SOPs		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>7</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.8A</b>	<b>Primary Task:</b>	<b>Fire Suppression – Class A Stack</b>	
<b>Objective(s) :</b>	5.3.8, 5.3.8(A), 5.3.8(B)	<b>NFPA Standard:</b>	1001	<b>Candidate #</b>
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	*Wears full protective equipment and SCBA properly			
2	Approaches fire from appropriate direction			
3	Verbalizes crew is protected for hazards			
4	*Selects and deploys appropriately-sized handline or master stream device			
5	Advances handline or operates master stream			
6	Facilitates suppression and overhaul			
7	Uses effective fire stream techniques to minimize water damage and runoff			
8	Maintains crew integrity and communication			
9	Notifies dispatch and/or command that fire is under control			
10	*Extinguishes fire			
11	Examines debris for hot spots			
12	Verbalizes the initiation of the origin/cause investigation given department SOPs			
<b>* Critical Task</b>	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass	<b>9</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.8B	<b>Primary Task:</b> Fire Suppression – Dumpster/Storage	
Objective(s) : 5.3.8, 5.3.8(A), 5.3.8(B)	NFPA Standard: 1001	Candidate # <span style="border: 1px solid black; display: inline-block; width: 50px; height: 20px;"></span>
<b>Performance Evaluation Sheet</b>		
<b>Tasks:</b>		
	<b>1st</b>	<b>2nd</b>
1 *Wears full protective equipment and SCBA properly		
2 Approaches fire from appropriate direction		
3 Verbalizes crew is protected for hazards		
4 *Selects and deploys appropriately-sized handline or master stream device		
5 Advances handline or operates master stream		
6 Facilitates suppression and overhaul		
7 Uses effective fire stream techniques to minimize water damage and runoff		
8 Maintains crew integrity and communication		
9 Notifies dispatch and/or command that fire is under control		
10 *Extinguishes fire		
11 Examines dumpster/storage debris for hot spots		
12 Verbalizes the initiation of the origin/cause investigation given department SOPs		
* Critical Task Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>9</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.8C</b>	<b>Primary Task:</b>	<b>Deploy Master Stream Device</b>	
Objective(s) : 5.3.8, 5.3.8(A), 5.3.8(B)		NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	*Wears full protective equipment properly			
2	Removes master stream device from apparatus and placed in position			
3	Selects, deploys and attaches feeder lines based on department SOPs and/or manufacturer's specification			
4	*Loops hose line in front of monitor to counteract water flow force			
5	Sets monitor for direct attack and/or exposure protection			
6	Calls for water			
7	Operates master stream as directed			
8	Replaces master stream device on apparatus			
* Critical Task      Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>		Total number tasks candidate must complete to pass <b>6</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.9A	<b>Primary Task:</b> Rescue with SCBA - Obscured Visibility		
Objective(s) : 5.3.9, 5.3.9(A), 5.3.9(B), 5.3.1, 5.3.1(A), 5.3.1(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	*Wears full protective equipment properly		
2	Brings appropriate hand tools for search		
3	*Notifies Command of entry to structure and intended search pattern		
4	Conducts systematic search		
5	*Stops periodically to listen for victims and sounds of fire		
6	Uses hand tools properly		
7	Searches all areas completely		
8	Maintains team integrity by communicating findings		
9	*Moves up and down stairs properly and safely		
10	*Checks doors for heat before opening		
11	*Communicates location of victim to partner and command		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>8</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.9B</b>	<b>Primary Task:</b>	<b>Remove by Ladder (conscious person)</b>	
<b>Objective(s) :</b>	5.3.9, 5.3.9(A), 5.3.9(B), 5.3.6, 5.3.6(A), 5.3.6(B)	<b>NFPA Standard:</b>	1001	<b>Candidate #</b> <span style="border: 1px solid black; display: inline-block; width: 50px; height: 20px; vertical-align: middle;"></span>
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly			
2	*Places ladder into position for rescue			
3	Ascends ladder safely			
4	Communicates with victim			
5	Assists victim onto ladder with verbal commands and hand prompting			
6	Positions victim for safe descent			
7	*Maintains physical contact and communicates with victim			
8	*Descends ladder safely with victim			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	
			Total number tasks candidate must complete to pass	<b>6</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.9C</b>	<b>Primary Task:</b>	<b>Remove by Ladder (unconscious person)</b>	
<b>Objective(s) :</b>	5.3.9, 5.3.9(A), 5.3.9(B), 5.3.6, 5.3.6(A), 5.3.6(B)	<b>NFPA Standard:</b>	1001	<b>Candidate #</b>
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	*Wears full protective equipment properly			
2	*Places ladder into position for rescue			
3	Ascends ladder safely			
4	*Places victim on ladder for safe descent			
5	Maintains contact with ladder			
6	*Descends the ladder safely			
* Critical Task      Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>		<b>5</b>
		Total number tasks candidate must complete to pass		

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.9D</b>	<b>Primary Task:</b>	<b>Conduct Primary Search</b>	
Objective(s) :	5.3.9, 5.3.9(A), 5.3.9(B), 5.3.1, 5.3.1(A), 5.3.1(B)	NFPA Standard:	1001	Candidate #
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	*Wears full protective equipment properly			
2	Brings appropriate hand tools for search			
3	*Notifies Command of entry to structure and intended search pattern			
4	Conducts systematic search			
5	*Stops periodically to listen for victims and sounds of fire			
6	Uses hand tools properly			
7	Searches all areas completely			
8	Maintains team integrity by communicating findings			
9	*Moves up and down stairs properly and safely			
10	*Checks doors for heat before opening			
11	*Communicates location of any victim to partner and Command			
* Critical Task      Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>8</b>	

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.9E	<b>Primary Task: Conduct Secondary Search</b>		
Objective(s) : 5.3.9, 5.3.9(A), 5.3.9(B), 5.3.1, 5.3.1(A), 5.3.1(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	*Wears full protective equipment and SCBA properly		
2	Brings appropriate hand tools for search		
3	*Notifies command of entry to structure and search pattern		
4	Conducts systematic search		
5	*Stops periodically to listen for victims and sounds of fire		
6	Uses hand tools properly		
7	Searches all areas completely		
8	Maintains team integrity by communicating findings		
9	*Moves up and down stairs properly and safely		
10	*Checks doors for heat before opening		
11	*Communicates location of any victim to partner and Command		
12	Protects evidence		
13	*Notifies command when search is complete		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>10</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.9F	<b>Primary Task:</b>	<b>Drags (one person)</b>
Objective(s) : 5.3.9, 5.3.9(A), 5.3.9(B)	NFPA Standard: 1001	Candidate # <span style="border: 1px solid black; display: inline-block; width: 50px; height: 20px; vertical-align: middle;"></span>
<b>Performance Evaluation Sheet</b>		
<b>Tasks:</b>		
	<b>1st</b>	<b>2nd</b>
1 Locates victim		
2 Communicates with victim		
3 Finds effective means of egress		
4 Positions victim for safe egress		
5 Places victim in/on dragging equipment, if available		
6 *Positions self for safe movement of victim		
7 *Considers actions to minimize victim injury during movement		
8 *Drags victim out to designated area safely		
* Critical Task      Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>6</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.9G	<b>Primary Task:</b>	<b>Carries (two persons)</b>	
Objective(s) : 5.3.9, 5.3.9(A), 5.3.9(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Locates victim		
2	Communicates with victim		
3	Finds effective means of egress		
4	Positions victim for safe egress		
5	Positions self and victim appropriately for lift and carry		
6	*Positions self, coordinates and communicates direction of egress		
7	*Carries victim out to designated area safely		
<b>Note:</b> Each candidate is equally responsible for all items listed above.			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>5</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*





State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.10A.2	<b>Primary Task:</b> Fire Suppression – Interior Structure Above Grade Level		
<b>Objective(s) :</b> 5.3.10, 5.3.10(A), 5.3.10(B)	<b>NFPA Standard:</b> 1001	<b>Candidate #</b>	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	*Wears full protective equipment and SCBA properly		
2	Properly advances hoseline from one of the following loads: <ul style="list-style-type: none"> <li>• Minuteman Load</li> <li>• Preconnected Flat Load with loops</li> <li>• Triple Layer Load</li> </ul>		
3	*Clears remaining hose from hose bed and flakes out hoseline before advancing to fire area		
4	*Calls for water, charges line, bleeds air from line, adjusts nozzle pattern (local fire department SOP--before entering structure or once fire is located)		
5	Maintains communication with other team members		
6	Enters structure safely (per building conditions) and maintains team and hoseline integrity		
7	*Ascends stairway quickly, laying hoseline properly to reduce hazards and injury		
8	Locates fire		
9	Extinguishes fire using the directed attack method		
10	*Properly reloads hoseline in bed per instructions		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>	
		Total number tasks candidate must complete to pass <b>7</b>	

9/23/09

**Prevent or prohibit any unsafe acts.  
Contact the Chief Examiner at any time with any questions.  
Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.10A.3	<b>Primary Task:</b> Fire Suppression – Interior Structure Below Grade Level		
Objective(s) : 5.3.10, 5.3.10(A), 5.3.10(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	*Wears full protective equipment and SCBA properly		
2	Properly advances hoseline from one of the following loads: <ul style="list-style-type: none"> <li>• Minuteman Load</li> <li>• Preconnected Flat Load with loops</li> <li>• Triple Layer Load</li> </ul>		
3	*Clears remaining hose from hose bed and flakes out hoseline before advancing to fire area		
4	*Calls for water, charges line, opens bail or throttle to bleed air, and adjust nozzle pattern (local fire department SOP--before entering structure or once fire is located)		
5	Maintains communication with other team members		
6	Enters structure safely (per building conditions) and maintains team and hoseline integrity		
7	*Descends stairway quickly, properly and safely to avoid injury hazards		
8	Locates fire		
9	Extinguishes fire using the directed attack method		
10	*Properly reloads hoseline in bed per instructions		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>7</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
Contact the Chief Examiner at any time with any questions.  
Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.10B.1</b>	<b>Primary Task:</b>	<b>Advance Pre-connected Flat Load</b>		
<b>Objective(s) :</b>	5.3.10, 5.3.10(A), 5.3.10(B), 5.3.8, 5.3.8(A), 5.3.8(B)	<b>NFPA Standard:</b>	1001	<b>Candidate #</b>	
<b>Performance Evaluation Sheet</b>					
<b>Tasks:</b>					
				<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly				
2	Places working end of hose (nozzle) over one shoulder				
3	Places other arm through loop				
4	Pulls load from the bed				
5	Walks toward structure or fire				
6	*Proceeds until hose is fully extended and out of the bed				
7	Conducts visual size-up and verbalizes hazards to crew members or IC				
8	*Properly reloads hoseline in bed with pre-connected flat load				
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass	<b>6</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.10B.2</b>	<b>Primary Task:</b>	<b>Advance Minuteman Load</b>	
Objective(s) :	5.3.10, 5.3.10(A), 5.3.10(B), 5.3.8, 5.3.8(A),5.3.8(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly			
2	Grasps nozzle and bottom loops			
3	Pulls load one-third to one-half out of bed			
4	Turns and faces away from bed			
5	Places load on shoulder with nozzle to front of body			
6	*Walks away from apparatus pulling hose completely from bed			
7	Advances toward structure or fire, allowing hose to peel off from top of load			
8	Conducts visual size-up and verbalizes hazards to crew members or IC			
9	*Properly reloads hoseline in bed with minuteman load			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass	<b>7</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.10B.3</b>	<b>Primary Task:</b>	<b>Advance Triple-Layer Load</b>		
Objective(s) :	5.3.10, 5.3.10(A), 5.3.10(B), 5.3.8, 5.3.8(A), 5.3.8(B)	NFPA Standard:	1001	Candidate #	
<b>Performance Evaluation Sheet</b>					
<b>Tasks:</b>					
				<b>1st</b>	<b>2nd</b>
1	*Wears full protective equipment properly				
2	Places the nozzle and fold of first tier over the shoulder while facing away from bed				
3	Walks away from the apparatus				
4	*Pulls hose completely out of bed				
5	Drops the folded end from shoulder after bed is cleared				
6	Advances toward structure or fire				
7	Conducts visual size-up and verbalizes hazards to crew members or IC				
8	*Properly reloads hoseline in bed with triple layer load				
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>		Total number tasks candidate must complete to pass	<b>6</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.10B.4</b>	<b>Primary Task:</b>	<b>Advance Shoulder-Load Method (two person)</b>	
<b>Objective(s) :</b>	5.3.10, 5.3.10(A), 5.3.10(B), 5.3.8, 5.3.8(A), 5.3.8(B)	<b>NFPA Standard:</b>	1001	<b>Candidate #</b>
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly			
2	Attaches nozzle to hoseline (if needed)			
3	Positions at tailboard facing direction of travel			
4	*Places initial fold over shoulder so nozzle is not lower than waist level			
5	Brings other folds over shoulder so that rear fold is as knees			
6	Makes folds on front to knee height			
7	*Takes 3 - 5 folds over the shoulder			
8	Advances in direction of fire area			
9	Peels off shoulder and extend hoseline			
10	Conducts visual size-up and report to crew members and IC			
11	Properly reloads hoseline in bed per instructions			
* Critical Task      Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>		Total number tasks candidate must complete to pass
				<b>8</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.10B.5	<b>Primary Task:</b>	<b>Advance Working Line Drag Method (two person)</b>	
Objective(s) : 5.3.10, 5.3.10(A), 5.3.10(B), 5.3.8, 5.3.8(A), 5.3.8(B)		NFPA Standard: 1001	Candidate #
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly		
2	Stands alongside single hoseline at coupling or nozzle		
3	Positions facing direction of travel		
4	*Places charged hose over shoulder so nozzle is not lower than waist level		
5	Brings other folds over shoulder so that rear fold is at knees		
6	*Places additional firefighters at coupling to assist in advancement		
7	Advances in direction of fire area		
8	Conducts visual size-up and report to crew members and IC		
9	Properly reloads hoseline in bed per instructions		
* Critical Task      Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>	
Total number tasks candidate must complete to pass			<b>7</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.10C</b>	<b>Primary Task:</b>	<b>Advance Hoseline</b>	
Objective(s) :	5.3.10, 5.3.10(A), 5.3.10(B)	NFPA Standard:	1001	Candidate #
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	*Wears full protective equipment properly			
2	*Bleeds air from line before entering the building or fire area			
3	Positions self, crew on same side of hoseline			
4	*Checks door for heat before opening			
5	Stays low and avoid blocking ventilation openings			
6	Chocks self-closing doors open to keep line from being pinched			
7	*Checks for and remove kinks			
8	Maintains communication with crew and IC			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	
			Total number tasks candidate must complete to pass	<b>6</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.10D		<b>Primary Task:</b> Operate Charged Hoseline from Ground Ladder (two person)		
Objective(s) : 5.3.6, 5.3.6(A), 5.3.6(B) 5.3.10, 5.3.10(A), 5.3.10(B)		NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly			
2	Raises ladder into window and above windowsill			
3	*Ascends ladder maintaining hand contact with ladder and hoseline at all times			
4	Maintains communication with firefighter who is heeling or footing ladder			
5	*Secures safety harness or correctly performs leg lock			
6	Uses hose strap to secure hose to ladder rung			
7	Assures proper position of nozzle for best penetration of water stream			
8	*Slowly opens nozzle and flows water			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass
				<b>6</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.10E</b>	<b>Primary Task:</b>	<b>Use of Nozzle</b>	
Objective(s) :	5.3.10, 5.3.10(B), 5.3.13(B), 5.3.8, 5.3.8(A), 5.3.8(B)	NFPA Standard:	1001	Candidate #
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	*Wears full protective equipment properly			
2	Identifies nozzle/appliance			
3	*Opens bail slowly			
4	Bleeds air and checks flow pattern			
5	Demonstrates the following nozzle settings when instructed: <ul style="list-style-type: none"> <li>• Straight Stream</li> <li>• Narrow Angle Fog</li> <li>• Wide Angle Fog</li> </ul>			
6	*Closes bail slowly			
* Critical Task      Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>		Total number tasks candidate must complete to pass <b>5</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
Contact the Chief Examiner at any time with any questions.  
Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.10F</b>	<b>Primary Task:</b>	<b>Replace Burst Hose</b>		
Objective(s) :	5.3.10, 5.3.10(A), 5.3.10(B)	NFPA Standard:	1001	Candidate #	
<b>Performance Evaluation Sheet</b>					
<b>Tasks:</b>					
				<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly				
2	*Controls water flow by using clamp or valve				
3	Selects two lengths to replace defective length				
4	Uncouples defective length				
5	Couples replacement lengths (2)				
6	*Removes clamp/opens valve to charged line slowly				
<b>NOTE:</b> If clamp is not used, water supply may be controlled at the source					
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>5</b>		

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.10G	<b>Primary Task:</b> Add Length of Hose		
Objective(s) : 5.3.10, 5.3.10(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly		
2	Selects hose to be added to line and places it in position		
3	*Opens gated wye or bail slightly		
4	Applies hose clamp or shuts off water at source		
5	*Adds additional length of hose by using foot-tilt, knee-press method		
6	*Removes clamp or turns water on at source slowly		
<b>NOTE:</b> If clamp is not used, water supply may be controlled at source			
<b>* Critical Task</b>	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>6</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.10H</b>	<b>Primary Task:</b>	<b>Couple/Uncouple Hose (one person)</b>		
Objective(s) :	5.3.10, 5.3.10(A), 5.3.10(B)	NFPA Standard:	1001	Candidate #	
<b>Performance Evaluation Sheet</b>					
<b>Tasks:</b>					
<b>Coupling/Coupling (one person)</b>				<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly				
2	Positions hose lines on level surface for coupling				
3	Verbalizes appropriate method (foot-tilt, knee press) to couple hose				
4	*Uses appropriate method (foot-tilt, knee press) to couple hose				
5	Positions hose line on level surface for uncoupling				
6	Verbalizes appropriate method (foot-tilt, knee press) to uncouple hose				
7	*Uses appropriate method (foot-tilt, knee press) to uncouple hose				
Total number tasks candidate must complete to pass				<b>5</b>	
<b>Coupling/Uncoupling (two person)</b>					
1	Wears full protective equipment properly				
2	Positions hose lines for coupling				
3	Communicates with partner				
4	*Properly couples hose				
5	Positions hose line for uncoupling				
6	Communicates with partner				
7	*Properly uncouples hose line				
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>		Total number tasks candidate must complete to pass <b>5</b>	

**Prevent or prohibit any unsafe acts.**  
**Contact the Chief Examiner at any time with any questions.**  
**Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
COMMISSION ON FIRE PREVENTION AND CONTROL  
Fire Fighter I



9/23/09

**Prevent or prohibit any unsafe acts.  
Contact the Chief Examiner at any time with any questions.  
Remember, you are an evaluator, not a trainer...**

***IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.***



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.10J	<b>Primary Task:</b> Remove Hose from Upper Floor		
Objective(s) : 5.3.10, 5.3..10(A), 5.3.10(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly		
2	Shuts down water supply		
3	*Opens bail or throttle to relieve water pressure (bathtub, out of window, etc.)		
4	Disconnects hose coupling to drain (window sill, front door, street curb, etc.)		
5	After draining, removes hose from structure using shoulder carry		
6	*Re-packs preconnect hose on apparatus by one of the following loads: <ul style="list-style-type: none"> <li>• Flat load</li> <li>• Triple layer load</li> <li>• Minuteman load</li> </ul>		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>5</b>

9/23/09

**Prevent or prohibit any unsafe acts.**  
**Contact the Chief Examiner at any time with any questions.**  
**Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.10K		<b>Primary Task:</b> Remove Hose to Minimize Water Damage		
Objective(s) : 5.3.10, 5.3.10(A), 5.3.10(B)		NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly			
2	Shuts down water supply			
3	*Opens nozzle to relieve pressure while protecting property			
4	Disconnects hose coupling to position and drain line while protecting property			
5	After draining, removes hose from structure using shoulder carry			
6	*Re-packs preconnect hose on apparatus by one of the following loads:			
	<ul style="list-style-type: none"> <li>• Flat load</li> <li>• Triple layer load</li> <li>• Minuteman load</li> </ul>			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass
				<b>5</b>

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.11A</b>	<b>Primary Task:</b>	<b>Leg Lock on a Ground Ladder</b>	
Objective(s) :	5.3.6, 5.3.6(A), 5.3.6(B), 5.3.11, 5.3.11(A), 5.3.11(B), 5.3.12, 5.3.12(A), 5.3.12(B)	NFPA Standard:	1001	Candidate #
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly			
2	Raises ladder to height for specific operation			
3	Climbs to the desired height maintaining hand contact with ladder at all times			
4	*Uses proper leg lock technique to safely perform specific task			
5	Upon completion of task, safely disengages from leg lock			
6	Descends ladder			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass	<b>5</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.11B</b>	<b>Primary Task:</b>	<b>Horizontal Ventilation - Clearing Window</b>	
<b>Objective(s) :</b>	5.3.11, 5.3.11(A), 5.3.11(B), 5.3.6, 5.3.6(A), 5.3.6(B)	<b>NFPA Standard:</b>	1001	<b>Candidate #</b>
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	*Wears full protective equipment properly			
2	Positions ladder beside or beyond window on the windward side			
3	Climbs maintaining hand contact with ladder with tool hands on beam			
4	*Properly uses safety harness or leg lock			
5	*Uses eye protection (safety glasses, face shield, or SCBA facepiece)			
6	Maintains safety area			
7	Strikes window correctly			
8	Clears window frame safely			
9	Descends ladder safely			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	
			Total number tasks candidate must complete to pass	<b>7</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.11C	<b>Primary Task:</b> Hydraulic Ventilation															
Objective(s) : 5.3.11, 5.3.11(A), 5.3.11(B)	NFPA Standard: 1001	Candidate #														
<b>Performance Evaluation Sheet</b>																
<b>Tasks:</b>																
		<table border="1" style="float: right; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%;">1st</th> <th style="width: 50%;">2nd</th> </tr> </thead> <tbody> <tr><td> </td><td> </td></tr> </tbody> </table>	1st	2nd												
1st	2nd															
1 *Wears full protective equipment properly																
2 *Identifies proper nozzle																
3 Extends nozzle outside of opening and opens bail																
4 Selects and demonstrates proper fog pattern and coverage																
5 Positions nozzle to maximize effectiveness of ventilation																
6 *Monitors progress of ventilation (verbalizes)																
* Critical Task	Failure of this task mandates failure on the entire objective	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 40%;">Safety is <b>PARAMOUNT</b></td> <td style="width: 60%;">Total number tasks candidate must complete to pass</td> </tr> <tr> <td></td> <td style="text-align: center; font-size: 2em;"><b>5</b></td> </tr> </table>	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass		<b>5</b>										
Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass															
	<b>5</b>															

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.11D	<b>Primary Task:</b> Negative-Pressure Ventilation		
Objective(s) : 5.3.11, 5.3.11(A),5.3.11(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly		
2	Determines ventilation opening and wind direction		
3	Properly places fan with respect to opening		
4	Selects proper exit point for removal of smoke		
5	*Removes any material hazards and/or obstructions		
6	Verbalizes actions to promote optimal performance of smoke ejector		
7	*Connects fan to power source, starts fan and checks air production		
8	Operates smoke ejector properly		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>	
		Total number tasks candidate must complete to pass <b>5</b>	

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.11E	<b>Primary Task:</b> Positive-Pressure Ventilation	
Objective(s) : 5.3.11, 5.3.11(A),5.3.11(B)	NFPA Standard: 1001	Candidate #
<b>Performance Evaluation Sheet</b>		
<b>Tasks:</b>		
	<b>1st</b>	<b>2nd</b>
1 Wears full protective equipment properly		
2 Determines ventilation opening and wind direction		
3 Properly places fan with respect to opening		
4 Selects proper exit point for removal of smoke		
5 *Removes any material hazards and/or obstructions		
6 *Connects fan to power source, starts fan and checks air production		
7 Allows smoke to clear		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>
		Total number tasks candidate must complete to pass <b>5</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #: 5.3.12A.1 Primary Task: Deploy Roof Ladder</b>		
Objective(s) : 5.3.12, 5.3.12(A), 5.3.12(B), 5.3.6, 5.3.6(A), 5.3.6(B)	NFPA Standard: 1001	Candidate #
<b>Performance Evaluation Sheet</b>		
<b>Tasks:</b>		
	<b>1st</b>	<b>2nd</b>
1 Wears full protective equipment properly		
2 Carries roof ladder safely and properly to directed area		
3 Deploys hooks properly		
4 Properly positions roof ladder with respect to extension ladder		
5 Ascends extension ladder and accesses roof ladder safely		
6 *Hoists roof ladder with proper hand placement		
7 Climbs to top of extension ladder		
8 *Safely secures safety harness or properly performs a leg lock		
9 *Properly positions and secures roof ladder on roof		
* Critical Task Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>7</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #: 5.3.12A.2 Primary Task: Lower and Remove Roof Ladder (two person)</b>			
Objective(s) : 5.3.12, 5.3.12(A), 5.3.12(B), 5.3.6, 5.3.6(A), 5.3.6(B)		NFPA Standard: 1001	Candidate #
Performance Evaluation Sheet			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly		
2	*Properly uses leg lock or safety harness		
3	Positions roof ladder for removal		
4	*Communicates with partner and lowers ladder safely		
5	*Disengages leg lock or safety harness		
6	Closes hooks		
7	Properly positions and carries roof ladder		
8	*Communicates with partner to properly and safely descend extension ladder		
9	Replaces ladders on apparatus or ground as directed		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>7</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #.</b>	<b>5.3.12B</b>	<b>Primary Task:</b>	<b>Climb Ladder With Tool</b>	
Objective(s) :	5.3.11, 5.3.11(A), 5.3.11(B) 5.3.12, 5.3.12(A), 5.3.12(B)	NFPA Standard:	1001	Candidate #
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly			
2	Checks ladder for appropriate angle			
3	*Climbs with free hand sliding under the beam and tool hand on beam <b>AND</b> <ul style="list-style-type: none"> <li>• tool hand on beam, <b>OR</b></li> <li>• other hand holding tool</li> </ul>			
4	* Secures safety harness or performs leg lock properly and safely			
5	Performs work as directed			
6	Descends ladder safely			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>5</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.12C</b>	<b>Primary Task:</b>	<b>Determine Roof Integrity</b>	
Objective(s) :	5.3.12, 5.3.12(A), 5.3.12(B)	NFPA Standard:	1001	Candidate #
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly			
2	Climbs ladder with tool properly			
3	*Properly performs a leg lock or secures safety harness			
3	Sounds roof with tool from ladder			
4	*Verbalizes reasons for "sounding the roof"			
5	Locates support members by sound and rebound			
6	*Maintains means of egress from roof			
7	Determines roof integrity (verbally)			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	
			Total number tasks candidate must complete to pass	<b>5</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #: 5.3.12D.1</b>		<b>Primary Task: Flat Roof Ventilation</b>	
Objective(s) : 5.3.12, 5.3.12(A), 5.3.12(B)		NFPA Standard: 1001	Candidate #
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly		
2	Sizes up scene for any hazards		
3	*Performs correct cut to determine roof and fire conditions		
4	*Properly performs first cut in correct position		
5	Properly performs second cut in correct relation to first cut		
6	Properly performs third cut in correct relation to second cut		
7	Properly performs fourth cut in correct relation to previous cuts		
8	Removes roofing material from ventiation opening with appropriate hand tools		
9	*Punches through interior ceiling with pike pole		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>7</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.12D.2	<b>Primary Task:</b> Roof Ventilation – Pitched		
Objective(s) : 5.3.12, 5.3.12(A), 5.3.12(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly		
2	Sizes up scene for any hazards		
3	Properly locates position and performs first cut		
4	*Performs second cut correctly and in proper relation to first cut.		
5	Performs third cut correctly and in proper relation to second cut		
6	Performs fourth cut correctly and in proper relation to previous cuts		
7	Removes roofing material from ventiation opening with appropriate hand tools		
8	*Punches through interior ceiling with pike pole		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>6</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.13A</b>	<b>Primary Task:</b>	<b>Expose Hidden Fire</b>	
<b>Objective(s) :</b>	5.3.13, 5.3.13(A), 5.3.13(B), 5.3.10, 5.3.10(A), 5.3.10(B)	<b>NFPA Standard:</b>	1001	<b>Candidate #</b>
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	*Wears full protective equipment properly			
2	Sizes up the wall or ceiling area for hazards			
3	*Uses appropriate hand tools to determine proper location and makes a hole			
4	Cuts and cleans close to the cut area			
5	Enlarges the opening and extends beyond immediate cut area as needed to locate hidden fire			
6	*Extinguishes fire and continues to overhaul			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	
			Total number tasks candidate must complete to pass	<b>5</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.14A</b>	<b>Primary Task:</b>	<b>Salvage Cover Deployment (two person)</b>	
Objective(s) :	5.3.14, 5.3.14(A), 5.3.14(B)	NFPA Standard:	1001	Candidate #
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly			
2	*Stacks objects carefully and safely			
3	Unfolds or unrolls cover			
4	Deploys cover using "Balloon Toss" method			
5	Secures cover			
<p><b>Note:</b> Each candidate is equally responsible for all items listed above.</p>				
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass	<b>5</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.14B</b>	<b>Primary Task:</b>	<b>Construct a Catch-all (two person)</b>		
Objective(s) :	5.3.14,5.3.14(A), 5.3.14(B)	NFPA Standard:	1001	Candidate #	
Performance Evaluation Sheet					
<b>Tasks:</b>					
				<b>1st</b>	<b>2nd</b>
1	Wears appropriate equipment properly				
2	Locates optimal position for catch-all				
3	Opens salvage cover				
4	Constructs catch-all				
5	*Verifies integrity of construction				
6	*Monitors containment				
<b>Note:</b> Each candidate is equally responsible for all items listed above.					
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>		Total number tasks candidate must complete to pass	<b>5</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.14C	<b>Primary Task:</b> Construct a Water Chute (two person)	
Objective(s) : 5.3.14, 5.3.14(A), 5.3.14(B)	NFPA Standard: 1001	Candidate #
Performance Evaluation Sheet		
<b>Tasks:</b>		
	<b>1st</b>	<b>2nd</b>
1 Wears appropriate equipment properly		
2 Locates optimal position for water chute		
3 Opens salvage cover		
4 Constructs catch-all using available equipment		
5 *Verifies integrity of construction		
6 *Routes water and debris to protect property		
7 *Monitors effectiveness of water chute		
* Critical task      Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>5</b>

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.14D	<b>Primary Task:</b> Route/Remove Water and Debris (vertical)	
Objective(s) : 5.3.14, 5.3.14(A), 5.3.14(B)	NFPA Standard: 1001	Candidate #
<b>Performance Evaluation Sheet</b>		
<b>Tasks:</b>		
	<b>1st</b>	<b>2nd</b>
1 Wears appropriate equipment properly		
2 Selects appropriate salvage tools		
3 Removes drain cover with tools		
4 *Forces water toward drain, scupper or floor opening with equipment (if applicable)		
5 Secures drain guard with tools		
6 Maintains scene safety with available equipment		
7 *Forces water down staircase while conserving property		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>
		Total number tasks candidate must complete to pass <b>5</b>

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.14E	<b>Primary Task:</b> Route/Remove Water and Debris (horizontal)	
Objective(s) : 5.3.14, 5.3.14(A), 5.3.14(B)	NFPA Standard: 1001	Candidate #
<b>Performance Evaluation Sheet</b>		
<b>Tasks:</b>		
	<b>1st</b>	<b>2nd</b>
1 Wears appropriate equipment properly		
2 Selects appropriate salvage tools		
3 Removes drain cover with tools		
4 *Forces water toward existing openings (if applicable)		
5 Secures drain guard with tools		
6 Maintains scene safety with available equipment		
7 *Verbalizes other means to remove water while conserving property		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>
		Total number tasks candidate must complete to pass
		<b>5</b>

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.14F	<b>Primary Task:</b> Route/Remove Water and Debris (below grade)	
Objective(s) : 5.3.14, 5.3.14(A), 5.3.14(B)	NFPA Standard: 1001	Candidate #
<b>Performance Evaluation Sheet</b>		
<b>Tasks:</b>		
	<b>1st</b>	<b>2nd</b>
1 Wears appropriate equipment properly		
2 Secures area from other hazards (electrically, natural gas, fuel oil, etc)		
3 *Sets pump and establishes electrical source (outside of structure) for pump operations		
4 *Secures strainer		
5 Notifies command and starts pump		
6 Monitors salvage and pump operations		
* Critical Task Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>5</b>

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.14G</b>	<b>Primary Task:</b>	<b>Close Up Building</b>		
Objective(s) :	5.3.14, 5.3.14(A) 5.3.14(B)	NFPA Standard:	1001	Candidate #	
<b>Performance Evaluation Sheet</b>					
<b>Tasks:</b>					
			<b>1st</b>	<b>2nd</b>	
1	Wears appropriate equipment properly				
2	Selects method (i.e. covers windows with plastic, doors with plywood, and roof with tarp)				
3	Selects appropriate materials for openings to conserve property				
4	*Applies materials to opening				
5	Notifies Command when completed				
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>		Total number tasks candidate must complete to pass	<b>4</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.14H		<b>Primary Task:</b> Separate/Remove Charred Material	
Objective(s) : 5.3.14, 5.3.14(A), 5.3.14(B), 5.3.13, 5.3.13(A), 5.3.13(B)		NFPA Standard: 1001	Candidate # <span style="border: 1px solid black; display: inline-block; width: 40px; height: 20px; vertical-align: middle;"></span>
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1 Wears full protective equipment properly			
2 Carries and uses appropriate hand tools for overhaul and evidence preservation			
3 *Identifies and protects stated "Area of Origin"			
4 Preserves evidence by guarding, tagging, or other safeguards			
5 Separates charred materials			
6 Removes charred materials to safe location			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>5</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.14J	<b>Primary Task:</b> Stop Water Flow from Sprinkler	
Objective(s) : 5.3.14, 5.3.14(A), 5.3.14(B)	NFPA Standard: 1001	Candidate #
<b>Performance Evaluation Sheet</b>		
<b>Tasks:</b>		
	<b>1st</b>	<b>2nd</b>
1 Wears full protective equipment properly		
2 Inserts wedges or tongs between sprinkler arms, flat sides against sprinkler		
3 *Drives wedges into sprinkler properly or correctly places tongs until water flow stops or is substantially reduced		
4 Identifies and closes main control valve		
5 Identifies and opens main drain valve		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>
		Total number tasks candidate must complete to pass <b>4</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.15A</b>	<b>Primary Task:</b>	<b>Static Source Drafting</b>	
Objective(s) :	5.3.15, 5.3.15(A), 5.3.15(B)	NFPA Standard:	1001	Candidate #
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly			
2	Removes pumper intake cap			
3	*Attaches strainer to hard suction hose male coupling			
4	Attaches rope to strainer			
5	Lowers hose and strainer into static source (portable tank, lake, stream)			
6	*Attaches female coupling of hard section hose to pumper intake			
7	Secures strainer rope to pumper or other stationary object			
8	*Assures strainer and strainer-to-hose coupling are under water			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>		Total number tasks candidate must complete to pass <b>6</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.15B	<b>Primary Task:</b> Hydrant to Pump Connection		
Objective(s) : 5.3.15, 5.3.15(A), 5.3.15(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly		
2	Removes pump intake cap		
3	Attaches the appropriate female end of the suction hose to the pump intake		
4	Removes the appropriate hydrant discharge cap and places the hydrant wrench on hydrant		
5	Inspects hydrant threads for damage and integrity. Inspects inside outlet for debris.		
6	Attaches the appropriate female end of the suction hose to the hydrant		
7	*Slowly opens hydrant fully		
8	Reduces any leakage by tightening connections and assures suction has no kinks		
9	Adds chafing block at point where hose touches ground (if available)		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	
Total number tasks candidate must complete to pass			<b>7</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.15C.1</b>	<b>Primary Task:</b>	<b>Hydrant Connection (Forward Lay)</b>	
Objective(s) :	5.3.15, 5.3.15(A), 5.3.15(B)	NFPA Standard:	1001	Candidate #
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly			
2	*Selects and uses correct tools and appliances			
3	*Wraps hydrant properly			
4	Tells apparatus driver to advance to the incident			
5	Unwraps hose and connects properly to hydrant			
6	*Opens gate slowly and completely on command			
7	Closes hydrant completely			
8	Checks hydrant drainage			
9	Recaps hydrant			
10	Collects and returns appliances			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass	<b>7</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.15C.2		<b>Primary Task:</b> Hydrant Connection (reverse lay)	
Objective(s) : 3.3.15, 3.3.15(A), 3.3.15(B)		NFPA Standard: 1001	Candidate #
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly		
2	*Selects and uses correct tools and appliances		
3	Connects supply line from hydrant to engine in-take properly		
4	Connects feeder line to engine discharge properly		
5	*Opens hydrant fully		
6	*Opens gate on command		
7	Closes hydrant fully		
8	Checks hydrant drainage		
9	Recaps hydrant		
10	Collects and returns appliances		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>	
		Total number tasks candidate must complete to pass	
		<b>7</b>	

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.15D	<b>Primary Task:</b> Fire Department Connection		
Objective(s) : 5.3.15, 5.3.15(A), 5.3.15(B)	NFPA Standard:	1001	Candidate #
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Wears full protective equipment properly		
2	Locates fire department connection (FDC)		
3	Extends hose line from engine discharge to FDC		
4	Removes caps on FDC inlet		
5	*Visually inspects interior of connections for debris		
6	Attaches hose line(s) to connection(s)		
7	Notifies pump operator		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>5</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.15E	<b>Primary Task:</b>	<b>Standpipe Operation</b>	
Objective(s) : 5.3.15, 5.3.15(A), 5.3.15(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	*Wears full protective equipment and SCBA properly		
2	Uses appropriate carry, carries sufficient fire hose to standpipe correct proximity to fire floor		
3	*Attaches the hose to the standpipe connection		
4	Flakes hose, advancing to proper location with respect to the fire floor		
5	*Slowly charges the hoseline by opening the standpipe valve		
6	*Bleeds air from hoseline		
7	Checks nozzle pattern		
8	Advances to the fire		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>6</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.16A</b>	<b>Primary Task:</b>	<b>Extinguish Class A Fire with Portable Extinguisher</b>	
Objective(s) :	5.3.16, 5.3.16(A), 5.3.16(B)	NFPA Standard:	1001	Candidate #
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	Wears appropriate protective clothing properly			
2	Sizes up fire from safe distance and determines Class A fire			
3	*Selects proper extinguisher for Class A fire			
4	Pulls pin at top of extinguisher to break inspection seal			
5	Tests to ensure proper operation			
6	Carries extinguisher to within stream's reach of fire			
7	Aims nozzle toward base of fire			
8	*Discharges agent properly			
9	Extinguishes fire completely			
10	*Backs away from fire area			
11	Tags extinguisher for recharge and inspection			
* Critical Task      Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>		Total number tasks candidate must complete to pass
				<b>8</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.16B	<b>Primary Task:</b> Extinguish Class B Fire with Portable Extinguisher	
Objective(s) : 5.3.16, 5.3.16(A), 5.3.16(B)	NFPA Standard: 1001	Candidate #
<b>Performance Evaluation Sheet</b>		
<b>Tasks:</b>		
	<b>1st</b>	<b>2nd</b>
1 Wears appropriate protective clothing properly		
2 Sizes up fire from safe distance and determines Class B fire		
3 *Selects proper extinguisher for Class B fire		
4 Pulls pin at top of extinguisher to break inspection seal		
5 Tests to ensure proper operation		
6 Carries extinguisher to within stream's reach of fire		
7 Aims nozzle toward base of fire		
8 *Discharges agent properly		
9 Extinguishes fire completely		
10 *Backs away from fire area		
11 Tags extinguisher for recharge and inspection		
* Critical Task      Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>8</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.16C	<b>Primary Task:</b> Extinguish Class C Fire with Portable Extinguisher		
Objective(s) : 5.3.16, 5.3.16(A), 5.3.16(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Wears appropriate protective clothing properly		
2	Sizes up fire from safe distance and determines Class C fire		
3	*Selects proper extinguisher for Class C fire		
4	*De-energizes electrical equipment		
5	Pulls pin at top of extinguisher to break inspection seal		
6	Tests to ensure proper operation		
7	Carries extinguisher to within stream's reach of fire		
8	Aims nozzle toward base of fire		
9	*Discharges agent properly		
10	Extinguishes fire completely		
11	*Backs away from fire area		
12	Tags extinguisher for recharge and inspection		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>9</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.17A	<b>Primary Task:</b> Safety Procedures for Lighting Equipment	
Objective(s) : 5.3.17, 5.3.17(A), 5.3.17(B)	NFPA Standard: 1001	Candidate #
<b>Performance Evaluation Sheet</b>		
<b>Tasks:</b>		
	<b>1st</b>	<b>2nd</b>
1 Describes and identifies inverter OR generator		
2 *Checks overall condition of tools, cords, plugs, and connectors		
3 Starts generator, brings up to speed		
4 Selects and verifies integrity of lighting equipment		
5 Plugs in load		
6 *Connects all lighting equipment in proper sequence		
7 Verbalizes safety precautions to avoid burns and electrocution		
8 Resets Ground Fault Interrupter (GFI) (as needed)		
* Critical Task Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>6</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.18A		<b>Primary Task:</b> Control Utility Services	
Objective(s) : 5.3.18, 5.3.18(A), 5.3.18(B)		NFPA Standard: 1001	Candidate #
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Wears appropriate protective equipment properly		
2	*Locates main electrical breaker and operates main breaker to cut power		
3	*Identifies type of heating service, locates and shuts off source		
4	*Locates main water shut-off and operates appropriate valve to stop water flow		
5	Notifies command		
* Critical Task      Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>	
		Total number tasks candidate must complete to pass	
		<b>4</b>	

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*





State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.3.19B	<b>Primary Task:</b> Fill, Use and Maintain Backpack Pump or Vest	
Objective(s) : 5.3.19, 5.3.19(A), 5.3.19(B)	NFPA Standard: 1001	Candidate #
<b>Performance Evaluation Sheet</b>		
<b>Tasks:</b>		
	<b>1st</b>	<b>2nd</b>
1 Assembles backpack pump or vest properly		
2 Maintains proper footing and stance		
3 *Maintains proper body position when filling		
4 Fills backpack pump or vest with clean or strained water		
5 Demonstrates clearing a clogged nozzle		
6 Demonstrates cleaning a quick connect		
7 Tags and identifies damage		
* Critical Task Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>5</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b>	<b>5.3.19C</b>	<b>Primary Task:</b>	<b>Use of Hand Tools while Building a Fire Control Line</b>	
<b>Objective(s) :</b>	5.3.19, 5.3.19(A), 5.3.19(B)	<b>NFPA Standard:</b>	1001	<b>Candidate #</b>
<b>Performance Evaluation Sheet</b>				
<b>Tasks:</b>				
			<b>1st</b>	<b>2nd</b>
1	*Wears appropriate protective equipment and clothing			
2	Verbalizes situational and environmental awareness			
3	*Selects and inspects proper tools before use			
4	Digs suppression line based on type of fuels and terrain			
5	Extinguishes fire			
6	Maintains fire control line			
7	Notifies Command of status			
* Critical Task      Failure of this task mandates failure on the entire objective		Safety is <b>PARAMOUNT</b>		Total number tasks candidate must complete to pass <b>5</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.5.1A	<b>Primary Task:</b>	<b>Clean, Maintain, and Inspect Ground Ladders</b>	
Objective(s) : 5.5.1, 5.5.1(A), 5.5.1(B)	NFPA Standard:	1001	Candidate #
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Lifts, carries and places ladder on sawhorses properly		
2	Washes and dries per manufacturer's specifications		
3	*Inspects halyard		
4	*Inspects all movable parts of ladder		
5	*Inspects all non-movable parts and markings		
6	Lubricates parts per manufacturer's specifications		
7	Verbalizes conditions that cannot be corrected through cleaning or maintenance		
8	Tags and records results based on findings		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>6</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.5.1B	<b>Primary Task:</b> Daily/Monthly SCBA Inspection		
Objective(s) : 5.5.1, 5.5.1(A), 5.5.1(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Cleans unit per manufacturer's guidelines or department SOPs		
2	*Checks cylinder gauge (at least 90% full)		
3	Compares shoulder gauge readings to cylinder gauge readings (within 100 psi)		
4	*Low-pressure alarm activated when cylinder valve is opened and relieved		
5	Checks all hose connections and air lines		
6	Checks straps and harness system		
7	Checks facepiece		
8	Checks regulators		
9	Checks all valves and switches		
10	*Activates PASS device (either in-line or independent system)		
11	Documents results		
* Critical Task	Failure of this taskmandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>8</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.5.1C	<b>Primary Task:</b> Salvage Cover Maintenance and Inspection		
<b>Objective(s) :</b> 5.5.1, 5.5.1(A), 5.5.1(B)	<b>NFPA Standard:</b> 1001	<b>Candidate #</b>	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Washes and cleans cover with clean water and detergent using a scrub brush		
2	Dries thoroughly to reduce mildew		
3	*Examines for damage (Property Conservation)		
4	Marks any holes found with chalk or marker		
5	Verbalizes patching/repairing according to manufacturer's specifications		
6	Documents findings		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	
Total number tasks candidate must complete to pass			<b>5</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.5.1D	<b>Primary Task:</b> Safety Rope Inspection and Bag Storage		
Objective(s) : 5.5.1, 5.5.1(A), 5.5.1(B)	NFPA Standard: 1001	Candidate #	
<b>Performance Evaluation Sheet</b>			
<b>Tasks:</b>			
		<b>1st</b>	<b>2nd</b>
1	Removes entire length of safety rope from bag		
2	*Using hands, inspects safety rope for softness, stiffness, brittle spots, cuts, nicks, and abrasions		
3	Determines if integrity of safety rope has been compromised		
4	Removes flawed safety rope from service, disposing of it or labeling it out-of-service		
5	Records information in logbook		
6	*Stores safety rope by bagging method		
7	Secures container		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>5</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.5.2A	<b>Primary Task:</b> Hose Rolls and Loads	
Objective(s) : 5.5.2, 5.5.2(A), 5.5.2(B)	NFPA Standard: 1001	Candidate #
<b>Performance Evaluation Sheet</b>		
<b>Tasks:</b>		
	<b>1st</b>	<b>2nd</b>
1 Rolls hose properly by using two of the following methods:		
<ul style="list-style-type: none"> <li>• Straight roll</li> <li>• Donut roll</li> <li>• Twin donut roll</li> <li>• Self-Locking twin donut roll</li> </ul>		
2 Unrolls hose properly		
3 *Couples, uncouples hose properly (foot tilt, knee press method)		
4 Loads hose into hose bed by one of the following methods:		
<ul style="list-style-type: none"> <li>• 1 ¾" – Preconnected Flat Load, Triple Layer Load, Minuteman Load</li> <li>• 2 ½" – Accordion Load, Horseshoe Load, Flat Load</li> </ul>		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>
		Total number tasks candidate must complete to pass <b>3</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*



State of Connecticut  
**COMMISSION ON FIRE PREVENTION AND CONTROL**  
**Fire Fighter I**



<b>Skill Sheet #:</b> 5.5.2B	<b>Primary Task:</b> Clean, Maintain, and Inspect Hose	
Objective(s) : 5.5.2, 5.5.2(A), 5.5.2(B)	NFPA Standard: 1001	Candidate #
<b>Performance Evaluation Sheet</b>		
<b>Tasks:</b>		
	<b>1st</b>	<b>2nd</b>
1 Inspects hose couplings		
2 Brushes off dust and dirt		
3 *Inspects and removes damaged gasket as needed		
4 Reseats gasket		
5 *Inspects hose and removes from service if needed		
6 Cleans hose		
7 Identifies and applies drying procedures for hose		
8 Rolls hose and places on storage rack		
9 Documents results		
* Critical Task Failure of this task mandates failure on the entire objective	Safety is <b>PARAMOUNT</b>	Total number tasks candidate must complete to pass <b>7</b>

9/23/09

**Prevent or prohibit any unsafe acts.  
 Contact the Chief Examiner at any time with any questions.  
 Remember, you are an evaluator, not a trainer...**

*IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.*