



Fire Fighter II – Skill Sheet Index

SS#	Skill Sheet Title	NFPA 1001 Objectives Addressed 2013 Edition
6.2.1A	Complete a Basic Incident Report	6.2.1, 6.2.1(A)(B)
6.2.2A	Communicate the Need for Assistance	6.2.2, 6.2.2(A)(B)
6.3.1A	Foam Stream Application	6.3.1, 6.3.1(A)(B)
6.3.1B	Fire Suppression - Open Pans of Combustible Liquids	6.3.1, 6.3.1(A)(B)
6.3.1C	Fire Suppression - Open Liquid Fire	6.3.1, 6.3.1(A)(B)
6.3.1D	Donning Personal Protective Clothing	6.3.1, 6.3.1(B), 6.3.2, 6.3.2(B)
6.3.1E	Donning SCBA	6.3.1, 6.3.1(B), 6.3.2, 6.3.2(B)
6.3.1F	Doffing SCBA	6.3.1, 6.3.1(B), 6.3.2, 6.3.2(B)
6.3.2A	Interior Attack – Grade Level	6.3.2, 6.3.2(A)(B), 6.2.2, 6.2.2(A)(B)
6.3.2B	Interior Attack – Above Grade	6.3.2, 6.3.2(A)(B), 6.2.2, 6.2.2(A)(B)
6.3.2C	Interior Attack – Below Grade	6.3.2, 6.3.2(A)(B), 6.2.2, 6.2.2(A)(B)
6.3.3A	Flammable Gas Cylinder	6.3.3, 6.3.3(A)(B)
6.3.4A	Preserve Evidence of Cause and Origin	6.3.4, 6.3.4(A)(B)
6.4.1A	Vehicle Extrication	6.4.1, 6.4.1(A)(B)
6.4.1B	Crib and Shore Vehicle	6.4.1, 6.4.1(A)(B)
6.4.2A	Rescue Team Assistance	6.4.2, 6.4.2(A)(B), 6.4.1, 6.4.1(A)(B)
6.5.1A	Private Dwelling Inspection	6.5.1, 6.5.1(A)(B)
6.5.2A	Prepared Program Presentation	6.5.2, 6.5.2(A)(B)
6.5.2B	Preparation of Documentation	6.5.2, 6.5.2(A)(B)
6.5.3A	Prepare a Pre-Incident Survey	6.5.3, 6.5.3(A)(B)
6.5.4A	Portable Power Plant Maintenance	6.5.4, 6.5.4(A)(B)
6.5.4B	Power Tool Selection	6.5.4, 6.5.4(A)(B), 6.4.1, 6.4.1(A)(B)
6.5.5A	Annual Service Test	6.5.5, 6.5.5(A)(B)

Rev 1/22/14

**Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.2.1A	Primary Task: Complete Basic Incident Report	
Objective(s) : 6.2.1, 6.2.1(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #
Performance Evaluation Sheet		
Tasks :		
		1st 2nd
1 * Records department FDID, and incident number		<input type="checkbox"/> <input type="checkbox"/>
2 * Records number of personnel responding		<input type="checkbox"/> <input type="checkbox"/>
3 Records Officer in charge (OIC)		<input type="checkbox"/> <input type="checkbox"/>
4 Records name and address of occupant/owner		<input type="checkbox"/> <input type="checkbox"/>
5 * Records type of structure		<input type="checkbox"/> <input type="checkbox"/>
6 * Records type of incident		<input type="checkbox"/> <input type="checkbox"/>
7 Records type of action taken		<input type="checkbox"/> <input type="checkbox"/>
8 Records damage estimate		<input type="checkbox"/> <input type="checkbox"/>
9 Records remarks/comments		<input type="checkbox"/> <input type="checkbox"/>
* Critical Task Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 6

12/18/13

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.2.2A	Primary Task: Communicate the Need for Assistance
Objective(s) : 6.2.2, 6.2.2(A)(B)	NFPA Standard: 1001, 2013 Edition
Candidate #	
Performance Evaluation Sheet	
Tasks :	
	1st 2nd
1 Describes alarm assignments based on department policy and procedures	<input type="checkbox"/> <input type="checkbox"/>
2 Demonstrates use of alerting procedures	<input type="checkbox"/> <input type="checkbox"/>
3 Demonstrates use of incident assignments	<input type="checkbox"/> <input type="checkbox"/>
4 Demonstrates fireground radio reporting procedures	<input type="checkbox"/> <input type="checkbox"/>
5 Demonstrates procedures for requesting additional response or resources	<input type="checkbox"/> <input type="checkbox"/>
6 Demonstrates radio traffic procedures	<input type="checkbox"/> <input type="checkbox"/>
7 * Demonstrates evacuation signal procedures	<input type="checkbox"/> <input type="checkbox"/>
* Critical Task Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT
Total number tasks candidate must complete to pass 5	

12/18/13

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.3.1A	Primary Task: Foam Stream Application	
Objective(s) : 6.3.1, 6.3.1(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #
Performance Evaluation Sheet		
Tasks :		
		1st 2nd
1	* Wears appropriate protective clothing in a manner consistent with training a manufacturer's recommendation	
2	* Assembles foam appliances and / or equipment	
3	* Matches nozzle to eductor	
4	Introduces eductor to foam concentrate	
5	Identifies fuel type (hydrocarbon or polar solvent)	
6	Sets the eductor metering valve to proper concentrate percentage rating	
7	Opens nozzle properly	
8	* Applies foam by demonstrating appropriate method as directed	
9	Establishes an adequate vapor suppression blanket	
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT
		Total number tasks candidate must complete to pass 6

Rev 1/22/14

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.3.1B	Primary Task: Fire Suppression – Open Pans of Combustible Liquids (with water)	
Objective(s) : 6.3.1, 6.3.1 (A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #
Performance Evaluation Sheet		
Tasks :		
		1st 2nd
1	* Wears approved full protective equipment with SCBA in a manner consistent with training and manufacturer’s recommendation	
2.	Describes the volume of water needed (extinguishment and reach)	
3	* Approaches liquid using wide fog pattern	
4	* Avoids stepping into pools of fuel and fuel runoff	
5	Locates and operates shut-off valve (where applicable)	
6	Retreats using wide fog pattern	
7	Follows all safety precautions	
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT
		Total number tasks candidate must complete to pass 5

Rev 1/22/14

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.3.1C	Primary Task: Fire Suppression - Open Liquid Fire	
Objective(s) : 6.3.1, 6.3.1(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #
Performance Evaluation Sheet		
Tasks :		
		1st 2nd
1	* Wears approved full protective equipment with SCBA in a manner consistent with training and manufacturer's recommendation	<input type="checkbox"/> <input type="checkbox"/>
2	Selects appropriate nozzle	<input type="checkbox"/> <input type="checkbox"/>
3	Approaches fire, maintaining team communication	<input type="checkbox"/> <input type="checkbox"/>
4	Operates fog nozzle on approach (wide fog pattern, if applicable)	<input type="checkbox"/> <input type="checkbox"/>
5	* Opens nozzle fully	<input type="checkbox"/> <input type="checkbox"/>
6	Extinguishes fire	<input type="checkbox"/> <input type="checkbox"/>
7	Executes effective retreat with wide fog pattern	<input type="checkbox"/> <input type="checkbox"/>
8	Follows all safety precautions	<input type="checkbox"/> <input type="checkbox"/>
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT
		Total number tasks candidate must complete to pass 6

Rev 1/22/14

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.3.1D	Primary Task: Donning Personal Protective Clothing		
Objective(s) : 6.3.1, 6.3.1(B), 6.3.2, 6.3.2(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1 * Don boots / trousers with suspenders on shoulders			
2 Dons hood (if applicable), extending around neck under coat or ear flaps down			
3 * Fastens coat completely with collar up and neck tab secured			
4 * Dons helmet, chin strap secured under chin			
5 * Dons gloves			
6 * Dons PPE completely within one minute			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	
Total number tasks candidate must complete to pass			5

Rev 1/22/14

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.3.1E	Primary Task: Donning Self Contained Breathing Apparatus (SCBA)	
Objective(s) : 6.3.1, 6.3.1(B), 6.3.2, 6.3.2(B)	NFPA Standard: 1001, 2013 Edition	Candidate #
Performance Evaluation Sheet		
Tasks :		
		1st 2nd
1	* Wears full protective clothing in a manner consistent with training and manufacturer's recommendation	
2	* Checks that cylinder is full (or at least 90%)	
3	* Opens cylinder fully	
4	Dons harness and connects waist straps	
5	Checks facepiece seal	
6	Turns on PASS Device (if applicable)	
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT
		Total number tasks candidate must complete to pass 4

Rev 1/22/14

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.3.1F	Primary Task: DoFFing Self Contained Breathing Apparatus (SCBA)	
Objective(s) : 6.3.1, 6.3.1(B), 6.3.2, 6.3.2(B)	NFPA Standard: 1001, 2013 Edition	Candidate #
Performance Evaluation Sheet		
Tasks :		
		1st 2nd
1 * Deactivate Positive Pressure if required		<input type="checkbox"/> <input type="checkbox"/>
2 Closes cylinder fully		<input type="checkbox"/> <input type="checkbox"/>
3 * Breathes off excess air, closes remaining valves (if applicable)		<input type="checkbox"/> <input type="checkbox"/>
4 Disconnect regulator from facepiece		<input type="checkbox"/> <input type="checkbox"/>
5 Removes facepiece, buckles and straps properly		<input type="checkbox"/> <input type="checkbox"/>
6 * Gently lowers unit to ground or case		<input type="checkbox"/> <input type="checkbox"/>
* Critical Task Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

12/18/13

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.3.2A Primary Task: Fire Suppression – Interior Attack at Grade Level			
Objective(s) : 6.3.2, 6.3.2(A)(B), 6.2.2, 6.2.2(A)(B)		NFPA Standard: 1001, 2013 Edition	Candidate #
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	* Wears full protective equipment and SCBA in a manner consistent with training and manufacturer's recommendation		
2	Advances hoseline, in a manner consistent with training, from one of the following methods <ul style="list-style-type: none"> • Minuteman Load • Preconnected Flat Load with loops • Triple Layer Load 		
3	* Clears remaining hose from hose bed and flakes out hoseline before advancing to fire area		
4	* Calls for water		
5	* Bleeds air from line, adjusts nozzle pattern		
6	* Maintains communication with other team members		
7	Advances hose line into structure maintaining team and hoseline integrity		
8	Locates fire		
9	* Extinguishes fire using the appropriate attack method		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 6

Rev 1/22/14

**Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.3.2B Primary Task: Fire Suppression – Interior Attack Above Ground	
Objective(s) : 6.3.2, 6.3.2(A)(B), 6.2.2, 6.2.2(A)(B)	NFPA Standard: 1001, 2013 Edition Candidate #
Performance Evaluation Sheet	
Tasks :	
	1st 2nd
1 * Wears full protective equipment and SCBA in a manner consistent with training and manufacturer's recommendation	<input type="checkbox"/> <input type="checkbox"/>
2 Advances hoseline, in a manner consistent with training, from one of the following loads:	<input type="checkbox"/> <input type="checkbox"/>
• Minuteman Load	
• Preconnected Flat Load with loops	
• Triple-Layer Load	
3 * Clears remaining hose from hose bed and flakes out hoseline before advancing to fire area	<input type="checkbox"/> <input type="checkbox"/>
4 * Calls for water	<input type="checkbox"/> <input type="checkbox"/>
5 * Bleeds air from line, adjusts nozzle pattern	<input type="checkbox"/> <input type="checkbox"/>
6 * Maintains communication with other team members	<input type="checkbox"/> <input type="checkbox"/>
7 Ascends stairway quickly, properly and safely to avoid injury hazards	<input type="checkbox"/> <input type="checkbox"/>
8 Locates fire	<input type="checkbox"/> <input type="checkbox"/>
9 * Extinguishes fire using the appropriate attack method	<input type="checkbox"/> <input type="checkbox"/>
* Critical Task Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT Total number tasks candidate must complete to pass 6

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.3.2C Primary Task: Fire Suppression – Interior Attack Below Grade			
Objective(s) : 6.3.2, 6.3.2(A)(B), 6.2.2, 6.2.2(A)(B)		NFPA Standard: 1001, 2013 Edition	Candidate #
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	* Wears full protective equipment and SCBA in a manner consistent with training and manufacturer’s recommendation		
2	Advances hoseline, in a manner consistent with training, from one of the following loads: <ul style="list-style-type: none"> • Minuteman Load • Preconnected Flat Load with loops • Triple Layer Load 		
3	* Clears remaining hose from hose bed and flakes out hoseline before advancing to fire area		
4	* Calls for water		
5	* Opens bail or throttle to bleed air, adjust nozzle pattern		
6	* Maintains communication with other team members		
7	Enters structure safely (per building conditions) maintains team and hoseline integrity		
8	* Descends stairway quickly, properly and safely to avoid injury hazards		
9	Locates fire		
10	* Extinguishes fire using the appropriate attack method		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 10

Rev 1/22/14

**Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.3.3A	Primary Task: Flammable Gas Cylinder	
Objective(s) : 6.3.3, 6.3.3(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #
Performance Evaluation Sheet		
Tasks :		
		1st 2nd
1	* Wears full protective equipment and SCBA in a manner consistent with training and manufacturer's recommendation	
2	* Selects appropriate nozzle	
3	Approaches fire from a safe distance	
4	Demonstrates proper nozzle technique (cooling cylinder)	
5	* Closes shutoff valve	
6	Applies additional agent to prevent re-ignition	
7	Executes proper and effective retreat	
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT
		Total number tasks candidate must complete to pass 5

Rev 1/22/14

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.3.4A	Primary Task: Preserve Evidence of Cause and Origin		
Objective(s) : 6.3.4, 6.3.4(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	* Wears full protective equipment in a manner consistent with training and manufacturer's recommendation		
2	Locates potential fire origin		
3	* Identifies evidence that needs to be preserved		
4	* Demonstrates appropriate techniques for protecting evidence		
5	Recognizes possible cause		
6	Records findings (diagrams, sketches, camera, videos)		
7	Protects evidence and scene		
8	* Notifies investigating agency		
9	Documents activity log		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	
Total number tasks candidate must complete to pass			6

Rev 1/22/14

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.4.1A	Primary Task: Vehicle Extrication	
Objective(s) : 6.4.1A, 6.4.1(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #
Performance Evaluation Sheet		
Tasks :		
		1st 2nd
1 * Wears full protective equipment in a manner consistent with training and manufacturer's recommendation		
2 Secures scene		
3 Communicates potential hazards at incident		
4 Confirms vehicle is stabilized		
5 * Protects victim		
6 Communicates with victim		
7 * Follows all safety procedures		
* Critical Task Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 5

Rev 1/22/14

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.4.1B	Primary Task: Crib and Shore Vehicle	
Objective(s) : 6.4.1, 6.4.1(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #
Performance Evaluation Sheet		
Tasks :		
		1st 2nd
1	* Wears full protective equipment in a manner consistent with training and manufacturer's recommendation	<input type="checkbox"/> <input type="checkbox"/>
2	Selects appropriate materials for cribbing	<input type="checkbox"/> <input type="checkbox"/>
3	Places cribbing pieces into position safely	<input type="checkbox"/> <input type="checkbox"/>
4	* Checks stabilization	<input type="checkbox"/> <input type="checkbox"/>
5	* Proper lifting techniques when cribbing vehicle (back to vehicle)	<input type="checkbox"/> <input type="checkbox"/>
6	* Proper hand placement when cribbing vehicle	<input type="checkbox"/> <input type="checkbox"/>
7.	* Builds proper Box crib	<input type="checkbox"/> <input type="checkbox"/>
8.	* Set Step Chock properly	<input type="checkbox"/> <input type="checkbox"/>
* Critical Task	Failure of this task mandates failure on the entire objective	6
Safety is PARAMOUNT		Total number tasks candidate must complete to pass

Rev 1/22/14

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.4.2A	Primary Task: Rescue Team Assistance	
Objective(s) : 6.4.2, 6.4.2(A)(B), 6.4.1, 6.4.1(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #
Performance Evaluation Sheet		
Tasks :		
		1st 2nd
1	* Wears full protective equipment in a manner consistent with training and manufacturer's recommendation	<input type="checkbox"/> <input type="checkbox"/>
2	* Identifies and states application for various types of rescue tools upon request	<input type="checkbox"/> <input type="checkbox"/>
3	Retrieves various types of rescue tools upon request	<input type="checkbox"/> <input type="checkbox"/>
4	Establishes public barriers	<input type="checkbox"/> <input type="checkbox"/>
5	Indicates potential hazards	<input type="checkbox"/> <input type="checkbox"/>
6	Assists rescue teams as a member of a team upon request	<input type="checkbox"/> <input type="checkbox"/>
7	* Follows safety procedures	<input type="checkbox"/> <input type="checkbox"/>
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT
		Total number tasks candidate must complete to pass 5

Rev 1/22/14

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.5.1A	Primary Task: Private Dwelling Inspections	
Objective(s) : 6.5.1, 6.5.1(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #
Performance Evaluation Sheet		
Tasks :		
		1st 2nd
1	* Have and wear appropriate identification, dresses in appropriate attire	<input type="checkbox"/> <input type="checkbox"/>
2	* Obtains permission from occupant	<input type="checkbox"/> <input type="checkbox"/>
3	Checks heating appliances	<input type="checkbox"/> <input type="checkbox"/>
4	Checks electrical distribution and appliances	<input type="checkbox"/> <input type="checkbox"/>
5	Checks cooking appliances	<input type="checkbox"/> <input type="checkbox"/>
6	Checks for smoking materials	<input type="checkbox"/> <input type="checkbox"/>
7	Checks attic and basement areas	<input type="checkbox"/> <input type="checkbox"/>
8	Checks yard and exterior areas	<input type="checkbox"/> <input type="checkbox"/>
9	Checks attached and detached buildings	<input type="checkbox"/> <input type="checkbox"/>
10	* Communicates findings to occupant/exit interview	<input type="checkbox"/> <input type="checkbox"/>
11	Follows proper procedures and record keeping	<input type="checkbox"/> <input type="checkbox"/>
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT
		Total number tasks candidate must complete to pass 8

12/18/13

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.5.2A	Primary Task: Presentation of a Prepared Program	
Objective(s) : 6.5.2, 6.5.2(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #
Performance Evaluation Sheet		
Tasks :		
		1st 2nd
1	* Selects lesson materials on safety-related topic for specific audience	
2	Wears appropriate attire for presentation	
3	Introduces self	
4	Introduces topic	
5	Presents lesson	
6	Provides correct answers to questions	
7	Summarizes lesson	
8	* Documents presentation for records	
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT
		Total number tasks candidate must complete to pass 6

12/18/13

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.5.2B	Primary Task: Preparation of Documentation	
Objective(s) : 6.5.2, 6.5.2(B)	NFPA Standard: 1001, 2013 Edition	Candidate #
Performance Evaluation Sheet		
Tasks :		
		1st 2nd
1 Identify program title		<input type="checkbox"/> <input type="checkbox"/>
2 Document participants by:		<input type="checkbox"/> <input type="checkbox"/>
Name		<input type="checkbox"/> <input type="checkbox"/>
Number		<input type="checkbox"/> <input type="checkbox"/>
3 Enter student evaluations		<input type="checkbox"/> <input type="checkbox"/>
* Critical Task Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 3

12/18/13

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.5.3A	Primary Task: Prepare a Pre-Incident Survey	
Objective(s) : 6.5.3, 6.5.3(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #
Performance Evaluation Sheet		
Tasks :		
		1st 2nd
1	*Records property name, address, owner, and emergency contact numbers accurately	<input type="checkbox"/> <input type="checkbox"/>
2	Reports occupancy type and capacity	<input type="checkbox"/> <input type="checkbox"/>
3	Identifies water supply (Hydrants)	<input type="checkbox"/> <input type="checkbox"/>
4	Identifies special water supply (water tank)	<input type="checkbox"/> <input type="checkbox"/>
5	* Identifies fire protection system(s) present	<input type="checkbox"/> <input type="checkbox"/>
6	Identifies Fire Dept. Connection	<input type="checkbox"/> <input type="checkbox"/>
7.	* Draws appropriate Building sketch from pre-incident data	<input type="checkbox"/> <input type="checkbox"/>
8.	* Draws appropriate Roads from pre-incident data	<input type="checkbox"/> <input type="checkbox"/>
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT
		Total number tasks candidate must complete to pass 6

Rev 1/22/14

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.5.4A	Primary Task: Portable Power Plant Maintenance	
Objective(s) : 6.5.4, 6.5.4(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #
Performance Evaluation Sheet		
Tasks :		
		1st 2nd
1	Maintains / services in a manner consistent with manufacturer's recommendation	<input type="checkbox"/> <input type="checkbox"/>
2	Checks gas / fuel	<input type="checkbox"/> <input type="checkbox"/>
3	Checks Oil	<input type="checkbox"/> <input type="checkbox"/>
4	Starts unit properly	<input type="checkbox"/> <input type="checkbox"/>
5	Shuts down unit properly	<input type="checkbox"/> <input type="checkbox"/>
6	Demonstrates safety devices / equipment on the unit	<input type="checkbox"/> <input type="checkbox"/>
7	* Tags for damaged and / or documents service records	<input type="checkbox"/> <input type="checkbox"/>
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT
		Total number tasks candidate must complete to pass 5

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.5.4B	Primary Task: Power Tool Selection	
Objective(s) : 6.5.4, 6.5.4(A)(B), 6.4.1, 6.4.1(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #
Performance Evaluation Sheet		
Tasks :		
		1st 2nd
1	* Wears protective equipment in a manner consistent with training and manufacturer's recommendation	
2	Selects proper tool for operation	
3	Completes all proper connections	
4	* Operates equipment properly including safety features	
5	* Tags for damaged equipment and / or documents for service records	
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT
		Total number tasks candidate must complete to pass 4

Rev 1/22/14

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.5.5A	Primary Task: Annual Service Test		
Objective(s) : 6.5.5, 6.5.5(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	* Wears protective equipment in a manner consistent with training and manufacturer's recommendation		
2	Verbalizes maximum allowable hose length for test based on current NFPA 1962 standard		
3	* Prepares hoseline and couplings for testing		
4	* Establishes safety barrier		
5	Tightens all connections		
6	Removes all air from hose lines		
7	* Verbalizes test pressure compliance based on current NFPA 1962 standard		
8	Verbalizes time limit for service test		
9	* Checks all couplings for hose separation		
10	* Records results of hose test		
11	Verbalizes removal of damaged equipment from service		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	
Total number tasks candidate must complete to pass			8

Rev 1/22/14

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.