

FIREFIGHTER I SKILLS EVALUATION SHEETS
NFPA 1001, 2008 Edition

SS #	SS Title	NFPA 1001 Objective Addressed
5.1.1.2A	Donning Personal Protective Equipment	5.1.2
5.1.1.2B	Knot Tying/Hoisting Tools	5.1.2
5.1.1.2C	Knot Selection and Tying	5.1.2
5.1.1.2D	Securing with Rope	5.1.2
5.2.1A	Emergency Telephone Procedures	5.2.1, 5.2.1(B)
5.2.1B	Emergency, Walk-Ins	5.2.1, 5.2.1(B)
5.2.1C	Emergency Telephone/Radio Fire Alarm Box	5.2.1, 5.2.1(B)
5.2.2A	Fire Department Telephone Skills	5.2.2, 5.2.2(B)
5.2.3A	Radio Procedures on the Fire Ground	5.2.3, 5.2.3(B)
5.3.1A.1	SCBA - Replacement of Cylinder (1 person)	5.3.1, 5.3.1(B)
5.3.1A.2	SCBA - Replacement of Cylinder (2 person)	5.3.1, 5.3.1(B)
5.3.1B	Donning SCBA	5.3.1, 5.3.1(B)
5.3.1E	SCBA Ready for Immediate Use	5.3.1, 5.3.1(B)
5.3.1F	SCBA - Restricted Passage (Vertical Passage)	5.3.1, 5.3.1(B), 5.3.9, 5.3.9(B)
5.3.1F.1	SCBA - Restricted Passage (Horizontal Egress)	5.3.1, 5.3.1(B), 5.3.9, 5.3.9(B)
5.3.1G	SCBA Failure Procedures	5.3.1, 5.3.1(B)
5.3.2A	Safety - Mounting, Riding, Dismounting Apparatus	5.3.2, 5.3.2(B)
5.3.3A	Deploy Traffic and Scene Control Devices	5.3.3, 5.3.3(B), 5.3.2, 5.3.2(B)
5.3.4A	Identify and Carry Tools	5.3.4, 5.3.4(B)
5.3.4B	Forcible Entry - Door	5.3.4, 5.3.4(B)
5.3.4C	Window Opening (Non- Destructive)	5.3.4, 5.3.4(B)
5.3.4D	Forcible Entry - Plaster or Gypsum Walls	5.3.4, 5.3.4(B)
5.3.5A.1	Action When Trapped/Disoriented (with hose)	5.3.5, 5.3.5(B)
5.3.5A.2	Action When Trapped/Disoriented (without hose)	5.3.5, 5.3.5(B)
5.3.6A	24' Ext. Ladder Carry/Raise (1 person)	5.3.6, 5.3.6(B)
5.3.6B	24' Ext. Ladder Lower/Removal (1 person)	5.3.6, 5.3.6(B)
5.3.6C	24/28' Ext. Ladder Carry/Raise (2 person)	5.3.6, 5.3.6(B)
5.3.6D	24/28' Ext. Ladder Lower/Removal (2 person)	5.3.6, 6.3.6(B)
5.3.6E	14/20' Single Ladder Carry/Raise (1 person)	5.3.6, 5.3.6(B)
5.3.6F	14/20' Single Ladder Lower/Removal (1 person)	5.3.6, 5.3.6(B)
5.3.6G	35' Ext. Ladder Carry and Raise (3 person)	5.3.6, 5.3.6(B)
5.3.6H	35' Ext. Ladder Lower/Removal (3 person)	5.3.6, 5.3.6(B)
5.3.7A	Fire Suppression - Vehicle Fires	5.3.7, 6.3.7(B), 5.3.10, 5.3.10(B)
5.3.8A	Fire Suppression - Piles/Stacks Class A	5.3.8, 5.3.8(B), 5.3.10, 5.3.10(B)
5.3.8B	Fire Suppression - Dumpster/Storage	5.3.8, 5.3.8(B), 5.3.10, 5.3.10(B)
5.3.8C	Deploy Master Stream Device	5.3.8, 5.3.8(B)
5.3.9B	Rescue with SCBA - Obscured Visibility	5.3.9, 5.3.9(B), 5.3.1, 5.3.1(B)
5.3.9C	Removal Over Ladder (Conscious Person)	5.3.9, 5.3.9(B), 5.3.6, 5.3.6(B)
5.3.9D	Removal Over Ladder (Unconscious Person)	5.3.9, 5.3.9(B), 5.3.6, 5.3.6(B)
5.3.9F	Primary Search	5.3.9, 5.3.9(B)

FIREFIGHTER I SKILLS EVALUATION SHEETS
NFPA 1001, 2008 Edition

5.3.9F.1	Secondary Search	5.3.9, 5.3.9(B)
5.3.9G	Drags and Carries (1 & 2 person)	5.3.9, 5.3.9(B)
5.3.10A.1	Fire Suppression - Grade Level	5.3.10, 5.3.10(B) 5.3.8, 5.3.8(B)
5.3.10A.2	Fire Suppression - Above Grade Level	5.3.10, 5.3.10(B) 5.3.8, 5.3.8(B)
5.3.10A.3	Fire Suppression - Below Grade Level	5.3.10, 5.3.10(B) 5.3.8, 5.3.8(B)
5.3.10B	Hose Carries	5.3.10, 5.3.10(B) 5.3.8, 5.3.8(B)
5.3.10C	Hoseline Advancement	5.3.10, 5.3.10(B), 5.3.13, 5.3.13(B)
5.3.10D	Hoseline Operation from Ground Ladder	5.3.10, 5.3.10(B)
5.3.10E	Use of Nozzle	5.3.10, 5.3.10(B), 5.3.13, 5.3.13(B), 5.3.8, 5.3.8(B)
5.3.10F	Replace Burst Section of Hose	5.3.10, 5.3.10(B)
5.3.10G	Adding a Length of Hose	5.3.10, 5.3.10(B)
5.3.10H.1	Couple/Uncouple Hose (1 person)	5.3.10, 5.3.10(B)
5.3.10H.2	Couple/Uncouple Hose (2 person)	5.3.10, 5.3.10(B)
5.3.10J	Remove Hose from Upper Floors	5.3.10, 5.3.10(B), 5.3.14, 5.3.14(B)
5.3.10K	Remove Hose to Minimize Water Damage	5.3.10, 5.3.10(B), 5.3.14, 5.3.14(B)
5.3.11A	Working from Ground Ladders	5.3.11, 5.3.11(B), 5.3.6, 5.3.6(B)
5.3.11B	Window Opening (Destructive)	5.3.11, 5.3.11(B), 5.3.6, 5.3.6(B)
5.3.11C	Hydraulic Ventilation	5.3.11, 5.3.11(B), 5.3.19, 5.3.10(B)
5.3.11D	Negative-Pressure Ventilation	5.3.11, 5.3.11(B)
5.3.11E	Positive-Pressure Ventilation	5.3.11, 5.3.11(B)
5.3.12A.1	Roof Ladder Deployment	5.3.12, 5.3.12(B), 5.3.6, 5.3.6(B)
5.3.12A.2	Roof Ladder-Lower and Removal	5.3.12, 5.3.12(B), 5.3.6, 5.3.6(B)
5.3.12B	Ladder Climb with Tool	5.3.12, 3-3.12(B), 5.3.11, 5.3.11(B)
5.3.12C	Determining Roof Integrity	5.3.12, 5.3.12(B)
5.3.12D.1	Roof Ventilation - Flat	5.3.12, 5.3.12(B)
5.3.12D.2	Roof Ventilation - Pitched	5.3.12, 5.3.12(B)
5.3.13A	Expose Hidden Fire	5.3.13, 5.3.13(B), 5.3.10, 5.3.10(B)
5.3.14A	Salvage Cover Deployment (2 person)	5.3.14, 5.3.14(B)
5.3.14B	Construct and Use Water Catch-all	5.3.14, 5.3.14(B)
5.3.14C	Construct and Use Water Chute	5.3.14, 5.3.14(B)
5.3.14F	Route/Remove Water and Debris (Vertical)	5.3.14, 5.3.14(B)
5.3.14G	Route/Remove Water and Debris (Horizontal)	5.3.14, 5.3.14(B)
5.3.14H	Route/Remove Water and Debris (Below Grade)	5.3.14, 5.3.14(B)
5.3.14J	Closes up Building	5.3.14, 5.3.14(B)
5.3.14K	Separate/Remove Charred Material	5.3.14, 5.3.14(B), 5.3.13, 5.3.13(B)
5.3.14M	Stop Water Flow from Sprinkler Head	5.3.14, 5.3.14(B)
5.3.15A	Drafting from a Static Source - (4 person)	5.3.15, 5.3.15(B)
5.3.15B	Hydrant to Pumper Connection	5.3.15, 5.3.15(B)
5.3.15C.1	Hydrant Connection (Forward Lay)	5.3.15, 5.3.15(B)
5.3.15C.2	Hydrant Connection (Reverse lay)	5.3.15, 5.3.15(B)
5.3.15D	Sprinkler/Standpipe Connection	5.3.15, 5.3.15(B)
5.3.15E	Standpipe Operation	5.3.15, 5.3.15(B)
5.3.16A	Extinguish Class A Fires	5.3.16, 5.3.16(B)
5.3.16B	Extinguish Class B Fires	5.3.16, 5.3.16(B)
5.3.16C	Extinguish Class C Fires	5.3.16, 5.3.16(B)
5.3.17A	Safety Procedures for Lighting Equipment	5.3.17, 5.3.17(B)
5.3.18A	Control Utility Services	5.3.18, 5.3.18(B)
5.3.19A	Donning Ground Cover PPE	5.3.19, 5.3.19(B)
5.3.19B	Fill, Use and Maintain a Backpack Pump	5.3.19, 5.3.19(B)

FIREFIGHTER I SKILLS EVALUATION SHEETS
NFPA 1001, 2008 Edition

5.3.19C	Use Tools/Appliances-Ground Cover Hose Lay	5.3.19, 5.3.19(B)
5.3.19D	Use of Hand Tools for Fire Control Line	5.3.19, 5.3.19(B)
5.5.3A	Inspect/Clean/Maintain Department Ladders	5.5.1, 5.5.1(B)
5.5.3C	SCBA Maintenance and Use	5.5.1, 5.5.1(B)
5.5.3D	Salvage Cover Inspection and Maintenance	5.5.1, 3.5.1(B)
5.5.3E	Rope Maintenance	5.5.1, 5.5.1(B)
5.5.4A	Hose Storage	5.5.2, 5.5.2(B)
5.5.4B	Hose Rolls	5.5.2, 5.5.2(B)
5.5.4C	Inspect/Clean/Maintain Fire Hose	5.5.2, 5.5.2(B)
5.5.4D	Inspect/Clean/Maintain Fire Hose Couplings	5.5.2, 5.5.2(B)



State of Connecticut
 COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.1.1.2A	Primary Task:	Donning Personal Protective Clothing	
Objective(s) :	5.1.2	NFPA Standard:	1001	Candidate # <input style="width: 50px;" type="text"/>
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Boots/Trousers			
2	* Coat fastened completely			
3	* Gloves			
4	Hood (all skin covered) if applicable			
5	* Helmet chin strap in place, ear flaps down (if applicable)			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass	4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
 COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.1.1.2B	Primary Task:	Knot Tying / Hoisting Tools and Equipment	
Objective(s) :	5.1.2	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Selects correct rope			
2	Verbalizes correct knot for the task			
3	* Ties correct knots to hoist tools / hose			
4	Hoists tools / hose successfully			
5	Ties tag lines properly (when applicable)			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass	4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.1.1.2C	Primary Task: Knot Selection and Tying		
Objective(s) : 5.1.2	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
At the direction of the examiner, the candidate will perform the following:			
1. * Selects proper size and length of rope		<input type="checkbox"/>	<input type="checkbox"/>
2. Ties Clove Hitch with overhand safety knot		<input type="checkbox"/>	<input type="checkbox"/>
3. Ties Figure of Eight on a Bight with overhand safety knot		<input type="checkbox"/>	<input type="checkbox"/>
4. Ties Becket (sheet) Bend with two safety knots		<input type="checkbox"/>	<input type="checkbox"/>
5. Ties Half Hitch		<input type="checkbox"/>	<input type="checkbox"/>
6. Ties Single Figure of Eight with safety knot		<input type="checkbox"/>	<input type="checkbox"/>
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.1.1.2D	Primary Task: Securing with Rope		
Objective(s) : 5.1.2	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1 Ties off to secure object			
2 Uses correct knot for selected object			
3 * Ties knot correctly			
4 Secures object correctly			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.2.1A	Primary Task: Emergency Telephone Procedures		
Objective(s) : 5.2.1, 5.2.1(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1. Answer phone in accordance with department's SOPs or other guidelines			
2. Have questions organized to control conversation			
3. Ask questions in an assertive voice (department's SOPs)			
4. Repeat information back to caller			
5. Forward information to proper authority (department SOPs)			
6. * Documents information			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.2.1C		Primary Task: Emergency Telephone/Radio/Fire Alarm Box Procedures	
Objective(s) : 5.2.1, 5.2.1(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1	Answers phone in accordance with department SOP's or other department guidelines		
2	Has questions organized to control conversation		
3	Asks questions in an assertive voice (department's SOPs)		
4	Repeats information back to the caller		
5	Forwards information to proper authority (department's SOPs)		
6	Documents information		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.2.2A	Primary Task:	Fire Department Telephone Skills (non-emergency from public)	
Objective(s) :	5.2.2, 5.2.2 (B)	NFPA Standard	1001	Candidate # <input style="width: 50px;" type="text"/>
Performance Evaluation Sheet				
Task				
			1st	2nd
1.	Answers calls promptly and in a professional manner		<input type="text"/>	<input type="text"/>
2.	Identifies himself/herself (rank & name) and the name of his/her fire department		<input type="text"/>	<input type="text"/>
3.	Records all information accurately – name, time, date, telephone number		<input type="text"/>	<input type="text"/>
4.	Terminates call courteously		<input type="text"/>	<input type="text"/>
5.	Forwards information to the proper authority (department SOP's)		<input type="text"/>	<input type="text"/>
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass	4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.2.3A	Primary Task: Radio Procedures on the Fire Ground		
Objective(s) : 5.2.3, 5.2.3(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1 * Identifies themselves (ex. Engine Company # 1)			
2 Identifies the contact that the message is being transmitted to (ex. Fire Alarm, Dispatch)			
3 Confirms location of incident, correct address (initial size-up)			
4 Voice is clear when transmitting			
5 Ensures message concise and to the point			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.10A.1	Primary Task:	Fire Suppression – Interior Structure, Grade Level	
Objective(s) :	5.3.10, 5.3.10(B), 5.3.8, 5.3.8(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective equipment and SCBA properly			
2	Properly advances hoseline from one of the following loads			
	• Minuteman Load			
	• Preconnected Flat Load			
	• Triple Layer Load			
3	* Clears remaining hose from hose bed and flakes out hoseline before entering			
4	Maintains communication			
5	Enters structure properly (per buildings condition)			
6	Locates fire and radios for water			
7	* Extinguishes fire using the directed attack methods			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass	5

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.10A.2	Primary Task: Fire Suppression – Interior Structure Above Grade Level	
Objective(s) : 5.3.10, 5.3.10(B), 5.3.8, 5.3.8(B)	NFPA Standard: 1001	Candidate # <input style="width: 50px;" type="text"/>
Performance Evaluation Sheet		
Task		
	1st	2nd
1 * Wears full protective clothing and SCBA correctly	<input type="text"/>	<input type="text"/>
2 Properly advances hoseline up interior stairs to the fire floor by one of the following loads		
• Preconnected flat load	<input type="text"/>	<input type="text"/>
• Minuteman load	<input type="text"/>	<input type="text"/>
• Triple layer load	<input type="text"/>	<input type="text"/>
3 * Clears all remaining hose from hose bed and flakes out hoseline before advancing to the fire area	<input type="text"/>	<input type="text"/>
4 Maintains communication	<input type="text"/>	<input type="text"/>
5 Locates fire and radios for water	<input type="text"/>	<input type="text"/>
6 * Extinguishes fire using the directed attack method	<input type="text"/>	<input type="text"/>
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT
		Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.10A.3	Primary Task: Fire Suppression – Interior Structure, Below Grade Level		
Objective(s) : 5.3.10, 5.3.10(B), 5.3.8, 5.3.8(B),	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1 * Wears full protective equipment and SCBA properly			
2 Enters structure properly (per Buildings condition)			
3 Maintains communications			
4 Removes all hose from hose bed, flakes hose prior to descending stairs			
5 Calls for water			
6 * Descends stairs safely (feet first in the sitting position) with charged line			
7 * Locates and extinguishes fire using the directed method			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 5

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.10B	Primary Task: Hose Carries		
Objective(s) : 5.3.10, 5.3.10(B), 5.3.8, 5.3.8(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1 * Wears full protective equipment properly			
2 Demonstrates deploying one of the following 1 ¾" loads			
• Preconnected flat load			
• Minuteman load			
• Triple layer load			
OR			
3 Demonstrates deploying one of the following 2 ½" loads			
• Accordion load			
• Flat load			
• Horseshoe load			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 2

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.10C	Primary Task: Hoseline Advancement		
Objective(s) : 5.3.10, 5.3.10(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1 * Wears full protective equipment properly			
2 Deploys hose properly to building or structure			
3 * Maintains communication (calls for water when needed)			
4 Works hoseline properly			
5 Maintains forward movement			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.10D Primary Task: Charged Hoseline Operation from Ground Ladder (2 person)				
Objective(s) : 5.3.10, 5.3.10(B)		NFPA Standard: 1001	Candidate # 	
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective equipment properly			
2	Ascends ladder safely with charged hose line			
3	* Maintains communication			
4	Assures proper position on ladder for best penetration			
5	* Uses leg lock or safety harness			
6	Projects nozzle between rungs for best results			
7	Uses hose strap to secure hose to ladder			
8	* Slowly opens nozzle and flows water safely			
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	Total number tasks candidate must complete to pass	6

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.10E	Primary Task:	Use of Nozzle			
Objective(s) :	5.3.10, 5.3.10(B), 5.3.13(B), 5.3.8(B)	NFPA Standard:	1001	Candidate # 		
Performance Evaluation Sheet						
Task						
			1st	2nd		
1	* Wears full protective equipment properly					
2	Identifies nozzle/appliance					
3	* Opens nozzle slowly					
4	Bleeds air and checks flow pattern					
5	Demonstrates the following nozzle settings					
	• Straight Stream					
	• Narrow Angle Fog					
	• Wide Angle Fog					
6	* Closes nozzle slowly					
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass	4		

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.10F	Primary Task:	Replace Burst Section of Hose	
Objective(s) :	5.3.10, 5.3.10(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective equipment properly			
2	Controls water flow by using clamp or valve			
3	Selects two lengths to replace defective length			
4	Uncouples defective length			
5	Couples replacement length			
6	Removes clamp / opens valve to charge line			
	Complete steps 1 to 5 using 1 3/4" line			
	OR			
	Complete steps 1 to 5 using 2 1/2" line			
NOTE: If clamp is not used, water supply may be controlled at the source.				
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT		4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.10G	Primary Task:	Adding a Length of Hose	
Objective(s) :	5.3.10, 5.3.10(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective equipment properly			
2	Selects hose to be added to line and places it in position			
3	* Opens gated wye or nozzle slightly			
4	Applies hose clamp or shuts off water at source			
5	* Adds additional length of hose by using foot-tilt, knee-press method			
6	Removes clamp slowly or turns water on at source			
<p>NOTE: If clamp is not used, water supply may be controlled at source.</p>				
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass	4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.10H.1	Primary Task:	Coupling and Uncoupling Hose (One Person)	
Objective(s) :	5.3.10, 5.3.10(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
ONE PERSON				
1	* Wears full protective equipment properly		<input type="text"/>	<input type="text"/>
2	Couples two lengths (supply line) Min. size 2 1/2" using foot-tilt method		<input type="text"/>	<input type="text"/>
3	Uncouples hoseline used in step #1 using knee-press method		<input type="text"/>	<input type="text"/>
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass	3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.10H.2	Primary Task:	Coupling / Uncoupling Hose (Two Person)	
Objective(s) :	5.3.10, 5.3.10(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
** TWO PERSON **				
1	* Wears full protective equipment properly			
2	Couples two lengths – minimum size 2 1/2"			
3	Uncouples line used in Step #2 using stiff–arm method			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass	3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.10J	Primary Task: Remove Hose from Upper Floors		
Objective(s) : 5.3.10, 5.3.10(B), 5.3.14, 5.3.14(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1 Shuts down water supply			
2 Opens nozzle to relieve water pressure (bathtub, out of window, etc.)			
3 Disconnects hose coupling to drain (window sill, front door, street curb, etc.)			
4 After draining, removes hose using shoulder carry			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.10K	Primary Task:	Remove Hose from Building to Minimize Water Damage		
Objective(s) :	5.3.10, 5.3.10(B), 5.3.14, 5.3.14(B)	NFPA Standard:	1001	Candidate #	
Performance Evaluation Sheet					
Task					
			1st	2nd	
1	* Wears full protective equipment properly				
2	Shuts down water supply				
3	Opens nozzle to relieve pressure (bathtub, out of window, etc.)				
4	Disconnects hose coupling to drain (window sill, front door, street curb, etc.)				
5	After draining, removes hose from building (using shoulder carry)				
6	Re-packs preconnect hose on apparatus by one of the following loads:				
	• Flat load				
	• Triple layer load				
	• Minuteman load				
* Critical Task		Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	
				Total number tasks candidate must complete to pass	
				4	

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.11A	Primary Task:	Working Safely from Ladders (Ground)	
Objective(s) :	5.3.11, 5.3.11(B), 5.3.6, 5.3.6(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective equipment properly			
2	Climbs ladder properly			
3	* Uses leg lock or safety harness properly			
4	Descends ladder safely			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass	3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.11B	Primary Task: Window Opening (Destructive)		
Objective(s) : 5.3.11, 5.3.11(B), 5.3.6(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1	* Wears full protective equipment properly		
2	Positions ladder (windward side of the window)		
3	Climbs ladder with tool		
4	* Uses leg lock or safety harness		
5	Maintains safety area		
6	Strikes window correctly (simulation)		
7	Clears window frame (simulation)		
8	Descends ladder safely		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 6

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.11D	Primary Task: Negative-Pressure Ventilation	
Objective(s) : 5.3.11, 5.3.11(B)	NFPA Standard: 1001	Candidate # <input style="width: 50px;" type="text"/>
Performance Evaluation Sheet		
Task		
	1st	2nd
1 * Wears full protective equipment properly	<input type="text"/>	<input type="text"/>
2 * Ensures proper placement in opening (same direction as natural wind)	<input type="text"/>	<input type="text"/>
3 * Removes any material that might disrupt air flow (if applicable)	<input type="text"/>	<input type="text"/>
4 Covers area around fan to prevent churning	<input type="text"/>	<input type="text"/>
5 Connects to power properly	<input type="text"/>	<input type="text"/>
* Critical Task Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.11E	Primary Task: Positive-Pressure Ventilation	
Objective(s) : 5.3.11, 5.3.11(B)	NFPA Standard: 1001	Candidate # <input style="width: 50px;" type="text"/>
Performance Evaluation Sheet		
Task		
	1st	2nd
1 * Wears full protective equipment properly	<input type="text"/>	<input type="text"/>
2 Selects proper point of entry	<input type="text"/>	<input type="text"/>
3 * Selects proper exit point to remove smoke (other areas should be closed)	<input type="text"/>	<input type="text"/>
4 Properly positions fan to completely cover entry with cone of air	<input type="text"/>	<input type="text"/>
5 Properly connects to power source (if applicable)	<input type="text"/>	<input type="text"/>
* Critical Task Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.12A.1	Primary Task:	Roof Ladder Deployment	
Objective(s) :	5.3.12, 5.3.12(B), 5.3.6(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective clothing properly			
2	Carries ladder properly as directed			
3	Deploys hooks			
4	Ascends ground ladder			
5	* Uses leg lock or safety harness			
6	Hoists roof ladder (hooks out)			
7	* Positions and secures roof ladder			
8	Desends down the ladder safely			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	
			Total number tasks candidate must complete to pass	6

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.12A.2 Primary Task: Roof Ladder – Lower and Removal (two person)			
Objective(s) : 5.3.12, 5.3.12(B), 5.3.6(B)		NFPA Standard: 1001	Candidate # <input style="width: 50px;" type="text"/>
Performance Evaluation Sheet			
Task			
		1st	2nd
1	* Wears full protective equipment properly		
2	Uses leg lock or safety harness		
3	Tilts roof ladder on its closest beam		
4	* Communicates and lowers ladder to the #2 man on the ladder		
5	Disengages leg lock or safety harness		
6	* Communicates and both descend ladder safely		
7	Closes hooks		
8	Carries ladder properly as directed		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 6

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.12B	Primary Task:	Ladder Climb with Tool	
Objective(s) :	5.3.12, 5.3.12(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective equipment properly			
2	Checks ladder for appropriate angle			
3	Method – 1 Climbs with free hand sliding under the beam and tool hand on beam			
OR				
3	Method – 2 Climbs with free hand sliding under the beam and other hand holding tool			
4	* Reaches objective, sounds roof with tool before getting on roof (if applicable)			
5	Descends ladder safely			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.12C	Primary Task:	Determining Roof Integrity	
Objective(s) :	5.3.12, 5.3.12(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective equipment properly			
2	Climbs ladder with tool properly			
3	Sounds roof with tool from ladder before transfer			
4	Identifies sound (from hitting roof)			
5	Determines roof integrity (verbally)			
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4	

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.12D.1		Primary Task: Roof Ventilation - Flat	
Objective(s) : 5.3.12, 5.3.12(B)		NFPA Standard: 1001	Candidate #
Performance Evaluation Sheet			
Task			
		1st	2nd
1	* Wears full protective equipment properly		
2	Climbs ladder with tool		
3	Sounds roof for integrity		
4	* Describes cutting 4' by 4' hole from the windward side		
5	* Describes removing roofing material from hole		
6	* Describes pushing ceiling in from windward side (plaster hook, boat hook)		
7	Descends ladder safely		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	Total number tasks candidate must complete to pass 5

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.12D.2	Primary Task:	Roof Ventilation – Pitched	
Objective(s) :	5.3.12, 5.3.12(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective equipment properly			
2	Climbs ladder with tool properly			
3	Sounds roof for integrity			
4	Opens roof from roof ladder (simulates)			
5	* Stands on proper side of opening and removes roofing material			
6	* Pushes ceiling in from windward side (if applicable) with correct tool			
7	Descends ladder safely			
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	Total number tasks candidate must complete to pass 5	

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.13A	Primary Task:	Expose Hidden Fire	
Objective(s) :	5.3.13, 5.3.13(B), 5.3.10, 5.3.10(B)	NFPA Standard:	1001	Candidate # <input style="width: 50px;" type="text"/>
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective equipment properly			
2	Detects hidden fire			
3	Uses proper tool			
4	Opens up hidden fire correctly (verbalize)			
5	Removes burned materials / extinguishes fire			
6	Maintains fire scene integrity			
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4	

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.14A	Primary Task:	Salvage Cover Deployment (Two Person)	
Objective(s) :	5.3.14, 5.3.14(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	Wears full protective equipment properly			
2	Stacks objects properly			
3	Covers objects properly with the balloon throw method			
4	Tucks corners / secures cover to local jurisdiction (procedures)			
* Critical Task	Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	Total number tasks candidate must complete to pass 3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.14B	Primary Task:	Construction and Use of Water Catchall	
Objective(s) :	5.3.14, 5.3.14(B)	NFPA Standard:	1001	Candidate # <input style="width: 50px;" type="text"/>
Performance Evaluation Sheet				
Task				
			1st	2nd
TWO PERSON				
1	Wears appropriate equipment properly		<input style="width: 40px; height: 25px;" type="text"/>	<input style="width: 40px; height: 25px;" type="text"/>
2	Selects materials needed to construct catchall		<input style="width: 40px; height: 25px;" type="text"/>	<input style="width: 40px; height: 25px;" type="text"/>
3	* Constructs catchall properly		<input style="width: 40px; height: 25px;" type="text"/>	<input style="width: 40px; height: 25px;" type="text"/>
4	Places catchall in operation (verbally)		<input style="width: 40px; height: 25px;" type="text"/>	<input style="width: 40px; height: 25px;" type="text"/>
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass	3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.14C	Primary Task:	Construction and Use of Water Chute	
Objective(s) :	5.3.14, 5.3.14(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
TWO PERSON				
1	Wears appropriate equipment properly			
2	Selects materials to construct water chute			
3	* Constructs water chute			
4	Places water chute in proper position (verbally)			
* Critical task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass	3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.14F	Primary Task:	Routing and Removal of Water and Debris (Vertical) – Upper Floors	
Objective(s) :	5.3.14, 5.3.14(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
VERTICAL				
1	Wears appropriate equipment properly			
2	Forces water toward scupper (if applicable) verbalize			
3	Removes drain cover (toilet, soil pipe) verbalize			
4	Secures drain guard (if applicable) verbalize			
5	Forces water down stairs case (water chute) verbalize			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.14G	Primary Task:	Routing and Removal of Water (Horizontal)	
Objective(s) :	5.3.14, 5.3.14(B)	NFPA Standard:	1001	Candidate # <input style="width: 50px;" type="text"/>
Performance Evaluation Sheet				
Task				
HORIZONTAL			1st	2nd
1	Wears appropriate equipment properly			
2	Opens ceiling below water accumulation			
3	* Establishes a means of removal (water chute, catch basin)			
4	Describes how to open floors of water accumulation			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.14H	Primary Task: Routing and Removal of Water and Debris (Below Grade)		
Objective(s) : 5.3.14, 5.3.14(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
BELOW GRADE		1st	2nd
1	Wears appropriate equipment properly		
2	Sets up pump properly		
3	Secures strainer (if applicable)		
4	Starts pump		
5	Identifies operation of pump		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.14J	Primary Task:	Closes up a Building	
Objective(s) :	5.3.14, 5.3.14(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	Wears appropriate equipment properly			
2	Selects method			
3	Applies materials to openings			
4	Seals openings			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass	3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.14K Primary Task: Separate and Remove Charred Material		
Objective(s) : 5.3.14, 5.3.14(B), 5.3.13(B) NFPA Standard: 1001	Candidate # <input style="width: 50px;" type="text"/>	
Performance Evaluation Sheet		
Task		
	1st	2nd
1 * Wears full protective equipment properly		
2 * Identifies and protects "Area of Origin"		
3 Preserves evidence by guarding, tagging, or other safeguards		
4 Separates charred materials		
5 Removes charred materials to safe location		
* Critical Task Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.14M	Primary Task: Stop Water Flow from Sprinkler		
Objective(s) : 5.3.14, 5.3.14(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1 * Wears full protective equipment properly			
2 Stops water flow from activated sprinkler head using wooden wedges or sprinkler wedge stopper			
3 Identifies and closes main control valve			
4 Identifies and opens main drain valve			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.15A	Primary Task: Drafting (Static Source) 4 Person Team		
Objective(s) : 5.3.15, 5.3.15(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1 * Wears full protective equipment properly			
2 Removes pumper intake cap			
3 * Attaches strainer to hard suction hose male coupling			
4 Attaches rope to strainer			
5 Lowers hose and strainer into static source (portable tank)			
6 Attaches female coupling of hard section hose to pumper intake			
7 Secures strainer rope to pumper or other stationary object			
8 * Assures strainer and strainer-to-hose coupling are under water			
9 * Completes the assembly as directed by the examiner			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 6

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.15B	Primary Task: Hydrant to Pumper Connection		
Objective(s) : 5.3.15, 5.3.15(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1	* Wears full protective equipment properly		
2	Removes pumper intake cap		
3	Attaches the appropriate female end of the soft suction hose to the pumper intake		
4	Removes the appropriate hydrant discharge cap and places the hydrant wrench on hydrant		
5	Inspects hydrant threads for damage & integrity. Inspects inside outlet for debris		
6	Hose not equipped with a STORZ connection requires two full twists to prevent kinking		
7	Attaches the appropriate female end of the soft suction hose to the hydrant		
8	* Slowly opens hydrant fully		
9	Reduces any leakage by tightening connections and assures soft suction has no kinks		
10	Adds chafing block at point where hose touches ground		
11	* Completes the connection as directed by the examiner		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 8

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.15C.1	Primary Task: Hydrant Connection (Forward Lay)		
Objective(s) : 5.3.15, 5.3.15(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1	* Wears full protective equipment properly		
2	* Selects correct tools and appliances		
3	Wraps hydrant properly		
4	Tells apparatus driver to advance to the incident		
5	Unwraps hose and connects properly to hydrant		
6	* Opens hydrant fully		
7	Opens gate slowly on command		
8	Closes hydrant completely		
9	Checks hydrant drainage		
10	Recaps hydrant		
11	Collects appliances and places them back on apparatus		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 8

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.15C.2	Primary Task: Hydrant Connection (Reverse Lay)		
Objective(s) : 3-3.15, 3-3.15(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1	* Wears full protective equipment properly		
2	* Selects and uses correct tools and appliances		
3	Connects supply line from hydrant to engine in-take properly		
4	Connects feeder line to engine discharge properly		
5	* Opens hydrant fully		
6	Opens gate on command		
7	Closes hydrant fully		
8	Checks hydrant drainage		
9	Recaps hydrant		
10	Collects appliances and places them back on apparatus		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 7

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.15D	Primary Task:	Sprinkler/Standpipe (Siamese) Fire Department Connection (FDC)	
Objective(s) :	5.3.15, 5.3.15(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective equipment properly			
2	Removes adequate amount of hose to make connection			
3	Inspects FDC (siamese) clapper valve			
4	Connects male end of feeder line to FDC properly			
5	Completes connection to pump discharge on apparatus (if applicable)			
6	Informs pump operator that connection is completed and calls for water			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass	4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.15E	Primary Task:	Standpipe Operation
Objective(s) : 5.3.15, 5.3.15(B)	NFPA Standard: 1001	Candidate #
Performance Evaluation Sheet		
Task		
		1st 2nd
1 * Dons PPE and SCBA properly		
2 Uses appropriate carry, carries sufficient fire hose to one level below the level of the fire		
3 * Attaches the hose to the standpipe connection one level below the fire		
4 Flakes out hose up the stairway above the fire floor, if possible		
5 * Slowly charges the hoseline by opening the standpipe valve		
6 * Bleeds the air out of the hoseline and checks pattern		
7 Advances to the fire		
* Critical Task Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 5

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.16A	Primary Task: Extinguish Class A Fires		
Objective(s) : 5.3.16, 5.3.16(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1	Wears appropriate protective clothing properly		
2	* Selects proper extinguisher for Class A fire		
3	Uses extinguisher selected in step 2 to extinguish Class A fire		
4	Applies agent to extinguish Class A fire properly		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	
Total number tasks candidate must complete to pass			3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL SHEET, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.16B	Primary Task:	Extinguish Class B Fires	
Objective(s) :	5.3.16, 5.3.16(B)	NFPA Standard:	1001	Candidate # <input style="width: 50px;" type="text"/>
Performance Evaluation Sheet				
Task				
			1st	2nd
1	Wears appropriate equipment properly			
2	* Selects proper extinguisher for Class B fire			
3	Uses extinguisher selected in step 2 to extinguish Class B fire			
4	Properly applies extinguishing agent			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.16C	Primary Task: Extinguish Class C Fires		
Objective(s) : 5.3.16, 5.3.16(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1 Wears appropriate equipment properly			
2 * Selects proper extinguisher for Class C fires			
3 * De-Energizes electrical equipment			
4 Uses extinguisher selected in step 2 to extinguish Class C fires			
5 Properly applies extinguishing agent			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.17A	Primary Task: Safety Procedures for Lighting Equipment		
Objective(s) : 5.3.17, 5.3.17(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1	Describes and identifies inverter (if applicable)		
	or		
	Describes and identifies generator (if applicable)		
2	* Checks overhaul condition of tools, cords, plugs, and connectors		
	a) Starts up generator, brings up to speed		
	b) Plugs in load		
3	Connects all lighting equipment in proper sequence		
4	Takes safety precautions to avoid burns		
5	Re-sets (GFI) Ground Fault Interrupter (if applicable)		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.18A	Primary Task: Control Utility Services		
Objective(s) : 5.3.18, 5.3.18(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1 Wears appropriate equipment properly			
2 Locates main electrical breaker and operates main breaker to cut power			
3 Identifies type of gas service and locates gas meter and shut off same			
4 Locates main water shut-off and operates appropriate valve to stop water flow			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.19A	Primary Task: Donning Ground Cover PPE		
Objective(s) : 5.3.19, 5.3.19(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1 Wears appropriate shirt and pants			
2 Helmet with chinstrap, headlamp, eye protection, hearing protection			
3 Gloves			
4 Boots and socks			
5 Equipment belt with fire shelter, canteen			
6 Shroud			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 5

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.19B	Primary Task: Fill, Use and Maintain a Backpack Pump		
Objective(s) : 5.3.19, 5.3.19(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1 Assembles backpack pump properly			
2 Maintains proper footing and stance			
3 Maintains proper body position; carrying and lifting			
4 Fills backpack pump with clean or strained water			
5 Demonstrates clearing a clogged nozzle			
6 Demonstrates cleaning a quick connect, if dirty			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 5

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No.	5.3.19C	Primary Task:	Use of Tools and Appliances for Simple Ground Cover Hose Lay	
Objective(s) :	5.3.19, 5.3.19(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	Shows hand signals for water use			
2	Identifies commonly used fittings and hose			
3	Demonstrates a simple hose lay			
4	Extends charged hose lay by properly clamping, crimping, disconnecting, inserting, and recoupling hose			
5	Sets nozzle setting appropriately for the situation			
6	Applies water properly			
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	Total number tasks candidate must complete to pass 5	

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.19D	Primary Task: Use of Hand Tools while Building a Fire Control Line		
Objective(s) : 5.3.19, 5.3.19(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1	* Selects the proper tool for the job		
2	Inspects the tool before use		
3	Determines if the tool may be used safely		
4	* Digs suppression line based on type of fuels and terrain		
5	Identifies the need for "Hot" spotting		
6	Throws dirt		
7	Cools line		
8	Insulates fuel		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	
		Total number tasks candidate must complete to pass 6	

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.1A.1	Primary Task: SCBA – Replacement of Cylinder (One Person) for Re-Entry		
Objective(s) : 5.3.1, 5.3.1(B)	NFPA Standard: 1001	Candidate #	
Performance evaluation sheet			
Task			
ONE PERSON			
		1st	2nd
1	* Wears full protective clothing properly		
2	Doffs SCBA correctly		
3	Closes cylinder and properly bleeds off pressure		
4	Removes, positions, protects high pressure hose		
5	Releases cylinder, replaces with new cylinder and secures		
6	* Checks that cylinder is full (or at least 90%)		
7	Checks valve opening and “O” ring		
8	Connects high pressure hose		
9	* Opens cylinder fully		
10	Checks all gauges		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 7

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.1A.2	Primary Task: SCBA – Replacement of Cylinder (Two Person) for Re-Entry	
Objective(s) : 5.3.1, 5.3.1(B)	NFPA Standard: 1001	Candidate #
Performance Evaluation Sheet		
Task		
TWO PERSON		
	1st	2nd
1 Changer turns off cylinder		
2 Changer instructs wearer to release pressure		
3 Changer disconnects high pressure hose		
4 Changer releases and removes cylinder		
5 Changer replaces cylinder, secures cylinder, and connects high pressure hose		
6 * Changer verifies that cylinder is full (or at least 90%)		
7 * Changer opens cylinder fully		
8 Pressure gauges verified by changer		
* Critical Task Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 6

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.1B	Primary Task:	Donning SCBA	
Objective(s) :	5.3.1, 5.3.1(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective clothing properly			
2	* Checks that cylinder is full (or at least 90%)			
3	* Opens cylinder fully			
4	Dons harness and connects waist straps			
5	Checks facepiece seal, (all skin is covered)			
6	Activates PASS Device (if applicable)			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass	4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.1E	Primary Task: SCBA – Ready for Immediate Use		
Objective(s) : 5.3.1, 5.3.1(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1. * Checks that cylinder is full (or at least 90%)			
2. Checks operation of all gauges. Verifies that the difference between cylinder and regulator. gauge does not exceed 100 psi			
3. Tests operation of low pressure alarm (to activate at 25%of cylinder)			
4. Checks all hose connections			
5. Checks condition of facepiece			
6. Checks condition of harness and straps			
7. Checks operation of donning and bypass valves			
8. Checks that unit is clean and sanitized			
9. * Tests PASS device			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 6

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.1F	Primary Task: Use of SCBA (Restricted Passage)		
Objective(s) : 5.3.1, 5.3.1(B), 5.3.9, 5.3.9(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
VERTICAL EGRESS (between wall studs)			
		1st	2nd
1	* Does not remove facepiece or PPE		
2	Loosens shoulder and waist straps		
3	Removes or loosens shoulder strap from the non-regulator side		
4	* Maintains contact with the regulator shoulder strap		
5	Slides backpack to the outside of the shoulder that he/she is maintaining contact with		
6	Checks for floor integrity (if possible)		
7	Side steps through restricted opening maintaining contact with SCBA		
8	* Exits the restricted area, redons the SCBA backpack, tightens all straps		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 6

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.1F.1	Primary Task: Use of SCBA (Restricted Passage)		
Objective(s) : 5.3.1, 5.3.1(B), 5.3.9, 5.3.9(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
HORIZONTAL EGRESS (crawl space)			1st 2nd
1.	* Does not remove facepiece or personal protective equipment		
2.	Removes backpack and places airpack before him/her holding the regulator side shoulder strap		
3	* Pushes airpack in front while crawling through restricted area, still holding the regulator side shoulder strap at all times		
4.	* Exits the restricted area, redons SCBA backpack and tightens all straps		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	Total number tasks candidate must complete to pass 3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.1G	Primary Task: SCBA Failure Procedures		
Objective(s) : 5.3.1, 5.3.1(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1 * Notifies partner/command			
2 Conserves air			
3 Utilizes bypass/purge valve to conserve air correctly			
4 Buddy breathes (when equipment and jurisdiction allow)			
5 * Manually alarm/activates PASS device			
6 Exits structure			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.2A	Primary Task:	Safety when Mounting, Riding, Dismounting Apparatus		
Objective(s) :	5.3.2, 5.3.2(B), 5.3.3, 5.3.3(B)	NFPA Standard:	1001	Candidate #	
Performance Evaluation Sheet					
Task					
				1st	2nd
1	Dresses into PPE before apparatus moves				
2	Mounts apparatus using handrail				
3	* Applies seat belt and other safety devices				
4	Places safety bar in proper position (if applicable)				
5	Communicates with officer				
6	Dismounts apparatus using hand rail				
	or				
	Demonstrates safe dismount when apparatus in contact with electrical wires				
* Critical Task	Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	Total number tasks candidate must complete to pass	4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.3A	Primary Task: Deployment of Traffic and Scene Control Devices to Operate at Emergency Scenes		
Objective(s) : 5.3.3, 5.3.3(B), 5.3.2, 5.3.2(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1 * Wears appropriate protective clothing (reflective vest if required).			
2 Establishes zone boundaries (how large of an area and degree of hazard), based on instructions			
3 Uses traffic cones and other scene devices (fire line tape) to cordon off area.			
4 Continues to monitor area to prevent people from crossing the line.			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.4A	Primary Task:	Identify and Carry Tools	
Objective(s) :	5.3.4, 5.3.4(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective equipment properly			
2	Identifies cutting tool			
3	Identifies prying tool			
4	Identifies striking tool			
5	Safely carries at least one of the above tools			
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4	

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.4B	Primary Task:	Forcible Entry – Door	
Objective(s) :	5.3.4, 5.3.4 (B)	NFPA Standard:	1001	Candidate # <input style="width: 50px;" type="text"/>
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective equipment properly			
2	Identifies tools and carries them properly			
3	Identifies door swing			
4	Determines if door is locked (try before you pry)			
5	Identifies lock mechanism			
6	Demonstrates forcing door			
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT		Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.4C	Primary Task:	Window Opening (Non-Destructive)	
Objective(s) :	5.3.4, 5.3.4(B)	NFPA Standard:	1001	Candidate # <input style="width: 50px;" type="text"/>
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective equipment properly		<input style="width: 40px; height: 25px;" type="text"/>	<input style="width: 40px; height: 25px;" type="text"/>
2	Identifies window type		<input style="width: 40px; height: 25px;" type="text"/>	<input style="width: 40px; height: 25px;" type="text"/>
3	Disengages lock mechanism		<input style="width: 40px; height: 25px;" type="text"/>	<input style="width: 40px; height: 25px;" type="text"/>
4	Opens window(s):		<input style="width: 40px; height: 25px;" type="text"/>	<input style="width: 40px; height: 25px;" type="text"/>
	Leeward – High		<input style="width: 40px; height: 25px;" type="text"/>	<input style="width: 40px; height: 25px;" type="text"/>
	Windward - Low		<input style="width: 40px; height: 25px;" type="text"/>	<input style="width: 40px; height: 25px;" type="text"/>
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.4D	Primary Task: Forcible Entry through Plaster or Gypsum Partition Walls		
Objective(s) : 5.3.4, 5.3.4(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1 * Wears full protective clothing properly			
2 Selects location for opening			
3 * Checks wall for electrical wall plugs and switches			
4 Sounds wall to locate wall studs			
5 Cuts along studs for opening to gain access			
6 * Sounds floor on other side before entering			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.5A.1 Primary Task: Action When Trapped/Disoriented with Hose		
Objective(s) : 5.3.5, 5.3.5(B)	NFPA Standard: 1001	Candidate # <input style="width: 50px;" type="text"/>
Performance Evaluation Sheet		
Task		
	1st	2nd
1 * Wears full protective clothing properly	<input type="text"/>	<input type="text"/>
2 Uses portable radio properly		
• Calls May Day	<input type="text"/>	<input type="text"/>
• Identifies location and situation	<input type="text"/>	<input type="text"/>
• Speaks Clearly	<input type="text"/>	<input type="text"/>
3 Controls breathing	<input type="text"/>	<input type="text"/>
4 Controls panic	<input type="text"/>	<input type="text"/>
5 Listens for noises or sounds	<input type="text"/>	<input type="text"/>
6 * Follows hoseline in proper direction	<input type="text"/>	<input type="text"/>
7 * Manually alarm/activates PASS device	<input type="text"/>	<input type="text"/>
* Critical Task Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 5

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.5A.2	Primary Task: Action When Trapped/Disoriented without Hose	
Objective(s) : 5.3.5, 5.3.5(B)	NFPA Standard: 1001	Candidate #
Performance Evaluation Sheet		
Task		
TRAPPED AND DISORIENTED WITHOUT HOSE	1st	2nd
1 * Wears protective equipment properly	<input type="checkbox"/>	<input type="checkbox"/>
2 Uses portable radio properly	<input type="checkbox"/>	<input type="checkbox"/>
• Calls May Day	<input type="checkbox"/>	<input type="checkbox"/>
• Identifies location and situation	<input type="checkbox"/>	<input type="checkbox"/>
• Speaks Clearly	<input type="checkbox"/>	<input type="checkbox"/>
3 Listens for noises or sounds	<input type="checkbox"/>	<input type="checkbox"/>
4 * Manually alarm/activates PASS alarm	<input type="checkbox"/>	<input type="checkbox"/>
5 Controls breathing	<input type="checkbox"/>	<input type="checkbox"/>
6 Controls panic	<input type="checkbox"/>	<input type="checkbox"/>
7 * Locates and follows wall in the same direction	<input type="checkbox"/>	<input type="checkbox"/>
8 Locates windows/door	<input type="checkbox"/>	<input type="checkbox"/>
* Critical Task Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 6

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.6A	Primary Task: 24' Extension Ladder – Carry / Raise / Extend (One Person)		
Objective(s) : 5.3.6, 5.3.6(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
ONE PERSON		1st	2nd
1	* Wears full protective equipment properly		
2	Picks up ladder properly as directed		
3	* Carries selected ladder properly as directed		
4	Places butt end of ladder at building to raise		
5	Verbalizes safety - overhead wires		
6	* Raises ladder correctly to building as directed		
7	* Raises and locks fly section (hand over hand on halyard)		
8	Ensures ladder locks (dogs) are secured		
9	Rotates ladder (bed section between fly section and building)		
10	Places ladder on the windward side of the opening (if applicable)		
11	Angles ladder properly for climbing		
12	Secures fly section with halyard		
13	* Butts ladder until completion of evolution (all firefighters are off the ladder)		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number Tasks candidate must complete to pass 9

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.6B	Primary Task: 24' Extension Ladder-Lower/ Removal (One Person)		
Objective(s) : 5.3.6, 5.3.6(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
ONE PERSON LOWER AND REMOVAL		1st	2nd
1	* Wears full protective clothing properly		
2	Unsecures halyard from ladder		
3	Places ladder to vertical position next to building		
4	Verbalizes overhead wires (safety)		
5	Rotates ladder (fly section between bed section and building)		
6	* Unlocks and lowers fly section (hand over hand on halyard)		
7	* Lowers ladder to ground (butting the heel of ladder next to building)		
8	Picks up ladder properly		
9	* Carries ladder properly to starting position as directed		
10	Lowers ladder to the ground properly		
Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	Total number tasks candidate must complete to pass 7

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.6C Primary Task: 24' to 28' Extension Ladder Carry / Raise (Two Person)			
Objective(s) : 5.3.6, 5.3.6(B)		NFPA Standard: 1001	Candidate #
Performance Evaluation Sheet			
Task :			
TIP PERSON		1st	2nd
1	Picks up ladder properly as directed		
2	* Carries selected ladder properly as directed		
3	Verbalizes overhead wires (safety)		
4	* Raises ladder correctly as directed		
5	* Raises and locks fly section (hand over hand on halyard)		
6	Ensures locks (dogs) are secured		
7	Angles ladder properly against building for climbing		
8	Secures fly section with halyard to bed section		
BUTT PERSON		Total number tasks candidate must complete to pass 6	
9	Picks up ladder properly (communicates by giving commands)		
10	* Carries selected ladder properly as directed		
11	Verbalizes overhead wires (safety)		
12	* Butts ladder to vertical properly		
13	Pivots ladder (if necessary)		
14	* Raises and locks fly section (hand over hand on halyard)		
15	Angles ladder properly against building for climbing		
16	Assists with securing ladder		
17	* Butts ladder until completion of evolution (when all firefighters are off the ladder)		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 6

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.6D	Primary Task: 24' to 28' Extension Ladder- Lowering / Removal (Two Person)		
Objective(s) : 5.3.6, 5.3.6(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
TIP PERSON		1st	2nd
1	Unsecures fly section		
2	Verbalizes overhead wires (safety)		
3	Removes ladder to vertical from building		
4	* Lowers fly section (hand over hand on halyard)		
5	Pivots ladder (if necessary)		
6	Lowers ladder to the ground correctly		
7	* Picks up, carries, and lowers ladder properly to the starting position as directed		
***BUTT PERSON ***		Total number tasks candidate must complete to pass 5	
8	Communicates positions to lower ladder from building		
9	* Butts ladder correctly to remove ladder from building to vertical		
10	Assists in ladder control as fly section is being loward		
11	Pivots ladder (if necessary)		
12	* Butts ladder correctly for lowering to ground from vertical position		
13	* Picks up, carries, and lowers ladder properly to the starting position as directed		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.6E	Primary Task:	14' to 20' Single Ladder Carry / Raise (One Person)	
Objective(s) :	5.3.6, 5.3.6(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective equipment properly			
2	Properly picks up ladder as directed			
3	* Carries selected ladder properly as directed			
4	Verbalizes overhead wires (safety)			
5	* Places butt end of ladder at building to raise as directed			
6	Raises ladder correctly to building			
7	Angles ladder properly for climbing			
8	Butts ladder until completion of evolution (if applicable)			
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	Total number Tasks candidate must complete to pass	6

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.6F	Primary Task: 14' to 20' Single Ladder - Lower / Removal (One Person)		
Objective(s) : 5.3.6, 5.3.6(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
** ONE PERSON LOWER AND REMOVAL**		1st	2nd
1	* Wears full protective clothing properly		
2	Verbalizes overhead wires (safety)		
3	Moves ladder to vertical position next to building		
4	* Lowers ladder properly (butting heel of ladder next to building)		
5	Picks up ladder properly as directed		
6	* Carries ladder properly to starting position as directed		
7	Lowers ladder to ground properly		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 5

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.6G	Primary Task:	35' Extension Ladder Carry / Raise (Three Person)			
Objective(s) :	5.3.6, 5.3.6(B)	NFPA Standard:	1001	Candidate # 		
Performance Evaluation Sheet						
Task						
*****BUTT PERSON*****			1st	2nd		
1	Communicates ladder positions and commands					
2	Picks up ladder properly					
3	* Carries selected ladder properly as directed					
4	Butt person states "raise ladder"					
5	* Butts ladder correctly for raising ladder to vertical position					
6	Pivots ladder (if necessary)					
7	* Assists in ladder control as fly section is raised and locked (hand over hand) on halyard					
8	Lowers ladder to building					
9	Angles ladder properly for climbing					
10	* Butts ladder until completion of evolution (until all firefighters are off the ladder)					
*****BEAM PERSONS*****			<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="padding: 5px;">Total number tasks candidate must complete to pass</td> <td style="text-align: center; font-size: 24px; font-weight: bold;">7</td> </tr> </table>		Total number tasks candidate must complete to pass	7
Total number tasks candidate must complete to pass	7					
11	Picks up ladder properly					
12	* Carries selected ladder properly as directed					
13	Verbalize overhead wires (safety)					
14	Raises ladder to vertical position					
15	Pivots ladder (if necessary)					
16	* Raises and locks fly section – (hand over hand on halyard)					
17	Lowers ladder to building					
18	Secures fly section to bed section with halyard					
* Critical Task	Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	Total number tasks candidate must complete to pass 5		

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.6H	Primary Task:	35' Extension Ladder Lowering (Three Person)	
Objective(s) :	5.3.6, 5.3.6(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
***** BUTT PERSON *****			1st	2nd
1	Communicates ladder positions and commands			
2	* Butts ladder correctly when removing ladder from building to vertical			
3	Assists in ladder control as fly section is lowered			
4	* Butts ladder correctly to lower ladder to the ground			
***** BEAM PERSONS *****			Total number tasks candidate must complete to pass 3	
5	Unties halyard from fly and bed sections			
6	Removes ladder from building to vertical			
7	Assists with ladder control			
8	* Lowers fly section (hand over hand on halyard))			
9	Pivots ladder (if necessary)			
10	Lowers ladder to the ground			
11	* Carries and lowers ladder properly back to the starting position as directed			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 5	

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.7A	Primary Task:	Fire Suppression – Vehicle Fires	
Objective(s) :	5.3.7, 5.3.7(B). 5.3.10(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective equipment and SCBA properly			
2	Identifies fuel type			
3	Approaches fire from appropriate direction (uphill, upwind if possible)			
4	* Recognizes approach hazards (tires, batteries, bumpers) - Verbalize			
5	Extinguishes fire on ground and under vehicle (1 1/2" hoseline minimum)			
6	Maintains communication			
7	Attacks remaining fire (proper nozzle pattern to provide flash protection)			
8	Follows safety procedures			
9	Gains access to all compartments using basic hand tools			
10	* Extinguishes remaining fire			
11	Checks stability of vehicle (blocks wheels)			
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT		Total number tasks candidate must complete to pass 8

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.8A	Primary Task:	Fire Suppression –Piles/Stacks of Class A Combustibles	
Objective(s) :	5.3.8, 5.3.8(B)	NFPA Standard:	1001	Candidate # <input style="width: 50px;" type="text"/>
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective equipment and SCBA properly			
2	Selects appropriate handline or master stream			
3	Advances handline or operates master stream			
4	* Extinguishes fire			
5	Uses tools to separate piles/stacks			
6	Examines debris for hot spots			
7	Follows safety procedures			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 5

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.8B	Primary Task:	Fire Suppression – Dumpster/Storage Container Fires	
Objective(s) :	5.3.8, 5.3.8(B), 5.3.10(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective equipment and SCBA properly			
2	Selects appropriate size handline or master stream			
3	Advances hoseline or operates master stream			
4	Protects possible exposures			
5	* Extinguishes fire			
6	Follows proper procedures for overhaul of dumpster/container			
7	Follows safety procedures			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 5

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.8C	Primary Task: Deploy Master Stream Device (2 person)		
Objective(s) : 5.3.8, 5.3.8(B),5.3.10(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1 * Wears full protective equipment properly			
2 Selects appropriate feeder lines			
3 Sets up for direct attack and exposures protection (if possible)			
4 Follows safety procedures to include securing the master stream device (if applicable)			
5 Calls for water			
6 Operates master stream			
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.9B	Primary Task:	Rescue with SCBA in Obscured Visibility	
Objective(s) :	5.3.9, 5.3.9(B), 5.3.1(B)	NFPA Standard:	1001	Candidate # <input style="width: 50px;" type="text"/>
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective equipment properly			
2	* Checks door for heat			
3	Enters room			
4	Stays low / crawls			
5	* Communicates / contact			
6	Probes with tools			
7	Conserves air			
8	* Locate / remove victim			
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT		Total number tasks candidate must complete to pass 6

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.9C	Primary Task:	Removal Over Ladder (Conscious Person)	
Objective(s) :	5.3.9, 5.3.9(B), 5.3.6(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	* Wears full protective equipment properly			
2	Checks angle of ladder			
3	Ascends ladder safely			
4	Communicates with victim			
5	Assists victim onto ladder			
6	* Maintains contact with victim			
7	* Descends ladder safely with victim			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 5

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No. 5.3.9D	Primary Task: Removal Over Ladder (Unconscious Person)		
Objective(s) : 5.3.9, 5.3.9(B), 5.3.6(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1	* Wears full protective equipment properly		
2	Checks for proper climbing angle		
3	Ensures ladder is heeled and secured and locks are seated		
4	Ascends the ladder to the victim		
	Places victim on ladder using one of the following methods:		
	* Method 1-Places victim on knee facing ladder places victim's legs outside beams		
	* Method 2-Places victim on knee facing the firefighter with victim's legs outside beams		
	* Method 3-Places victim facing the firefighter with victim's legs at the knees draped over the firefighter's shoulders		
5	Keeps hands on the rungs and under the victim's arm pits		
6	* Descends the ladder rung by rung while moving hands down on each rung		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.9F	Primary Task: Conduct a Primary Search	
Objective(s) : 5.3.9, 5.3.9(A)	NFPA Standard: 1001	Candidate # <input style="width: 50px;" type="text"/>
Performance Evaluation Sheet		
Task		
		1st 2nd
1	* Wears full protective equipment and SCBA properly	<input style="width: 40px; height: 25px;" type="text"/>
2	Carries a forcible entry tool	<input style="width: 40px; height: 25px;" type="text"/>
3	Searches on hands and knees in low visibility	<input style="width: 40px; height: 25px;" type="text"/>
4	Starts on an outside wall and continues in the same direction	<input style="width: 40px; height: 25px;" type="text"/>
5	Searches behind and under all objects	<input style="width: 40px; height: 25px;" type="text"/>
6	Searches all areas such as closets, showers. etc.	<input style="width: 40px; height: 25px;" type="text"/>
7	Searches one room before moving onto the next	<input style="width: 40px; height: 25px;" type="text"/>
8	Pauses occasionally to listen for sounds of building collapse, cries for help etc.	<input style="width: 40px; height: 25px;" type="text"/>
9	* Moves up and down stairs, head always up.	<input style="width: 40px; height: 25px;" type="text"/>
10	* Finds victim	<input style="width: 40px; height: 25px;" type="text"/>
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT
		Total number tasks candidate must complete to pass 7

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.3.9F.1	Primary Task: Conduct a Secondary Search		
Objective(s) : 5.3.9, 5.3.9(A)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1	* Wears full protective equipment and SCBA properly		
2	Carries a forcible entry tool		
3	Searches with portable lighting (if possible)		
4	Searches are conducted slowly and methodically		
5	Searches behind and under all objects		
6	Searches all areas such as closets, showers. etc.		
7	Searches one room before moving onto the next		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	
Total number tasks candidate must complete to pass			5

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.3.9G	Primary Task:	Drags and Carries	
Objective(s) :	5.3.9, 5.3.9(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
One Person				
1	Demonstrates lone rescuer incline drag			
2	Demonstrates blanket carry			
Two Person				
3	Demonstrates extremities carry			
	<ul style="list-style-type: none"> • Rescuer 1 • Rescuer 2 			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.5.3A	Primary Task:	Cleaning, Maintaining & Inspecting Department Ladders		
Objective(s) :	5.5.1, 5.5.1(B)	NFPA Standard:	1001	Candidate #	
Performance Evaluation Sheet					
Task					
				1st	2nd
1	Washes and dries per manufacturer's specifications				
2	* Checks all heat sensors and their dates				
3	Checks rungs, bolts and rivets				
4	Checks welds and beams for cracks				
5	Checks all ladder hardware and condition of halyard				
6	Lubricates properly per manufacturer's specifications (verbally)				
7	Marks and documents defects (verbally)				
* Critical Task		Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	
				Total number tasks candidate must complete to pass	
				5	

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.5.3C	Primary Task:	SCBA Maintenance and Use	
Objective(s) :	5.5.1, 5.5.1(B)	NFPA Standard:	1001	Candidate #
Performance Evaluation Sheet				
Task				
			1st	2nd
1	Performs inspection			
2	* Checks cylinder gauge (at least 90% full)			
3	Compares shoulder gauge readings to cylinder gauge readings (within 100lbs.)			
4	Checks physical appearance			
5	Checks straps			
6	Checks Mask			
7	Cleans / Sanitizes			
8	Exchanges cylinder (if needed)			
9	Documents results			
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	Total number tasks candidate must complete to pass 7	

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.5.3D	Primary Task: Salvage Cover Inspection & Maintenance		
Objective(s) : 5.5.1, 5.5.1(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1	Washes and cleans cover properly		
2	Dries properly to reduce mildew		
3	Examines for damage (passing salvage cover over their head looking for holes)		
4	Marks any holes found with chalk		
5	Depending on the material, holes may be repaired by duck or mastic tape, iron-on patches		
6	Folds or rolls cover properly to local jurisdiction		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.5.3E	Primary Task:	Rope Maintenance	
Objective(s) :	5.5.1, 5.5.1(B)	NFPA Standard:	1001	Candidate # <input style="width: 50px;" type="text"/>
Performance Evaluation Sheet				
Task				
			1st	2nd
1	Inspects rope			
2	Bundles / coils / bags rope			
3	Stores rope properly			
4	Documents results			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.5.4A	Primary Task:	Hose Storage	
Objective(s) :	5.5.2, 5.5.2(B)	NFPA Standard:	1001	Candidate # <input style="width: 50px;" type="text"/>
Performance Evaluation Sheet				
Task				
			1st	2nd
1	Rolls hose properly as directed			
2	Unrolls hose properly as directed			
3	Couples hose properly			
4	Loads hose into hose bed (if applicable)			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill No.	5.5.4B	Primary Task:	Hose Rolls	
Objective(s) :	5.5.2, 5.5.2(B)	NFPA Standard:	1001	Candidate # <input style="width: 50px;" type="text"/>
Performance Evaluation Sheet				
Task				
			1st	2nd
1	Rolls hose properly by using two of the following methods:			
	<ul style="list-style-type: none"> • Straight roll • Donut roll • Twin donut roll • Self-Locking twin donut roll 			
2	Unrolls hose properly			
3	* Couples, Uncouples hose properly (foot tilt, knee press method if applicable)			
4	Loads hose into hose bed by one of the following methods :			
	<ul style="list-style-type: none"> • 1 ¾" – Preconnected Flat Load, Triple Layer Load, Minuteman Load • 2 ½" – Accordion Load, Horseshoe Load, Flat Load 			
* Critical Task		Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	
			Total number tasks candidate must complete to pass	3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.5.4C	Primary Task: Cleaning / Maintaining / Inspecting Hose		
Objective(s) : 5.5.2, 5.5.2(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Task			
		1st	2nd
1	Brushes off dust and dirt		
2	Uses scrub brush and water		
3	Rinses hose with clear water		
4	Identifies and applies drying procedures for hose (hose tower or hose dryer)		
5	* Inspects hose for abrasions and cuts in outer jacket		
6	Rolls hose (straight roll) and places on storage rack		
7	Documents results		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	
		Total number tasks candidate must complete to pass 5	

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter I

Skill Sheet No. 5.5.4D Primary Task: Cleaning, Maintaining & Inspecting Hose Couplings		
Objective(s) : 5.5.2, 5.5.2(B)	NFPA Standard: 1001	Candidate #
Performance Evaluation Sheet		
Task		
	1st	2nd
1 Brushes male threads with wire brush		
2 Removes gasket and washes swivel		
3 Brushes dust and dirt from female threads		
4 Checks gasket for deterioration		
5 Replaces gasket properly		
6 Inspects hose and coupling for physical damage		
7 Documents results		
* Critical Task Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 5

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE