State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I Evaluation Skill Sheet

SS#	Skill Sheet Title	NFPA 1001 Objective Addressed 2013 Edition
5.1.2A	Donning Personal Protective Clothing	5.2.1
5.2.1A	Emergency Telephone Procedures	5.2.1, 5.2.1(A)(B)
5.2.1B	Emergency Walk-Ins	5.2.1, 5.2.1(A)(B)
5.2.1C	Emergency Telephone/Radio/Fire Alarm Box Procedures	5.2.1, 5.2.1(A)(B)
5.2.2A	Fire Department Telephone Skills (non-emergency)	5.2.2, 5.2.2(A)(B)
5.2.3A	Radio Procedures for Fire Ground Size-Up	5.2.3, 5.2.3(A)(B)
5.2.4A	Activate Emergency Call for Assistance	5.2.4, 5.2.4(A)(B)
5.3.1A1	SCBA – Replacement of Cylinder (one person)	5.3.1, 5.3.1(A)(B)
5.3.1A2	SCBA – Replacement of Cylinder (two person)	5.3.1, 5.3.1(A)(B)
5.3.1B	Donning SCBA	5.3.1, 5.3.1(A)(B)
5.3.1C	SCBA – Ready for Immediate Use	5.3.1, 5.3.1(A)(B)
5.3.1D	Use of SCBA – Restricted Passage (vertical egress)	5.3.1, 5.3.1(A)(B), 5.3.9, 5.3.9(A)(B)
5.3.1D1	Use of SCBA – Restricted Passage (horizontal egress)	5.3.1, 5.3.1(A)(B), 5.3.9, 5.3.9(A)(B)
5.3.1E	SCBA Failure Procedures	5.3.1, 5.3.1(A)(B)
5.3.2A	Safety – Mounting, Riding, Dismounting Apparatus	5.3.2, 5.3.2(A)(B), 5.3.3, 5.3.3(A)(B)
5.3.3A	Deployment – Scene Control Devices	5.3.3, 5.3.3(A)(B), 5.3.2, 5.3.2(A)(B)
5.3.4A	Identify and Carry Tools	5.3.4, 5.3.4(A)(B)
5.3.4B	Forcible Entry – Door	5.3.4, 5.3.4(A)(B)
5.3.4C	Window Opening (non-destructive)	5.3.4, 5.3.5(A)(B)
5.3.4D	Forcible Entry – Plaster or Gypsum Partition Walls	5.3.4, 5.3.4(A)(B)
5.3.5A1	Trapped/Disoriented with Hose	5.3.5, 5.3.5(A)(B)
5.3.5A2	Trapped/Disoriented without Hose	5.3.5, 5.3.5(A)(B)
5.3.6A	24’ Extension Ladder – Carry/Raise/Extend (one person)	5.3.6, 5.3.6(A)(B)
5.3.6B	24’ Extension Ladder – Lower/Removal (one person)	5.3.6, 5.3.6(A)(B)
5.3.6C	24’/28’ Extension Ladder – Carry/Raise/Extend (two person)	5.3.6, 5.3.6(A)(B)
5.3.6D	24’/28’ Extension Ladder – Lowering/Removal (two person)	5.3.6, 5.3.6(A)(B)
5.3.6E	14’/20’ Single Ladder – Carry/Raise (one person)	5.3.6, 5.3.6(A)(B)
5.3.6F	14’/20’ Single Ladder – Lower Removal (one person)	5.3.6, 5.3.6(A)(B)
5.3.6G	35’ Extension Ladder – Carry/Raise/Extend (three person)	5.3.6, 5.3.6(A)(B)
5.3.6H	35’ Extension Ladder – Lowering/Removal (three person)	5.3.6, 5.3.6(A)(B)
5.3.7A	Fire Suppression – Vehicle Fires	5.3.7, 5.3.7(A)(B)
5.3.8A	Fire Suppression – Piles/Stacks of Class A Combustibles	5.3.8, 5.3.8(A)(B)
5.3.8B	Fire Suppression – Dumpster/Storage Container Fires	5.3.8, 5.3.8(A)(B)
5.3.8C	Deploy Master Stream Device (two person)	5.3.8, 5.3.8(A)(B)
5.3.9A	Rescue with SCBA Obscured Visibility	5.3.9, 5.3.9(A)(B), 5.3.1, 5.3.1(A)(B)
5.3.9B	Removal Over Ladder (conscious person)	5.3.9, 5.3.9(A)(B), 5.3.6, 5.3.6(A)(B)
5.3.9C	Removal Over Ladder (unconscious person)	5.3.9, 5.3.9(A)(B), 5.3.6, 5.3.6(A)(B)
5.3.9D	Conduct a Primary Search	5.3.9, 5.3.9(A)(B)
5.3.9D1	Conduct a Secondary Search	5.3.9, 5.3.9(A)(B)
5.3.9E	Drags and Carries	5.3.9, 5.3.9(A)(B)
5.3.10A1	Fire Suppression – Interior Structure, Grade Level	5.3.10, 5.3.10(A)(B)
5.3.10A2	Fire Suppression – Interior Structure, Above Grade Level	5.3.10, 5.3.10(A)(B)
5.3.10A3	Fire Suppression – Interior Structure, Below Grade Level	5.3.10, 5.3.10(A)(B)
5.3.10B	Hose Deployment	5.3.10, 5.3.10(A)(B), 5.3.8, 5.3.8(A)(B)
5.3.10C	Hoseline Advancement	5.3.10, 5.3.10(A)(B), 5.3.8, 5.3.8(A)(B)
5.3.10D	Charged Hoseline Operation from Ground Ladder (2person)	5.3.10, 5.3.10(A)(B)
5.3.10E	Use of Nozzle	5.3.10, 5.3.10(A)(B), 5.3.13, 5.3.13(A)(B), 5.3.8, 5.3.8(A)(B)
5.3.10F	Replace Burst Section of Hose	5.3.10, 5.3.10(A)(B)
5.3.10G	Adding a Length of hose	5.3.10, 5.3.10(A)(B)
5.3.10H1	Coupling and Uncoupling Hose (one person)	5.3.10, 5.3.10(A)(B)

5.3.10H2	Coupling and Uncoupling Hose (two person)	5.3.10, 5.3.10(A)(B)
5.3.10J	Remove Hose from Upper Floors	5.3.10, 5.3.10(A)(B), 5.3.14, 5.3.14(A)(B)
5.3.10K	Remove hose from Building to Minimize Water Damage	5.3.10, 5.3.10(A)(B), 5.3.14, 5.3.14(A)(B)
5.3.11A	Working Safely from Ground Ladders	5.3.11, 5.3.11(A)(B), 5.3.6, 5.3.6(A)(B)
5.3.11B	Window Opening (destructive)	5.3.11, 5.3.11(A)(B), 5.3.6, 5.3.6(A)(B)
5.3.11C	Hydraulic Ventilation	5.3.11, 5.3.11(A)(B)
5.3.11D	Negative Pressure Ventilation	5.3.11, 5.3.11(A)(B)
5.3.11E	Positive Pressure Ventilation	5.3.11, 5.3.11(A)(B)
5.3.12A1	Roof Ladder Deployment	5.3.12, 5.3.12(A)(B), 5.3.6, 5.3.6(A)(B)
5.3.12A2	Roof Ladder – Lower/Removal (two person)	5.3.12, 5.3.12(A)(B), 5.3.6, 5.3.6(A)(B)
5.3.12B	Ladder Climb with tool	5.3.12, 5.3.12(A)(B), 5.3.11, 5.3.11(A)(B), 5.3.6, 5.3.6(B)
5.3.12C	Determining Roof Integrity	5.3.12, 5.3.12(A)(B)
5.3.12D1	Roof Ventilation – Flat	5.3.12, 5.3.12(A)(B)
5.3.12D2	Roof Ventilation – Pitched	5.3.12, 5.3.12(A)(B)
5.3.13A	Expose Hidden Fire	5.3.13, 5.3.13(A)(B), 5.3.10, 5.3.10(A)(B)
5.3.14A	Salvage Cover Deployment (two person)	5.3.14, 5.3.14(A)(B)
5.3.14B	Construction and Use of Water Catchall	5.3.14, 5.3.14(A)(B)
5.3.14C	Construction and use of Water Chute	5.3.14, 5.3.14(A)(B)
5.3.14D	Routing/Removal of Water and Debris (vertical) Upper Floors	5.3.14, 5.3.14(A)(B)
5.3.14E	Routing/Removal of Water and Debris (horizontal)	5.3.14, 5.3.14(A)(B)
5.3.14F	Routing/Removal of Water and Debris (below grade)	5.3.14, 5.3.14(A)(B)
5.3.14G	Closes up a Building	5.3.14, 5.3.14(A)(B)
5.3.14H	Separate and Remove Charred Material	5.3.14, 5.3.14(A)(B), 5.3.13, 5.3.13(A)(B)
5.3.14I	Stop Water Flow from Sprinkler	5.3.14, 5.3.14(A)(B)
5.3.15A	Drafting (static source) Four Person	5.3.15, 5.3.15(A)(B)
5.3.15B	Hydrant to Pumper Connection	5.3.15, 5.3.15(A)(B)
5.3.15C1	Hydrant Connection (forward lay)	5.3.15, 5.3.15(A)(B)
5.3.15C2	Hydrant Connection (reverse lay)	5.3.15, 5.3.15(A)(B)
5.3.15D	Sprinkler/Standpipe (siamese) FDC	5.3.15, 5.3.15(A)(B)
5.3.15E	Standpipe Operation	5.3.15, 5.3.15(A)(B)
5.3.16A	Extinguish Class A Fires	5.3.16, 5.3.16(A)(B)
5.3.16B	Extinguish Class B Fires	5.3.16, 5.3.16(A)(B)
5.3.16C	Extinguish Class C Fires	5.3.16, 5.3.16(A)(B)
5.3.17A	Safety Procedures for Lighting Equipment	5.3.17, 5.3.17(A)(B)
5.3.18A	Control Utility Service	5.3.18, 5.3.18(A)(B)
5.3.19A	Donning Ground Cover Personal Protective Equipment	5.3.19, 5.3.19(A)(B)
5.3.19B	Fill, Use and Maintain a Backpack Pump	5.3.19, 5.3.19(A)(B)
5.3.19C	Tool and Appliances for Simple Ground Cover Hose Lay	5.3.19, 5.3.19(A)(B)
5.3.19D	Use of Hand Tools while Building a Fire Control Line	5.3.19, 5.3.19(A)(B)
5.3.20A	Tie Knots and Hoist Tools	5.3.20, 5.3.20(A)(B)
5.3.20B	Knot Selection and Tying	5.3.20, 5.3.20(A)(B)
5.5.1A	Cleaning/Maintaining/Inspecting Department Ladders	5.5.1, 5.5.1(A)(B)
5.5.1B	Maintenance/Use SCBA	5.5.1, 5.5.1(A)(B)
5.5.1C	Inspection/Maintenance of Salvage Cover	5.5.1, 5.5.1(A)(B)
5.5.1D	Rope Maintenance	5.5.1, 5.5.1(A)(B)
5.5.2A	Hose Storage	5.5.2, 5.5.2(A)(B)
5.5.2B	Hose Rolls	5.5.2, 5.5.2(A)(B)
5.5.2C	Hose Bed Attack	5.5.2, 5.5.2(A)(B)
5.5.2D	Hose Bed Supply	5.5.2, 5.5.2(A)(B)
5.5.2E	Cleaning/Maintaining/Inspecting Hose	5.5.2, 5.5.2(A)(B)
5.5.2F	Cleaning/Maintaining/Inspecting Hose Couplings	5.5.2, 5.5.2(A)(B)

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.1.2A**	**Primary Task:**	**Donning Personal Protective Clothing**	
Objective(s) : 5.1.2		NFPA Standard: 1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task:

		1st	2nd
1	* Dons boots / trousers with suspenders on shoulders		
2	* Dons hood extending around neck under coat		
3	* Fastens coat completely with collar up and neck tab secured		
4	* Dons helmet, chin strap secured under chin		
5	* Dons gloves		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **5**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.2.1A**	**Primary Task:**	**Emergency Telephone Procedures**	
Objective(s) : 5.2.1, 5.2.1(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1.	Answer phone in accordance with department's SOPs or other guidelines		
2.	Have questions organized to control conversation (type of incident and location etc.)		
3.	Ask questions in an assertive voice (department's SOPs)		
4.	Repeat information back to caller		
5.	Foward information to proper authority (department SOPs)		
6.	* Documents information		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **4**

12/19/13

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.2.1B**	**Primary Task:**	**Emergency Walk-Ins**	
Objective(s) : 5.2.1, 5.2.1(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	Acts in a professional manner		
2	* Obtains location and type of incident		
3	Obtains person's name and address if possible		
4	Forwards information to proper authority (department's SOPs)		
5	* Documents information		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **4**

12/19/13

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.2.1C**	**Primary Task:**	**Emergency Telephone/Radio/Fire Alarm Box Procedures**
Objective(s) : 5.2.1, 5.2.1(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	Answers phone in accordance with department SOP's or other department guidelines		
2	* Has questions organized to control conversation (type of incident, location etc.)		
3	Asks questions in an assertive voice (department's SOPs)		
4	Repeats information back to the caller		
5	Forwards information to proper authority (department's SOPs)		
6	* Documents information		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**4**

12/19/13

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.2.2A**	**Primary Task:**	**Fire Department Telephone Skills (non-emergency from public)**
Objective(s) : 5.2.2, 5.2.2 (A)(B)	NFPA Standard 1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1.	Answers calls promptly and in a professional manner		
2.	Identifies himself/herself (rank & name) and the name of his/her fire department		
3.	Records all information accurately – name, time, date, telephone number		
4.	Terminates call courteously		
5.	Forwards information to the proper authority (department SOP's)		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**4**

12/19/13

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.2.3A**	**Primary Task:**	**Radio Procedures for Fire Ground Size-Up**	
Objective(s) : 5.2.3, 5.2.3(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	Identifies the contact that the message is being transmitted to (ex. Fire Alarm, Dispatch)		
2	* Identifies themselves (ex. Engine Company # 1)		
3	* Confirms location of incident, correct address (initial size-up)		
4	Voice is clear when transmitting		
5	Ensures message concise and to the point		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**4**

12/19/13

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.2.4A**	**Primary Task:**	**Activate Emergency Call for Assistance**	
Objective(s) : 5.2.4, 5.2.4(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Identify need to declare “May Day”		
2	* Announce “May Day, May Day, May Day” over communications channel		
3	Provide Command with information (LUNAR)		
4	* Activate PASS device		
5	Move to safe location		
6	Activate flashlight, pointed at ceiling		
7	Conserve air supply		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **5**

12/19/13

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	5.3.1A1	Primary Task:	SCBA – Replacement of Cylinder (One Person)	
Objective(s) : 5.3.1, 5.3.1(A)(B)		NFPA Standard:	1001, 2013 Edition	Candidate #

Performance evaluation sheet

Task

	ONE PERSON	1st	2nd
1	Closes cylinder		
2	Properly bleeds off pressure		
3	Removes, protects high pressure hose		
4	Releases cylinder, replaces with new cylinder and secures		
5	* Checks that cylinder is full (or at least 90%)		
6	Checks valve opening and “O” ring		
7	Connects high pressure hose		
8	* Opens, checks for leaks		
9	Checks all gauges		
10	Verify gauges		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**7**

12/19/13

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	5.3.1A2	Primary Task:	SCBA – Replacement of Cylinder (Two Person) for Re-Entry	
Objective(s) : 5.3.1, 5.3.1(A)(B)		NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

	TWO PERSON	1st	2nd
1	Changer turns off cylinder		
2	Changer instructs wearer to release pressure		
3	Changer disconnects high pressure hose		
4	Changer releases and removes cylinder		
5	* Changer verifies that cylinder is full (or at least 90%)		
6	Changer replaces cylinder, secures cylinder, and connects high pressure hose		
7	* Changer opens cylinder fully		
8	Verify gauges		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**6**

12/19/13

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	**5.3.1B**	**Primary Task:**	**Donning SCBA**		
Objective(s) : 5.3.1, 5.3.1(A)(B)		NFPA Standard:	1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective clothing correctly (SS 5.1.2A)		
2	* Checks that cylinder is full (or at least 90%)		
3	* Opens cylinder fully		
4	Dons harness and connects waist straps		
5	Dons facepiece properly		
6	Checks facepiece seal		
7	Activate air flow		
8	* Activates PASS Device		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**6**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.1C**	**Primary Task:**	**SCBA – Ready for Immediate Use**	
Objective(s) : 5.3.1, 5.3.1(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1.	* Checks that cylinder is full (or at least 90%)		
2.	Checks operation of all gauges. Verifies that the difference between cylinder and regulator gauge does not exceed 100 psi		
3.	* Tests operation of low pressure alarm (to activate at 25%of cylinder)		
4.	Checks all hose connections		
5.	Checks condition of facepiece		
6.	Checks condition of harness and straps		
7.	Checks operation of donning and bypass valves		
8.	Checks that unit is clean and sanitized		
9.	* Tests PASS device		
10	* Place components in position for Emergency Response		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **7**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.1D**	**Primary Task:**	**Use of SCBA (Restricted Passage)**	
Objective(s) : 5.3.1, 5.3.1(A)(B), 5.3.9, 5.3.9(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

	REDUCED EGRESS	1st	2nd
1	* Checks for floor integrity		
2	* Does not remove facepiece or PPE		
3	Loosens shoulder straps and waist straps		
4	Removes or loosens shoulder strap from the non-regulator side		
5	* Must maintain contact with the regulator or shoulder strap		
6	Slides backpack to the outside of the shoulder that he/she is maintaining contact with		
7	* Side steps through restricted opening maintaining contact with SCBA		
8	* Exits the restricted area, redons the SCBA backpack, tightens all straps		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**6**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.1D1**	**Primary Task:**	**Use of SCBA (Restricted Passage)**
Objective(s) : 5.3.1, 5.3.1(A)(B), 5.3.9, 5.3.9(A)(B)	NFPA Standard: 1001, 2013, Edition	Candidate #

Performance Evaluation Sheet

Task

	LOW PROFILE	1st	2nd
1	* Does not remove facepiece or personal protective equipment		
2	Removes air-pack and places air-pack before him/her holding the regulator side shoulder strap		
3	* Pushes airpack in front while crawling through restricted area, still holding the regulator side shoulder strap at all times		
4	* Exits the restricted area, redons SCBA backpack and tightens all straps		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**3**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.1E**	**Primary Task:**	**SCBA Failure Procedures**	
Objective(s) : 5.3.1, 5.3.1(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Notifies partner/command of MAY DAY		
2	* Manually activates PASS device to alarm mode		
3	Conserves air		
4	Utilizes bypass/purge valve to conserve air correctly		
5	Buddy breathes (when equipment and jurisdiction allow)		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **4**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.2A**	**Primary Task:**	**Mounting, Riding, and Dismounting Apparatus**	
Objective(s) : 5.3.2, 5.3.2(A)(B), 5.3.3, 5.3.3(A)(B)	NFPA Standard:	1001 2013, Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	Dons PPE before apparatus moves		
2	Mounts apparatus using handrail		
3	* Applies seat belt and other safety devices		
4	Communicates with officer		
5	Checks traffic movement		
6	Checks for other hazards		
7	* Dismounts apparatus using hand rail in a manner consistent with training		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**5**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.3A**	**Primary Task:**	**Deployment of Traffic and Scene Control Devices to Operate at Emergency Scenes**	
Objective(s) : 5.3.3, 5.3.3(A)(B), 5.3.2, 5.3.2(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears appropriate protective clothing (reflective vest if required).		
2	Establishs zone boundaries (how large of an area and degree of hazard), based on instructions		
3	Uses traffic cones and other scene devices (fire line tape) to cordon off area.		
4	Continues to monitor area to prevent people from crossing the line.		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**3**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.4A**	**Primary Task:**	**Identify and Carry Tools**	
Objective(s) : 5.3.4, 5.3.4(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Identifies cutting tool		
3	Identifies prying tool		
4	Identifies striking tool		
5	* Safely carries at least one of the above tools		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**4**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	**5.3.4B**	**Primary Task:**	**Forcible Entry – Door**		
Objective(s) :	5.3.4, 5.3.4 (A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Identifies tools and carries them in a manner consistent with training		
3	* Determines if door is locked (try before you pry)		
4	Identifies door swing		
5	Identifies lock mechanism		
6	* Demonstrates forcing door		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**5**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.4C**	**Primary Task:**	**Window Opening (Non-Destructive)**	
Objective(s) : 5.3.4, 5.3.4(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Identifies window type		
3	Disengages lock mechanism		
4	Opens window(s):		

Leeward – High

Windward - Low

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**3**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.4D**	**Primary Task:** **Forcible Entry through Wood Frame Walls**	
Objective(s) : 5.3.4, 5.3.4(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective clothing correctly (SS 5.1.2A)		
2	Selects location for opening		
3	Cuts inspection hole		
4	* Checks wall for electrical wall plugs and switches		
5	Sounds wall to locate wall studs		
6	Cuts along studs for opening to gain access		
7	Sounds floor on other side before entering		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **5**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.5A1**	**Primary Task:**	**Action When Trapped/Disoriented with Hose**
Objective(s) : 5.3.5, 5.3.5(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective clothing correctly (SS 5.1.2A)		
2	Uses portable radio properly (speaks clearly)		
3	* Calls May Day		
4	* Identifies location and situation		
5	* Manually activates PASS device to alarm mode		
6	Controls breathing		
7	Controls panic		
8	Listens for noises or sounds		
9	Systematically search to locate hoseline		
10	* Follows hoseline in proper direction using hose coupling		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **7**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.5A2**	**Primary Task:**	**Action When Trapped/Disoriented without Hose**
Objective(s) : 5.3.5, 5.3.5(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

	TRAPPED AND DISORIENTED WITHOUT HOSE	1st	2nd
1	* Wears protective equipment correctly (SS 5.1.2A)		
2	Uses portable radio appropriately (speaks clearly)		
3	* Calls May Day		
4	* Identifies location and situation		
5	Listens for noises or sounds		
6	* Manually activates PASS alarm to alarm mode		
7	Controls breathing		
8	Controls panic		
9	* Locates and follows wall in the same direction		
10	Locates windows/door		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**7**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	**5.3.6A**	**Primary Task:**	**24' Extension Ladder – Carry / Raise / Extend (One Person)**		
Objective(s) :	5.3.6, 5.3.6(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

	ONE PERSON	1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Picks up ladder properly as directed		
3	* Carries selected ladder as directed		
4	Places butt end of ladder at building to raise		
5	* Verbalizes overhead hazards		
6	* Raises ladder correctly to building as directed with the fly section in		
7	Pulls the base of the ladder away from the building slightly		
8	* Extends and locks fly section (hand over hand on halyard)		
9	Ensures ladder locks (dogs) are secured		
10	Rotates ladder (fly section out)		
11	Places ladder on the windward side of the opening (if applicable)		
12	* Angles ladder appropriately for climbing		
13	Secures fly section with halyard		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number Tasks candidate must complete to pass	**9**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	**5.3.6B**	**Primary Task:**	**24' Extension Ladder-Lower/ Removal (One Person)**		
Objective(s) :	5.3.6, 5.3.6(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

	ONE PERSON LOWER AND REMOVAL	1st	2nd
1	* Wears full protective clothing correctly (SS 5.1.2A)		
2	Unsecures halyard from ladder		
3	* Rotates ladder (fly section in)		
4	Places ladder to vertical position next to building		
5	* Verbalizes overhead hazards		
6	* Unlocks and lowers fly section (hand over hand on halyard)		
7	* Lowers ladder to ground (butting the heel of ladder next to building)		
8	Picks up ladder as directed		
9	* Carries ladder to starting position as directed		
10	Lowers ladder to the ground as directed		

*Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**7**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. 5.3.6C	Primary Task: 24' to 28' Extension Ladder Carry / Raise (Two Person)	
Objective(s) : 5.3.6, 5.3.6(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task:

	****TIP PERSON****	1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	* Picks up and carries selected ladder as directed		
3	* Verbalizes overhead hazards		
4	* Raises ladder as directed		
5	Ensures locks (dogs) are secured		
6	Angles ladder appropriately against building for climbing		
7	Secures fly section with halyard to bed section		
	Total number tasks candidate must complete to pass		**5**
	****BUTT PERSON****		
1	* Wears full protective equipment in a manner consistent with training and manufacturer's recommendation		
2	Picks up ladder as directed (communicates by giving commands)		
3	* Carries selected ladder as directed		
4	* Verbalizes overhead hazards		
5	* Butts ladder to vertical		
6	Pivots ladder (if necessary)		
7	* Extends and locks fly section (hand over hand on halyard)		
8	Angles ladder appropriately against building for climbing		
9	Assists with securing ladder		
10	* Butts ladder until completion of evolution (when firefighters are off the ladder)		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**7**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	**5.3.6D**	**Primary Task:**	**24' to 28' Extension Ladder-Lowering / Removal (Two Person)**		
Objective(s) :	5.3.6, 5.3.6(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

	TIP PERSON	1st	2nd
1	* Wears full protective clothing correctly (SS 5.1.2A)		
2	Unsecures fly section		
3	* Verbalizes overhead hazards		
4	Places ladder to vertical from building		
5	Pivots ladder (if necessary)		
6	Lowers ladder to ground properly		
7	* Picks up, carries, and lowers ladder to starting position as directed		

Total number tasks candidate must complete to pass **5**

	***BUTT PERSON ***		
1	* Wears full protective clothing correctly (SS 5.1.2A)		
2	Communicates positions to lower ladder from building		
3	* Verbalizes overhead hazards		
4	* Butts ladder to remove ladder from building to vertical		
5	Lowers fly section (hand over hand on halyard)		
6	Pivots ladder (if necessary)		
7	* Butts ladder for lowering to ground from vertical position		
8	* Picks up, carries, and lowers ladder to the starting position as directed		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**6**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.6E**	**Primary Task:**	**14' to 20' Single Ladder Carry / Raise (One Person)**	
Objective(s) : 5.3.6, 5.3.6(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Picks up ladder as directed		
3	* Carries selected ladder as directed		
4	* Verbalizes overhead hazards		
5	* Places butt end of ladder at building to raise as directed		
6	Raises ladder to building		
7	* Angles ladder appropraitely for climbing		
8	Butts ladder until completion of evolution (if applicable)		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number Tasks candidate must complete to pass **6**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.6F**	**Primary Task:**	**14' to 20' Single Ladder - Lower / Removal (One Person)**	
Objective(s) : 5.3.6, 5.3.6(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

	** ONE PERSON LOWER AND REMOVAL**	1st	2nd
1	* Wears full protective clothing correctly (SS 5.1.2A)		
2	* Verbalizes overhead hazards		
3	Moves ladder to vertical position next to building		
4	* Lowers ladder in a manner consistent with training (butting heel of ladder next to building)		
5	Picks up ladder as directed		
6	* Carries ladder to starting position as directed		
7	Lowers ladder to ground as directed		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**5**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.6G**	**Primary Task:**	**35' Extension Ladder Carry / Raise (Three Person)**	
Objective(s) : 5.3.6, 5.3.6(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

	*******BUTT PERSON*******	1st	2nd
1	* Wears full protective clothing correctly (SS 5.1.2A) and communicates ladder positions and commands		
2	Picks up ladder properly		
3	* Carries selected ladder properly as directed		
4.	* Verbalizes overhead wires (safety)		
5	Butt person states "raise ladder"		
6	* Butts ladder for raising ladder to vertical position		
7	Pivots ladder (if necessary)		
8	* Extended and locks fly section -- (hand over hand on halylard)		
9	Lowers ladder to building		
10	Secures fly section to bed section with halyard		
11	Angles ladder appropriately for climbing		
12	* Butts ladder until completion of evolution (until all firefighters are off the ladder)		
	*******BEAM PERSONS*******	Total number tasks candidate must complete to pass	**8**
1	* Wears full protective clothing correctly (SS 5.1.2A) and picks up ladder as directed		
2	* Carries selected ladder properly as directed		
3	* Verbalize overhead wires (safety)		
4	Raises ladder to vertical position and pivots ladder (if necessary)		
5	* Assists in ladder control as fly section is extended and locked (hand over hand) on halyard		
7	Lowers ladder to building		
8	Angles ladder appropriately for climbing		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**6**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	5.3.6H	Primary Task:	35' Extension Ladder Lowering – Three Person
Objective(s) : 5.3.6, 5.3.6(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

	********BUTT PERSON*******	1st	2nd
1	* Wears full protective clothing correctly (SS 5.1.2A) and communicates ladder positions and commands		
2	* Verbalizes overhead wires		
3	Unties halyard from fly and bed sections		
4	* Butts ladder correctly when removing ladder from building to vertical		
5	* Retracts fly section (hand over hand on halyard)		
6	* Butts ladder correctly to lower ladder to the ground		
	********BEAM PERSONS*******	Total number tasks candidate must complete to pass	**4**
1	* Wears full protective clothing correctly (SS 5.1.2A) s		
2	* Verbalizes overhead wire		
3	Removes ladder from building to vertical		
4	Assists in ladder control as fly section is retracted		
5	Pivots ladder (if necessary)		
6	Lowers ladder to the ground		
7	* Carries and lowers ladder back to the starting position as directed		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**5**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.7A**	**Primary Task:**	**Fire Suppression – Vehicle Fires**	
Objective(s) : 5.3.7, 5.3.7(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A) with SCBA		
2	Identifies fuel type		
3	Approaches fire from appropriate direction (uphill, upwind at 45 degree angle if possible)		
4	* Recognizes approach hazards (tires, batteries, bumpers) - Verbalize		
5	Extinguishes fire on ground and under vehicle (1 1/2” hoseline minimum)		
6	Checks stability of vehicle (blocks wheels if possible)		
7	* Maintains communication		
8	Attacks remaining fire (proper nozzle pattern to provide flash protection)		
9	Follows safety procedures		
10	Gains access to all compartments using basic hand tools		
11	* Extinguishes remaining fire (overhaul)		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**8**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.8A**	**Primary Task:**	**Fire Suppression –Piles/Stacks of Class A Combustibles**	
Objective(s) : 5.3.8, 5.3.8(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A) with SCBA		
2	Selects appropriate handline or master stream		
3	Advances handline or operates master stream		
4	Uses proper nozzle technique		
5	* Extinguishes fire		
6	Uses tools to separate piles/stacks		
7	Examines debris for hot spots		
8	Follows safety procedures		
9	Preserves areas of origin and signs of arson		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **6**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.8B**	**Primary Task:**	**Fire Suppression – Dumpster/Storage Container Fires**	
Objective(s) : 5.3.8, 5.3.8(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A) with SCBA		
2	Selects appropriate size handline or master stream		
3	Advances hoseline or operates master stream		
4	Uses proper nozzle technique		
5	Protects possible exposures		
6	* Extinguishes fire		
7	Follows proper procedures for overhaul of dumpster/container		
8	Follows safety procedures		
9	Preserve areas of origin and signs of arson		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **6**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.8C**	**Primary Task:**	**Deploy Master Stream Device**	
Objective(s) : 5.3.8, 5.3.8(A)(B)	NFPA Standard: 1001 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Selects and attaches appropriate feeder lines		
3	Sets up for direct attack or exposures protection (if possible)		
4	Follows safety procedures to include securing the master stream device (if applicable)		
5	* Calls for water		
6	Operates master stream		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **4**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.9A**	**Primary Task:**	**Rescue with SCBA in Obscured Visibility**	
Objective(s) : 5.3.9, 5.3.9(A)(B), 5.3.1, 5.3.1(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	* Checks door for heat		
3	Searches structure using established search patterns		
4	Stays low / crawls		
5	* Communicates / contact		
6	Probes with tools		
7	Conserves air		
8	* Locate / remove victim		
9	Report completion to Supervisor		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**6**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.9B**	**Primary Task:**	**Removal Over Ladder (Conscious Person)**	
Objective(s) : 5.3.9, 5.3.9(A)(B), 5.3.6, 5.3.6(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task	1st	2nd
1 * Wears full protective equipment correctly (SS 5.1.2A)		
2 Positions ladder appropriately		
3 * Checks angle of ladder		
4 Ascends ladder safely		
5 Communicates with victim		
6 Assists victim onto ladder		
7 * Maintains contact with victim		
8 * Descends ladder safely with victim		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**6**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	5.3.9C	Primary Task:	Removal Over Ladder (Unconscious Person)
Objective(s) :	5.3.9, 5.3.9(A)(B), 5.3.6, 5.3.6(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Positions ladder appropriately		
3	* Checks for correct climbing angle		
4	Ensures ladder is heeled, secured and locks are seated		
5	Ascends the ladder to the victim		
6	Places victim on ladder using one of the following methods:		
	a. Method 1: Places victim on knee facing ladder places victim's legs outside beams		
	b. Method 2: Places victim on knee facing the firefighter with victim's legs outside beams		
	c. Method 3: Places victim facing the firefighter with victim's legs at the knees draped over the firefighter's shoulders		
	d. Method 4: Places one arm under the victim's arm and the other arm under the opposite leg		
7	Keeps hands on the ladder **rungs**		
8	* Maintains contact with ladder		
9	* Decends the ladder safely with victim		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**6**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.9D**	**Primary Task:**	**Conduct a Primary Search**	
Objective(s) : 5.3.9, 5.3.9(A)(B)	NFPA Standard: 1001 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A) with SCBA		
2	Carries a forcible entry tool		
3	Searches as conditions allow		
4	Searches structure systematically using established search patterns		
5	Searches all areas		
6	Pauses occasionally to listen for sounds of building collapse, cries for help etc.		
7	* Moves up and down stairs safely		
8	* Finds victim and removes		
9	Reports findings to Supervisor		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **6**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.9D1**	**Primary Task:**	**Conduct a Secondary Search**	
Objective(s) : 5.3.9, 5.3.9(A)(B)	NFPA Standard: 1001 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A) with SCBA		
2	Carries a forcible entry tool		
3	Searches with portable lighting (if possible)		
4	Searches are conducted slowly and methodically		
5	Searches all areas		
6	Searches all areas such as closets, showers. etc.		
7	Searches systematically		
8	Reports findings to Supervisor		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **6**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter I

Skill No.	**5.3.9E**	**Primary Task:**	**Drags and Carries**		
Objective(s) :	5.3.9, 5.3.9(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task	1st	2nd
One Person		
1 Demonstrates lone rescuer drag		
2 Demonstrates cradle in arm carry		
Two Person		
3 Demonstrates extremities carry		
• * Rescuer 1 (correct position)		
• * Rescuer 2 (correct position)		
4 Seat Carry		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**3**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. 5.3.10A.1	Primary Task:	Fire Suppression – Interior Structure, Grade Level
Objective(s) : 5.3.10, 5.3.10(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A) withSCBA		
2	* Advances hoseline as directed		
3	* Clears all remaining hose from hose bed		
4	* Maintains communication and radios for water		
5	* Checks nozzle pattern and bleeds air from hose line		
6	Safely enters structure (per building condition)		
7	Advances hoseline into structure		
8	Operates nozzle in a manner consistent with training		
9	* Locates and extinguishes fire using appropriate attack methods		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**6**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. 5.3.10A.2	Primary Task:	Fire Suppression – Interior Structure, Above Grade Level
Objective(s) : 5.3.10, 5.3.10(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A) with SCBA		
2	* Advances hoseline as directed		
3	* Clears all remaining hose from hose bed		
4	* Maintains communication and radios for water		
5	* Checks nozzle pattern and bleeds air from hose line		
6	Safely enters structure (per building condition)		
7	Advances hoseline into structure		
8	Operates nozzle in a manner consistent with training		
9	* Locates and extinguishes fire using appropriate attack methods		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **6**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.10A.3**	**Primary Task:**	**Fire Suppression – Interior Structure, Below Grade Level**	
Objective(s) : 5.3.10, 5.3.10(A)(B)	NFPA Standard: 1001 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A) with SCBA		
2	* Advances hoseline as directed		
3	* Clears all remaining all hose from hose bed, flakes hose out prior to descending stairs		
4	* Maintains communications and calls for water		
5	* Checks nozzle pattern and bleeds air from hoseline		
6	Safely enters structure (per building condition)		
7	Advances hoseline into structure		
8	* Descends stairs safely with charged hoseline		
9	Operates nozzle in a manner consitent with training		
10	* Locates and extinguishes fire using appropriate method		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **7**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.10B**	**Primary Task:**	**Hose Deployment**	
Objective(s) : 5.3.10, 5.3.10(A)(B), 5.3.8, 5.3.8(A)(B)	NFPA Standard: 1001 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Demonstrates deploying one of the following 1 ¾" loads • Preconnected flat load • Minuteman load • Triple layer load		
	OR		
3	Demonstrates deploying one of the following 2 ½" loads • Accordion load • Flat load • Horseshoe load		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**2**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	**5.3.10C**	**Primary Task:**	**Hoseline Advancement**		
Objective(s) :	5.3.10, 5.3.10(A)(B), 5.3.8, 5.3.8(A)(B)	NFPA Standard:	1001 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Deploys hose to building or structure as directed		
3	* Maintains communication (calls for water when needed)		
4	* Checks nozzle pattern and bleeds air from hoseline		
5	Operates nozzle in a manner consistent with training		
6	Works hoseline in a manner consistent with training		
7	Maintains forward movement		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**5**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.10D** **Primary Task:**	**Charged Hoseline Operation from Ground Ladder**		
Objective(s) : 5.3.10, 5.3.10(A)(B)	NFPA Standard: 1001 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Ascends ladder safely with hose line		
3	* Maintains communication		
4	Assures correct position on ladder for best penetration		
5	* Uses leg lock or safety harness		
6	Projects nozzle in window for best results		
7	Secures hose to ladder		
8	* Slowly opens nozzle and flows water safely		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **6**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.10E**	**Primary Task:**	**Use of Nozzle**	
Objective(s) : 5.3.10, 5.3.10(A)(B), 5.3.13(A)(B), 5.3.8(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Identifies nozzle/appliance		
3	* Opens nozzle slowly		
4	Bleeds air and checks flow pattern		
5	Demonstrates the following nozzle settings		
	• Straight Stream		
	• Narrow Angle Fog		
	• Wide Angle Fog		
6	* Closes nozzle slowly		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**4**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.10F**	**Primary Task:**	**Replace Burst Section of Hose**	
Objective(s) : 5.3.10, 5.3.10(A)(B)	NFPA Standard:	1001 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Controls water flow		
3	Selects two lengths to replace defective length		
4	* Uncouples defective length by using knee press method		
5	* Couples replacement length by using foot tilt method		
6	Charges line		

Complete steps 1 to 5 using 1 3/4" line

OR

Complete steps 1 to 5 using 2 1/2" line

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**4**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.10G**	**Primary Task:**	**Adding a Length of Hose**	
Objective(s) : 5.3.10, 5.3.10(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Selects hose to be added to line and places it in position		
3	Shuts off water at source		
4	Bleed off pressure		
5	* Adds hose to nozzle end of hose line using foot-tilt, knee-press method		
6	Turns water on at source		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**4**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	5.3.10H1	Primary Task:	Coupling and Uncoupling Hose (One Person)
Objective(s) : 5.3.10, 5.3.10(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
	****ONE PERSON****		
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Couples two lengths (supply line) minimum size 2 ½" using foot-tilt method		
3	Uncouples hoseline used in step # 2 using knee-press method		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**3**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	5.3.10H2	Primary Task:	Coupling / Uncoupling Hose (Two Person)
Objective(s) : 5.3.10, 5.3.10(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
	**** TWO PERSON ****		
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Couples two lengths – minimum size 2 1/2”		
3	Uncouples line used in Step #2 using stiff–arm method		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **3**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.10J**	**Primary Task:**	**Remove Hose from Upper Floors**
Objective(s) : 5.3.10, 5.3.10(A)(B), 5.3.14, 5.3.14(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Shuts down water supply		
3	Opens nozzle to relieve water pressure (bathtub, out of window, etc.)		
4	Disconnects hose coupling to drain (window sill, front door, street curb, etc.)		
5	After draining, removes hose using shoulder carry		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **4**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.10K**	Primary Task:	**Remove Hose from Building to Minimize Water Damage**
Objective(s) : 5.3.10, 5.3.10(A)(B), 5.3.14, 5.3.14(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Shuts down water supply		
3	Opens nozzle to relieve pressure (bathtub, out of window, etc.)		
4	Disconnects hose coupling to drain (window sill, front door, street curb, etc.)		
5	After draining, removes hose from building (using shoulder carry)		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **4**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.11A**	**Primary Task:**	**Working Safely from Ladders (Ground)**	
Objective(s) : 5.3.11, 5.3.11(A)(B), 5.3.6, 5.3.6(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Climbs ladder safely		
3	* Uses leg lock or safety harness properly		
4	Descends ladder safely		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**3**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.11B**	**Primary Task:**	**Window Opening (Destructive)**
Objective(s) : 5.3.11, 5.3.11(A)(B), 5.3.6(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	* Positions ladder correctly		
3	Climbs ladder with tool		
4	* Uses leg lock or safety harness		
5	Maintains safety area		
6	Strikes window correctly		
7	Clears window frame		
8	Descends ladder safely		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **6**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.11C**	**Primary Task:**	**Hydraulic Ventilation**	
Objective(s) : 5.3.11, 5.3.11(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	* Identifies appropriate nozzle		
3	Selects and demonstrates correct pattern		
4	Selects proper distance from opening for maximum effectiveness		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **3**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.11D**	**Primary Task:**	**Negative-Pressure Ventilation**	
Objective(s) : 5.3.11, 5.3.11(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	* Ensures appropriate placement in opening (same direction as natural wind)		
3	* Removes any material that might disrupt air flow (if applicable)		
4	Covers area around fan to prevent churning		
5	Connects to power properly		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **4**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.11E**	**Primary Task:**	**Positive-Pressure Ventilation**	
Objective(s) : 5.3.11, 5.3.11(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Selects proper point of entry		
3	Correctly positions fan to completely cover entry with cone of air		
4	* Selects appropriate exit point to remove smoke		
5	Safely connects to power source (if applicable)		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **4**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.12A1**	**Primary Task:** **Roof Ladder Deployment**	
Objective(s) : 5.3.12, 5.3.12(A)(B), 5.3.6(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	*Carries ladder as directed		
3	Deploys hooks		
4	Ascends ground ladder		
5	*Uses leg lock or safety harness		
6	Hoists roof ladder (hooks out)		
7	* Positions and secures roof ladder		
8	Descends down the ladder safely		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**6**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter I

Skill Sheet No. **5.3.12A2**	**Primary Task:**	**Roof Ladder – Lower and Removal (two person)**	
Objective(s) : 5.3.12, 5.3.12(A)(B), 5.3.6(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	* Uses leg lock or safety harness		
3	Tilts roof ladder on its closest beam		
4	* Communicates and lowers ladder to the #2 man on the ladder		
5	Disengages leg lock or safety harness		
6	* Communicates and both descend ladder safely		
7	Closes hooks		
8	Carries ladder as directed		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**6**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.12B**	**Primary Task:**	**Ladder Climb with Tool**	
Objective(s) : 5.3.12, 5.3.12(A)(B), 5.3.11, 5.3.11(A)(B), 5.3.6(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	* Checks ladder for appropriate angle		
3	Method – 1 Climbs with free hand sliding under the beam and tool hand on beam		
	OR		
3	Method – 2 Climbs with free hand sliding under the beam and other hand holding tool		
4	* Reaches objective, sounds roof with tool before getting on roof (if applicable)		
5	Descends ladder safely		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**4**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	**5.3.12C**	**Primary Task:**	**Determining Roof Integrity**		
Objective(s) :	5.3.12, 5.3.12(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Climbs ladder with tool		
3	* Sounds roof with tool before transfer from ladder		
4	Determines roof integrity (verbally)		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**3**

Rev 1/9/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.12D1**	**Primary Task:** **Roof Ventilation - Flat**		
Objective(s) : 5.3.12, 5.3.12(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Checks operation of tool		
3	Safely climbs ladder with tool		
4	Sounds roof for integrity		
5	* Describes cutting 4' by 4' hole from the windward side		
6	* Describes removing roofing material from hole		
7	* Describes pushing ceiling in from windward side (plaster hook, pike pole)		
8	Descends ladder safely		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **6**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.12D2**	**Primary Task:**	**Roof Ventilation – Pitched**	
Objective(s) : 5.3.12, 5.3.12(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Checks operation of tool		
3	Safely climbs ladder with tool		
4	Sounds roof for integrity		
5	Opens roof from roof ladder (cutting a 4' by 4' from the windward side)		
6	* Stands on correct side of opening and removes roofing material		
7	* Pushes ceiling in from windward side (if applicable) with correct tool		
8	Descends ladder safely		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **6**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.13A**	**Primary Task:**	**Expose Hidden Fire**	
Objective(s) : 5.3.13, 5.3.13(A)(B), 5.3.10, 5.3.10(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Deploys tool and attack line		
3	Detects hidden fire		
4	Demonstrates use(s) of tool		
5	Opens up hidden fire correctly (verbalize)		
6	Removes burned materials / extinguishes fire		
7	Maintains structural integrity		
8	Fire cause evidence is preserved		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**6**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.14A**	**Primary Task:**	**Salvage Cover Deployment (Two Person)**	
Objective(s) : 5.3.14, 5.3.14(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Stacks objects in a manner consistent with training		
3	Covers objects as directed		
4	Tucks corners / secures cover to local jurisdiction (procedures)		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**3**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	**5.3.14B**	**Primary Task:**	**Construction and Use of Water Catchall**	
Objective(s) :	5.3.14, 5.3.14(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
	TWO PERSON		
1	* Wears protective equipment correctly (SS 5.1.2A)		
2	Opens the salvage cover		
3	Lays the salvage cover flat in the selected location		
4	* Rolls the sides inward approximately 3 feet		
5	Lay the ends of the side rolls over at 90 degree angle to form the corners		
6	Rolls one end into a tight roll on top of the side roll and forms a projected flap		
7	Lifts the edge roll		
8	Tucks the end roll to lock the corners		
9	* Rolls the other end in a like manner		
10	Locks the corners		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**7**

Rev 1/9/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter I

Skill No. **5.3.14C**	**Primary Task:**	**Construction and Use of Water Chute**	
Objective(s) : 5.3.14, 5.3.14(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
	TWO PERSON		
1	* Wears protective equipment correctly (SS 5.1.2A)		
2	Selects materials to construct water chute		
3	* Constructs water chute		
4	Places water chute in correct position		

* Critical task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**3**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.14D**	**Primary Task:**	**Routing and Removal of Water and Debris (Horizontal) – Upper Floors**	
Objective(s) : 5.3.14, 5.3.14(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
	****VERTICAL****		
1	* Wears protective equipment correctly (SS 5.1.2A)		
2	Forces water toward scupper (if applicable) verbalize		
3	Removes drain cover (toilet, soil pipe) verbalize		
4	Secures drain guard (if applicable) verbalize		
5	Forces water down stairs case (water chute) verbalize		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**4**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.14E**	**Primary Task:**	**Routing and Removal of Water (Vertical)**
Objective(s) : 5.3.14, 5.3.14(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

	****HORIZONTAL****	1st	2nd
1	* Wears protective equipment correctly (SS 5.1.2A)		
2	Opens ceiling below water accumulation		
3	* Establishes a means of removal (water chute, catch basin)		
4	Describes how to open floors of water accumulation		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**3**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.14F**	**Primary Task:**	**Routing and Removal of Water and Debris (Below Grade)**	
Objective(s) : 5.3.14, 5.3.14(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

	BELOW GRADE	1st	2nd
1	* Wears protective equipment i correctly (SS 5.1.2A)		
2	Sets up pump in a manner consistent with training		
3	Secures strainer (if applicable)		
4	Starts pump		
5	Identifies operation of pump		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**4**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter I

Skill No. **5.3.14G**	**Primary Task:**	**Closes up a Building**	
Objective(s) : 5.3.14, 5.3.14(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears protective equipment correctly (SS 5.1.2A)		
2	Selects method		
3	Applies materials to openings		
4	Secures openings		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**3**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.14H**	**Primary Task:**	**Separate and Remove Charred Material**	
Objective(s) : 5.3.14, 5.3.14(A)(B), 5.3.13(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears protective equipment correctly (SS 5.1.2A)		
2	* Identifies and protects “Area of Origin”		
3	Preserves evidence by guarding, tagging, or other safeguards		
4	Separates charred materials		
5	Removes charred materials to safe location		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**4**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.14I**	**Primary Task:**	**Stop Water Flow from Sprinkler**	
Objective(s) : 5.3.14, 5.3.14(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Stops water flow from activated sprinkler head using wooden wedges or sprinkler wedge stopper		
3	Identifies and closes main control valve		
4	Identifies and opens main drain valve		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**3**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.15A**	**Primary Task:**	**Drafting (Static Source)**	
Objective(s) : 5.3.15, 5.3.15(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Checks the hard suction coupling (dirt, debris, worn gaskets)		
3	Removes pumper intake cap		
4	* Attaches strainer to hard suction hose male coupling		
5	Attaches rope to strainer		
6	Lowers hose and strainer into static source (portable tank)		
7	Attaches female coupling of hard section hose to pumper intake		
8	Secures strainer rope to pumper or other stationary object		
9	* Assures strainer and strainer-to-hose coupling are under water		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **6**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.15B**	**Primary Task:**	**Hydrant to Pumper Connection**	
Objective(s) : 5.3.15, 5.3.15(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Removes pumper intake cap		
3	Attaches the appropriate female end of the soft suction hose to the pumper intake		
4	Removes the appropriate hydrant discharge cap and places the hydrant wrench on hydrant		
5	Inspects hydrant threads for damage & integrity. Inspects inside outlet for debris		
6	Attaches the appropriate female end of the soft suction hose to the hydrant		
7	* Slowly opens hydrant fully		
8	Reduces any leakage by tightening connections and assures soft suction has no kinks		
9	Adds chafing block at point where hose touches ground		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**6**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.15C1**	**Primary Task:**	**Hydrant Connection (Forward Lay)**	
Objective(s) : 5.3.15, 5.3.15(A)(B)	NFPA Standard:	1001 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	* Selects correct tools and appliances		
3	Wraps hydrant in a manner consistent with training		
4	Tells apparatus driver to advance to the incident		
5	* Unwraps hose and connects properly to hydrant		
6	* Opens hydrant fully		
7	Opens gate slowly on command		
8	Closes hydrant completely		
9	Checks hydrant drainage		
10	Recaps hydrant		
11	Collects tools and appliances and places them back on apparatus		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**8**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.15.2**	**Primary Task:**	**Hydrant Connection (Reverse Lay)**	
Objective(s) : 5.3.15, 5.3.15(A)(B)	NFPA Standard:	1001 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	* Selects and uses correct tools and appliances		
3	Connects supply line from hydrant to engine intake		
4	Connects feeder line to engine discharge		
5	* Opens hydrant fully		
6	Opens gate on command		
7	Closes hydrant fully		
8	Checks hydrant drainage		
9	Recaps hydrant		
10	Collects appliances and places them back on apparatus		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**7**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.3.15D**	**Primary Task:**	**Sprinkler/Standpipe (Siamese) Fire Department Connection (FDC)**	
Objective(s) : 5.3.15, 5.3.15(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A)		
2	Removes adequate amount of hose to make connection		
3	Inspects FDC (siamese) clapper valve		
4	Connects male end of feeder line to FDC		
5	Completes connection to pump discharge on apparatus (if applicable)		
6	* Informs pump operator that connection is completed and calls for water		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **4**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.15E**	**Primary Task:**	**Standpipe Operation**	
Objective(s) : 5.3.15, 5.3.15(A)(B)	NFPA Standard: 1001 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears full protective equipment correctly (SS 5.1.2A) with SCBA		
2	Uses appropriate carry, carries sufficient fire hose to one level below the level of the fire		
3	Removes cap and checks for foreign material in discharge		
4	* Attaches the hose to the standpipe connection one level below the fire		
5	Flakes out hose up the stairway above the fire floor, if possible		
6	* Slowly charges the hoseline by opening the standpipe valve		
7	* Bleeds the air out of the hoseline and checks pattern		
8	Advances to the fire		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**6**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.16A**	**Primary Task:**	**Extinguish Class A Fires**	
Objective(s) : 5.3.16, 5.3.16(A)(B)	NFPA Standard: 1001 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears appropriate protective clothing correctly (SS 5.1.2A)		
2	* Selects proper extinguisher for Class A fire		
3	Check extinguisher for full charge		
4	Operates selected extinguisher		
5	Applies agent to extinguish Class A fire effectively and extinguishes fire		
6	Ensures fire is completely extinguished		
7	Tags extinguisher for recharge		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **5**

Rev 1/9/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL SHEET, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.16B**	**Primary Task:**	**Extinguish Class B Fires**	
Objective(s) : 5.3.16, 5.3.16(A)(B)	NFPA Standard: 1001 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears appropriate protective clothing correctly (SS 5.1.2A)		
2	* Selects proper extinguisher for Class B fire		
3	Checks extinguisher fully charged		
4	Operates selected extinguisher		
5	Applies agent to extinguish Class B fire effectively and extinguishes fire		
6	Ensures fire is completely extinguished		
7	Tags extinguisher for recharge		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **5**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL SHEET, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.16C**	**Primary Task:**	**Extinguish Class C Fires**	
Objective(s) : 5.3.16, 5.3.16(A)(B)	NFPA Standard: 1001 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears appropriate protective clothing correctly (SS 5.1.2A)		
2	* Selects proper extinguisher for Class C fire		
3	Checks extinguisher fully charged		
4	* De-Energizes electrical equipment		
5	Operates selected extinguisher		
6	Applies agent to extinguish Class C fire effectively and extinguishes fire		
7	Ensures fire is completely extinguished		
8	Tags extinguisher for recharge		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **6**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL SHEET, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter I

Skill Sheet No. **5.3.17A**	**Primary Task:**	**Safety Procedures for Lighting Equipment**	
Objective(s) : 5.3.17, 5.3.17(A)(B)	NFPA Standard: 1001 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	Describes and identifies inverter (if applicable)		
	or		
	Describes and identifies generator (if applicable)		
2	* Checks overhaul condition of tools, cords, plugs, and connectors		
3	* Connects all lighting equipment in proper sequence		
	a) Starts up generator, brings up to speed		
	b) Plugs in load		
4	Takes safety precautions to avoid burns		
5	Re-sets (GFI) Ground Fault Interrupter (if applicable)		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **4**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	**5.3.18A**	**Primary Task:**	**Control Utility Services**		
Objective(s) :	5.3.18, 5.3.18(A)(B)	NFPA Standard:	1001 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears protective equipment correctly (SS 5.1.2A)		
2	Locates main electrical breaker and operates main breaker to cut power		
3	Identifies type of gas service and locates gas meter and shut off same		
4	Locates main water shut-off and operates appropriate valve to stop water flow		
5	Communicate with Command		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **4**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.19A**	**Primary Task:**	**Donning Ground Cover PPE**	
Objective(s) : 5.3.19, 5.3.19(A)(B)	NFPA Standard: 1001 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task	1st	2nd
1 Wears appropriate shirt and pants (or jump suit)		
2 Helmet with chinstrap, headlamp, eye protection, hearing protection		
3 Gloves		
4 Boots and socks		
5 Equipment belt with fire shelter, canteen		
6 Neck shroud		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **4**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.19B**	**Primary Task:**	**Fill, Use and Maintain a Backpack Pump**	
Objective(s) : 5.3.19, 5.3.19(A)(B)	NFPA Standard: 1001 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	Assembles backpack pump		
2	Maintains proper footing and stance		
3	Maintains proper body position; carrying and lifting		
4	Fills backpack pump with clean or strained water		
5	Demonstrates clearing a clogged nozzle		
6	Demonstrates cleaning a quick connect, if dirty		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **4**

Rev 1/9/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No.	5.3.19C	Primary Task:	Use of Tools and Appliances for Simple Ground Cover Hose Lay
Objective(s) :	5.3.19, 5.3.19(A)(B)	NFPA Standard: 1001 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears appropriate equipment as directed		
2	Identifies commonly used fittings and hose		
3	Demonstrates a simple hose lay		
4	Extends charged hose lay by properly clamping, crimping, disconnecting, inserting, and recoupling hose		
5	Sets nozzle setting appropriately for the situation		
6	Applies water in a manner consistent		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **4**

1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.3.19D**	**Primary Task:**	**Use of Hand Tools while Building a Fire Control Line**	
Objective(s) : 5.3.19, 5.3.19(A)(B)	NFPA Standard: 1001 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Wears appropriate equipment as directed		
2	* Selects the appropriate tool		
3	Inspects the tool before use		
4	Determines if the tool may be used safely		
5	Determines the location of the control line		
6	* Digs suppression line based on type of fuels and terrain		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**4**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	5.3.20A	Primary Task:	Tie Knots and Hoist Tools
Objective(s) : 5.3.20, 5.3.20(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task:

		1st	2nd
1	* Selects correct rope		
2	Verbalizes correct knot for the task		
3	* Ties correct knots to hoist tools / hose		
4	* Ties knot in proper location		
5	Hoists tools / hose successfully		
6	Ties tag lines (when applicable)		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **4**

Rev 1/22/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	**5.3.20B**	**Primary Task:**	**Knot Selection and Tying**		
Objective(s) :	5.3.20, 5.3.20(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1.	* Selects correct rope		
2.	Ties Clove Hitch with overhand safety knot		
3.	Ties Half Hitch		
4.	Ties Figure of Eight on a Bight with overhand safety knot		
5.	Ties Becket (Sheet) Bend with two overhand safety knots		
6.	Ties Bowline		
7.	Ties Figure of Eight with follow through		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**5**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.5.1A**	**Primary Task:**	**Cleaning, Maintaining & Inspecting Department Ladders**	
Objective(s) : 5.5.1, 5.5.1(A)(B)	NFPA Standard: 1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	Washes and dries ladder per manufacturer's specifications		
2	* Checks all heat sensors and their dates		
3	Checks rungs, bolts and rivets		
4	* Checks welds and beams for cracks		
5	Checks all ladder hardware and condition of halyard		
6	Lubricates per manufacturer's specifications (verbally)		
7	* Marks and documents defects (verbally)		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**5**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.5.1B**	**Primary Task:**	**SCBA Maintenance and Use**	
Objective(s) : 5.5.1, 5.5.1(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1.	* Checks that cylinder is full (or at least 90%)		
2.	Checks operation of all gauges. Verifies that the difference between cylinder and regulator gauge does not exceed 100 psi		
3.	* Tests operation of low pressure alarm (to activate at 25%of cylinder)		
4.	Checks all hose connections		
5.	Checks condition of facepiece		
6.	Checks condition of harness and straps		
7.	Checks operation of donning and bypass valves		
8.	Checks that unit is clean and sanitized		
9.	* Tests PASS device		
10	* Place components in position for Emergency Response		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **7**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Fire Fighter I

Skill Sheet No. **5.5.1C**	**Primary Task:**	**Salvage Cover Inspection & Maintenance**	
Objective(s) : 5.5.1, 5.5.1(A)(B)	NFPA Standard: 1001 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	Washes and cleans cover in a manner consistent with training		
2	Dries cover to reduce mildew		
3	Examines for damage (passing salvage cover over their head looking for holes)		
4	Marks any holes found with chalk		
5	Depending on the material, holes may be repaired by duck or mastic tape, iron-on patches		
6	Folds or rolls cover properly to local jurisdiction		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**4**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Chief Examiner at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	**5.5.1D**	**Primary Task:**	**Rope Maintenance**		
Objective(s) :	5.5.1, 5.5.1(A)(B)	NFPA Standard:	1001 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Inspects rope in a manner consistent with training		
2	Bundles / coils / bags rope		
3	Stores rope in proper location		
4	Documents results		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**3**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.5.2A**	**Primary Task:**	**Hose Storage**	
Objective(s) : 5.5.2, 5.5.2(A)(B)	NFPA Standard:	1001 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

		1st	2nd
1	Rolls hose as directed		
2	Unrolls hose as directed		
3	Couples hose as directed		
4	Loads hose on hose storage rack		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **3**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	**5.5.2B**	**Primary Task:**	**Hose Rolls**		
Objective(s) :	5.5.2, 5.5.2(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	* Rolls hose by using two of the following methods: • Straight roll • Donut roll • Twin donut roll • Self-Locking twin donut roll		
2	Unrolls hose as directed		
3	* Couples, Uncouples hose as direcetd (foot tilt, knee press method if applicable)		
4	* Loads hose into hose bed by one of the following methods : • 1 ¾" – Preconnected Flat Load, Triple Layer Load, Minuteman Load • 2 ½" – Accordian Load, Horseshoe Load, Flat Load		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**3**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No.	**5.5.2C**	**Primary Task:**	**Hose Bed - Attack**		
Objective(s) :	5.5.2, 5.5.2(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	Unrolls hose as direcetd		
2	Loads--1 ¾ Attack hose into hose bed by one of the following methods : • Preconnected Flat Load, • Triple Layer Load, • Minuteman Load -- Attack		
3	* Couples, Uncouples hose as directed (foot tilt, knee press method if applicable)		
4	Uses the Higbee cut		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**3**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill No. **5.5.2D**	**Primary Task:**	**Hose Bed Loads - Supply**	
Objective(s) : 5.5.2, 5.5.2(A)(B)	NFPA Standard:	1001, 2013 Edition	Candidate #

Performance Evaluation Sheet

Task

	1st	2nd
1 Unrolls hose as directed		
2 Loads—2 1/2 Supply hose into hose bed by one of the following methods :		
• Accordian Load,		
• Flat Load,		
• Horseshoe Load		
3 * Couples, Uncouples hose as dircetd (foot tilt, knee press method if applicable)		
4. Demostrates us of use the Dutchman		
5. Proper location of couplings		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**4**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.5.2E**	**Primary Task:** **Cleaning / Maintaining / Inspecting Hose**	
Objective(s) : 5.5.2, 5.5.2(A)(B)	NFPA Standard: 1001 2013 Edition	Candidate #

Performance Evaluation Sheet

Task	1st	2nd
1 Brushes off dust and dirt		
2 Uses scrub brush and water		
3 Rinses hose with clear water		
4 Identifies and applies drying procedures for hose (hose tower or hose dryer)		
5 * Inspects hose for abrasions and cuts in outer jacket		
6 Rolls hose (straight roll) and places on storage rack		
7 Documents results		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass	**5**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE

State of Connecticut

COMMISSION ON FIRE PREVENTION AND CONTROL

Firefighter I

Skill Sheet No. **5.5.2F**	**Primary Task:**	**Cleaning, Maintaining & Inspecting Hose Couplings**	
Objective(s) : 5.5.2, 5.5.2(A)(B)	NFPA Standard: 1001 2013 Edition	Candidate #	

Performance Evaluation Sheet

Task

		1st	2nd
1	Brushes male threads with wire brush		
2	Removes gasket and washes swivel		
3	Brushes dust and dirt from female threads		
4	Checks gasket for deterioration		
5	Replaces gasket properly		
6	* Inspects hose and coupling for physical damage		
7	Documents results		

* Critical Task	Failure of this task mandates failure on the entire objective	Safety is **PARAMOUNT**	Total number tasks candidate must complete to pass **5**

Rev 1/23/14

Prevent or prohibit any unsafe acts.
Contact the Lead Evaluator at any time with any questions.
Remember, you are an evaluator, not a trainer…

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE