

**Docket No. 272 – Development and Management Plan Inspection**

The Connecticut Light and Power Company Certificate of Environmental Compatibility and Public Need for the construction of a new 345-kV electric transmission line and associated facilities between Scovill Rock Switching Station in Middletown and Norwalk Substation in Norwalk, Connecticut, including reconstruction of portions of existing 115-kV and 345-kV electric transmission line, the construction of Beseck Switching Station in Wallingford, East Devon Substation in Milford, (and Singer Substation in Bridgeport), modifications at Scovill Rock Switching Station and Norwalk Substation, and the reconfiguration of certain interconnections.

**Segment 2b Inspection**

**Date:** June 7, 2007

**Inspector:** Matt Kelly

**Location:** Segment 2b – Cheshire/Hamden Town Line to East Devon Substation

**Rainfall:** 2.57” of precipitation was recorded in the week since the last inspection, with 1.83” of the total reported on 6/4 (NOAA data at New Haven, CT).

Areas of Inspection	Observation	Recommended Action	Corrected Action
Access roads and adjacent roadways <b>Orange, CT</b> Ridge Rd, Rolling Ridge Rd, Sunset Dr, Hall Dr, Edward Ct, Racebrook Rd, Overland Dr, Hunting Hill Pl, Harbor View, Saddle Ridge, Route 152, Treat Lane, Pine Tree Dr, Lambert Rd, Russell Ave, and Hunting Hill Rd, Dogwood Road, Dogburn Road, Route 34  All access roads (above)	Clearing/road construction appears to be complete in these sections at this time. 6/7/07	Continue to monitor. Install mats if necessary. 6/7/07	Not Applicable (NA)
	Mats remain at the wetland crossings in these sections. 6/7/07	Continue to monitor. 6/7/07	NA
	Stone pads remain in place at all entrances to access roads. Sediment tracking was not an issue this week. 6/7/07	Continue to monitor for sediment tracking. Sweep roadways as necessary. 6/7/07	Needs regular attention
	“Silt saks” (or similar) remain intact within catch basins in the vicinity of the constructed access roads. Silt sak fabric was pulled over the curb drop inlet at those catch basins located immediately adjacent to the constructed access roads. 6/7/07	Continue to monitor and evaluate methods to protect the curb drop inlet and prevent sedimentation as needed. See Erosion Control Section for more detail. 6/7/07	CB controls in place. Improve as necessary.

Areas of Inspection	Observation	Recommended Action	Corrected Action
<p><b>Milford, CT</b> Fresh Meadow Road/West River Street, Eisenhower Park, East Rutland Ave, Naugatuck Ave, Caswell Street, Wheelers Farm Road, Plains Road to Oronoque Rd, Lexington Lane, Woodruff Road, and Route 121</p>	<p>Clearing and access road construction appears to be complete in these sections at this time. 6/7/07</p>	<p>Continue to monitor and add controls as necessary. See EC section. 6/7/07</p>	<p>NA</p>
<p><b>Woodbridge, CT</b> Pease Road, Salem Road, Rimmon Road (west), Woodbine Rd, Manville Rd, Clark Street, Brookwood and Cowpath Lane, and SCRRWA (Glen Dam), JCC and B'Nai Jacob, Oak Lane Country Club, and Center Rd</p>	<p>Clearing and access road construction appear to be complete in these sections at this time. 6/7/07</p>	<p>Continue to monitor. Sweep roadway as needed. 6/7/07</p>	<p>NA</p>
<p><b>Bethany, CT</b> Morris to Hatifeld and Downs Road (to West Todd, Hamden)</p>	<p>Access road construction continues in these sections. Culverts and timber mat crossings have been constructed/ installed. 6/7/07</p>	<p>Continue to monitor and add controls as necessary. See EC Section. 6/7/07</p>	<p>NA</p>
<p>Downs Rd, Hoadley Rd and Raccio Drive</p>	<p>Access road construction appears to be complete in these sections.</p>	<p>Continue to monitor and add controls as necessary. See EC Section. 6/7/07</p>	<p>NA</p>
<p><b>Hamden, CT</b> West Todd Street and Tom Swamp Rd/Arrow Rd</p>	<p>Access road construction appears to be complete in these sections. Culverts, water bars, and drainage swales are in place. 6/7/07</p>	<p>Continue to monitor and add controls as necessary. See EC Section. 6/7/07</p>	<p>NA</p>
<p>115-kV underground transmission line</p>	<p>The access road adjacent to the catch basin is now stabilized with stone. 6/7/07</p>	<p>Monitor during next large rain event. Curb inlet protection may be necessary. 6/7/07</p>	<p>NA at this time.</p>
<p>Foundation and site construction <b>Orange, CT</b> Sunset Dr, Overland Dr, Route 152, Ridge Rd, Edward Ct, Racebrook</p>	<p>Foundation work appears to be complete in these sections at this time. Timber mat and stone crane pads remain in</p>	<p>None at this time. 6/7/07</p>	<p>NA</p>

Areas of Inspection	Observation	Recommended Action	Corrected Action
<p>Rd, Hall Dr, and Russell Ave, Rolling Ridge Rd, Treat Lane, Pine Tree Dr, Dogwood Rd, Lambert Rd, Saddle Ridge Rd, Hunting Hill Rd and Place, Dogburn Rd to Route 34 and Route 34 west.</p>	<p>crane pads remain in place. Structure installation continues. 6/7/07</p> <p>Line installation had begun off Route 34 this week. 6/7/07</p>	<p>None at this time. 6/7/07</p>	<p>NA</p>
<p>Dogburn Rd</p>	<p>Drilling/ foundation work continues in this area. 6/7/07</p>	<p>Continue to monitor. 6/7/07</p>	<p>NA</p>
<p><b>Milford , CT</b> Eisenhower Park Lexington Lane, East Rutland Rd, Wheelers Farm Rd, Woodruff Rd, Fresh Meadow Road (west), Fresh Meadow Rd, West River Street Route 121 and Oronoque Rd</p>	<p>Foundation work appears to be complete in these areas. Structure installation continues in some areas. Stone and timber mat crane pads remain. 6/7/07</p>	<p>None at this time. 6/7/07</p>	<p>NA</p>
<p>Shelland Street, Plains Road, Naugatuck Ave and Caswell Street</p>	<p>Foundation drilling/pouring continues in these areas. 6/7/07</p>	<p>None at this time. See Dewatering and EC Sections. 6/7/07</p>	<p>NA</p>
<p><b>Woodbridge, CT</b> Pease Road SCCRWA (Glen Dam Reservoir) Dillon Rd to Morris Rd, Cowpath Lane</p>	<p>Foundation drilling/pouring continues in these sections. Stone crane pads remain. 6/7/07</p>	<p>Continue to monitor. See Dewatering and EC Sections. 5/24/07</p>	<p>NA</p>
<p>Salem Rd, Brookwood Dr, JCC, Manville Rd and Rimmon Rd, Center Road</p>	<p>Foundation work has not yet begun, but stone pads have been constructed in these sections. Timber mat crane pads were remain in the wetland areas off Rimmon Rd, Salem Rd and Manville Rd. 6/7/07</p>	<p>Continue to monitor. See Dewatering and EC Sections. 6/7/07</p>	<p>NA</p>
<p><b>Bethany, CT</b> Morris (Hamden) to Hatfield, Downs Road to West Todd (Hamden)</p>	<p>Foundation work has not yet begun, but crane pads have been constructed in these sections. 6/7/07</p>	<p>Continue to monitor. See Dewatering and EC Sections. 6/7/07</p>	<p>NA</p>
<p><b>Hamden, CT</b> Tom Swamp/Arrow Road West Todd Street, Willow St, and</p>	<p>Foundation work has not yet begun, but crane pads have been constructed in</p>	<p>Continue to monitor. See Dewatering and EC Sections. 6/7/07</p>	<p>NA</p>

Areas of Inspection	Observation	Recommended Action	Corrected Action
Brooksvale Ave	have been constructed in these sections. 6/7/07		
Erosion and sediment controls  All work areas	Roots have been retained in most cleared areas to maintain some soil stability. Crews have made good efforts to temporarily stabilize most disturbed areas with hay mulch. When work occurs in or adjacent to wetlands, timber mat crane pads are in place with erosion controls along the edge. 6/7/07	None. Continue to temporarily stabilize disturbed soils as necessary. 6/7/07	NA
<b>Orange, CT</b>  Route 34 and Dogburn Rd	Filter socks, silt fence and/or haybales are in place along the access road and crane pads. Hay mulch is in place on disturbed slopes and soil. Spoil piles appear to be contained on site. 6/7/07	Continue to monitor and maintain controls as necessary. 6/7/07	Mulch is in place on disturbed soils for temporary stabilization.
Russell Ave	Some ruts remain within the ROW here. Soils are too soft to support equipment. 11/20-6/7/07	Stabilize soil (tracks) as it becomes necessary. 11/20-6/7/07	NA at this time
Russell Drive, Sunset Dr, Overland Dr, and Treat Lane	All spoil piles are on liners and remain partially covered with plastic in these sections. The plastic covering should be adjusted in some areas. 2/16-6/7/07	Adjust plastic on spoil piles as needed. 6/7/07	Needs proactive attention when feasible.
Rolling Ridge Road and Hall Dr	The spoil piles here remain uncovered but appear to be contained on site. 2/16-6/7/07	Inactive piles should be covered with plastic when feasible. 2/16-6/7/07	Needs proactive attention when feasible
Racebrook Rd	Silt fence is in need of repair along the edge of the crane pad at the wetland off Racebrook Rd. 3/23- 6/7/07	Repair and maintain controls as necessary. 6/7/07	Needs some attention
Edward Court	Some of the mulch was washed downslope at the	Continue to monitor. Additional stabilization	Needs proactive attention when feasible

Areas of Inspection	Observation	Recommended Action	Corrected Action
Hunting Hill Road	<p>disturbed area, but the haybales and silt sak continue to protect the catch basin here. 2/22-6/7/07</p> <p>The majority of the silt fence remains intact at the matted wetland here. Snow was piled on the fence near the southeastern corner of the mat the week of 3/23. 6/7/07</p>	<p>measures may be necessary here. Re-apply mulch in this area if needed. 2/22-6/7/07</p> <p>Continue to monitor and maintain as necessary. 3/23- 6/7/07</p>	<p>Needs proactive attention when feasible</p>
<b>Milford, CT</b> West River Street	<p>Portions of the wetland have been disturbed outside of the crane pad work area in some locations. Filter socks are in place along the outer edge of disturbance. 6/7/07.</p>	<p>All equipment should remain within the limits of the crane pad/work area and wetland areas restored when feasible. Continue to monitor and maintain as necessary. 6/7/07</p>	<p>Controls are in place along the outer edge of disturbance (new) to prevent potential harm to the adjacent, undisturbed wetland. Wetland areas should be restored when feasible.</p>
Route 121	<p>Silt fence check dams are in disrepair due to previous storm events. The silt fence at the wetland edge is also in need of repair, but this area appears to be stabilizing with vegetation (east). 6/7/07</p>	<p>Continue to monitor and maintain as necessary. 6/7/07</p>	<p>Silt fence needs attention</p>
Wheelers Farm Road	<p>Snow and sediment were piled on the silt fence due to snow clearing (east) 3/19-5/3/07. Silt fence may need to be extended near the wetland, downgradient of the dewatering area here. 3/23-6/7/07. The stockpile near the road is not covered. 4/13-6/7/07</p>	<p>Continue to monitor. Silt fence needs repair. Any remaining sediment needs to be pulled back to the work side of the fence. See Dewatering Section. 3/23-6/7/07. All inactive stockpiles should be covered.6/7/07</p>	<p>Silt fence and stockpiles need attention</p>
Oronoque Road	<p>Spoil piles were noted within the ROW this week. 6/7/07</p>	<p>Continue to monitor. Spoil piles appear to be contained on site. 6/7/07</p>	<p>NA</p>
<b>Woodbridge, CT</b> SCCRWA (Glen Dam Reservoir) Dillon Rd to	<p>Increased grass growth was noted in the recently restored upland area. just</p>	<p>Continue to monitor for stabilization. Re-seed if necessary. 6/7/07</p>	<p>Increased grass growth noted</p>

Areas of Inspection	Observation	Recommended Action	Corrected Action
Morris Rd	restored upland area, just outside the access gate. 6/7/07		
Pease Road	A spoil pile from the foundation drilling was placed on a plastic liner here. 6/7/07	Cover the pile with plastic if necessary. 6/7/07	Spoil pile was placed on a plastic liner
JCC	Silt fence remains along the stream and wetland area. Hydro-seed was applied to the remaining disturbed areas. 6/7/07	Continue to monitor for stabilization and adjust controls as necessary. 6/7/07	Hydro-seed was applied to the remaining disturbed areas
B'Nai Jacob	Mats were used in the wetland where necessary. However, ruts were noted in the upland areas of the ROW here. Soils were too soft to support equipment. Stormwater continues to flow within the large rut located along the edge of ROW. 4/27-6/7/07	Stabilize soil (tracks) as soon as practicable. Use mats where necessary to reduce overall soil disturbance. 6/7/07	Needs attention
Bethany, CT Morris (Hamden) to Hatfield and Downs	Silt fence/haybales are in place along portions of the access road and wetland areas. Three 36" culverts were installed in the access road off Rt. 69 6/7/07	Continue to monitor and adjust controls as work continues here. 6/7/07	Three 36" culverts were installed within the access road to control water flow
	A temporary timber mat bridge is place at the first stream/wetland crossing within the ROW accessed from Route 69. Silt fence and haybales were installed at the crossing and mulch was applied to disturbed stream banks. 6/7/07.	Continue to monitor and adjust controls as work continues here. 6/7/07	A temporary timber mat bridge and erosion controls are in place at the stream crossing. Hay mulch was applied to disturbed soils for temporary stabilization.
	Spoil was removed from the silt fence and erosion controls repaired last week. 6/7/07	Continue to monitor and adjust controls as necessary. 6/7/07	Spoil was removed and silt fence and controls repaired

Areas of Inspection	Observation	Recommended Action	Corrected Action
<p><b>Hamden,CT</b> Tom Swamp Rd/Arrow Rd</p>	<p>Temporary culverts are in place within the access roads here. Stone sediment traps and haybale check dams remain at the outlets. Sediment accumulation was noted within the stone trap at the 2<sup>nd</sup> culvert outlet off Tom Swamp (east). 3/30-6/7/07</p>	<p>Continue to monitor and add/maintain controls as necessary. Remove sediment to restore capacity and function here when needed. 3/30-6/7/07</p>	<p>Needs proactive attention.</p>
<p>West Todd Street</p>	<p>Controls are in place at the water bar and culvert outlets but sediment from past rain events remains in the adjacent upland areas. 6/7/07</p> <p>In approximately three areas, stormwater pooled along the perimeter controls and filtered though as concentrated flow off the ROW (4/27/07). This only occurs during large rain events and wetland resource areas were not affected by this off site flow. 6/7/07</p>	<p>Continue to improve controls at the water bar outlets and stabilize remaining sediment to prevent potential sedimentation off site. 6/7/07</p> <p>Investigate additional solutions to prevent stormwater conveyances off site. Although good efforts were made to control stormwater flow, continue to improve the on-site containment. 6/7/07</p>	<p>Needs proactive attention</p> <p>Good efforts were made but needs additional attention</p>
<p>115-kV underground transmission line</p>	<p>A gap was noted between the haybales of the check dam at the culvert outlet off West Todd (east). Some sediment accumulation from a previous rain event was noted in the adjacent wetland. 6/7/07</p>	<p>Repair and reinforce controls. Carefully removed sediment from wetland if it is greater than 2" in depth. 4/20-6/7/07</p>	<p>Needs attention</p>
<p>115-kV underground transmission line</p>	<p>The overhead access road has been stabilized with stone. Silt fence and haybales remain at the intersection of the access road and Old Lane Rd. 6/7/07</p>	<p>Monitor during large rain events to confirm curb inlet protection is no longer needed. 6/7/07</p>	<p>Monitor during next large rain event</p>

Areas of Inspection	Observation	Recommended Action	Corrected Action
<p>Inland Wetland and Watercourse encroachment and mitigation</p> <p><b>Orange, CT</b> Sunset Drive, Pine Tree Rd (east), Lambert Rd, Russell Ave, Racebrook Rd, and Route 34</p>	<p>The ACOE permit is in hand and approved wetland work continues. 6/7/07</p> <p>Timber mat crane pads remain at the wetland areas here. A stone wetland crossing is in place at Lambert Rd. Approved foundations were installed in the wetland at both Russell Ave and Racebrook Rd. 6/7/07</p>	<p>Follow general guidelines of the permit whenever work in wetlands occurs. 6/7/07</p> <p>Continue to monitor. 6/7/07</p>	<p>NA</p> <p>NA</p>
<p>Hunting Hill Rd &amp; <b>Milford, CT</b> Rt 121</p>	<p>Timber mat crane pads remain adjacent to/in wetlands in these sections. 6/7/07</p>	<p>Continue to monitor. Install controls as necessary. 6/7/07</p>	<p>NA at this time</p>
<p>West River Street</p>	<p>Portions of the wetland have been disturbed outside of the crane pad work area in some locations. Controls are in place. 6/7/07</p>	<p>Continue to monitor. See EC Section. 6/7/07</p>	<p>See EC Section</p>
<p>West River Street and Eisenhower Park</p>	<p>A stone access road was installed within the wetland accessed from West River Street. Timber mat crane pads remain within the wetland areas in these sections. 6/7/07</p>	<p>Continue to monitor. Adjust controls as necessary. 6/7/07</p>	<p>NA at this time.</p>
<p>East Rutland Road (western access point)</p>	<p>A stone access road remains at the wetland crossing off East Rutland. An existing stone culvert was already in place here. 6/7/07</p>	<p>Continue to monitor. Install controls as necessary. 6/7/07</p>	<p>NA at this time.</p>
<p><b>Woodbridge, CT</b> Pease Road/JCC/B'Nai Jacob</p>	<p>Mats remain in the potential wetland area near Pease Road. 6/7/07</p>	<p>Continue to monitor. The contractor states that this wetland was removed from the most recent version of the D&amp;M plan, but flags were staked in the field. 6/7/07</p>	<p>NA at this time</p>

Areas of Inspection	Observation	Recommended Action	Corrected Action
<p>Cow Path Lane, Salem Rd, Rimmon Rd, Ansonia Rd and Manville Rd</p> <p><b>Hamden, CT</b></p> <p>Tom Swamp/ Arrow Road</p> <p>115-kV underground transmission line</p>	<p>The wetland areas near the JCC and B’Nai Jacob have been cleared as a result of the permitted re-location of the ROW. Stone access roads were constructed through portions of the wetlands in these sections. 6/7/07</p> <p>Timber mat crane pads remain within the wetlands in these sections. 6/7/07</p> <p>Boulders and silt fence were placed across the ATV path in an effort to prevent further (non project related) wetland disturbance in the Jepp Brook area. 3/30-6/7/07</p> <p>The overhead access road was stabilized, but the water within the wetland remains turbid. 6/7/07</p>	<p>Continue to monitor. Adjust controls as necessary. 6/7/07</p> <p>Continue to monitor. 6/7/07</p> <p>None at this time. 6/7/07.</p> <p>Monitor during next large rain event. Evaluate sediment accumulation within adjacent wetland. Carefully remove sediment from the wetland is greater than 2” in depth. 6/15/07</p>	<p>NA at this time</p> <p>NA at this time</p> <p>NA at this time</p> <p>Needs evaluation</p>
<p>State species of concern, threatened and endangered species.</p>	<p>According to the D&amp;M plan, Wood Turtles are known to occur near the Wepawaug River at Eisenhower Park. Active work is currently occurring in this area. 4/5-6/7/07</p>	<p>Since wood turtles are no longer dormant and active work is occurring here, field crews should receive the appropriate training in the recognition and removal of individual wood turtles from the construction area. 4/5-6/7/07</p>	<p>Contractors stated that field crews have received the appropriate training and sweeps are occurring.</p>
<p>Vegetative clearing or stabilization</p> <p>All active roads</p>	<p>Vegetative clearing was noted within the ROW. Most species were invasive and were removed. “Hedgerows”, including cedars and similar short tree species were retained along the</p>	<p>Continue to retain appropriate vegetation for stabilization. Retain as much vegetation as possible for screening. Confirm that clearing/cutting is limited</p>	<p>NA</p>

Areas of Inspection	Observation	Recommended Action	Corrected Action
<p><b>Orange, CT</b> Orange Center Rd, Sunset Dr, Ridge Rd, Russell Ave, Hall Drive, Rolling Ridge Rd, Overland Dr, Hunting Hill Place, Lambert Rd, and Route 34</p>	<p>were retained along the ROW where feasible. Select shrubs, especially those adjacent to wetlands, also remain in most areas. 6/7/07</p> <p>Wood chips are in place along the upland portions of the cleared ROW in these sections. 6/7/07</p> <p>Wood chips near the cul-de-sac off Hunting Hill Place are currently piled in a “depression” in the ROW and other piles were noted off Ridge Road and Route 152. 1/11-6/7/07</p>	<p>only to areas defined in D&amp;M plan. Provide as much buffer as possible for homeowners. 6/7/07</p> <p>Continue to maintain a depth of 3” or less so vegetative growth is not inhibited. 6/7/07</p> <p>Piles need to be either removed from the ROW or spread in appropriate upland areas to a depth of 3” or less. 1/11-6/7/07</p>	<p>Wood chips were spread in appropriate locations.</p> <p>Needs attention when feasible.</p>
<p><b>Milford , CT</b> East Rutland Rd, Naugatuck Ave, Caswell Street, Wheelers Farm Road, Plains Road to Oronoque Rd, Lexington Lane, Woodruff Road, and Route 121, and West River Street</p>	<p>Clearing appears to be complete in these sections at this time. 6/7/07</p>	<p>None at this time. 6/7/07</p>	<p>NA</p>
<p><b>Woodbridge, CT</b> B’Nai Jacob</p>	<p>Major clearing has occurred in this section due to the relocation of the ROW here. 6/7/07.</p>	<p>Continue to monitor. Add controls as necessary. 6/7/07</p>	<p>NA</p>
<p>Pease Road/JCC Bypass, SCCRWA (Glen Dam Reservoir) Dillon Rd to Morris Rd Manville Road, Rimmon Rd (west), Salem Rd, Brookwood Dr, Center Rd and Cowpath Lane</p>	<p>Clearing appears to be complete in these sections at this time. 6/7/07</p>	<p>None at this time. 6/7/07</p>	<p>Efforts were noted to retain shrubs and low growth.</p>
<p><b>Bethany, CT</b> Morris to Hatfiled, Downs Rd, Hoadley Rd and Raccio Dr</p>	<p>Major clearing appears to be complete in these sections at this time. Some clearing for access and vegetative management continues. 6/7/07</p>	<p>Continue to monitor. 6/7/07</p>	<p>Efforts were noted to retain shrubs and low growth</p>

Areas of Inspection	Observation	Recommended Action	Corrected Action
<p><b>Hamden, CT</b> Tom Swamp Rd/Arrow Rd, West Todd Street, Brooksvale Ave, and Willow Street</p>	<p>Clearing appears to be complete in these sections at this time. Small trees and shrubs were retained where feasible. 6/7/07</p>	<p>Continue to monitor. 6/7/07</p>	<p>Efforts were noted to retain shrubs and low growth</p>
<p>Dewatering <b>Orange, CT</b> Route 34 and Dogburn Road (all other area are inactive at this time)</p>	<p>Dewatering containment remains within the ROW in these sections. This includes silt fence and haybale corrals and dewatering basins. 6/7/07</p>	<p>Continue to monitor and adjust controls as necessary. 6/7/07</p>	<p>Dewatering areas installed proactively.</p>
<p><b>Woodbridge, CT</b> Pease Rd/JCC, Manville Rd, Salem Rd, Brookwood Dr, Cowpath Lane, and Country Ct</p>	<p>Dewatering basins remain in place at the proposed drilling sites. 6/7/07</p>	<p>Continue to monitor and adjust controls as necessary. 6/7/07</p>	<p>Dewatering containment areas were installed proactively.</p>
<p><b>Milford, CT</b> East Rutland (eastern access), Fresh Meadow Road, Route 121, Woodruff Rd, Naugatuck Ave Lexington Ln, Wheelers Farm Rd, Caswell St, and Plains to Oronoque Rd.</p>	<p>Dewatering basins remain in place at new and proposed drilling sites. 6/7/07</p>	<p>Continue to monitor and adjust controls as necessary. 6/7/07</p>	<p>Dewatering containment areas were installed proactively.</p>
<p><b>Hamden and Bethany, CT</b> Tom Swamp Rd/Arrow Rd and West Todd Street, Morris to Hatfield</p>	<p>Dewatering basins remain at new and proposed drilling sites. 6/7/07</p>	<p>Continue to monitor and adjust controls as necessary. 6/7/07</p>	<p>Dewatering containment areas were installed proactively.</p>
<p>Blasting</p>	<p>No blasting is proposed at this time. 6/7/07</p>	<p>None</p>	<p>NA</p>
<p>Spills, soils and material storage.</p>	<p>Contractor receiving yard is set up near Shelland St. in Milford. This also appears to be used for Segment 3 construction. 6/7/07</p>	<p>In general, store materials and equipment appropriately. Ensure that vehicles are equipped with spill kits. All construction vehicles should be parked at least 100 feet from a wetland or waterbody when feasible. 6/7/07</p>	<p>NA</p>
<p>Additional Observations</p>	<p>Non-project related activity was noted within the ROW off Sunset Dr. A trench was dug near the first structure and a</p>	<p>Noted for the record. 1/18-6/7/07</p>	<p>NA</p>

Areas of Inspection	Observation	Recommended Action	Corrected Action
	pipe appears to have been installed to divert water from an unknown location. 1/18-6/7/07		

**Next likely scheduled inspection:** Friday June 15, 2007

I have personally examined and am familiar with the information submitted in this document and all attachments and certify that based on reasonable investigation, including my inquiry of those individuals responsible for obtaining the information, the submitted information is true, accurate and complete to the best of my knowledge and belief, and I understand that any false statements made in this document or its attachments may be punishable as a criminal offense in accordance with Section 22a-6 under Section 53a-157 of the Connecticut General Statutes.

**Field Inspector:** Matt Kelly, BSC Group

**Reviewer:** Lee Curtis, BSC Group




Oronoque Road (Milford): Foundation drilling/pouring is complete in this section.



Oronoque Road (Milford): Spoil piles were placed within the limits of the crane pad work area and appear to be contained on site.



West River Street (Milford): Installation of structure #3836. Proper control measures (timber mats, hay bales and filter socks) remain in place.



Route 69 (Bethany): Access road/crane pad construction continues in this section. Proper control measures are being installed as work progresses.



Route 69 (Bethany): Stone was added to portions of the access road and haybales and silt fence are in place at the wetland crossing.



Route 34 (Orange): Initial stages of line installation.



Dogburn Road (Orange): Foundation drilling continues in this section. Proper erosion controls are in place.



Dogburn Road (Orange): Dewatering basins remain intact and spoil piles appear to be contained on site.