

July 1, 2015

Melanie A. Bachman  
Acting Executive Director  
Connecticut Siting Council  
10 Franklin Square  
New Britain, CT 06051

Re: **EM-VER-011-140114 – Cellco Partnership d/b/a Verizon Wireless  
1021 Blue Hills Avenue, Bloomfield, Connecticut**

Dear Ms. Bachman:

On June 29, 2014, the Siting Council acknowledged receipt of Cellco's notice of intent to modify its telecommunications facility at 1021 Blue Hills Avenue in Bloomfield, Connecticut. The modifications involved the replacement of certain antenna and installation of remote radio heads and a fiber optic antenna cable.

As a condition of that acknowledgement, Cellco was required to provide the Council with a letter stating that the modifications referenced in the structural report were completed. Attached is a Professional Engineer's Certification Letter verifying that the tower and foundation modifications were installed. All construction associated with these modifications has now been completed.

If you have any questions please do not hesitate to contact me.

Sincerely,



Kenneth C. Baldwin

Copy to:  
Tim Parks

June 29, 2015

**Mr. Tim Parks**

Verizon Wireless  
99 East River Drive  
East Hartford, Connecticut 06108

**Re: Tower Modification Certification**

**Project:** Verizon Cottage Grove  
1021 Blue Hills Avenue, Bloomfield, CT

**Tower Owner:** SBA Communications  
5900 Broken Sound Pkwy NW, Boca Raton, FL

**Engineer:** FDH Engineering  
6521 Meridien Drive, Raleigh, NC

**Centek Project No.:** 14055.028

**CSC Exempt Mod Reference No.:** EM-VER-011-140114

Dear Mr. Parks,

We are providing this "Existing Telecommunications Facility Tower Certification Letter" with regard to the antenna upgrade by Verizon Wireless at the above referenced project.

The following are the basis for substantiating compliance with the FDH Engineering structural analysis report (FDH Project No. 13SFTM1400 (R1)) dated November 15, 2013:

- Review of the FDH structural analysis report dated 11/15/2013.
- Field observations by Centek personnel of the coax installation on 05/29/2015 which determined all coax lines were installed in general compliance with the recommendations of the structural analysis report prepared by FDH Engineering on 11/15/2013.

The structural analysis prepared by FDH Engineering demonstrates the tower will not exceed 100 percent of the post construction structural rating. The work under this Contract has been reviewed and found, to the Engineer's best knowledge, information and belief, to be completed in general compliance with the documents referenced above. This certification is not a review of the adequacy or effectiveness of the referenced structural analysis.

Sincerely,



Carlo F. Centore, PE  
Principal - Structural Engineer

