

Fax 860-827-2950

TO: Mr. S. Derek Phelps
Executive Director
State of Connecticut

FROM: Harold W. Borden, Esq.
PSEG Power LLC

RE: Docket F-2005 Connecticut Siting Council Review of the Ten-
Year Forecast of Connecticut Electric Loads and Resources

DATE: May 26, 2005

MESSAGE:

Attached is our response to your Interrogatories.
The original is being sent to you by overnight mail.

CONNECTICUT SITING COUNCIL
MAY 26 2005
RECEIVED

Harold W. Borden
Vice President and General Counsel

PSEG Power LLC
80 Park Plaza, 25B, Newark, NJ 07102-4194
tel: 973 430 6868 fax: 973.643.6026



May 26, 2005
RECEIVED
MAY 26 2005
CONNECTICUT
SITING COUNCIL

Mr. S. Derek Phelps
Executive Director
State of Connecticut
Ten Franklin Square
New Britain, CT 06051

RE: DOCKET NO. F-2005 – Connecticut Siting Council Review of the Ten-Year Forecast of Connecticut Electric Loads and Resources

Dear Mr. Phelps,

Pursuant to your letter of April 6, 2005 in the above referenced docket, attached hereto are the responses of PSEG Power Connecticut to the questions raised in that letter.

Question 1: "Listed below are the data from the April 2005 ISO-New England Seasonal Claimed Capability Report. Does PSEG Power Connecticut LLC (PSEG) agree with these numbers? If no, provide the correct data.

Net Capability - MW	Summer	Winter
Bridgeport Harbor 2	130.49 <i>Agree</i>	147.51 <i>Agree</i>
Bridgeport Harbor 3	372.20 <i>Agree</i>	370.37 <i>Agree</i>
Bridgeport Harbor 4	9.92 <i>Agree</i>	14.72 <i>Agree</i>
New Haven Harbor	447.89 <i>Agree</i>	454.64 <i>Agree</i>

Question 2: How does PSEG compute seasonal claimed capability?

Seasonal claimed capability is computed in accordance with the ISO - NE / NEPOOL Seasonal Claimed Capability Demonstration Test criteria. In the summer season, BHS 2, 3 and NHHS are subjected to an 8-hour test, the average demonstrated capability of the 8-hour period being the result as listed in the table in question 1. In the winter the test is a 4-hour duration with the average demonstrated capability for the 4-hour period being the result.

For BHS 4, the summer and winter tests are two hours in duration.

Question 3: Do any of PSEG's generating facilities in Connecticut have black start Capability?

No.

Question 4: Does PSEG have any planned upgrades and/or modifications to any of the above power plants?

Yes, we are in the early stages of planning to add some new equipment to enhance emissions controls on Bridgeport Harbor Unit. 3.

If you have any further questions, please do not hesitate to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Howard Gordon", with a long horizontal flourish extending to the right.