


Dominion Nuclear Connecticut, Inc.
Millstone Power Station
Rope Ferry Road
Waterford, CT 06385



Serial No.: RA-05-022
MPS Lic/DF: R0
Docket No.: F-2005

MAY 19 2005

Mr. S. Derek Phelps
Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051



Re: Docket No. F-2005 – Response to Pre-Hearing Interrogatories

Dear Mr. Phelps:

This letter forwards the responses of Dominion Nuclear Connecticut, Inc. to the pre-hearing interrogatories contained in a letter from the Connecticut Siting Council dated May 10, 2005.¹ The interrogatories and DNC's responses are provided in Attachment 1. In accordance with your instructions, the original and 20 copies are enclosed.

Please contact Mr. Daniel A. Weekley, Director, Northeast Government Affairs at (860) 444-5271 with questions or if additional information is needed.

Sincerely,


J. Alan Price
Site Vice President – Millstone

Attachment: as stated

cc: Daniel A. Weekley
Lillian M. Cuoco, Esq.
Kenneth C. Baldwin, Esq.

¹ Letter from S. Derek Phelps, Connecticut Siting Council, to J. Alan Price, "Docket No. F-2005 – Connecticut Siting Council Review of the Ten-Year Forecast of Connecticut Electric Loads and Resources," dated May 10, 2005.

Attachment 1

Docket No. F-2005 – Response to Pre-Hearing Interrogatories
Connecticut Siting Council Review of the Ten-Year Forecast of Connecticut
Electric Loads and Resources

Dominion Pre-Hearing Interrogatories, Set One

1. Listed below are the data from the May 2005 ISO-New England Seasonal Claimed Capability Report (rounded to two decimal places). Does Dominion Nuclear Connecticut, Inc. (Dominion) agree with the numbers listed below? If no, provide the most up to date data.

Net Capacity – MW	Summer	Winter
Millstone Point 2	882.14	881.96
Millstone Point 3	1155.00	1155.48

Answer: Dominion agrees with the numbers.

2. How does Dominion compute seasonal claimed capacity?

Answer: Dominion computes seasonal claimed capability in accordance with the process contained in "ISO-NE Manual 20, Installed Capacity," current revision.

3. Describe Dominion's effort for license renewal for both Unit 2 and Unit 3.

Answer: The license renewal applications for Millstone Power Station, Units 2 and 3 were submitted to the U.S. Nuclear Regulatory Commission on January 22, 2004. The NRC is currently reviewing the applications, and has issued a draft Environmental Impact Statement and a draft Safety Evaluation Report. The NRC is expected to complete its review of the applications in July 2006. Renewed operating licenses would allow Unit 2 and Unit 3 to continue to operate until 2035 and 2045, respectively.

4. Are any further modifications and/or upgrades to the Millstone plant planned?

Answer: Plant projects that may potentially impact power output are being evaluated for Units 2 and 3. However no definitive plans are in place at this time for modifications and/or upgrades that would increase power output.