

The United Illuminating Company  
Peak Load - Historical Forecasts and Actuals

Years	1983	1984	1985	1986	1987	1988	1989	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	Actual	
	Forecasted Peak Load	Peak Load																						
1983	933																							970
1984	946	961																						989
1985	958	988	974																					1,019
1986	976	959	983	987																				986
1987	994	966	990	997	1,019																			1,073
1988	1,013	982	1,004	1,004	1,000	1,080																		1,132
1989	1,031	992	1,021	995	1,004	1,079	1,132																	1,093
1990	1,046	1,010	1,038	1,006	1,012	1,090	1,150	1,134																1,055
1991	1,062	1,030	1,057	1,013	1,007	1,087	1,151	1,134	1,070															1,149
1992	1,078	1,051	1,077	1,027	1,023	1,080	1,158	1,142	1,083															1,034
1993		1,069	1,094	1,041	1,042	1,085	1,159	1,142	1,091		1,130													1,115
1994		1,089	1,113	1,051	1,059	1,090	1,159	1,144	1,095		1,134	1,130												1,131
1995		1,110		1,089	1,087	1,087	1,168	1,155	1,102		1,144	1,139	1,121											1,157
1996		1,130		1,115	1,114	1,094	1,174	1,162	1,112		1,160	1,148	1,128	1,167										1,045
1997		1,153		1,142	1,138	1,105	1,185	1,173	1,121		1,177	1,163	1,130	1,164	1,151									1,173
1998		1,175		1,166	1,170	1,115	1,193	1,182	1,136		1,186	1,181	1,134	1,167	1,155	1,194								1,143
1999		1,196		1,192	1,188	1,133	1,202	1,193	1,144		1,198	1,207	1,141	1,175	1,171	1,205	1,157							1,273
2000		1,217		1,218	1,207	1,144	1,210	1,204	1,150		1,209	1,222	1,150	1,183	1,192	1,222	1,177	1,271						1,153
2001		1,236		1,248	1,231	1,158	1,216	1,206	1,153		1,224	1,242	1,161	1,191	1,200	1,235	1,186	1,281	1,157					1,318
2002		1,260		1,279	1,255	1,173	1,255	1,213	1,155		1,241	1,268	1,172	1,200	1,210	1,245	1,195	1,291	1,168	1,195				1,300
2003		1,280		1,305	1,282	1,189	1,236	1,223	1,163		1,259	1,286	1,182	1,208	1,218	1,254	1,204	1,300	1,183	1,198	1,221			1,274
2004				1,335	1,311	1,201	1,250	1,236	1,166		1,278	1,300	1,186	1,217	1,229	1,266	1,213	1,310	1,198	1,204	1,229	1,235		1,201
Years																								
1983	4.0%																							
1984	5.6%	4.0%																						
1985	6.4%	3.1%	4.6%																					
1986	1.0%	2.8%	0.3%	-0.1%																				
1987	7.9%	11.1%	8.4%	7.6%																				
1988	11.7%	15.3%	12.7%	12.7%	13.2%	4.8%																		
1989	6.0%	10.2%	7.1%	9.8%	8.9%	1.3%	-3.4%																	
1990	0.9%	4.5%	1.6%	4.9%	4.2%	-3.2%	-8.3%	-7.0%																
1991	8.2%	11.6%	8.7%	13.4%	14.1%	5.7%	-0.2%	1.3%	7.4%															
1992	-4.1%	-1.6%	-4.0%	0.7%	1.1%	-4.3%	-10.7%	-9.5%	-4.5%															
1993	4.3%	1.9%	7.1%	7.0%	2.7%	-3.8%	-2.4%	2.2%		-1.3%														
1994	3.9%	1.6%	6.6%	6.8%	3.8%	-2.4%	-1.1%	3.3%		-0.3%	0.1%													
1995	4.2%	6.2%	6.4%	6.4%	6.4%	-0.9%	0.2%	5.0%		1.1%	1.6%	3.2%												
1996	-7.6%	-5.3%	-6.2%	-6.2%	-4.5%	-11.0%	-10.1%	-6.1%		-9.9%	-9.0%	-7.4%	-10.5%											
1997	1.7%	2.7%	3.1%	6.2%	-1.0%	0.0%	4.7%			-0.3%	0.9%	3.8%	0.8%	1.9%										
1998	-2.7%	-2.0%	-2.3%	-2.3%	-2.3%	-4.2%	-3.3%	-3.6%		-3.2%	-3.2%	0.6%	-2.1%	-1.0%	-4.3%									
1999	6.4%	6.8%	7.2%	12.4%	5.9%	6.7%	11.3%			6.3%	5.5%	11.6%	8.3%	8.7%	5.6%	10.0%								
2000	-5.3%	-5.3%	-4.5%	0.8%	-4.7%	-4.2%	0.3%			-4.6%	-5.6%	-4.2%	0.3%	-2.5%	-3.3%	-5.6%	-2.0%	-9.3%						
2001	6.6%	5.6%	7.1%	13.8%	8.4%	9.3%	14.3%			7.7%	6.1%	13.5%	10.7%	9.8%	6.7%	11.1%	2.9%	13.9%						
2002	3.2%	1.6%	3.6%	10.8%	6.1%	7.2%	12.6%			4.8%	-5.0%	10.9%	8.3%	7.4%	4.4%	8.8%	0.7%	11.3%	8.8%					
2003	-0.4%	-2.4%	-0.6%	7.2%	3.1%	4.2%	9.6%			1.2%	-0.9%	7.8%	5.5%	4.6%	1.6%	5.8%	-2.0%	7.7%	6.4%					
2004		-10.0%	-8.4%	0.0%	-3.9%	-2.8%	3.0%			-6.0%	-7.6%	1.3%	-1.3%	-2.3%	-5.1%	-1.0%	-8.3%	0.3%	-0.2%					

Note: Long Range forecasts produced in 1983 and 1985 are 10 year forecasts only.

Source:  
Forecasted GWH sales are from the 1983-2000 Siting Council Reports.  
Forecasted GWH sales data was not available before 1983.