



**Northeast
Utilities System**

107 Selden Street, Berlin, CT 06037

Northeast Utilities Service Company
P.O. Box 270
Hartford, CT 06141-0270
(860) 665-5000
www.nu.com

June 14, 2006

Mr. S. Derek Phelps
Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

RECEIVED
JUN 14 2006

CONNECTICUT
SITING COUNCIL

Re: Docket F-06 - Connecticut Siting Council Review of 2006 Forecasts of Electric Loads and Resources

Dear Mr. Phelps:

This letter provides the response to requests for the information listed below.

Response to HD-01 Late Filed Exhibits dated 06/01/2006
LF-001

Very truly yours,

A handwritten signature in cursive script, appearing to read "Paula M. Taupier".

Paula M. Taupier
Manager
Regulatory Policy - Transmission
NUSCO
As Agent for CL&P

PMT/dd
cc: Service List

The Connecticut Light and Power Company
Docket No. F-06

Late Filed Exhibit HD-01
Dated: 06/01/2006
Q-LF-001
Page 1 of 2

Witness: Allen W. Scarfone
Request from: Connecticut Siting Council

Question:
Provide a graph of 2005 power flows on the Norwalk Harbor-to-Northport 138 kV transmission line (also called the "1385 line").

Response:

The attached chart identifies the number of hours, magnitude, and direction of power flow on the underwater 138-kV Norwalk Harbor (CT) - Northport (NY) 1385 line for 2005. The chart indicates that in 2005 there was not a predominant flow of power in either direction.

138-kV Norwalk Harbor (CT) - Northport (NY) 1385 line
 (2005 Power Flow Data)

