



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@po.state.ct.us

www.ct.gov/csc

March 30, 2006

Andrew W. Lord, Esq.
Murtha Cullina LLP
CityPlace I, 29th Floor
185 Asylum Street
Hartford, CT 06103-3469

RE: **DOCKET NO. F-2006** – Connecticut Siting Council Review of the Ten-Year Forecast of Connecticut Electric Loads and Resources

Dear Attorney Lord:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than April 20, 2006. To help expedite the Council's review, please file individual responses as soon as they are available.

Please forward an original and 20 copies to this office. In accordance with the State Solid Waste Management Plan, the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. A list of parties and intervenors is enclosed. Fewer copies of bulk material may be provided as appropriate.

Yours very truly,

S. Derek Phelps
Executive Director

SDP/MP

c: Council Members
Parties and Intervenors
Judith E. Lagano, NRG Energy Inc.
Raymond G. Long, NRG Energy Inc.

Docket F-2006
NRG Pre-Hearing Interrogatories, Set One

1. Listed below are the data from the March 2006 ISO-NE Seasonal Claimed Capability Report. Does NRG Northeast Generating, LLC (NRG) agree with these numbers? If no, provide the correct data.

Net Capability - MW	Summer	Winter
Branford 10	15.84	20.95
Cos Cob 10	17.88	22.78
Cos Cob 11	18.24	23.23
Cos Cob 12	18.44	23.34
Devon 11	29.58	39.10
Devon 12	29.24	38.45
Devon 13	30.76	39.76
Devon 14	29.75	40.33
Franklin Drive 10	15.42	20.53
Middletown 1	0.00	0.00
Middletown 10	17.12	22.02
Middletown 2	117.00	120.00
Middletown 3	236.00	245.00
Middletown 4	400.00	402.00
Montville 10 & 11	5.30	5.35
Montville 5	81.00	81.59
Montville 6	407.40	409.91
Norwalk Harbor 1	162.00	164.00
Norwalk Harbor 10	11.93	17.13
Norwalk Harbor 2	168.00	172.00
Torrington Terminal 10	15.64	20.75

2. How does NRG compute seasonal claimed capability?
3. Are Devon 7 and Devon 8 still considered deactivated reserve?
4. Do any NRG generating facilities in Connecticut have black start capability? If yes, specify which ones.
5. Does NRG have any planned upgrades and/or modifications to any of the above power plants?
6. Discuss clean coal technology and the possibility of NRG bringing this technology into Connecticut.
7. Review the 2005 report titled *Connecticut Siting Council Review of the Forecast of Connecticut Electric Loads and Resources*, and provide any comments that may be helpful in the preparation of the 2006 report. For example, are there any new topics that NRG believes should be addressed in the 2006 report that were not covered in the 2005 report?