



STATE OF CONNECTICUT  
CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)

Internet: [ct.gov/csc](http://ct.gov/csc)

Daniel F. Caruso  
Chairman

April 18, 2007

Andrew W. Lord, Esq.  
Murtha Cullina LLP  
CityPlace I, 29<sup>th</sup> Floor  
185 Asylum Street  
Hartford, CT 06103-3469

RE: **DOCKET NO. F-2007** – Connecticut Siting Council Review of the Ten-Year Forecast of Connecticut Electric Loads and Resources

Dear Attorney Lord:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than May 9, 2007. To help expedite the Council's review, please file individual responses as soon as they are available.

Please forward an original and 20 copies to this office. In accordance with the State Solid Waste Management Plan, the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. A list of parties and intervenors is enclosed. Fewer copies of bulk material may be provided as appropriate.

Yours very truly,

S. Derek Phelps  
Executive Director

SDP/MP

c: Council Members  
Parties and Intervenors  
Judith E. Lagano, NRG Energy Inc.  
Raymond G. Long, NRG Energy Inc.

**Docket F-2007**  
**NRG Pre-Hearing Interrogatories, Set One**

1. Listed below are the data from the April 2007 ISO-NE Seasonal Claimed Capability Report. Does NRG Northeast Generating, LLC (NRG) agree with these numbers? If no, provide the correct data.

<b>Net Capability - MW</b>	<b>Summer</b>	<b>Winter</b>
<b>Branford 10</b>	15.84	20.95
<b>Cos Cob 10</b>	17.18	22.08
<b>Cos Cob 11</b>	18.24	23.23
<b>Cos Cob 12</b>	18.44	23.34
<b>Devon 10</b>	13.98	15.98
<b>Devon 11</b>	29.58	39.10
<b>Devon 12</b>	29.24	38.45
<b>Devon 13</b>	30.76	39.76
<b>Devon 14</b>	29.75	40.33
<b>Franklin Drive 10</b>	15.42	20.53
<b>Middletown 10</b>	17.12	22.02
<b>Middletown 2</b>	117.00	120.00
<b>Middletown 3</b>	236.00	245.00
<b>Middletown 4</b>	400.00	402.00
<b>Montville 10 &amp; 11</b>	5.30	5.35
<b>Montville 5</b>	81.00	81.59
<b>Montville 6</b>	407.40	409.91
<b>Norwalk Harbor 1</b>	162.00	164.00
<b>Norwalk Harbor 10</b>	11.93	17.13
<b>Norwalk Harbor 2</b>	168.00	172.00
<b>Torrington Terminal 10</b>	15.64	20.75

2. How does NRG compute seasonal claimed capability?
3. Are Devon 7 and Devon 8 still considered deactivated reserve? What is the status of their return to service?
4. Do any NRG generating facilities in Connecticut have black start capability? If yes, specify which ones.
5. Does NRG have any planned upgrades and/or modifications to any of the above power plants?
6. Review the 2006 report titled *Connecticut Siting Council Review of the Forecast of Connecticut Electric Loads and Resources*, and provide any comments that may be helpful in the preparation of the 2007 report. For example, are there any new topics that NRG believes should be addressed in the 2007 report that were not covered in the 2006 report?