



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

Internet: ct.gov/csc

Daniel F. Caruso
Chairman

June 11, 2008

Daniel A. Weekley
Managing Director of Northeast Government Affairs
Dominion Resources Services, Inc.
Rope Ferry Road (Route 156)
Waterford, CT 06385

RE: **DOCKET NO. F-2008** – Connecticut Siting Council Review of the Ten-Year Forecast of Connecticut Electric Loads and Resources

Dear Mr. Weekley:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than June 25, 2008. To help expedite the Council's review, please file individual responses as soon as they are available.

Please forward an original and 20 copies to this office. In accordance with the State Solid Waste Management Plan, the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. A list of parties and intervenors is enclosed. Fewer copies of bulk material may be provided as appropriate.

Yours very truly,

S. Derek Phelps
Executive Director

SDP/MP

c: Council Members
Parties and Intervenors
Lillian M. Cuoco, Esq., Senior Counsel, Dominion Resources Services Inc.
Kenneth C. Baldwin, Esq., Robinson & Cole LLP

Docket F-2008
Dominion Pre-Hearing Interrogatories

1. Listed below are the data from the June 2008 ISO-New England Seasonal Claimed Capability Report (rounded to two decimal places). Does Dominion Nuclear Connecticut, Inc. (Dominion) agree with the numbers listed below? If no, provide the most up to date data.

Net Capability - MW	Summer	Winter
Millstone Point 2	876.92	878.41
Millstone Point 3	1144.24	1146.93

2. How does Dominion compute seasonal claimed capability?
3. In Dominion's 2008 Forecast Report dated February 29, 2008, Dominion notes that it is seeking approval from the Nuclear Regulatory Commission to increase the output of Millstone No. 3 by approximately 80 megawatts. Explain how this additional power output would be achieved. Would this require any upgrades to the plant?