

WHITMAN BREED ABBOTT & MORGAN LLC  
ATTORNEYS AT LAW

500 WEST PUTNAM AVENUE  
P.O. Box 2250  
GREENWICH, CONNECTICUT 06830

203-869-3800  
TELECOPIER: 203-869-1951

WRITER'S E-MAIL ADDRESS:  
[amacleod@wbamct.com](mailto:amacleod@wbamct.com)

ORIGINAL  
RECEIVED  
JUL 3 - 2008

CONNECTICUT  
SITING COUNCIL

WRITER'S DIRECT DIAL NUMBER:  
(203) 862-2458

ORIGINAL

July 2, 2008

By Electronic and Overnight Mail

Mr. S. Derek Phelps  
Executive Director  
Connecticut Siting Council  
Ten Franklin Square  
New Britain, CT 06051


Re: Docket F-2008 - 2008 Ten Year Forecast Of Electric Loads And Resources

Dear Mr. Phelps:

On behalf of ISO New England Inc. ("ISO"), I am enclosing herewith an original and fifteen copies of ISO's Response to Interrogatories CEAB 29 and 30. The enclosed document and this cover letter are also being filed with the Siting Council and distributed to the service list electronically today.

Please contact me if you have any questions or need additional information.

Sincerely,



Anthony M. Macleod

AMM:dcs  
Enclosures

cc: Kevin Flynn, Esq.  
Mr. Eric Johnson  
Mr. David Ehrlich  
Service List

**STATE OF CONNECTICUT  
CONNECTICUT SITING COUNCIL**

**ISO New England Inc.  
Docket F-2008**

**Witness: David Ehrlich  
Page 1 of 1**

**Response to CEAB Interrogatory 29**

**CEAB-29      Please explain why the CT value for the 2007 actual energy from the CELT 2008 of 33,947 GWH is 2.5% higher than the sum of the 2007 actual net electrical energy output requirements as reported by CL&P, UI, and CMEEC.**

**Response:**      For 2007, the ISO energy of 33,947 GWH for Connecticut is approximately 1.9% higher than the total of the energy outputs reported by CL&P (25,185 GWH), UI (6,119 GWH) and CMEEC (2,010 GWH ). The ISO energy value for Connecticut is based on Revenue Quality Metering of all generation and tie lines within Connecticut and the ISO control area. Without knowing how the utilities calculated their actual net electrical energy output, the ISO cannot explain the difference.

**STATE OF CONNECTICUT  
CONNECTICUT SITING COUNCIL**

ISO New England Inc.

Witnesses: David Ehrlich,  
Frank Mezzanotte, and Robert Ethier  
Page 1 of 1

Docket F-2008

**Response to CEAB Interrogatory 30**

**CEAB-30** Please submit the following documents for the record in this proceeding:

- a. 2008 ISO Load Forecast Reports
- b. 2008 CELT Report,
- c. System Studies regarding NEEWS and other CT transmission projects
- d. FCA1 results

Response:

a. The 2008 Load Forecast is located at:  
[http://www.iso-ne.com/trans/celt/fsct\\_detail/index.html](http://www.iso-ne.com/trans/celt/fsct_detail/index.html)

b. The 2008 CELT Report is located at:  
<http://www.iso-ne.com/trans/celt/report/index.html>

c. Publicly available NEEWS reports are located at:

[http://www.iso-ne.com/trans/rsp/2008/a\\_snetr-neews\\_needs\\_report.pdf](http://www.iso-ne.com/trans/rsp/2008/a_snetr-neews_needs_report.pdf)

[http://www.iso-ne.com/trans/rsp/2008/news\\_options\\_final\\_redacted.pdf](http://www.iso-ne.com/trans/rsp/2008/news_options_final_redacted.pdf)

d. The results from the first Forward Capacity Auction, as filed with the Federal Energy Regulatory Commission on March 3, 2008 in Docket No. ER08-633-000 are located at:  
<http://www.iso-ne.com/regulatory/ferc/filings/2008/mar/index.html>