



STATE OF CONNECTICUT
CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051
Phone: (860) 827-2935 Fax: (860) 827-2950
E-Mail: siting.council@ct.gov
www.ct.gov/csc

VIA ELECTRONIC MAIL

April 8, 2016

James R. Morrissey, Esq.
UIL Holdings Corporation
157 Church Street, 16th Floor
New Haven, CT 06510

RE: PETITION NO. 1218 – PSEG Power Connecticut LLC petition for a declaratory ruling that no Certificate of Environmental Compatibility and Public Need is required for the construction, maintenance, and operation of a new 485 megawatt (MW) dual fuel combined-cycle electric generating facility at the existing Bridgeport Harbor Station located at 1 Atlantic Street, Bridgeport, Connecticut.

Dear Attorney Morrissey:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than April 28, 2016. To help expedite the Council's review, please file individual responses as soon as they are available.

Please forward an original and 15 copies to this office, as well as a copy via electronic mail. In accordance with the State Solid Waste Management Plan, the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. Fewer copies of bulk material may be provided as appropriate.

Copies of your responses shall be provided to all parties and intervenors listed on the service list, which can be found on the Council's pending proceedings website.

Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Yours very truly,

Melanie A. Bachman
Acting Executive Director

MB/MP/lm

c: Council Members
Parties and Intervenors

Petition No. 1218
PSEG
Bridgeport
Set One - UI

1. PSEG Power Connecticut LLC (PSEG) submitted its Petition (Petition) dated March 9, 2016 for a proposed approximately 400 megawatt combined-cycle power plant. If the proposed project is approved, would The United Illuminating Company (UI) and/or PSEG file a separate petition for the 345-kV underground electrical transmission cable and interconnection portion of the project or is this part of the instant Petition? If the electrical interconnection is part of the instant Petition, please provide the following information relative to the electrical interconnection of the plant:

- a) A route map for the proposed underground interconnection cable;
- b) The type and size of underground cable;
- c) Electric and magnetic fields profiles for the cross-section of the proposed underground cable and general compliance or consistency with the Council's Best Management Practices;
- d) Planned modifications at UI's substation to accommodate the interconnection.

Alternatively, if the interconnection is part of the instant Petition, but the final electrical design is not complete, could a general description of the proposed interconnection project be provided at this time, and the specific details a) through d) be included later in PSEG's Development and Management Plan for the plant?