

The Connecticut Light and Power Company
Docket No. 352

Data Request CSC-01
Dated: 01/14/2008
Q-CSC-001
Page 1 of 1

Witness: CL&P Panel
Request from: Connecticut Siting Council

Question:

Estimate the amount of woodland clearing necessary to construct the substation.

Response:

The amount of clearing necessary to construct the substation is approximately 50,000 square feet, including approximately 35,000 square feet for the substation footprint and 15,000 square feet for a 20-foot-wide construction zone surrounding the footprint.