

**The Connecticut Light and Power Company**  
**Docket No. 352**

**Data Request CSC-01**  
**Dated: 01/14/2008**  
**Q-CSC-004**  
**Page 1 of 1**

**Witness: CL&P Panel**  
**Request from: Connecticut Siting Council**

**Question:**

Page H-7 states portions of Wetland 3 have been filled. Does the substation footprint extend into any of these filled areas?

**Response:**

Yes, the eastern portion of the substation will extend slightly into Wetland 3, resulting in a permanent impact of approximately 490 square feet.