

The Connecticut Light and Power Company
Docket No. 352

Data Request CSC-01
Dated: 01/14/2008
Q-CSC-007
Page 1 of 1

Witness: CL&P Panel
Request from: Connecticut Siting Council

Question:

How much of the sand dune community would be disturbed during construction? What type of disturbance would occur?

Response:

Approximately 2,140 square feet of the sand dune community will be disturbed. The elevation of the dunes would be reduced to meet the existing road elevation to provide necessary transmission line clearances above ground.