

**Martin, David C.**

---

**From:** McKeon, Kelli  
**Sent:** Thursday, April 01, 2010 8:11 AM  
**To:** Martin, David C.  
**Cc:** DeCastro, John S; Palazzi, Peter E  
**Subject:** docket no. 395 East Haddam

David,

Here are the comments for the proposed AT&T/Cingular tower on SR. 434:

1. The proposed driveway must be 12' wide with 5' minimum radii, the drive should be perpendicular to the centerline of SR. 434 and driveway apron to be paved to State right of way.
2. An anti-tracking pad must be installed during construction of site.
3. The driveway must be constructed to preclude sheet flow from entering onto SR 434.
4. There is a large tree within the sightline triangle that may require removal. The tree to be removed should be specifically noted on the plan.
5. An encroachment permit will be issued upon receipt of a completed application, a Bond (on State form CLA-5) in the amount of \$10,000 in the contractor's name; a Certificate of Insurance (on State form CON-32 Rev. 11/07) requiring Bodily Injury Liability \$1,000,000 each accident or occurrence and Property Damage Liability, Aggregate \$2,000,000; a check or money order in the amount of \$100.00 made payable to "Treasurer-State of Connecticut." Proof of town approval will also be required.

If you have any further question please let me know. Thanks

*Kelli McKeon  
Lead Transportation District Service Agent  
State of Connecticut  
Department of Transportation  
171 Salem Turnpike  
Norwich, CT 06360  
1-860-823-3229*