

STATE OF CONNECTICUT  
CONNECTICUT SITING COUNCIL

Connecticut Light & Power Company

application for the

Interstate Reliability Project

RECEIVED Docket No. 424  
NOV 26 2012

CONNECTICUT  
SITING COUNCIL  
November 26, 2012

**Correction of Error In Party Comments**

To: Ms. Linda Roberts  
Executive Director  
Connecticut Siting Council  
Ten Franklin Square  
New Britain, Ct 06051

The undersigned party respectfully requests to correct his document entitled "Comments on the Draft Findings of Facts" dated Nov 23, 2012. Replace the last paragraph on page 3 with:

"P 77 Correction: Eliminate the entire paragraph

This paragraph is not correct. Connecticut import capacity is over 100% of its peak load. The Connecticut import from lines 3419/1870s > 2100MW (CL&P 26 p2, (August 28 Transcript p38), Cross cable is 330MW p22, Norwalk cable is 200MW p23, and New York is 1400MW p21.(August 28 Transcript) In addition the Card to Lake Road Line 330 is 1900MW( August 28 Transcript pg 59) GSRP is 2040MW (Council Admin, Notice 33 Vol1 I.4.2 Docket 370A) and in addition the Southwick and Salisbury lines."



Victor Civie, 160 Beech Mt Road, Mansfield CT 06250, 860-456-2022

I hereby certify that a copy of the foregoing document was (electronically mailed/sent by U.S. mail) to the Docket No. 424 service list on (11/26/12).



Victor Civie