



June 3, 2013

Melanie Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

RE: Waterside Power Docket No. F2012/2013 Response

Dear Ms. Bachman:

The following information is provided in response to the above referenced data request:

- 1) Waterside Power calculates seasonal claimed capacity based on ISO-New England requirements.
- 2) May 2013 ISO-NE claimed capability report is correct.

Waterside Power Net Capability-MW:

Summer	68.88
Winter	70.42

- 3) Waterside Power has black start capability.
- 4) The typical service life for this type of facility is between 20 and 30 years; the average remaining service life of this facility falls within that range.
- 5) Waterside Power does not have a decommissioning plan in place as the facility has more than 20 years of remaining service life.

If you should have any questions please contact me at (912) 826-3232 or via email at jseward@camsops.com.

Sincerely,

Ms. Jobie Seward
EHS Specialist