



Capitol District Energy Center Cogeneration Associates
1210, 715 – 5 Avenue S.W.
Calgary, Alberta T2P 2X6

June 20th, 2013

Melanie Bachman
Acting Executive Director
Connecticut Siting Council
Ten Franklin Square, New Britain, CT
06051

RE: Docket NO. F-2012/2013 – Connecticut Siting Council Review of the Ten-Year Forecast of Connecticut Electric Loads and Resources

Dear Ms. Bachman,

Please find enclosed in this letter our response to the CDECCA Pre-Hearing Interrogatories.

1. CDECCA intends to operate with its current summer and winter capabilities to the end of its service life.
2. Seasonal claimed capability is determined by ISO-NE. The initial plant capability is tested during a Claimed Capability Audit Establish as administered by ISO-NE. After that point, CDECCA submits a Seasonal Claimed Capability Audit to ISO-NE both during the winter and summer seasons to confirm its capability.
3. Yes, the commitment period 2012-13 Seasonal Claimed Capability values are correct.
4. CDECCA has black start capability but does not participate in the ISO-NE Black Start Program.
5. Typical Service Life: 40 years. Currently in year 24.
6. CDECCA has not hired a company to do this but has obtained a quote from a contractor to perform the service. Further detail on this matter will be handled as the unit gets closer to the end of its service life.

Sincerely,

A handwritten signature in black ink, appearing to read "Zane Westerbeek". The signature is fluid and cursive, written over a white background.

Zane Westerbeek
Sr. Energy Marketing Analyst