



Northeast
Utilities

107 Selden Street, Berlin, CT 06037

Northeast Utilities Service Company
P.O. Box 270
Hartford, CT 06141-0270
(860) 665-5000
www.nu.com

March 15, 2011

Ms. Linda Roberts
Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Re: Petition No. 983

Dear Ms. Roberts:

This letter provides the response to requests for the information listed below.

Response to FAIRWIND-01 Interrogatories dated 02/22/2011
FAIR-001, 002, 003, 004

Very truly yours,

Christopher R. Bernard
Manager
Regulatory Policy
NUSCO
As Agent for CL&P

cc: Service List

The Connecticut Light and Power Company
Petition No. 983

Data Request FAIRWIND-01
Dated: 02/22/2011
Q-FAIR-001
Page 1 of 1

Witness: David A. Ferrante
Request from: FairwindCT, Inc.

Question:

When did BNE Energy, Inc. ("BNE") first approach or contact you with respect to the project that is the subject of Petition No. 983 ("Wind Colebrook South")?

Response:

BNE contacted CL&P on or about the week ending March 6, 2010.

The Connecticut Light and Power Company
Petition No. 983

Data Request FAIRWIND-01
Dated: 02/22/2011
Q-FAIR-002
Page 1 of 1

Witness: David A. Ferrante
Request from: FairwindCT, Inc.

Question:

If Wind Colebrook South is approved and constructed, what work will need to be done by CL&P to integrate the electricity generated from Wind Colebrook South into the grid?

Response:

In accordance with the CL&P and UI Guidelines for Generator Interconnection, dated May 12, 2010, filed with the DPUC, CL&P is in the process of conducting Interconnection Studies, but they have not been completed; therefore, the scope of work to interconnect the proposed generating facility to the grid has not been identified.

The Connecticut Light and Power Company
Petition No. 983

Data Request FAIRWIND-01
Dated: 02/22/2011
Q-FAIR-003
Page 1 of 1

Witness: David A. Ferrante
Request from: FairwindCT, Inc.

Question:
How much will the work described in Interrogatory No. 2 cost?

Response:
At this time, CL&P has not developed the costs of the work described in Interrogatory Q-Fair-002.

The Connecticut Light and Power Company
Petition No. 983

Data Request FAIRWIND-01
Dated: 02/22/2011
Q-FAIR-004
Page 1 of 1

Witness: David A. Ferrante
Request from: FairwindCT, Inc.

Question:
Who will pay for the costs described in Interrogatory No. 3?

Response:
In accordance with the CL&P and UI Guidelines for Generator Interconnection, dated May 12, 2010, filed with the DPUC, the Generator is responsible for paying all construction, modification or upgrade costs associated with Interconnection of the Facility.