



# STATE OF CONNECTICUT

POWER FACILITY EVALUATION COUNCIL

STATE OFFICE BUILDING HARTFORD, CONNECTICUT 06115

TEL (203) 566-5612

Petition No. 18

Danbury, Ct. May 22, 1978

Chairman Guitar, John Cox, and Duncan Reid met Mr. Liss and Mr. Dery of Northeast Utilities to review completed Petition No. 18.

This project consists of an underground double circuit 115kV transmission line from Triangle Street substation to Middle River substation in Danbury. The line follows approximately 3.5 miles of streets in Danbury. The conductors are sealed within steel pipes and buried 5 feet below the street surface.

The trench for the pipes has been repaved and sealed with tar or the street has been totally repaved.

There are no significant adverse environmental impacts associated with this project. Therefore, it is recommended that this petition be finally approved.

Duncan C. Reid  
Environmentalist

6-1-78