



STATE OF CONNECTICUT

DEPARTMENT OF BUSINESS REGULATION

POWER FACILITY EVALUATION COUNCIL

Petition No. 53
Brookfield, Connecticut
August 26, 1980

Mr. Gelston, Chris Wood, and Duncan Reid met Messrs. Hill and Myer for a final review of Petition No. 53.

The construction described in Petition No. 53 includes the installation of taps and associated hardware on an existing lattice steel tower and a span of approximately 150 feet of conductor to a terminal structure located within the new Stony Hill Substation in Brookfield. This project is necessary to tap an existing 115kV line from Shepaug Substation to Brookfield Tap to feed the Stony Hill distribution substation.

An existing access road was used for this construction. This access road, with a chain link gate at Stony Hill Road, has been stabilized with processed stone and is now used as the access to the substation.

Virtually no clearing was required for this project.

Except for the gate at Stony Hill Road the area appears no different than before construction of the substation which is well screened from the road.

Final approval is recommended.

Duncan C. Reid
Environmentalist
August 27, 1980

Phone 566-5612

State Office Building — Hartford, Connecticut 06115

An Equal Opportunity Employer