



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

136 Main Street, Suite 401
New Britain, Connecticut 06051
Phone: 827-7682

Petition No. 191
West Brookfield Substation
Staff Report
March 22, 1988

Connecticut Light and Power Company is notifying the Council of modifications to the mobile transformer position within the West Brookfield Substation in the Town of Brookfield, Connecticut.

The Council approved Petition 191 on October 6, 1987. Subsequently, detailed engineering of the approved changes to the substation has resulted in minor adjustments to the plans. These would include:

1. Moving the original mobile transformer switch approximately 90° and perpendicular to the originally approved position;
2. Enlarging the existing entrance gate from 14 feet to 20 feet;
3. Moving the station's eastern fence outward to a position in line with the fence located outside of the control building; and
4. Not moving the northern fence as originally planned.

These changes would facilitate access to the substation by large equipment transports and would allow CL&P to remove a defective transformer with a mobile transformer installed.

All other aspects of Petition 191, as approved, remain unchanged.

Thomas E. Fanning, Jr.
Siting Analyst

0256G