

PERMIT TO OPERATE
EP-12 NEW 6-72



STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION



PREMISE NO.: 089-065

STACK NO.: 12

PERMIT NO.
089-0025

File for renewal 120 days before expiration date.

EQUIPMENT CLASSIFICATION			DATE ISSUED	EXPIRATION DATE
<input checked="" type="checkbox"/> FUEL BURNING	<input type="checkbox"/> INCINERATOR	<input type="checkbox"/> PROCESS MFG.	8/18/80	4/1/84
CONDITIONS				

This Cleaver Brooks Delta 60 Watertube Boiler shall be operated in accordance with the specifications listed in the permit application, with the terms of the permit letter, and with all applicable sections of the Connecticut Administrative Regulations for the Abatement of Air Pollution.

FUEL/MAXIMUM FIRING RATE: #2 oil/371 gals/hr (51.0×10^6 BTU/hr)
#6 oil/344 gals/hr (50.5×10^6 BTU/hr)
Natural Gas/51,000 cu. ft/hr (52.5×10^6 BTU/hr)

MINIMUM STACK HEIGHT: 100 ft

SMOKE MONITOR: Preferred Utilities Model JC30F4C

FIRM NAME

Frito-Lay, Inc.

LOCATION OF EQUIPMENT (No. & Street, Town, Zip)

Maple St., Killingly 06239

APPLICANT'S SIGNATURE

COMMISSIONER OR HIS REPRESENTATIVE

Stanley J. Pace

Permit is invalid unless signed by Applicant, such signature constituting agreement to the conditions listed above.

APPLICANT