

PERMIT TO OPERATE

EP-12 NEW 6-72


 STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION


PREMISE NO.: 089-065

STACK NO.: 12

 PERMIT NO.
 089-0026

File for renewal 120 days before expiration date.

| EQUIPMENT CLASSIFICATION | | | | DATE ISSUED | EXPIRATION DATE |
|---|--------------------------------------|--|---|-------------|-----------------|
| <input checked="" type="checkbox"/> FUEL <input checked="" type="checkbox"/> BURNING | <input type="checkbox"/> INCINERATOR | <input type="checkbox"/> PROCESS MFG. | <input type="checkbox"/> AIR POLLUTION CONTROL | 8/18/80 | 4/1/84 |
| CONDITIONS | | | | | |

This Cleaver Brooks Delta 60 Watertube Boiler shall be operated in accordance with the specifications listed in the permit application, with the terms of the permit letter, and with all applicable sections of the Connecticut Administrative Regulations for the Abatement of Air Pollution.

FUEL/MAXIMUM FIRING RATE: #2 oil/371 gals/hr (51.0×10^6 BTU/hr)
 #6 oil/344 gals/hr (50.5×10^6 BTU/hr)
 Natural Gas/51,000 cu. ft/hr (52.5×10^6 BTU/hr)

MINIMUM STACK HEIGHT: 100 ft

SMOKE MONITOR: Preferred Utilities Model JC30F4C

FIRM NAME

Erito-Lay, Inc.

LOCATION OF EQUIPMENT (No. & Street, Town, Zip)

Maple St., Killingly 06239

APPLICANT'S SIGNATURE

COMMISSIONER OR HIS REPRESENTATIVE

Permit is invalid unless signed by Applicant, such signature constituting agreement to the conditions listed above.

APPLICANT