



STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION

ORIGINAL

TOWN NO. 117	PREMISE NO. 53	PERMIT NO. 0136	STACK NO. 12
-----------------	-------------------	--------------------	-----------------

EQUIPMENT CLASSIFICATION		DATE ISSUED	EXPIRATION DATE (NONE UNLESS NOTED)
<input type="checkbox"/> FUEL BURNING	<input type="checkbox"/> INCINERATOR	5/25/95	
<input checked="" type="checkbox"/> PROCESS MFG.		OTHER _____	

THE FOLLOWING SHALL BE CONSTRUCTED/OPERATED IN ACCORDANCE WITH THE SPECIFICATIONS LISTED IN THE PERMIT APPLICATION, WITH THE TERMS OF THE PERMIT LETTER, AND WITH ALL APPLICABLE SECTIONS OF THE CONNECTICUT "ADMINISTRATIVE REGULATIONS" FOR THE ABATEMENT OF AIR POLLUTION."

EQUIPMENT DESCRIPTION (I.D.): UNLEADED PREMIUM GASOLINE STORAGE TANK #25

TANK DIMENSIONS: 110 foot diameter; 56 foot height

THROUGHPUT: 750 Million gallons/year

CONTROLS: Altech internal pan and double wiper seal system

DESIGN REQUIREMENTS:

This is a NSPS source and subject to all applicable design criteria as specified in 40 CFR 60 Subpart Kb. This includes 60.112b with respect to design requirements for internal floating roof tanks constructed after July 23, 1984.

MONITORING REQUIREMENTS:

Monitoring of operations and recorkeeping requirements shall be in full accordance with the NSPS requirements as published April 8, 1987.

TRANSFERRED TO:

*Motiva Enterprises, LLC
481 East Shore Parkway
New Haven CT, 06512-1813*

ENGINEER: *KJW* DATE: *1/6/95*

RECORDS INDICATING CONTINUAL COMPLIANCE WITH ALL ABOVE CONDITIONS MUST BE KEPT ON SITE AT ALL TIMES AND MADE AVAILABLE UPON DEPARTMENTAL REQUEST FOR THE DURATION OF THIS PERMIT.

FIRM NAME: NORTHEAST PETROLUUM, DIVISION OF CARGILL, INC.

LOCATION OF EQUIPMENT (No. & Street, Town, Zip): 481 EAST SHORE PARKWAY, NEW HAVEN, CONNECTICUT 06512

COMMISSIONER OR HIS REPRESENTATIVE
[Signature]

PERMIT IS INVALID UNLESS SIGNED BY APPLICANT, SUCH SIGNATURE CONSTITUTING AGREEMENT TO THE CONDITIONS IN THIS PERMIT.

BUREAU OF AIR MANAGEMENT - PERMITS



ORIGINAL

OPERATING MODE ID: Unleaded Premium Gasoline Storage Tank #25

TOWN NO. 117	PREMISE NO. 53	PERMIT NO. 0136	STACK NO. 12
-----------------	-------------------	--------------------	-----------------

CRITERIA POLLUTANTS	LB/HOUR				TPY
TSP					
SO _x , expressed as SO ₂					
NO _x , expressed as NO ₂					
HC	1.88				8.20
CO					
Pb					
PM-10					
<u>NON-CRITERIA POLLUTANTS</u>					
H ₂ SO ₄					

COMMENTS :

FIRM NAME
EXXON COMPANY, U.S.A.

LOCATION OF EQUIPMENT (No. & Street, Town, Zip)
481 EAST SHORE PARKWAY, NEW HAVEN, CONNECTICUT 06512