

NetDMR Attachment

Exide Group, Inc.

NPDES Permit No. CT0030651

Site Address: 2190 Post Road, Fairfield, CT 06824

Monitoring Period: October 1, 2014 - October 31, 2014

One clarification associated with the influent is presented in this attachment, summarized as follows:

1. Influent Temperature

Table A in Section 5.A. (page 5) of the NPDES permit requires hourly (continuous) monitoring for temperature for Discharge Serial Number 101-1 on the influent "Hydraulically dredged material from Mill River prior to treatment." The permit parameter listed in the permit is "Temperature, Maximum" and the footnote states, "The Permittee shall report the maximum monthly temperature based on hourly (continuous) monitoring."

The NetDMR parameter is listed as "Temperature, water deg. Fahrenheit" (code 00011) and the NetDMR requires the "monthly average" and "daily maximum." These two reporting requirements (between NetDMR and the NPDES permit) are not the same, so based on our understanding, we are providing the information required by the NPDES permit in this attachment.

Parameter	Monthly Average Value	Daily Maximum Value	Units	Number of Ex.	Frequency of Analysis	Sample Type
Temperature, Maximum	64.8	69.5	deg F	0	Hourly	Continuous