

**STATE OF CT DEPARTMENT OF HOUSING (DOH)  
COMMUNITY DEVELOPMENT BLOCK GRANT DISASTER RECOVERY PROGRAM (CDBG-DR)  
OWNER-OCCUPIED REHABILITATION AND REBUILDING PROGRAM (OORR)**

**For the Rehabilitation/Reconstruction work to:**

**Project #1187, Garelick-Casa Residence  
280 Richards Avenue, Norwalk, CT 06850**

**ADDENDUM NUMBER 2**

**Issue Date: 10/10/14**

**Addendum Content:**

1. Questions and Answers
2. Addendum Acknowledgement to be submitted with contractor's bid proposal

**ACKNOWLEDGEMENT of all Addenda must be submitted with the contractor's bid proposal.**

**STATE OF CT DEPARTMENT OF HOUSING (DOH)  
COMMUNITY DEVELOPMENT BLOCK GRANT DISASTER RECOVERY PROGRAM (CDBG-DR)  
OWNER-OCCUPIED REHABILITATION AND REBUILDING PROGRAM (OORR)**

**For the Rehabilitation/Reconstruction work to:**

**Project #1187, Garelick-Casa Residence  
280 Richards Avenue, Norwalk, CT 06850**

**ADDENDUM NUMBER 2**

**Issue Date: 10/10/14**

**Questions and Answers**

**Question:**

1) addendum #1 does not directly answer the question. If windows are not being disturbed / repaired do they still need to be abated.?

**Answer:**

Windows that are not disturbed during the pane replacement will not require abatement of PCBs. The only windows that will require PCB abatement are windows where glass is being replaced. Abatement shall be limited to the disturbed area.

**Question:**

2) The environmental report identifies mold, lead, asbestos and PCB's that need to be abated, however the bid sheet does not identify those all those specific tasks under the heading of "hazardous material remediation " please clarify

**Answer:**

Contractors shall bid the scope provided. Please refer to Section 4.0 of the NEPA Environmental Review Report.

**ACKNOWLEDGEMENT of all Addenda must be submitted with the contractor's bid proposal.**

**STATE OF CT DEPARTMENT OF HOUSING (DOH)  
COMMUNITY DEVELOPMENT BLOCK GRANT DISASTER RECOVERY PROGRAM (CDBG-DR)  
OWNER-OCCUPIED REHABILITATION AND REBUILDING PROGRAM (OORR)**

**For the Rehabilitation/Reconstruction work to:**

**Project #1187, Garelick-Casa Residence  
280 Richards Avenue, Norwalk, CT 06850**

**ADDENDUM ACKNOWLEDGEMENT**

<b>Addendum No.</b>	<b>Issue Date</b>
1.	10/2/14
2.	10/10/14
3.	
4.	
5.	

**ACKNOWLEDGEMENT of all Addenda must be submitted with the contractor's bid proposal.**

**Bidder's Name:** \_\_\_\_\_

**Authorized Officer:**

\_\_\_\_\_  
(Signature)

\_\_\_\_\_  
(Date)

\_\_\_\_\_  
(Print Name)

\_\_\_\_\_  
(Title/Position)