



Quisenberry Arcari Architects, LLC  
318 Main Street  
Farmington, CT 06032

[www.qa-architects.com](http://www.qa-architects.com)

(860) 677 – 4594 office

(860) 677 – 8534 facsimile

FACSIMILE COVER PAGE

DATE : 02.19.15	JOB # : 1491 QA1346-47
RE: <b>9 Crown Street, Waterbury, CT</b>	
(CDBG-DR) & (OORR) Programs	
ADDENDUM #2	

**PLEASE COMPLETE SECTION BELOW AND FAX BACK TO 860-677-8534**

Received (Addendum #2)

CONTRACTOR : \_\_\_\_\_

SIGNED : \_\_\_\_\_ Date: \_\_\_\_\_

NUMBER OF PAGES INCLUDING THIS COVER PAGE: 3

FROM: Jeff Jahnke, AIA

**Community Development Block Grant Disaster Recovery Program (CDBG-DR)  
Owner Occupied Rehabilitation and Rebuilding Program (OORR)**

**9 CROWN STREET, WATERBURY, CT**

**Addendum # 2  
February 19, 2015**

**GENERAL / CLARIFICATIONS**

Clarification



1. See the attached Addendum Sketch – SKA-021915a. It describes the interior drainage system what will be used in lieu of the originally designed exterior drainage system. Replacement of front porch and rear and side steps and landings will still occur as indicated on plans.
2. The work described in Add Alternate # 1 shall be incorporated in the base bid, as the work involved to install the interior drain necessitates it. Refer to Add Alternate # 1 as “N/A” on your bid sheet. Add Alternate #2 and Add Alternate # 3 shall remain.
3. The Bid date originally scheduled for February 17, 2015 is postponed until 4:00 PM on February 24, 2015 – not 4:30 PM as stated on Addendum # 1.

**END OF ADDENDUM #2**

NEW PERIMETER TRENCH

BASEMENT WATERPROOFING SHALL BE PERFORMED BY A COMPANY SPECIALIZING IN THIS WORK FOR A MINIMUM OF 10 YEARS, AND SHALL COME WITH A LIFETIME GUARANTEE. SCOPE OF WORK DESCRIBED BELOW IS BASED ON CONNECTICUT BASEMENT SYSTEMS:

1. PROVIDE PERIMETER TRENCH IN BASEMENT FLOOR. REMOVE AND DISPOSE OF CONCRETE.
2. EXCAVATE TO TOP OF FOOTING. DISPOSE OF EXCAVATED MATERIAL.
3. INSTALL PERIMETER FRENCH DRAIN EQUAL TO "WATERGUARD".
4. PROVIDE PACKAGED SUMP PUMP RECESSED INTO BASEMENT FLOOR EQUAL TO "SUPER PUMP". PIPE DISCHARGE TO BUILDING EXTERIOR. REMOVE AND DISPOSE OF CONCRETE FLOORING AND EXCAVATED MATERIAL. PROVIDE NEW GFI RECEPTACLE AND CIRCUIT AS REQUIRED. PROVIDE CHECK VALVE ON PUMP DISCHARGE.
5. CONNECT FRENCH DRAIN TO SUMP PUMP USING SOLID PVC DRAIN PIPE.
6. PATCH FLOOR WITH CONCRETE TO MATCH EXISTING FINISHED FLOOR ELEVATION.
7. PROVIDE ENERGY STAR CERTIFIED "SANI-DRY XP" DEHUMIDIFIER (109 PINTS/DAY @ 80F/60% RH) IN BASEMENT SPACE. PIPE CONDENSATE TO PERIMETER DRAINAGE SYSTEM. PROVIDE NEW GFI RECEPTACLE AND CIRCUIT AS REQUIRED.



**ADDENDUM # 2 SKETCH**

Scale: 1/4" = 1'-0"

**QUISENBERRY ARCARI ARCHITECTS, LLC**

www.qa-architects.com  
 T (860) 677-4594  
 F (860) 677-8534  
 318 Main Street  
 Farmington, CT 06032

**REPAIRS TO RESIDENCE FOR:  
 MONROE & BEVERLY  
 WEBSTER**

**Hurricane Sandy Disaster Recovery Program  
 9 CROWN STREET - WATERBURY, CT**

Issue Date:  
 02.19.15

Sheet #:  
**SKA-021915a**

Project #:  
 1491

Drawn By:  
 JWJ