

February 13, 2015

BID # 2112

BID PACKAGE
FOR
REHABILITATION/RECONSTRUCTION WORK TO
SHAPIRO RESIDENCE
13 BLAIR STREET
MILFORD, CONNECTICUT

ENGINEERS: DIVERSIFIED TECHNOLOGY CONSULTANTS

ADDENDUM NO. 3

Pre-Bid Sign-In sheets are attached for your use.

The following shall be incorporated into the work.

CONTRACTOR REQUESTS FOR INFORMATION RESPONSES

1. Where is the electrical service to be located? UI requirements state the meter is to be 5 foot to center above grade. This is far below the 500 year flood plane level. Please clarify.
 - a. Meter to be installed per UI requirements
2. The drawings make no mention of a meter circuit breaker disconnect enclosure. Based on the location one will be required. Please confirm.
 - a. Provide required meter circuit breaker disconnect.
3. Keynote #2 on drawing E-100 states "Provide 100 amp rated service entrance wiring from meter to new panel location". The drawing does not indicate the panel is to be moved. It states replace existing. Please clarify.
 - a. Panel is existing to remain. Only the 100 amp entrance wiring shall be new
4. Does the project spec a certain brand heat trace?
 - a. Drawing MP-300 indicates Raychem 8XL1 model
5. The drawings show no weatherproof 3 way switches at the bottom of the new stairs. Additional exterior lighting will be required for the new staircase. Please confirm.
 - a. One exterior lighting fixture shall be required at stairs. Provide wall mounted, wet location listed, energy star rated lighting fixture with integral photo sensor similar to the Lithonia OWP342F120. Fixture shall be controlled by new three way switch located at bottom of

OORR PROGRAM
Shapiro Residence
13 Blair Street
Milford, CT
Project #: 2112
Addendum No. 3

stairs and at first floor entrance. Tie to existing exterior lighting circuit and provide for 3-way operation.

DRAWING A-101

1. **Section 3/A101, Typical Floor Section: The Foam In Place Insulation Shall be installed to provide R-30 Insulation for the floor section.**

THE BID DATE AND TIME IS NOT CHANGED IN THIS ADDENDUM.

CONTRACTORS SHALL ACKNOWLEDGE THIS ADDENDUM ON THE BID FORM.

END OF ADDENDUM NO. 3.