

RFI #1 RESPONSE
Project 2158 – 70-72 Kent Avenue

| RFI-# | RFI Text | A/E Response |
|-------|---|--|
| 1 | No Plans are posted on the website. Are Plans available? | No plans are available |
| 2.1 | Under Summary of Work 01 10 00 Section 1. Roofing: Item 1.1 indicates to remove the shingle in areas indicated. Do we replace the whole roof? | Roof shingles to be removed on entire main roof. Porch roofs are excluded from scope of work. |
| 2.2 | Under Summary of Work 01 10 00 Section 1. Roofing: Item 1.3 indicates to replace asphalt shingles with 3 tab to match existing. The existing appeared to be Architectural type. Should we price Architectural? | Existing roof has been patched with three tab shingles. Remainder of roof is architectural shingle. Price architectural shingle replacement. |
| 2.3 | Under Summary of Work 01 10 00 Section 3. Windows and Doors Item 3.3 indicates remove and dispose windows that are damaged. Besides the 2 specified in this section how many need to be priced? | Item 3.3 includes only the replacement of two (2) windows. |
| 2.4 | Under Summary of Work 01 10 00 Section 3. Windows and Doors Item 3.5 indicates re-glaze cracked windows. Can you give a count? | Item 3.5 count for windows to be reglazed is one (1) window. |