

**STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH**

2003 ORGANICS REPORT



Keeping Connecticut Healthy

www.dph.state.ct.us

Governor John G. Rowland

Commissioner J. Robert Galvin, M.D., M.P.H.

**REPORT PER SECTION 25-39a OF THE CONNECTICUT GENERAL STATUTES
MONITORING, HEALTH RISKS, AND TREATMENT COSTS
FOR ORGANIC CHEMICALS IN PUBLIC DRINKING WATER
FOR THE YEAR 2003**

February, 2003

REPORT PER SECTION 25-39a OF THE CONNECTICUT GENERAL STATUTES
MONITORING, HEALTH RISKS, AND TREATMENT COSTS
FOR ORGANIC CHEMICALS IN PUBLIC DRINKING WATER
FOR THE YEAR 2003

INDEX

	<u>PAGE</u>
Executive Summary	
I. Introduction	1
II. Organic Chemical Monitoring Requirements	1
TABLES I – III	2-5
III. Total Trihalomethane (TTHM's)	6
IV. Organic Test Results	6
V. Revised Organic Chemical Regulation	7
VI. Action Levels for Chemical Contaminants In Public Water Systems	7
VII. Estimating Potential Risk of Carcinogenic Chemicals And Reproductive Hazards In Drinking Water	8
VIII. Costs of Removal	8
IX. Treatment Costs - Tetrachloroethylene Removal From Groundwater	8-9
X. Treatment Costs - Trihalomethane Removal From Drinking Water	9
XI. Treatment Costs - Organics Removal From Private Water Systems	9
XII. Cost Impact of Public Health Code Modifications For Organic Chemicals to Public Water Systems	9
XIII. Regulatory Information	9
XIV. Organic Chemical Maximum Contaminant Level Violations, 2003	10
XV. Public Water Systems Which Detected Organic Chemicals During 2003 ATTACHMENT XV	11-22
XVI. Public Water Systems Treating for Organic Chemicals ATTACHMENT XVI	23-43
XVII. Ranking of Carcinogens by Cancer Group ATTACHMENT XVII	44

EXECUTIVE SUMMARY

REPORT PER SECTION 25-39a OF THE CONNECTICUT GENERAL STATUTES MONITORING, HEALTH RISKS, AND TREATMENT COSTS FOR ORGANIC CHEMICALS IN PUBLIC DRINKING WATER FOR THE YEAR 2003

The State of Connecticut, Department of Public Health (DPH), as required under Connecticut General Statutes Section 25-39a is providing this annual report to the Governor and the General Assembly that contains the results of organic chemical testing by Connecticut's public water systems. The relative health risk of each of the identified carcinogenic contaminants is provided, as well as the associated cost for treatment. The DPH is responsible for the regulation of Connecticut public drinking water systems and as such provides the following information, details of which are in specific sections of the report.

In 2003, there was only one maximum contaminant level (MCL) violation issued against any public water systems for organics. Although increased surveillance has resulted in more organic detections, it has led to only one violation for the calendar year 2003.

One hundred and eighty-three (183) systems in 86 towns have organic chemicals present at concentrations below legally enforceable standards or have organic chemicals present for which no legally enforceable standards exist or for which no public health risk is defined. Of the 183 public water systems, 63 are community and 120 are non-community water systems. All such systems are mandated by regulations to increase monitoring and submit analytical results to the department for review and compliance purposes. Results will determine the need for further regulatory action.

Fifty-one (51) public drinking water supplies in the State are currently treating their water to remove organic chemical contaminants. Due to this treatment, all 51 suppliers provide drinking water that meets all legal standards. Of these, 19 are community public water systems.

Of the organic chemicals detected in Connecticut's public drinking water supplies: 1,1,1 Trichloroethane, 1,1,2 Trichloroethane, 1,1, Dichloroethane, 1,1 Dichloroethylene, 1,2,3, Trichloropropane, 1,2,4 Trimethylbenzene, 1,2, Dichloroethane, 1,2 Dichloropropane, 1,3,5 Trimethylbenzene, 2,2 Dichloropropane, Benzene, Bromodichloromethane, Bromoform, Bromomethane, Carbon Tetrachloride, Chlorodibromomethane, Chloroform, Chloromethane, CIS-1,2 Dichloroethylene, Dibromomethane, Dichloromethane, Ethylbenzene, Methyl Tert-Butyl Ether (MTBE), Monochlorobenzene, N-Butylbenzene, Naphthalene, P-Dichlorobenzene, Styrene, Tetrachloroethylene, Toluene, Trans-1,2 Dichloroethylene, Trichloroethylene, Vinyl Chloride, Xylenes (Meta, Ortho, Para).

It is expected that even more systems with organic chemical contaminants will be identified in 2004 because of increased efforts focused on the non-community systems. These systems (which include schools, town halls, restaurants, etc.) will require tracking, increased monitoring, reporting and possibly treatment. The DPH will be required to expend additional resources to provide the appropriate level of surveillance, assistance and regulation. Organic chemical contamination remains a concern in Connecticut as in all other States. The DPH's continued efforts are necessary to reduce the risk of exposure to Connecticut's citizens from organic chemicals in drinking water.

REPORT PER SECTION 25-39a OF THE CONNECTICUT GENERAL STATUTES
MONITORING, HEALTH RISKS, AND TREATMENT COSTS
FOR ORGANIC CHEMICALS IN PUBLIC DRINKING WATER
FOR THE YEAR 2003

I. INTRODUCTION:

Pursuant to the mandate of Connecticut General Statutes 25-39a the DPH is submitting the following report, concerning the monitoring of public water supplies for organic chemicals, the carcinogenic ranking of organic chemicals, and the evaluation of techniques and costs for the removal of these chemicals from public water supplies. DPH is responsible for the regulation of Connecticut public drinking water supplies.

Connecticut General Statutes Sec. 25-39a reads as follows: "Monitoring of public water supplies for organic chemicals. Listing of harmful carcinogens. Reports re. Each public water company, as defined in section 25-32a, shall monitor, in accordance with regulations adopted by the Commissioner of the Department of Public Health, the organic chemical content of all public water supplies to determine what potentially harmful carcinogens are in the water supply and shall report the results to the Department of Public Health. The Department shall rank such carcinogens in order of potential danger and estimate the cost of removal of the more dangerous ones. The Department shall report its findings and cost estimates to the General Assembly and the Governor on or before February first of each year."

The Drinking Water Division of the DPH has jurisdiction over the purity and adequacy of drinking water from all of Connecticut's public water supplies, 593 community systems, 667 non-transient non-community systems, and approximately 1756 transient non-community water systems.

Regulations regarding the frequency of organics monitoring and the type of parameters to be tested are embodied in the Connecticut Public Health Code Section 19-13-B102. Basically, this section of the Public Health Code establishes maximum contaminant levels and prescribes a minimum frequency of testing for the following three groups of organic compounds:

1. Selected Pesticides and Herbicides - Section 19-13-B102(e)3
2. Total Trihalomethanes (TTHM's) - Section 19-13-B102(e)4
3. Volatile Organic Chemicals (VOC's) - Section 19-13-B102(e)4

II. ORGANIC CHEMICAL MONITORING REQUIREMENTS (See TABLE I):

Community, Non-Transient Non-Community, and seasonal water systems were required to conduct monitoring for organic chemicals, pesticides, herbicides, PCBs, and trihalomethanes beginning in the initial compliance period from January 1993 through December 1995. This was to determine compliance with the maximum contaminant levels specified in Sections (3) and (4) of subsection 19-13-B102(e) of the regulations of Connecticut State Agencies. Systems serving fewer than one hundred and fifty (150) service connections began monitoring in the second compliance period from January 1996 through December 1998 for the following chemicals: Benzo(A) Pyrene, Dalapon, Di(2-Ethylhexyl) Adipate, Di(2-Ethylhexyl) Phthalate, Dinoseb, Diquat, Endothall, Endrin, Glyphosate, Hexachlorobenzene, Hexachlorocyclopentadiene, Oxamyl(Vydate), Picloram, Simazine, and 2,3,7,8-TCDD (Dioxin).

TABLE I

MONITORING FREQUENCY FOR COMMUNITY, NON-TRANSIENT NON-COMMUNITY, AND SEASONAL WATER SYSTEMS

<u>CONTAMINANT</u>	<u>BASE SAMPLING REQUIREMENT</u>		<u>REDUCED SAMPLING REQUIREMENT</u>	
	<u>GROUND WATER SYSTEMS</u>	<u>SURFACE WATER(4) SYSTEMS</u>	<u>GROUND WATER SYSTEMS</u>	<u>SURFACE WATER(4) SYSTEMS</u>
ORGANIC CHEMICALS	QUARTERLY	QUARTERLY	ANNUALLY*(3)	ANNUALLY(3)
PESTICIDES, HERBICIDES AND PCBs	QUARTERLY	QUARTERLY	Systems serving more than 3300 persons: two quarters per year every 3 years (3). Systems serving 3300 persons or less: every 3 years (3)	
TRICHALOMETHANES	QUARTERLY(5)	QUARTERLY	ANNUALLY	QUARTERLY

- (3) Applicable only if no single contaminant is detected in the results of the four (4) consecutive quarters of the base sampling requirement.
- * Reduce to once every three (3) years after three (3) years of no detection of any contaminant in annual sampling.
- (4) Or groundwater under the influence of surface water systems.
- (5) For groundwater systems which serve 10,000 people or more and disinfect.

TABLE II

PESTICIDES, HERBICIDES, PCBS, AND THEIR LIMITS

(A) Pesticides, herbicides and PCBs. Community and Non-transient Non-community Public Water Systems shall test for pesticides, herbicides and PCBs as specified below:

<u>CHEMICAL</u>	<u>MAXIMUM CONTAMINANT LEVEL</u> <u>Milligrams/Liter (mg/l)</u>
<u>Alachlor</u>	0.002
<u>Aldicarb</u>	**
<u>Aldicarb Sulfoxide</u>	**
<u>Aldicarb Sulfone</u>	**
<u>Aldrin</u>	**
<u>Atrazine</u>	0.003
<u>Benzo(A)Pyrene</u>	0.0002
<u>Butachlor</u>	**
<u>Carbaryl</u>	**
<u>Carbofuran</u>	0.04
<u>Chlordane</u>	0.002
<u>Dalapon</u>	0.2
<u>Di(2-Ethylhexyl)Adipate</u>	0.4
<u>Di(2-Ethylhexyl)Phthalates</u>	0.006
<u>Dicamba</u>	**
<u>Dieldrin</u>	**
<u>Dinoseb</u>	0.007
<u>Diquat</u>	0.02
<u>Dibromochloropropane (DBCP)</u>	0.0002
<u>2,4-D</u>	0.07
<u>Ethylene Dibromide (EDB)</u>	0.00005
<u>Endrin</u>	0.002
<u>Endothall</u>	0.1
<u>Glyphosate</u>	0.7
<u>Heptachlor</u>	0.0004*
<u>Heptachlor Elpoxide</u>	0.0002*
<u>Hexachlorobenzene</u>	0.001
<u>Hexachlorocyclopentadiene</u>	0.05
<u>3-Hydroxycarbofuran</u>	**
<u>Lindane</u>	0.0002
<u>Methoxychlor</u>	0.04
<u>Methomyl</u>	**
<u>Metolachlor</u>	**
<u>Metribuzin</u>	**
<u>Oxamyl (Vydate)</u>	0.2
<u>Picloram</u>	0.5
<u>Propachlor</u>	**
<u>Simazine</u>	0.004
<u>2,3,7,8-TCDD (Dioxin)</u>	0.00000003
<u>Polychlorinated Biphenyls (PCBs)</u>	0.0005
<u>Pentachlorophenol</u>	0.001
<u>Toxaphene</u>	0.003
<u>2,4,5-TP (Silvex)</u>	0.05

* If monitoring results in detection of one (1) or more of these contaminants, then subsequent monitoring shall analyze for all these contaminants.

**Maximum Contaminant Level has not been established for this chemical.

TABLE III

ORGANIC CHEMICALS AND THEIR LIMITS

(B) Organic Chemicals. Community and Non-transient Non-community Public Water Systems shall test for organic chemicals as specified below.

<u>CHEMICAL</u>	<u>MAXIMUM CONTAMINANT LEVEL</u> <u>Milligrams/Liter (mg/l)</u>
<u>Benzene</u>	0.005
<u>Bromobenzene</u>	**
<u>Bromomethane</u>	**
<u>N-Butyl Benzene</u>	**
<u>Carbon Tetrachloride</u>	0.005
<u>Chlorobenzene</u>	0.1
<u>Chloroethane</u>	**
<u>Chloromethane</u>	**
<u>O-Chlorotoluene</u>	**
<u>P-Chlorotoluene</u>	**
<u>Dibromomethane</u>	**
<u>M-Dichlorobenzene</u>	**
<u>O-Dichlorobenzene</u>	0.6
<u>P-Dichlorobenzene</u>	0.075
<u>1,1-Dichloroethane</u>	**
<u>1,2-Dichloroethane (EDC)</u>	0.005
<u>1,1-Dichloroethylene</u>	0.007
<u>Cis-1,2-Dichloroethylene</u>	0.07
<u>Trans-1,2-Dichloroethylene</u>	0.1
<u>Dichloromethane (Methylene Chloride)</u>	0.005
<u>1,2-Dichloropropane</u>	0.005
<u>1,3-Dichloropropane</u>	**
<u>2,2-Dichloropropane</u>	**
<u>1,1-Dichloropropene</u>	**
<u>1,3 Dichloropropene</u>	**
<u>Ethylbenzene</u>	0.7
<u>Methyl Tert Butyl Ether (MTBE)</u>	**
<u>Naphthalene</u>	**
<u>N-Propyl Benzene</u>	**
<u>Styrene</u>	0.1
<u>1,1,1,2-Tetrachloroethane</u>	**
<u>1,1,1,2,2-Tetrachloroethane</u>	**
<u>Tetrachloroethylene</u>	0.005
<u>Toluene</u>	1.0
<u>Total Trihalomethanes (TTHM)</u>	0.100
<u>Bromodichloromethane</u>	*
<u>Bromoform</u>	*
<u>Chlorodibromomethane</u>	*
<u>Chloroform</u>	*
<u>1,1,1-Trichloroethane</u>	0.200
<u>1,1,2-Trichloroethane</u>	0.005
<u>1,2,4-Trichlorobenzene</u>	0.07
<u>Trichloroethylene</u>	0.005
<u>1,2,3-Trichloropropane</u>	**
<u>1,2,4-Trimethylbenzene</u>	**
<u>1,3,5-Trimethylbenzene</u>	**
<u>Vinyl Chloride</u>	0.002
<u>Xylenes (TOTAL)</u>	10.0
<u>M-Xylene</u>	***
<u>O-Xylene</u>	***
<u>P-Xylene</u>	***

NOTES:

- * The maximum contaminant level for Total Trihalomethanes is 0.100 mg/l, this is the sum of the four (4) constituent Trihalomethanes.
- ** The maximum contaminant level has not been established for this chemical.
- *** The maximum contaminant level for Xylenes (Total) is 10.0 mg/l, this is the sum of the three (3) constituent Xylenes.
 - (i) The method detection limit for all organic chemicals is 0.0005 mg/l with the exception of MTBE which has a method detection limit of 0.002 mg/l.
 - (ii) The DPH may require the testing of other chemicals for which a maximum contaminant level goal has been proposed by the Environmental Protection Agency or which the DPH has reason to believe may be health threatening.
 - (iii) Quarterly analysis for vinyl chloride is required for ground water systems only when one or more of the following compounds are detected: Trichloroethylene, 1,2 Tetrachloroethylene, 1,2 Dichloroethane, 1,1,1 Trichloroethane, cis-1,2 Dichloroethylene, trans-1,2 Dichloroethylene, or 1,1 Dichloroethylene. If the first analysis does not detect vinyl chloride, the DPH may reduce the frequency of vinyl chloride monitoring to once every three (3) years.

A system shall monitor quarterly beginning in the next quarter, if in any one sample an organic chemical, pesticide, herbicide or PCBs is detected at a level exceeding the method detection limit.

The DPH may decrease the quarterly monitoring requirement of Section 19-13-B102(e)(7)(C)(ii) for organic chemicals along with pesticides, herbicides, and PCB to annual sampling provided it has determined that the system is below the maximum contaminant level for a minimum of two (2) consecutive quarters for a ground water system and a minimum of four (4) consecutive quarters for a surface water system. The DPH may decrease the quarterly monitoring requirement for systems that violated the maximum contaminant level for organic chemicals, pesticides, herbicides and PCBs to annual sampling provided that the system is below the maximum contaminant level for a minimum of four (4) consecutive quarters. The DPH may decrease the quarterly monitoring requirement for systems that exceeded the method detection limit for a contaminant that does not have an established maximum contaminant level to the reduced sampling requirement.

After three (3) consecutive annual samples, as required in Section 19-13B102(e)(7)(C)(iii), are less than the method detection limit, the DPH may allow a system to reduce the sampling frequency for organic chemicals, pesticides, herbicides and PCBs to the reduced sampling requirement.

With the exception of Trihalomethanes, the DPH may allow the use of monitoring data collected after January 1, 1990 to satisfy the base sampling requirement provided the monitoring protocol is consistent with Subsection 19-13-B102(e) for pesticides, herbicides, PCBs and organic chemicals. Systems which use grandfathered samples of organic chemicals and did not detect any of the contaminants listed in Subsection 19-13-B102(e)(4) were to monitor annually beginning January 1, 1993.

III. TOTAL TRIHALOMETHANE (TTHM's):

Although the TTHM standard applies to all water systems, only systems serving more than 10,000 people are required to monitor quarterly. It should be noted that in doing conventional testing for organic chemicals the TTHM's are included. Therefore, systems analyzing for organic chemicals are in effect analyzing for TTHM compounds.

The Federal Environmental Protection Agency in accordance with the Code of Federal Register (CFR) 141.64 has reduced the maximum contaminant level for TTHM from 100 ug/l to 80 ug/l effective January 1, 2002 for all surface water utilities serving more than 10,000 people. The Environmental Protection Agency has also established a maximum contaminant level of 60 ug/l for haloacetic acids effective January 1, 2002 for all surface water utilities serving 10,000 persons or more. Those utilities with surface water sources serving more than 10,000 people conducted quarterly monitoring for TTHM's and haloacetic acids during the 2002 survey year to determine compliance with the maximum contaminant levels. Those utilities which exceeded 80% of the maximum contaminant levels for TTHM's and haloacetic acids were required to conduct additional monitoring during the 2002 survey year to gather data to develop and establish disinfection profiles and benchmarks to enhance filtration performance.

All surface water systems serving 10,000 or less people were required to conduct quarterly monitoring during the third quarter of 2002 for TTHM's and haloacetic acids to ensure that TTHM and haloacetic acids levels throughout the distribution system do not exceed the newly enacted maximum contaminant levels of 80 ug/l and 60 ug/l.

The surface water systems serving more than 10,000 people were also required to conduct total organic carbon monitoring for both raw and treated water to reduce, through the filtration process, precursors (organic matter) which enhance the formation of TTHM's.

With respect to TTHM monitoring, surface water sources shall be tested quarterly. It is common knowledge that chlorinated surface waters produce TTHM's, therefore, proper surface water treatment will reduce those amounts. TTHM's of surface waters are also indicated in this report. None of these systems are in violation. Samples shall be collected in the distribution system at locations approved by DPH. The sampling locations and frequency may coincide with that approved under this Section for organic chemicals. Community water systems that serve a population of 10,000 or more must comply with the Code of Federal Register 141.30. When TTHM's are detected in water entering the distribution system as a result of disinfection, the DPH may exempt systems from the quarterly testing requirement provided the DPH determines that such testing is not necessary for the protection of public health.

IV. ORGANIC TEST RESULTS:

Organic test results are systematically reviewed by staff for determination of compliance with standards. Water systems that have sources violating standards must provide DPH with a proposal to show how compliance with standards can be achieved. Historically less than 3% of Connecticut's systems have organic chemical standard violations. However, there are water systems that have contaminants within allowable levels. These systems must monitor for organic chemicals appropriately in order to prevent possible exposures from any exceedances of organic chemical standards. The DPH ensures that water systems monitor appropriately. Non compliers may be brought into monitoring compliance through various enforcement actions if necessary.

Historically, the evaluation of TTHM/organic analytical results has precipitated a number of ground water investigation cases. One of the most notable ground water investigation cases began with the coincidental detection of Ethylene Dibromide, a pesticide used in the Connecticut River Valley farming communities to kill nematodes. The monitoring of private and public wells for Ethylene Dibromide continues in several towns today.

The Ethylene Dibromide case is an example of a detailed investigation of contamination to both public and private water supplies stemming from general TTHM/organic analyses. The discovery of Ethylene Dibromide contamination has led to the extension of water mains from public water supply systems to areas that have Ethylene Dibromide private well contamination. A detailed inventory listing of all sampling and contamination sites is available through the DPH.

It is important to note that the documented presence of an organic chemical in a public water supply does not necessarily constitute either a public health concern or regulatory violation. The particular organic chemical detected and its concentration determine the public health concern or regulatory violation and govern the regulatory action warranted.

Sections XIV and XV list by category those public water supplies that have organic chemical contamination. Section XVI provides information on all public water supplies currently treating for organic chemical contaminants.

V. REVISED ORGANIC CHEMICAL REGULATION:

To comply with federal primacy requirements (State primary enforcement responsibility over public water supplies), the DPH continually revises the State organic chemical regulations to be consistent with the Federal Environmental Protection Agency requirements. The Federal standards were adopted by Connecticut to enable the State to retain the proper legal authority to enforce federal mandates, including the increased emphasis by the Federal Environmental Protection Agency on the surveillance and monitoring of the non-community water systems.

The Safe Drinking Water Act Amendments as well as Public Health Code Regulation 19-13-B102(e) place the burden of organic chemical sampling and testing on the water utilities and private laboratories. The DPH has revised Public Health Code Regulation 19-13-B102(e) to incorporate the Federal organic chemical mandates adopted by the Environmental Protection Agency. The most recently revised version of Public Health Code Regulation 19-13-B102(e) became law on July 23, 2001.

VI. ACTION LEVELS FOR CHEMICAL CONTAMINANTS IN PUBLIC WATER SYSTEMS:

The chemical and concentration levels listed below are the 2003 action levels that were used by the DPH to determine the potability of water in the absence of formal standards. Action levels are based on the determination of health risk using the best available toxicological information. Action levels may change when warranted by new evidence of toxicity or risk management considerations.

<u>Chemical</u>	<u>2003 Action Level</u>	<u>Micrograms Per Liter (ug/l)</u>
Chloromethane		55
1,3 Dichlorobenzene		210
Dichlorodifluoromethane		350
1,1 Dichloroethane		80
Dieldrin		0.03
Isopropyl alcohol (Isopropanol)		2,300
Methyl Tert-Butyl Ether (MTBE)		70
Naphthalene		6.5
1,1,1,2 Tetrachloroethane		21
1,1,2,2 Tetrachloroethane		28
1, 2,3 Trichloropropane		0.05
T-Butanol		5*
Dibromomethane		5*
2,2 Dichloropropane		0.1*
Metolachlor		5*
Trichlorofluoromethane		1300
1,3 Dichloropropane		0.1*
Chlordane		0.3
1,2 Dichloroethane		1.0
Trimethylbenzenes		36
Benzene		1.0

* Special Review: If contamination is found in excess of the concentration listed, DPH will determine potability on a case by case basis.

VII. ESTIMATING POTENTIAL RISK OF CARCINOGENIC CHEMICALS AND REPRODUCTIVE

HAZARDS IN DRINKING WATER:

In assessing the danger of a particular compound, the Connecticut DPH considers the quality of evidence available in determining whether a particular chemical is a carcinogen, mutagen, teratogen or a reproductive hazard. The DPH also uses quantitative risk estimates that have been developed from risk extrapolation methods and information on toxicity from primary literature sources.

Connecticut DPH utilizes risk assessment methods established nationally by the US Environmental Protection Agency and the Agency for Toxic Substances and Disease Registry to evaluate ground water contamination and set Action Levels. These methods are consistent with the setting of drinking water maximum contaminant levels by the US Environmental Protection Agency. These methods cover the assessment of carcinogenic and non-carcinogenic toxic agents, and include an assessment of reproductive hazards.

In evaluating the risk associated with these chemicals, it is also significant to consider their frequency of occurrence. The trihalomethanes would be expected to occur in virtually all chlorinated surface water supplies. They are a by-product of the combination of the type of water disinfectant (typically chlorine based), disinfectant dosage and naturally occurring organic compounds in surface water.

Trichloroethylene, Trichloroethane, Tetrachloroethylene and Benzene are widely used in Connecticut as industrial solvents and are the most frequently occurring compounds found in major contamination investigations. Benzene, MTBE, ethylene dibromide and 1,2 Dichloroethane are also commonly associated with gasoline contamination. Most contamination incidents involving these chemicals occur in groundwater.

VIII. COSTS OF REMOVAL:

Contamination problems can be and have been resolved in a number of ways and the cost of remediation is evaluated on a case-by-case basis. There are two primary types of treatment for TTHM's and Organic Chemicals: granular activated carbon filtration and aeration. In addition, in the special case of trihalomethane formation in chlorinated surface water, alternative disinfectants or modifications to the conventional water treatment processes can eliminate or reduce the formation of trihalomethanes. New source development or blending and diluting the contaminated supplies are two other methods of resolving problems that do not involve treatment.

It is extremely difficult to evaluate treatment costs because of the many variables that must be considered, however, Sections IX, X, and XI indicate the generic estimated costs by the respective treatment techniques. These are the most current cost estimates available from the Environmental Protection Agency to determine the cost of regulatory compliance for utilities providing treatment. The exact cost of a particular treatment is dependent upon specific site conditions. Some of the most important variables are system size, water quality, specific chemicals to be removed, concentrations of chemicals to be removed, degree of removal, and technical parameters for the treatment process itself. Nevertheless it is possible to make logical estimates.

IX. TREATMENT COSTS - TETRACHLOROETHYLENE REMOVAL FROM GROUNDWATER:

The January 30, 1991, Environmental Protection Agency Federal Register Notice "National Primary Drinking Water Regulations: Synthetic Organic Chemicals and Inorganic Chemicals: Final Rule" included a study of the various costs associated with satisfying the provisions of the regulation. The Environmental Protection Agency discussed estimated treatment costs utilizing Packed Tower Aeration (PTA) or Granular Activated Carbon filtration (GAC) for 90% removal of Tetrachloroethylene in groundwater to ensure compliance with the maximum contaminant level of 5 micrograms/liter. Annual per household costs including capital and annual operation and maintenance based on year 2003 dollars are as follows:

SYSTEM SIZE (POPULATION SERVED)

	<u>25-100</u>	<u>10,000-25,000</u>	<u>Over 1,000,000</u>
GAC Cost/Household/Year	\$ 1,289.00	\$ 71.00	\$ 21.00
PTA Cost/Household/Year	\$ 180.00	\$ 11.00	\$ 8.00

X. TREATMENT COSTS - TRIHALOMETHANE REMOVAL FROM DRINKING WATER:

The December 16, 1998 Environmental Protection Agency Federal Register Notice "National Primary Drinking Water Regulations: Disinfectants and Disinfection Byproducts: Final Rule" included a study of estimated costs for granular activated carbon filtration or enhanced coagulation for a typical surface water system to satisfy the proposed maximum contaminant level for Total Trihalomethanes at 80 micrograms per liter. Annual per household costs including capital and annual operation and maintenance based on year 2003 dollars are as follows:

SYSTEM SIZE (POPULATION SERVED)

	<u>3,300-10,000</u>	<u>10,000-25,000</u>	<u>100,000-500,000</u>
GAC Cost/Household/Year	\$ 56.00	\$ 42.00	\$ 20.00
Enhanced Coagulation Cost/Household/Year	\$ 10.00	\$ 8.00	\$ 7.00

XI. TREATMENT COSTS - ORGANICS REMOVAL FROM PRIVATE RESIDENTIAL WATER SYSTEMS:

The cost of treating a private residential well with Granular Activated Carbon is considerable. It costs approximately \$1,000.00 to \$1,500.00 for initial installation, \$100.00 to \$200.00 each time the filter media (carbon) is replaced, and approximately \$100.00 to analyze an individual sample for compliance/monitoring purposes. As a specific example: Treatment costs for Ethylene Dibromide average \$1,000.00 per filter for a single family home and about \$400.00 per year for maintenance and monitoring. A public water main extension alternative costs on the average \$50.00 - \$100.00 per foot of main and the service line installation costs approximately \$1000.00 per home. Annual water bills vary by water company.

XII. COST IMPACT OF PUBLIC HEALTH CODE MODIFICATIONS FOR ORGANIC CHEMICALS TO PUBLIC WATER SYSTEMS:

Estimated analytical costs to a public water supply is approximately \$1,700 for a single round of sampling as required for organics testing. The DPH recognizes that these organic monitoring costs are substantial and has encouraged utilities to composite samples as well as request monitoring waivers. Provided that initial monitoring results are satisfactory, a waiver could be granted and reduce the annual cost of the analyses for the parameters required in the regulations by approximately 60%.

XIII. REGULATORY INFORMATION:

Specific information regarding organic chemical monitoring and analytical results is available from DPH on request. DPH reports compliance information to the Environmental Protection Agency quarterly in a Federally prescribed manner. In addition, starting in 1996, Connecticut issued to the public, an annual Public Water Systems Violation Report citing Safe Drinking Water Act violations. This report for 2003 will be available through the Drinking Water Division of the DPH after July 1, 2003. Water quality standard violations in Connecticut are not extensive, in part due to an active surveillance program. The threat of contamination is widespread and can occur at anytime. The remaining sections highlight pertinent organic chemical information.

XIV. ORGANIC CHEMICAL MAXIMUM CONTAMINANT LEVELS VIOLATIONS, 2003

One (1) public water system exceeded organic chemical maximum contaminant levels or action levels during 2003. The system and its corresponding levels are specified below:

<u>Town</u>	<u>Public Water System</u>	<u>Contaminant/ Standard (ppb)</u>	<u>Levels (ppb)</u>
Glastonbury 27.1 ppb	J. T. Slocomb Corp.* (CT 0540912)	Trichloroethylene/5ppb	

* This Public Water System is no longer active and the well has been abandoned.

ATTACHMENT XV
PUBLIC WATER SYSTEMS THAT DETECTED ORGANIC
CHEMICALS DURING 2003

During 2003, one hundred and eighty-three (183) Public Water Systems detected organic chemicals above minimum detection limits but below the maximum contaminant levels entering distribution. Those utilities are listed in Attachment XV. Of these, 63 are community supplies and 120 are non-community supplies.

Positive Organics for Calendar Year 2003

TOWN	SYSTEM TYPE	SYSTEM NAME	PWSID	FACILITY NAME	FACILITY TYPE	COLLECTION DATE	CHEMICAL	MEASURE	UNIT OF MEASURE
ASHFORD	NON TRAN NON COMM	ASHFORD ELEMENTARY SCHOOL	CT0030152	ENTRY POINT	SS	06/16/2003	TETRACHLOROETHYLENE	0.0016	MG/L
ASHFORD	NON TRAN NON COMM	ASHFORD ELEMENTARY SCHOOL	CT0030152	ENTRY POINT	SS	07/18/2003	TETRACHLOROETHYLENE	0.0071	MG/L
ASHFORD	NON TRANSIENT	CUMBERLAND FARMS	CT0030164	ENTRY POINT	SS	11/18/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.9	MG/L
ASHFORD	NON TRANSIENT	CUMBERLAND FARMS	CT0030164	WELL	WL	11/18/2003	METHYL TERT-BUTYL ETHER (MTBE)	9	MG/L
AVON	COMMUNITY	AVON WATER CO	CT0040011	ENTRY POINT-FW#1	SS	05/19/2003	DICHLOROMETHANE	0.00063	MG/L
AVON	COMMUNITY	AVON WATER CO	CT0040011	ENTRY POINT-FW#2	SS	11/05/2003	DICHLOROMETHANE	0.00062	MG/L
AVON	COMMUNITY	AVON WATER CO	CT0040011	ENTRY POINT-WELL#2	SS	08/28/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00139	MG/L
BERLIN	COMMUNITY	BERLIN WATER CONTROL COMMISSION	CT0070021	ELTON WELL 2A	WL	09/10/2003	TRICHLOROETHYLENE	0.0035	MG/L
BERLIN	COMMUNITY	BERLIN WATER CONTROL COMMISSION	CT0070021	ELTON WELL 2A	WL	12/09/2003	TRICHLOROETHYLENE	0.0042	MG/L
BERLIN	COMMUNITY	BERLIN WATER CONTROL COMMISSION	CT0070021	ENTRY POINT	SS	05/08/2003	TRICHLOROETHYLENE	0.0016	MG/L
BERLIN	COMMUNITY	BERLIN WATER CONTROL COMMISSION	CT0070021	ENTRY POINT	SS	09/10/2003	TRICHLOROETHYLENE	0.0015	MG/L
BERLIN	COMMUNITY	BERLIN WATER CONTROL COMMISSION	CT0070021	ENTRY POINT	SS	12/09/2003	TRICHLOROETHYLENE	0.0018	MG/L
BETHANY	NON TRANSIENT	NONNIES DELI	CT0080154	BETWEEN GAC FILTRATION	TP	09/04/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.14	MG/L
BETHANY	NON TRANSIENT	NONNIES DELI	CT0080154	BETWEEN GAC FILTRATION	TP	09/04/2003	CIS-1,2-DICHLOROETHYLENE	0.0005	MG/L
BETHANY	NON TRANSIENT	NONNIES DELI	CT0080154	BETWEEN GAC FILTRATION	TP	12/17/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.210	MG/L
BETHANY	NON TRANSIENT	NONNIES DELI	CT0080154	POST GAC TREATMENT	TP	12/17/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.230	MG/L
BETHANY	NON TRANSIENT	NONNIES DELI	CT0080154	WELL	WL	12/17/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.199	MG/L
BETHEL	NON TRANSIENT	SEVEN-ELEVEN (7-11) FOOD STORE	CT0090224	ENTRY POINT	SS	01/09/2003	CIS-1,2-DICHLOROETHYLENE	0.0016	MG/L
BETHEL	NON TRANSIENT	SEVEN-ELEVEN (7-11) FOOD STORE	CT0090224	ENTRY POINT	SS	01/09/2003	TRICHLOROETHYLENE	0.0019	MG/L
BETHEL	NON TRANSIENT	SEVEN-ELEVEN (7-11) FOOD STORE	CT0090224	ENTRY POINT	SS	01/09/2003	TETRACHLOROETHYLENE	0.0016	MG/L
BETHEL	NON TRANSIENT	SEVEN-ELEVEN (7-11) FOOD STORE	CT0090224	ENTRY POINT	SS	02/11/2003	CIS-1,2-DICHLOROETHYLENE	0.0015	MG/L
BETHEL	NON TRANSIENT	SEVEN-ELEVEN (7-11) FOOD STORE	CT0090224	ENTRY POINT	SS	02/11/2003	TRICHLOROETHYLENE	0.0018	MG/L
BETHEL	NON TRANSIENT	SEVEN-ELEVEN (7-11) FOOD STORE	CT0090224	ENTRY POINT	SS	02/11/2003	TETRACHLOROETHYLENE	0.0014	MG/L
BETHEL	NON TRANSIENT	SEVEN-ELEVEN (7-11) FOOD STORE	CT0090224	ENTRY POINT	SS	07/15/2003	CIS-1,2-DICHLOROETHYLENE	0.0020	MG/L
BETHEL	NON TRANSIENT	SEVEN-ELEVEN (7-11) FOOD STORE	CT0090224	ENTRY POINT	SS	07/15/2003	TRICHLOROETHYLENE	0.0026	MG/L
BETHEL	NON TRANSIENT	SEVEN-ELEVEN (7-11) FOOD STORE	CT0090224	ENTRY POINT	SS	07/15/2003	TETRACHLOROETHYLENE	0.0018	MG/L
BOLTON	NON TRAN NON COMM	BOLTON CENTER SCHOOL (K-8)	CT0120212	ENTRY POINT	SS	10/10/2003	TOLUENE	0.00051	MG/L
BOZRAH	NON TRAN NON COMM	KOKKOFF EGG FARM	CT0130123	ENTRY POINT	SS	11/11/2003	1,2-DICHLOROPROPANE	0.0012	MG/L
BRISTOL	COMMUNITY	CHIPPANYDALE ASSOCIATION	CT0176021	ENTRY POINT	SS	07/17/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0008	MG/L
BROOKFIELD	COMMUNITY	20 STATION ROAD - APT BUILDING	CT0187041	ENTRY POINT	SS	02/20/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0035	MG/L
BROOKFIELD	COMMUNITY	20 STATION ROAD - APT BUILDING	CT0187041	WELL 2	WL	02/20/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0028	MG/L
BROOKFIELD	COMMUNITY	20 STATION ROAD - APT BUILDING	CT0187041	WELL 2	WL	02/20/2003	1,2,4-TRICHLOROBENZENE	0.0011	MG/L
BROOKFIELD	COMMUNITY	20 STATION ROAD - APT BUILDING	CT0187041	WELL 2	WL	02/20/2003	CIS-1,2-DICHLOROETHYLENE	0.0036	MG/L
BROOKFIELD	COMMUNITY	20 STATION ROAD - APT BUILDING	CT0187041	WELL 2	WL	02/20/2003	M-DICHLOROBENZENE	0.0019	MG/L
BROOKFIELD	COMMUNITY	20 STATION ROAD - APT BUILDING	CT0187041	WELL 2	WL	02/20/2003	O-DICHLOROBENZENE	0.0016	MG/L
BROOKFIELD	COMMUNITY	20 STATION ROAD - APT BUILDING	CT0187041	WELL 2	WL	02/20/2003	P-DICHLOROBENZENE	0.0014	MG/L
BROOKFIELD	COMMUNITY	20 STATION ROAD - APT BUILDING	CT0187041	WELL 2	WL	02/20/2003	TRICHLOROETHYLENE	0.013	MG/L
BROOKFIELD	COMMUNITY	20 STATION ROAD - APT BUILDING	CT0187041	WELL 2	WL	02/20/2003	TETRACHLOROETHYLENE	0.160	MG/L
BROOKFIELD	COMMUNITY	20 STATION ROAD - APT BUILDING	CT0187041	WELL 2	WL	08/28/2003	TETRACHLOROETHYLENE	107	MG/L
BROOKFIELD	COMMUNITY	20 STATION ROAD - APT BUILDING	CT0187041	WELL 2	WL	09/30/2003	TETRACHLOROETHYLENE	109	MG/L
BROOKFIELD	NON TRAN NON COMM	BROOKFIELD CENTER LLC	CT0180152	ENTRY POINT	SS	05/07/2003	NAPHTHALENE	0.002	MG/L
BROOKFIELD	NON TRAN NON COMM	BROOKFIELD CENTER LLC	CT0180152	ENTRY POINT	SS	05/07/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0018	MG/L
BROOKFIELD	NON TRAN NON COMM	BROOKFIELD CENTER LLC	CT0180152	WELL	WL	05/07/2003	NAPHTHALENE	0.00085	MG/L
BROOKFIELD	NON TRAN NON COMM	BROOKFIELD CENTER LLC	CT0180152	WELL	WL	05/07/2003	TRICHLOROETHYLENE	0.00079	MG/L
BROOKFIELD	NON TRANSIENT	BROOKFIELD SHELL	CT0180634	ENTRY POINT	SS	03/05/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0007	MG/L
BROOKFIELD	NON TRANSIENT	BROOKFIELD SHELL	CT0180634	ENTRY POINT	SS	03/05/2003	TOLUENE	0.0015	MG/L
BROOKFIELD	NON TRANSIENT	BROOKFIELD SHELL	CT0180634	ENTRY POINT	SS	07/31/2003	TRICHLOROETHYLENE	0.0016	MG/L
BROOKFIELD	NON TRANSIENT	BROOKFIELD SHELL	CT0180634	TREATMENT PLANT	TP	03/05/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0004	MG/L
BROOKFIELD	NON TRANSIENT	BROOKFIELD SHELL	CT0180634	TREATMENT PLANT	TP	03/05/2003	TOLUENE	0.000069	MG/L
BROOKFIELD	NON TRANSIENT	BROOKFIELD SHELL	CT0180634	WELL	WL	03/05/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00052	MG/L
BROOKFIELD	NON TRANSIENT	BROOKFIELD SHELL	CT0180634	WELL	WL	03/05/2003	TOLUENE	0.0011	MG/L
BROOKFIELD	NON TRANSIENT	BROOKFIELD SHELL	CT0180634	WELL	WL	07/31/2003	TRICHLOROETHYLENE	0.0061	MG/L
BROOKFIELD	NON TRANSIENT	BROOKFIELD SHELL	CT0180634	WELL	WL	07/31/2003	TETRACHLOROETHYLENE	0.001	MG/L
BROOKFIELD	NON TRANSIENT	BROOKFIELD SHELL	CT0180634	WELL	WL	10/30/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00059	MG/L
BROOKFIELD	NON TRANSIENT	BROOKFIELD SUNOCO	CT0180664	WELL	WL	12/09/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.2381	MG/L
BROOKFIELD	NON TRAN NON COMM	CANDLEBROOK VILLAGE	CT0189293	BETWEEN GAC FILTERS	SS	08/14/2003	TETRACHLOROETHYLENE	0.0007	MG/L
BROOKFIELD	NON TRAN NON COMM	CANDLEBROOK VILLAGE	CT0189293	COMBINED RAW WATER DISCHARGE	SS	05/20/2003	TETRACHLOROETHYLENE	0.0025	MG/L
BROOKFIELD	NON TRAN NON COMM	COUNTRY KIDS CLUB	CT0189763	WELL #1	WL	03/13/2003	TETRACHLOROETHYLENE	0.0013	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	BETWEEN GAC FILTERS	SS	03/21/2003	TRICHLOROETHYLENE	0.0044	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	BETWEEN GAC FILTERS	SS	03/21/2003	TETRACHLOROETHYLENE	0.0232	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	BETWEEN GAC FILTERS	SS	06/27/2003	CIS-1,2-DICHLOROETHYLENE	0.00575	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	BETWEEN GAC FILTERS	SS	06/27/2003	TRICHLOROETHYLENE	0.00491	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	BETWEEN GAC FILTERS	SS	06/27/2003	TETRACHLOROETHYLENE	0.0226	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	BETWEEN GAC FILTERS	SS	08/28/2003	CIS-1,2-DICHLOROETHYLENE	0.00247	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	BETWEEN GAC FILTERS	SS	08/28/2003	TRICHLOROETHYLENE	0.00213	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	BETWEEN GAC FILTERS	SS	08/28/2003	TETRACHLOROETHYLENE	0.0105	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	BETWEEN GAC FILTERS	SS	12/12/2003	CIS-1,2-DICHLOROETHYLENE	0.00124	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	ENTRY POINT	SS	06/27/2003	CIS-1,2-DICHLOROETHYLENE	0.00572	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	ENTRY POINT	SS	06/27/2003	TRICHLOROETHYLENE	0.00196	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	ENTRY POINT	SS	06/27/2003	TETRACHLOROETHYLENE	0.00437	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	ENTRY POINT	SS	12/12/2003	CIS-1,2-DICHLOROETHYLENE	0.00095	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	WELL #3	WL	06/27/2003	CIS-1,2-DICHLOROETHYLENE	0.00705	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	WELL #3	WL	06/27/2003	TRICHLOROETHYLENE	0.0064	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	WELL #3	WL	06/27/2003	TETRACHLOROETHYLENE	0.0288	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	WELL #3	WL	09/25/2003	CIS-1,2-DICHLOROETHYLENE	0.0101	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	WELL #3	WL	09/25/2003	TRICHLOROETHYLENE	0.0084	MG/L

Positive Organics for Calendar Year 2003

TOWN	SYSTEM TYPE	SYSTEM NAME	PWSID	FACILITY NAME	FACILITY TYPE	COLLECTION DATE	CHEMICAL	MEASURE	UNIT OF MEASURE
ASHFORD	NON TRAN NON COMM	ASHFORD ELEMENTARY SCHOOL	CT0030152	ENTRY POINT	SS	06/16/2003	TETRACHLOROETHYLENE	0.0016	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	WELL #3	WL	09/25/2003	TETRACHLOROETHYLENE	0.0344	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	WELL #3	WL	12/12/2003	CIS-1,2-DICHLOROETHYLENE	0.00757	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	WELL #3	WL	12/12/2003	TRICHLOROETHYLENE	0.0051	MG/L
BROOKFIELD	NON TRAN NON COMM	DORCAL CAOB ASSOCIATES-RADIO SHACK WELL	CT0189703	WELL #3	WL	12/12/2003	TETRACHLOROETHYLENE	0.0349	MG/L
BROOKFIELD	NON TRAN NON COMM	GRAYS BRIDGE COMMONS	CT0189743	ENTRY POINT BUILDING B	SS	04/08/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0133	MG/L
BROOKFIELD	NON TRAN NON COMM	KOHL'S DEPARTMENT STORES, INC.	CT0189473	ENTRY POINT	SS	02/21/2003	TRICHLOROETHYLENE	0.00279	MG/L
BROOKFIELD	NON TRAN NON COMM	KOHL'S DEPARTMENT STORES, INC.	CT0189473	ENTRY POINT	SS	03/18/2003	P-DICHLOROETHYLENE	0.0006	MG/L
BROOKFIELD	NON TRAN NON COMM	KOHL'S DEPARTMENT STORES, INC.	CT0189473	ENTRY POINT	SS	03/18/2003	TRICHLOROETHYLENE	0.0026	MG/L
BROOKFIELD	NON TRAN NON COMM	KOHL'S DEPARTMENT STORES, INC.	CT0189473	ENTRY POINT	SS	04/10/2003	TRICHLOROETHYLENE	0.0025	MG/L
BROOKFIELD	NON TRAN NON COMM	KOHL'S DEPARTMENT STORES, INC.	CT0189473	ENTRY POINT	SS	06/18/2003	TRICHLOROETHYLENE	0.00267	MG/L
BROOKFIELD	NON TRAN NON COMM	KOHL'S DEPARTMENT STORES, INC.	CT0189473	ENTRY POINT	SS	07/22/2003	TRICHLOROETHYLENE	0.0024	MG/L
BROOKFIELD	NON TRAN NON COMM	KOHL'S DEPARTMENT STORES, INC.	CT0189473	ENTRY POINT	SS	09/15/2003	TRICHLOROETHYLENE	0.00239	MG/L
BROOKFIELD	NON TRAN NON COMM	KOHL'S DEPARTMENT STORES, INC.	CT0189473	ENTRY POINT	SS	11/18/2003	TRICHLOROETHYLENE	0.0021	MG/L
BROOKFIELD	NON TRAN NON COMM	KOHL'S DEPARTMENT STORES, INC.	CT0189473	ENTRY POINT	SS	12/12/2003	TRICHLOROETHYLENE	0.00127	MG/L
BROOKFIELD	NON TRANSIENT	WEBSTER BANK	CT0180064	GAC FILTERS	TP	10/07/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.003	MG/L
BROOKFIELD	NON TRANSIENT	WEBSTER BANK	CT0180064	GAC FILTERS	TP	12/09/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0009	MG/L
BROOKFIELD	NON TRANSIENT	WEBSTER BANK	CT0180064	WELL	WL	12/09/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0685	MG/L
BROOKFIELD	NON TRANSIENT	WEBSTER BANK	CT0180064	WELL	WL	12/09/2003	TRICHLOROETHYLENE	0.0022	MG/L
BROOKFIELD	NON TRANSIENT	WENDYS RESTAURANT	CT0180614	WELL #1	WL	05/20/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.013	MG/L
BROOKFIELD	NON TRANSIENT	WENDYS RESTAURANT	CT0180614	WELL #1	WL	05/20/2003	TRICHLOROETHYLENE	0.0025	MG/L
BROOKFIELD	NON TRANSIENT	WENDYS RESTAURANT	CT0180614	WELL #1	WL	12/10/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.023	MG/L
BROOKFIELD	NON TRANSIENT	WENDYS RESTAURANT	CT0180614	WELL #1	WL	12/10/2003	TRICHLOROETHYLENE	0.0029	MG/L
BURLINGTON	NON TRAN NON COMM	BURLINGTON COMMONS	CT0209213	BETWEEN GAC FILTERS	SS	02/26/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0007	MG/L
BURLINGTON	NON TRAN NON COMM	BURLINGTON COMMONS	CT0209213	BETWEEN GAC FILTERS	SS	04/17/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0005	MG/L
BURLINGTON	NON TRAN NON COMM	BURLINGTON COMMONS	CT0209213	WELL	WL	01/22/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.003	MG/L
BURLINGTON	NON TRAN NON COMM	BURLINGTON COMMONS	CT0209213	WELL	WL	02/26/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.006	MG/L
BURLINGTON	NON TRAN NON COMM	BURLINGTON COMMONS	CT0209213	WELL	WL	04/17/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.005	MG/L
BURLINGTON	NON TRAN NON COMM	BURLINGTON COMMONS	CT0209213	WELL	WL	05/12/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.005	MG/L
BURLINGTON	NON TRAN NON COMM	BURLINGTON COMMONS	CT0209213	WELL	WL	06/19/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.004	MG/L
BURLINGTON	NON TRAN NON COMM	BURLINGTON COMMONS	CT0209213	WELL	WL	08/13/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0005	MG/L
BURLINGTON	NON TRAN NON COMM	BURLINGTON POST OFFICE	CT0200114	ENTRY POINT	SS	09/04/2003	TOLUENE	0.0006	MG/L
BURLINGTON	NON TRAN NON COMM	BURLINGTON POST OFFICE	CT0200114	ENTRY POINT	SS	09/04/2003	TOLUENE	0.0006	MG/L
BURLINGTON	NON TRAN NON COMM	YOUNG BEGINNINGS CHILDRENS CENTER, INC.	CT0209313	ENTRY POINT	SS	11/04/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00106	MG/L
CANAAN	NON TRAN NON COMM	TOWN OF CANAAN - FALLS VILLAGE DAYCARE	CT0210023	ENTRY POINT	SS	06/30/2003	1,2,4-TRIMETHYLBENZENE	0.0010	MG/L
CANAAN	NON TRAN NON COMM	TOWN OF CANAAN - FALLS VILLAGE DAYCARE	CT0210023	ENTRY POINT	SS	06/30/2003	1,3,5-TRIMETHYLBENZENE	0.0005	MG/L
CHESHIRE	NON TRAN NON COMM	CURTIS HOMESTEAD VILLAGE	CT0250233	ENTRY POINT	SS	07/07/2003	TOLUENE	0.0014	MG/L
CHESTER	COMMUNITY	AARON MANOR NURSING & REHAB CENTER	CT0261001	WELL 5	WL	06/10/2003	NAPHTHALENE	0.0013	MG/L
CHESTER	COMMUNITY	AARON MANOR NURSING & REHAB CENTER	CT0261001	WELL 5	WL	06/10/2003	1,2,4-TRIMETHYLBENZENE	0.0016	MG/L
CHESTER	COMMUNITY	AARON MANOR NURSING & REHAB CENTER	CT0261001	WELL 5	WL	06/10/2003	1,3,5-TRIMETHYLBENZENE	0.0005	MG/L
CHESTER	COMMUNITY	DENLAR APARTMENTS - BUILDINGS 17 & 19	CT0261021	ENTRY POINT	SS	05/12/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00052	MG/L
CHESTER	COMMUNITY	DENLAR APARTMENTS - BUILDINGS 17 & 19	CT0261021	ENTRY POINT	SS	05/12/2003	1,1-DICHLOROETHANE	0.0009	MG/L
CHESTER	COMMUNITY	DENLAR APARTMENTS - BUILDINGS 17 & 19	CT0261021	ENTRY POINT	SS	05/12/2003	TRICHLOROETHYLENE	0.00054	MG/L
CHESTER	COMMUNITY	DENLAR APARTMENTS - BUILDINGS 17 & 19	CT0261021	ENTRY POINT	SS	08/12/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00061	MG/L
CHESTER	COMMUNITY	DENLAR APARTMENTS - BUILDINGS 17 & 19	CT0261021	ENTRY POINT	SS	08/12/2003	1,1-DICHLOROETHANE	0.00076	MG/L
CHESTER	COMMUNITY	DENLAR APARTMENTS - BUILDINGS 17 & 19	CT0261021	ENTRY POINT	SS	10/21/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00065	MG/L
CHESTER	COMMUNITY	DENLAR APARTMENTS - BUILDINGS 17 & 19	CT0261021	ENTRY POINT	SS	10/21/2003	1,1-DICHLOROETHANE	0.0011	MG/L
CHESTER	COMMUNITY	DENLAR APARTMENTS - BUILDINGS 17 & 19	CT0261021	ENTRY POINT	SS	10/21/2003	TRICHLOROETHYLENE	0.00055	MG/L
CHESTER	NON TRAN NON COMM	GBR SYSTEMS CORPORATION	CT0261043	WELL	WL	07/23/2003	TETRACHLOROETHYLENE	0.0048	MG/L
CHESTER	NON TRAN NON COMM	ROTO FRANK OF AMERICA	CT0261053	ENTRY POINT	SS	04/08/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0032	MG/L
CHESTER	NON TRAN NON COMM	ROTO FRANK OF AMERICA	CT0261053	ENTRY POINT	SS	07/08/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0012	MG/L
CLINTON	COMMUNITY	EVERGREEN TRAILER PARK - SYSTEM #3	CT0270101	ENTRY POINT	SS	02/12/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0016	MG/L
CLINTON	COMMUNITY	EVERGREEN TRAILER PARK - SYSTEM #3	CT0270101	ENTRY POINT	SS	07/31/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0008	MG/L
CLINTON	COMMUNITY	EVERGREEN TRAILER PARK - SYSTEM #4	CT0270111	ENTRY POINT	SS	02/12/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0019	MG/L
CLINTON	COMMUNITY	EVERGREEN TRAILER PARK - SYSTEM #4	CT0270111	ENTRY POINT	SS	05/29/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0012	MG/L
CLINTON	COMMUNITY	EVERGREEN TRAILER PARK - SYSTEM #4	CT0270111	ENTRY POINT	SS	07/31/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0028	MG/L
COLCHESTER	NON TRAN NON COMM	109 LOOMIS ROAD	CT0280163	ENTRY POINT	SS	11/06/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.001	MG/L
COLCHESTER	COMMUNITY	COLCHESTER SEWER & WATER COMMISSION	CT0280011	CABIN ROAD WTP ENTRY POINT	SS	03/26/2003	METHYL TERT-BUTYL ETHER (MTBE)	1.0	MG/L
COLCHESTER	COMMUNITY	COLCHESTER SEWER & WATER COMMISSION	CT0280011	CABIN ROAD WTP ENTRY POINT	SS	09/10/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0011	MG/L
COLCHESTER	COMMUNITY	COLCHESTER SEWER & WATER COMMISSION	CT0280011	CABIN ROAD WTP ENTRY POINT	SS	12/09/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0011	MG/L
COLCHESTER	COMMUNITY	COLCHESTER SEWER & WATER COMMISSION	CT0280011	WELL #4 WTP ENTRY POINT	SS	06/17/2003	TETRACHLOROETHYLENE	0.00077	MG/L
COLCHESTER	COMMUNITY	COLCHESTER SEWER & WATER COMMISSION	CT0280011	WELL #4 WTP ENTRY POINT	SS	09/10/2003	TETRACHLOROETHYLENE	0.0007	MG/L
COLCHESTER	COMMUNITY	COLCHESTER SEWER & WATER COMMISSION	CT0280011	WELL #4 WTP ENTRY POINT	SS	12/09/2003	TETRACHLOROETHYLENE	0.00071	MG/L
COLUMBIA	NON TRAN NON COMM	COLUMBIA FORD	CT0300182	ENTRY POINT	SS	06/19/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00056	MG/L
COLUMBIA	NON TRAN NON COMM	COLUMBIA FORD	CT0300182	ENTRY POINT	SS	07/10/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00062	MG/L
COLUMBIA	NON TRAN NON COMM	COLUMBIA FORD	CT0300182	ENTRY POINT	SS	11/06/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00064	MG/L
COLUMBIA	NON TRAN NON COMM	COLUMBIA FORD	CT0300182	ENTRY POINT	SS	11/06/2003	STYRENE	0.0012	MG/L
COLUMBIA	NON TRAN NON COMM	HORACE PORTER SCHOOL	CT0300062	ENTRY POINT	SS	03/14/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.002	MG/L
COLUMBIA	NON TRAN NON COMM	HORACE PORTER SCHOOL	CT0300062	ENTRY POINT	SS	05/16/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.003	MG/L
COLUMBIA	NON TRAN NON COMM	HORACE PORTER SCHOOL	CT0300062	ENTRY POINT	SS	05/16/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.002	MG/L
COLUMBIA	NON TRAN NON COMM	HORACE PORTER SCHOOL	CT0300062	ENTRY POINT	SS	12/18/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.004	MG/L
COVENTRY	COMMUNITY	BIRMINGHAM UTIL - GENERAL WATER DIVISION	CT0320071	ENTRY POINT	SS	07/09/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00079	MG/L
COVENTRY	NON TRAN NON COMM	MEADOWBROOK SHOPPING CENTER	CT0321172	ENTRY POINT	SS	06/23/2003	1,2-DICHLOROETHANE	0.0006	MG/L
CROMWELL	COMMUNITY	CROMWELL FIRE DISTRICT WATER DEPARTMENT	CT0330011	GARDINER WELL 2	WL	02/26/2003	1,1,1-TRICHLOROETHANE	0.0011	MG/L
CROMWELL	COMMUNITY	CROMWELL FIRE DISTRICT WATER DEPARTMENT	CT0330011	GARDINER WELL 2	WL	05/29/2003	1,1,1-TRICHLOROETHANE	0.0011	MG/L

Positive Organics for Calendar Year 2003

TOWN	SYSTEM TYPE	SYSTEM NAME	PWSID	FACILITY NAME	FACILITY TYPE	COLLECTION DATE	CHEMICAL	MEASURE	UNIT OF MEASURE
ASHFORD	NON TRAN NON COMM	ASHFORD ELEMENTARY SCHOOL	CT0030152	ENTRY POINT	SS	06/16/2003	TETRACHLOROETHYLENE	0.0016	MG/L
CROMWELL	COMMUNITY	CROMWELL FIRE DISTRICT WATER DEPARTMENT	CT0330011	GARDINER WELL 2	WL	11/25/2003	1,1,1-TRICHLOROETHANE	0.0006	MG/L
CROMWELL	COMMUNITY	CROMWELL FIRE DISTRICT WATER DEPARTMENT	CT0330011	GARDINER WELL 3	WL	02/26/2003	1,1,1-TRICHLOROETHANE	0.0018	MG/L
CROMWELL	COMMUNITY	CROMWELL FIRE DISTRICT WATER DEPARTMENT	CT0330011	GARDINER WELL 3	WL	02/26/2003	TRICHLOROETHYLENE	0.0008	MG/L
CROMWELL	COMMUNITY	CROMWELL FIRE DISTRICT WATER DEPARTMENT	CT0330011	GARDINER WELL 3	WL	05/29/2003	1,1,1-TRICHLOROETHANE	0.0015	MG/L
CROMWELL	COMMUNITY	CROMWELL FIRE DISTRICT WATER DEPARTMENT	CT0330011	GARDINER WELL 3	WL	08/27/2003	1,1,1-TRICHLOROETHANE	0.0019	MG/L
CROMWELL	COMMUNITY	CROMWELL FIRE DISTRICT WATER DEPARTMENT	CT0330011	GARDINER WELL 3	WL	08/27/2003	TRICHLOROETHYLENE	0.0006	MG/L
CROMWELL	COMMUNITY	CROMWELL FIRE DISTRICT WATER DEPARTMENT	CT0330011	GARDINER WELL 3	WL	11/25/2003	1,1,1-TRICHLOROETHANE	0.0014	MG/L
CROMWELL	COMMUNITY	CROMWELL FIRE DISTRICT WATER DEPARTMENT	CT0330011	GARDINER WELL 3	WL	11/25/2003	TRICHLOROETHYLENE	0.0006	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY (112 NEWTOWN ROAD)	CT0341334	ENTRY POINT	SS	09/08/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00094	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	BETWEEN GAC FILTERS	SS	03/05/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0011	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	BETWEEN GAC FILTERS	SS	03/05/2003	XYLENE, PARA	0.0013	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	BETWEEN GAC FILTERS	SS	03/05/2003	TOLUENE	0.032	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	BETWEEN GAC FILTERS	SS	03/05/2003	XYLENE, META	0.0013	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	BETWEEN GAC FILTERS	SS	05/06/2003	TOLUENE	0.0059	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	BETWEEN GAC FILTERS	SS	07/07/2003	BROMOMETHANE	0.00079	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	BETWEEN GAC FILTERS	SS	07/07/2003	TOLUENE	0.0041	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	BETWEEN GAC FILTERS	SS	10/01/2003	CHLOROMETHANE	0.0008	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	BETWEEN GAC FILTERS	SS	11/03/2003	TOLUENE	0.0022	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	BETWEEN GAC FILTERS	SS	12/11/2003	TOLUENE	0.0018	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	DISTRIBUTION SYSTEM	DS	03/05/2003	TOLUENE	0.0025	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	ENTRY POINT	SS	05/06/2003	TOLUENE	0.0015	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	ENTRY POINT	SS	07/07/2003	BROMOMETHANE	0.00076	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	ENTRY POINT	SS	07/07/2003	TOLUENE	0.0012	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	ENTRY POINT	SS	09/08/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.000103	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	ENTRY POINT	SS	10/01/2003	CHLOROMETHANE	0.00067	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	ENTRY POINT	SS	10/01/2003	BROMOMETHANE	0.00075	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	ENTRY POINT	SS	10/01/2003	TOLUENE	0.00057	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	ENTRY POINT	SS	11/03/2003	TOLUENE	0.0013	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	WELL #1	WL	03/05/2003	XYLENE, PARA	0.0012	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	WELL #1	WL	03/05/2003	TOLUENE	0.02	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	WELL #1	WL	03/05/2003	XYLENE, META	0.0012	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	WELL #1	WL	03/31/2003	TOLUENE	0.0022	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	WELL #1	WL	05/06/2003	TOLUENE	0.0065	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	WELL #1	WL	07/07/2003	TOLUENE	0.0025	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	WELL #1	WL	08/08/2003	CHLOROMETHANE	0.00063	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	WELL #1	WL	09/08/2003	CHLOROMETHANE	0.00099	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	WELL #1	WL	09/08/2003	TOLUENE	0.00052	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	WELL #1	WL	11/03/2003	TOLUENE	0.0017	MG/L
DANBURY	NON TRANSIENT	GLOBAL DANBURY - FEDERAL RD	CT0341324	WELL #1	WL	12/11/2003	TOLUENE	0.0017	MG/L
DARIEN	COMMUNITY	AQUARION WATER CO OF CT-NOROTON SYSTEM	CT0350011	REWAK WELL	WL	02/12/2003	CIS-1,2-DICHLOROETHYLENE	0.0016	MG/L
DARIEN	COMMUNITY	AQUARION WATER CO OF CT-NOROTON SYSTEM	CT0350011	REWAK WELL	WL	02/12/2003	TRICHLOROETHYLENE	0.0007	MG/L
DARIEN	COMMUNITY	AQUARION WATER CO OF CT-NOROTON SYSTEM	CT0350011	REWAK WELL	WL	02/12/2003	TETRACHLOROETHYLENE	0.0014	MG/L
DARIEN	COMMUNITY	AQUARION WATER CO OF CT-NOROTON SYSTEM	CT0350011	REWAK WELL	WL	05/14/2003	TRICHLOROETHYLENE	0.0005	MG/L
DARIEN	COMMUNITY	AQUARION WATER CO OF CT-NOROTON SYSTEM	CT0350011	REWAK WELL	WL	05/14/2003	TETRACHLOROETHYLENE	0.0011	MG/L
DARIEN	COMMUNITY	AQUARION WATER CO OF CT-NOROTON SYSTEM	CT0350011	REWAK WELL	WL	08/19/2003	TRICHLOROETHYLENE	0.0006	MG/L
DARIEN	COMMUNITY	AQUARION WATER CO OF CT-NOROTON SYSTEM	CT0350011	REWAK WELL	WL	08/19/2003	TETRACHLOROETHYLENE	0.0011	MG/L
DARIEN	COMMUNITY	AQUARION WATER CO OF CT-NOROTON SYSTEM	CT0350011	REWAK WELL	WL	11/10/2003	TRICHLOROETHYLENE	0.0007	MG/L
DARIEN	COMMUNITY	AQUARION WATER CO OF CT-NOROTON SYSTEM	CT0350011	REWAK WELL	WL	11/10/2003	TETRACHLOROETHYLENE	0.0013	MG/L
DEEP RIVER	COMMUNITY	RIDGEWOOD HILLS ASSOCIATION, SYSTEM #1	CT0361011	ENTRY POINT, SYSTEM #3	SS	06/23/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00053	MG/L
DURHAM	NON TRANSIENT	DURHAM COMMONS	CT0380094	ENTRY POINT	SS	03/25/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.194	MG/L
DURHAM	NON TRANSIENT	DURHAM COMMONS	CT0380094	GAC FILTRATION	TP	05/13/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.27	MG/L
DURHAM	NON TRANSIENT	DURHAM COMMONS	CT0380094	WELL	WL	05/13/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.44	MG/L
DURHAM	NON TRANSIENT	DURHAM COMMONS	CT0380094	WELL	WL	08/28/2003	METHYL TERT-BUTYL ETHER (MTBE)	5.4	MG/L
DURHAM	NON TRANSIENT	DURHAM COMMONS	CT0380094	WELL	WL	12/16/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.250	MG/L
DURHAM	NON TRAN NON COMM	DURHAM MANUFACTURING	CT0380372	BETWEEN GAC FILTERS	SS	04/23/2003	TRICHLOROETHYLENE	0.0017	MG/L
DURHAM	NON TRAN NON COMM	DURHAM MANUFACTURING	CT0380372	ENTRY POINT	SS	01/13/2003	TRICHLOROETHYLENE	0.0016	MG/L
DURHAM	NON TRAN NON COMM	DURHAM MANUFACTURING	CT0380372	WELL	WL	01/13/2003	CIS-1,2-DICHLOROETHYLENE	0.037	MG/L
DURHAM	NON TRAN NON COMM	DURHAM MANUFACTURING	CT0380372	WELL	WL	01/13/2003	1,1-DICHLOROETHANE	0.0019	MG/L
DURHAM	NON TRAN NON COMM	DURHAM MANUFACTURING	CT0380372	WELL	WL	01/13/2003	1,1,1-TRICHLOROETHANE	0.0021	MG/L
DURHAM	NON TRAN NON COMM	DURHAM MANUFACTURING	CT0380372	WELL	WL	01/13/2003	TRICHLOROETHYLENE	0.0022	MG/L
DURHAM	NON TRAN NON COMM	FRANK WARD STRONG SCHOOL	CT0380462	WELL	WL	06/09/2003	CIS-1,2-DICHLOROETHYLENE	0.717	MG/L
DURHAM	NON TRAN NON COMM	FRANK WARD STRONG SCHOOL	CT0380462	WELL	WL	06/09/2003	VINYL CHLORIDE	0.0522	MG/L
DURHAM	NON TRAN NON COMM	FRANK WARD STRONG SCHOOL	CT0380462	WELL	WL	06/09/2003	1,1-DICHLOROETHYLENE	0.0345	MG/L
DURHAM	NON TRAN NON COMM	FRANK WARD STRONG SCHOOL	CT0380462	WELL	WL	06/09/2003	1,1-DICHLOROETHANE	0.0914	MG/L
DURHAM	NON TRAN NON COMM	FRANK WARD STRONG SCHOOL	CT0380462	WELL	WL	06/09/2003	1,1,1-TRICHLOROETHANE	0.0318	MG/L
DURHAM	NON TRAN NON COMM	FRANK WARD STRONG SCHOOL	CT0380462	WELL	WL	06/09/2003	TRICHLOROETHYLENE	1.573	MG/L
DURHAM	NON TRAN NON COMM	FRANK WARD STRONG SCHOOL	CT0380462	WELL	WL	06/09/2003	TETRACHLOROETHYLENE	0.0681	MG/L
DURHAM	NON TRAN NON COMM	FRANK WARD STRONG SCHOOL	CT0380462	WELL	WL	12/04/2003	CIS-1,2-DICHLOROETHYLENE	1.508	MG/L
DURHAM	NON TRAN NON COMM	FRANK WARD STRONG SCHOOL	CT0380462	WELL	WL	12/04/2003	VINYL CHLORIDE	0.0302	MG/L
DURHAM	NON TRAN NON COMM	FRANK WARD STRONG SCHOOL	CT0380462	WELL	WL	12/04/2003	1,1-DICHLOROETHYLENE	0.0494	MG/L
DURHAM	NON TRAN NON COMM	FRANK WARD STRONG SCHOOL	CT0380462	WELL	WL	12/04/2003	1,1-DICHLOROETHANE	0.075	MG/L
DURHAM	NON TRAN NON COMM	FRANK WARD STRONG SCHOOL	CT0380462	WELL	WL	12/04/2003	TRANS-1,2-DICHLOROETHYLENE	0.0038	MG/L
DURHAM	NON TRAN NON COMM	FRANK WARD STRONG SCHOOL	CT0380462	WELL	WL	12/04/2003	1,1,1-TRICHLOROETHANE	0.0244	MG/L
DURHAM	NON TRAN NON COMM	FRANK WARD STRONG SCHOOL	CT0380462	WELL	WL	12/04/2003	TRICHLOROETHYLENE	0.816	MG/L
DURHAM	NON TRAN NON COMM	FRANK WARD STRONG SCHOOL	CT0380462	WELL	WL	12/04/2003	TETRACHLOROETHYLENE	0.0402	MG/L
DURHAM	NON TRAN NON COMM	GRAPHITE DIEMOLD - BUILDING #1	CT0389103	ENTRY POINT	SS	05/12/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0281	MG/L
DURHAM	NON TRAN NON COMM	GRAPHITE DIEMOLD - BUILDING #1	CT0389103	ENTRY POINT	SS	08/25/2003	METHYL TERT-BUTYL ETHER (MTBE)	2.7	MG/L
DURHAM	NON TRANSIENT	LNJS REALTY FAMILY LIMITED PARTNERSHIP	CT0380054	WELL	WL	10/21/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0035	MG/L
DURHAM	COMMUNITY	TWIN MAPLES NURSING HOME	CT0381011	ENTRY POINT	SS	01/17/2003	1,2-DICHLOROETHANE	0.00062	MG/L

Positive Organics for Calendar Year 2003

TOWN	SYSTEM TYPE	SYSTEM NAME	PWSID	FACILITY NAME	FACILITY TYPE	COLLECTION DATE	CHEMICAL	MEASURE	UNIT OF MEASURE
ASHFORD	NON TRAN NON COMM	ASHFORD ELEMENTARY SCHOOL	CT0030152	ENTRY POINT	SS	06/16/2003	TETRACHLOROETHYLENE	0.0016	MG/L
EAST GRANBY	NON TRAN NON COMM	GALASSO MATERIALS, LLC-GARAGE WELL	CT0400153	ENTRY POINT	SS	09/30/2003	1,1-DICHLOROETHYLENE	2.55	MG/L
EAST GRANBY	NON TRAN NON COMM	GALASSO MATERIALS, LLC-GARAGE WELL	CT0400153	ENTRY POINT	SS	09/30/2003	1,1-DICHLOROETHANE	4.62	MG/L
EAST GRANBY	NON TRAN NON COMM	GALASSO MATERIALS, LLC-GARAGE WELL	CT0400153	ENTRY POINT	SS	09/30/2003	1,1,1-TRICHLOROETHANE	11.8	MG/L
EAST GRANBY	NON TRAN NON COMM	GALASSO MATERIALS, LLC-GARAGE WELL	CT0400153	ENTRY POINT	SS	09/30/2003	TETRACHLOROETHYLENE	1.00	MG/L
EAST GRANBY	NON TRAN NON COMM	GALASSO MATERIALS, LLC-GARAGE WELL	CT0400153	ENTRY POINT	SS	12/16/2003	1,1-DICHLOROETHYLENE	2.1	MG/L
EAST GRANBY	NON TRAN NON COMM	GALASSO MATERIALS, LLC-GARAGE WELL	CT0400153	ENTRY POINT	SS	12/16/2003	1,1-DICHLOROETHANE	4.0	MG/L
EAST GRANBY	NON TRAN NON COMM	MAGNATECH	CT0400212	ENTRY POINT	SS	10/27/2003	P-DICHLOROBENZENE	0.0006	MG/L
EAST HADDAM	NON TRAN NON COMM	SALLY'S CHILD CARE CENTER, INC.	CT0410803	ENTRY POINT	SS	06/20/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0022	MG/L
EAST HADDAM	NON TRAN NON COMM	SALLY'S CHILD CARE CENTER, INC.	CT0410803	ENTRY POINT	SS	11/07/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00065	MG/L
EAST HAMPTON	NON TRAN NON COMM	AMERICAN DISTILLING & MANUFACTURING, INC	CT0420024	BETWEEN GAC FILTERS	SS	03/05/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.003	MG/L
EAST HAMPTON	NON TRAN NON COMM	AMERICAN DISTILLING & MANUFACTURING, INC	CT0420024	BETWEEN GAC FILTERS	SS	06/04/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0041	MG/L
EAST HAMPTON	NON TRAN NON COMM	AMERICAN DISTILLING & MANUFACTURING, INC	CT0420024	BETWEEN GAC FILTERS	SS	09/30/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.005	MG/L
EAST HAMPTON	NON TRAN NON COMM	AMERICAN DISTILLING & MANUFACTURING, INC	CT0420024	WELL 1	WL	10/29/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.002	MG/L
EAST HAMPTON	COMMUNITY	CHATHAM APARTMENTS	CT0420071	ENTRY POINT	SS	04/28/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0016	MG/L
EAST HAMPTON	NON TRAN NON COMM	CL&P EAST HAMPTON SERVICE CTR	CT0429023	WELL #1	SS	06/20/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00073	MG/L
EAST HAMPTON	NON TRANSIENT	DONUT DEPOT	CT0420144	ENTRY POINT	SS	06/27/2003	1,1-DICHLOROETHANE	0.0007	MG/L
EAST HAMPTON	NON TRAN NON COMM	EAST HAMPTON HIGH SCHOOL	CT0420902	ENTRY POINT	SS	08/05/2003	ETHYLBENZENE	0.0009	MG/L
EAST HAMPTON	NON TRAN NON COMM	EAST HAMPTON HIGH SCHOOL	CT0420902	ENTRY POINT	SS	08/05/2003	XYLENE, META	0.0061	MG/L
EAST HAMPTON	NON TRAN NON COMM	EAST HAMPTON TOWN HALL	CT0420562	ENTRY POINT	SS	08/05/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0025	MG/L
EAST HAMPTON	NON TRAN NON COMM	EAST HAMPTON TOWN HALL	CT0420562	ENTRY POINT	SS	11/19/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0006	MG/L
EAST HAMPTON	COMMUNITY	EAST HAMPTON WATER & SEWER AUTHORITY	CT0429031	ENTRY POINT	SS	04/10/2003	METHYL TERT-BUTYL ETHER (MTBE)	1.0	MG/L
EAST HAMPTON	COMMUNITY	EAST HAMPTON WATER & SEWER AUTHORITY	CT0429031	ENTRY POINT	SS	04/10/2003	TETRACHLOROETHYLENE	0.0037	MG/L
EAST HAMPTON	COMMUNITY	EAST HAMPTON WATER & SEWER AUTHORITY	CT0429031	WELL 1	WL	01/14/2003	CIS-1,2-DICHLOROETHYLENE	0.0047	MG/L
EAST HAMPTON	COMMUNITY	EAST HAMPTON WATER & SEWER AUTHORITY	CT0429031	WELL 1	WL	01/14/2003	TRICHLOROETHYLENE	0.0075	MG/L
EAST HAMPTON	COMMUNITY	EAST HAMPTON WATER & SEWER AUTHORITY	CT0429031	WELL 1	WL	01/14/2003	TETRACHLOROETHYLENE	0.0332	MG/L
EAST HAMPTON	COMMUNITY	EAST HAMPTON WATER & SEWER AUTHORITY	CT0429031	WELL 1	WL	09/10/2003	CIS-1,2-DICHLOROETHYLENE	0.0054	MG/L
EAST HAMPTON	COMMUNITY	EAST HAMPTON WATER & SEWER AUTHORITY	CT0429031	WELL 1	WL	09/10/2003	TRICHLOROETHYLENE	0.0053	MG/L
EAST HAMPTON	COMMUNITY	EAST HAMPTON WATER & SEWER AUTHORITY	CT0429031	WELL 1	WL	09/10/2003	TETRACHLOROETHYLENE	0.0169	MG/L
EAST HAMPTON	NON TRANSIENT	FOOD BAG	CT0420274	ENTRY POINT	SS	06/27/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.005	MG/L
EAST HAMPTON	NON TRAN NON COMM	LAKEVIEW COURT, LLC	CT0429103	ENTRY POINT	SS	05/20/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.002	MG/L
EAST HAMPTON	NON TRAN NON COMM	MARKHAM MEADOWS CAMPGROUND-WELL #2	CT0421041	ENTRY POINT	SS	05/29/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0022	MG/L
EAST HAMPTON	NON TRAN NON COMM	MCDONALDS OF EAST HAMPTON	CT0420374	ENTRY POINT	SS	04/28/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0021	MG/L
EAST HAMPTON	NON TRAN NON COMM	MCDONALDS OF EAST HAMPTON	CT0420374	ENTRY POINT	SS	10/14/2003	METHYL TERT-BUTYL ETHER (MTBE)	1.0017	MG/L
EAST HAMPTON	COMMUNITY	WESTCHESTER EAST LIMITED PARTNERSHIP	CT0427021	ENTRY POINT #1	SS	04/08/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00051	MG/L
EAST HAMPTON	COMMUNITY	WESTSIDE MANOR	CT0421001	ENTRY POINT	SS	06/18/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0013	MG/L
EAST LYME	COMMUNITY	EAST LYME WATER & SEWER COMMISSION	CT0450011	INDUSTRIAL PARK ROAD WTP ENTRY POINT	SS	02/14/2003	TETRACHLOROETHYLENE	0.001	MG/L
EAST LYME	COMMUNITY	EAST LYME WATER & SEWER COMMISSION	CT0450011	WELL 4A WTP ENTRY POINT	SS	02/14/2003	TETRACHLOROETHYLENE	0.0008	MG/L
EAST LYME	COMMUNITY	EAST LYME WATER & SEWER COMMISSION	CT0450011	WELL 6 WTP ENTRY POINT	SS	11/24/2003	TETRACHLOROETHYLENE	0.0009	MG/L
EAST LYME	NON TRANSIENT	SUNOCO SERVICE STATION #0005-6861	CT0450184	TREATMENT PLANT	TP	05/07/2003	TOLUENE	0.0028	MG/L
EAST WINDSOR	COMMUNITY	CTWC - NORTHERN REG-WESTERN SYSTEM	CT0473011	ENTRY POINT - WOODLAND PARK WELL	SS	07/16/2003	TRICHLOROETHYLENE	0.0011	MG/L
EASTON	NON TRAN NON COMM	SAMUEL STAPLES ELEMENTARY SCHOOL	CT0460112	ENTRY POINT	SS	03/05/2003	1,1-DICHLOROETHANE	0.00069	MG/L
EASTON	NON TRAN NON COMM	SAMUEL STAPLES ELEMENTARY SCHOOL	CT0460112	ENTRY POINT	SS	03/05/2003	TETRACHLOROETHYLENE	0.00095	MG/L
EASTON	NON TRAN NON COMM	SAMUEL STAPLES ELEMENTARY SCHOOL	CT0460112	ENTRY POINT	SS	09/11/2003	1,1-DICHLOROETHANE	0.00121	MG/L
EASTON	NON TRAN NON COMM	SAMUEL STAPLES ELEMENTARY SCHOOL	CT0460112	ENTRY POINT	SS	09/11/2003	TRICHLOROETHYLENE	0.000631	MG/L
EASTON	NON TRAN NON COMM	SAMUEL STAPLES ELEMENTARY SCHOOL	CT0460112	ENTRY POINT	SS	09/11/2003	TETRACHLOROETHYLENE	0.00175	MG/L
EASTON	NON TRAN NON COMM	SAMUEL STAPLES ELEMENTARY SCHOOL	CT0460112	ENTRY POINT	SS	10/17/2003	1,1-DICHLOROETHANE	0.00154	MG/L
ENFIELD	COMMUNITY	CONNECTICUT CORRECTIONAL INSTITUTE	CT0490031	SOMERS WELL 2	WL	03/13/2003	TETRACHLOROETHYLENE	13	MG/L
ENFIELD	COMMUNITY	CONNECTICUT CORRECTIONAL INSTITUTE	CT0490031	SOMERS WELL 2	WL	05/20/2003	TETRACHLOROETHYLENE	17.4	MG/L
ENFIELD	COMMUNITY	CONNECTICUT CORRECTIONAL INSTITUTE	CT0490031	SOMERS WELL 2	WL	09/16/2003	TETRACHLOROETHYLENE	0.0016	MG/L
ENFIELD	COMMUNITY	CONNECTICUT CORRECTIONAL INSTITUTE	CT0490031	SOMERS WELL 2	WL	12/22/2003	TETRACHLOROETHYLENE	0.0098	MG/L
ENFIELD	COMMUNITY	CONNECTICUT CORRECTIONAL INSTITUTE	CT0490031	SOMERS WELL 3	WL	03/13/2003	TETRACHLOROETHYLENE	3	MG/L
ENFIELD	COMMUNITY	CONNECTICUT CORRECTIONAL INSTITUTE	CT0490031	SOMERS WELL 3	WL	05/20/2003	TETRACHLOROETHYLENE	4.2	MG/L
ENFIELD	COMMUNITY	CONNECTICUT CORRECTIONAL INSTITUTE	CT0490031	SOMERS WELL 3	WL	09/16/2003	TETRACHLOROETHYLENE	0.0022	MG/L
ENFIELD	COMMUNITY	HAZARDVILLE WATER COMPANY	CT0490021	ENTRY POINT - SOUTH MAPLE ST WELL	SS	01/08/2003	TRICHLOROETHYLENE	0.001	MG/L
ENFIELD	COMMUNITY	HAZARDVILLE WATER COMPANY	CT0490021	ENTRY POINT - SOUTH MAPLE ST WELL	SS	04/08/2003	TRICHLOROETHYLENE	0.0012	MG/L
ENFIELD	COMMUNITY	HAZARDVILLE WATER COMPANY	CT0490021	ENTRY POINT - SOUTH MAPLE ST WELL	SS	07/16/2003	TRICHLOROETHYLENE	0.0011	MG/L
ENFIELD	COMMUNITY	HAZARDVILLE WATER COMPANY	CT0490021	ENTRY POINT - SOUTH MAPLE ST WELL	SS	11/10/2003	TRICHLOROETHYLENE	0.00091	MG/L
FARMINGTON	COMMUNITY	MAPLE RIDGE FARMS WATER ASSN, INC	CT0520041	WELL #1 TP ENTRY POINT	SS	03/26/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00267	MG/L
FARMINGTON	NON TRAN NON COMM	UNIONVILLE WATER COMPANY - FIP SYSTEM	CT0520092	ENTRY POINT-WELL#3	SS	01/28/2003	1,1,1-TRICHLOROETHANE	0.0013	MG/L
FARMINGTON	NON TRAN NON COMM	UNIONVILLE WATER COMPANY - FIP SYSTEM	CT0520092	ENTRY POINT-WELL#3	SS	04/14/2003	1,1,1-TRICHLOROETHANE	0.00104	MG/L
FARMINGTON	NON TRAN NON COMM	UNIONVILLE WATER COMPANY - FIP SYSTEM	CT0520092	ENTRY POINT-WELL#3	SS	07/28/2003	1,1,1-TRICHLOROETHANE	0.0020	MG/L
FARMINGTON	NON TRAN NON COMM	UNIONVILLE WATER COMPANY - FIP SYSTEM	CT0520092	ENTRY POINT-WELL#3	SS	07/28/2003	TETRACHLOROETHYLENE	0.0013	MG/L
FARMINGTON	NON TRAN NON COMM	UNIONVILLE WATER COMPANY - FIP SYSTEM	CT0520092	ENTRY POINT-WELL#3	SS	07/28/2003	TETRACHLOROETHYLENE	0.0006	MG/L
FARMINGTON	NON TRAN NON COMM	UNIONVILLE WATER COMPANY - FIP SYSTEM	CT0520092	ENTRY POINT-WELL#3	SS	10/21/2003	DICHLOROMETHANE	0.00061	MG/L
FARMINGTON	NON TRAN NON COMM	UNIONVILLE WATER COMPANY - FIP SYSTEM	CT0520092	ENTRY POINT-WELL#3	SS	10/21/2003	1,1,1-TRICHLOROETHANE	0.00102	MG/L
FARMINGTON	NON TRAN NON COMM	UNIONVILLE WATER COMPANY - FIP SYSTEM	CT0520092	ENTRY POINT-WELL#3	SS	10/21/2003	TETRACHLOROETHYLENE	0.0005	MG/L
FARMINGTON	NON TRAN NON COMM	UNIONVILLE WATER COMPANY - FIP SYSTEM	CT0520092	ENTRY POINT-WELL#4	SS	10/21/2003	DICHLOROMETHANE	0.00063	MG/L
FARMINGTON	NON TRAN NON COMM	UNIONVILLE WATER COMPANY - FIP SYSTEM	CT0520092	ENTRY POINT-WELL#4	SS	10/21/2003	TETRACHLOROETHYLENE	0.00123	MG/L
FARMINGTON	NON TRAN NON COMM	UNIONVILLE WATER COMPANY - FIP SYSTEM	CT0520092	WELL #4	WL	06/12/2003	TETRACHLOROETHYLENE	0.00129158	MG/L
GLASTONBURY	NON TRAN NON COMM	J.T. SLOCOMB CORP. - WELL #2	CT0549033	ENTRY POINT	SS	07/31/2003	1,1-DICHLOROETHYLENE	0.0012	MG/L
GLASTONBURY	NON TRAN NON COMM	J.T. SLOCOMB CORP. - WELL #2	CT0549033	ENTRY POINT	SS	07/31/2003	1,1,1-TRICHLOROETHANE	0.0035	MG/L
GLASTONBURY	NON TRAN NON COMM	PREFERRED FIXTURE MANUFACTURING CO.	CT0540182	ENTRY POINT	SS	05/13/2003	TETRACHLOROETHYLENE	0.0006	MG/L
GREENWICH	COMMUNITY	AQUARIUM WATER CO OF CT-GREENWICH SYSTEM	CT0570011	ENTRY POINT - MIANUS TREATMENT PLANT	SS	05/13/2003	XYLENE, META	0.008	MG/L

Positive Organics for Calendar Year 2003

TOWN	SYSTEM TYPE	SYSTEM NAME	PWSID	FACILITY NAME	FACILITY TYPE	COLLECTION DATE	CHEMICAL	MEASURE	UNIT OF MEASURE
ASHFORD	NON TRAN NON COMM	ASHFORD ELEMENTARY SCHOOL	CT0030152	ENTRY POINT	SS	06/16/2003	TETRACHLOROETHYLENE	0.0016	MG/L
GREENWICH	COMMUNITY	AQUARIAN WATER CO OF CT-GREENWICH SYSTEM	CT0570011	ENTRY POINT - PUTNAM TREATMENT PLANT	SS	03/11/2003	DIBROMOMETHANE	0.0011	MG/L
GREENWICH	NON TRAN NON COMM	BANKSVILLE COMMUNITY HOUSE	CT0570194	ENTRY POINT	SS	09/09/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0006	MG/L
GREENWICH	NON TRAN NON COMM	BURNING TREE COUNTRY CLUB	CT0570044	ENTRY POINT	SS	03/18/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0013	MG/L
GRISWOLD	COMMUNITY	CTWC - SHORELINE REG-BAY MOUNTAIN	CT0580041	ENTRY POINT	SS	03/04/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0033	MG/L
GRISWOLD	COMMUNITY	CTWC - SHORELINE REG-BAY MOUNTAIN	CT0580041	ENTRY POINT	SS	05/14/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0029	MG/L
GRISWOLD	COMMUNITY	JEWETT CITY WATER COMPANY	CT0580011	WELL #3	WL	11/12/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00093	MG/L
GROTON	COMMUNITY	ROGERS MOBILE HOME PARK	CT0597021	ENTRY POINT	SS	03/25/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0023	MG/L
HEBRON	NON TRAN NON COMM	BIRMINGHAM UTIL - HEBRON CENTER	CT0672031	ENTRY POINT	SS	10/28/2003	1,2,4-TRIMETHYLBENZENE	0.0021	MG/L
HEBRON	COMMUNITY	WELLSWOOD ESTATES FOUNDATION, INC.	CT0671021	WELL 2	WL	03/14/2003	1,2,4-TRIMETHYLBENZENE	0.0068	MG/L
HEBRON	COMMUNITY	WELLSWOOD ESTATES FOUNDATION, INC.	CT0671021	WELL 2	WL	03/14/2003	1,2,4-TRIMETHYLBENZENE	0.0068	MG/L
HEBRON	COMMUNITY	WELLSWOOD ESTATES FOUNDATION, INC.	CT0671021	WELL 2	WL	03/14/2003	XYLENE, PARA	0.00395	MG/L
HEBRON	COMMUNITY	WELLSWOOD ESTATES FOUNDATION, INC.	CT0671021	WELL 2	WL	03/14/2003	XYLENE, PARA	0.00395	MG/L
HEBRON	COMMUNITY	WELLSWOOD ESTATES FOUNDATION, INC.	CT0671021	WELL 2	WL	03/14/2003	TOLUENE	0.15	MG/L
HEBRON	COMMUNITY	WELLSWOOD ESTATES FOUNDATION, INC.	CT0671021	WELL 2	WL	03/14/2003	TOLUENE	0.15	MG/L
HEBRON	COMMUNITY	WELLSWOOD ESTATES FOUNDATION, INC.	CT0671021	WELL 2	WL	03/14/2003	XYLENE, META	0.00395	MG/L
HEBRON	COMMUNITY	WELLSWOOD ESTATES FOUNDATION, INC.	CT0671021	WELL 2	WL	03/14/2003	XYLENE, META	0.00395	MG/L
KILLINGLY	COMMUNITY	CRYSTAL WATER COMPANY	CT0690011	ENTRY POINT - HOPKINS	SS	04/01/2003	1,1,1-TRICHLOROETHANE	0.00091	MG/L
KILLINGLY	COMMUNITY	CRYSTAL WATER COMPANY	CT0690011	ENTRY POINT - HOPKINS	SS	05/27/2003	TETRACHLOROETHYLENE	0.00056	MG/L
KILLINGLY	COMMUNITY	ELMVILLE HEIGHTS TRAILER PARK	CT0690071	ENTRY POINT	SS	03/18/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0014	MG/L
LEBANON	NON TRAN NON COMM	THE SCOTTS-HYPONEX COMPANY-BAGGING PLANT	CT0719083	ENTRY POINT	SS	02/25/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0015	MG/L
LEBANON	NON TRAN NON COMM	THE SCOTTS-HYPONEX COMPANY-MAIN PLANT	CT0719053	ENTRY POINT	SS	02/25/2003	METHYL TERT-BUTYL ETHER (MTBE)	2.2	MG/L
LEBANON	NON TRAN NON COMM	THE SCOTTS-HYPONEX COMPANY-MAIN PLANT	CT0719053	ENTRY POINT	SS	05/20/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0039	MG/L
LEBANON	NON TRAN NON COMM	THE SCOTTS-HYPONEX COMPANY-MAIN PLANT	CT0719053	ENTRY POINT	SS	05/20/2003	P-DICHLOROENZENE	0.0012	MG/L
LEBANON	NON TRAN NON COMM	THE SCOTTS-HYPONEX COMPANY-MAIN PLANT	CT0719053	ENTRY POINT	SS	08/06/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0022	MG/L
LEBANON	NON TRAN NON COMM	THE SCOTTS-HYPONEX COMPANY-MAIN PLANT	CT0719053	ENTRY POINT	SS	08/06/2003	P-DICHLOROENZENE	0.0014	MG/L
LEBANON	NON TRAN NON COMM	THE SCOTTS-HYPONEX COMPANY-MAIN PLANT	CT0719053	ENTRY POINT	SS	10/14/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0019	MG/L
LEBANON	NON TRAN NON COMM	THE SCOTTS-HYPONEX COMPANY-MAIN PLANT	CT0719053	ENTRY POINT	SS	10/14/2003	P-DICHLOROENZENE	0.0014	MG/L
LEDYARD	COMMUNITY	GRANDVIEW TRAILER PARK - SYSTEM #1	CT0721011	ENTRY POINT - SYSTEM #2	SS	03/25/2003	TRICHLOROETHYLENE	0.0014	MG/L
LEDYARD	NON TRAN NON COMM	HOLDRIDGE FARM NURSERY-BAKE SHOPPE	CT0720104	ENTRY POINT	SS	04/30/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.005	MG/L
LEDYARD	NON TRAN NON COMM	HOLDRIDGE FARM NURSERY-BAKE SHOPPE	CT0720104	ENTRY POINT	SS	10/08/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.005	MG/L
LEDYARD	NON TRAN NON COMM	HOLDRIDGE FARM NURSERY-MAIN SYSTEM	CT0720034	ENTRY POINT	SS	04/30/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.002	MG/L
LEDYARD	COMMUNITY	LEDYARD WPCA, SABLEWOODS SYSTEM	CT0727061	ENTRY POINT	SS	03/12/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.013	MG/L
LEDYARD	COMMUNITY	LEDYARD WPCA, SABLEWOODS SYSTEM	CT0727061	ENTRY POINT	SS	03/12/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0015	MG/L
LEDYARD	COMMUNITY	SCWA, GRAY FARMS DIVISION (GRF)	CT0720081	ENTRY POINT	SS	06/11/2003	TETRACHLOROETHYLENE	0.0012	MG/L
LISBON	COMMUNITY	ROUND HILL LLC	CT0731021	ENTRY POINT	SS	06/20/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0015	MG/L
LISBON	COMMUNITY	ROUND HILL LLC	CT0731021	ENTRY POINT	SS	07/10/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0012	MG/L
LISBON	COMMUNITY	ROUND HILL LLC	CT0731021	ENTRY POINT	SS	11/24/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00075	MG/L
LITCHFIELD	COMMUNITY	AQUARIAN WATER CO OF CT-LITCHFIELD SYS	CT0740011	DISTRIBUTION SYSTEM	DS	06/12/2003	ETHYLBENZENE	0.0008	MG/L
LITCHFIELD	COMMUNITY	AQUARIAN WATER CO OF CT-LITCHFIELD SYS	CT0740011	DISTRIBUTION SYSTEM	DS	06/12/2003	XYLENE, META	0.0033	MG/L
LITCHFIELD	COMMUNITY	AQUARIAN WATER CO OF CT-LITCHFIELD SYS	CT0740011	DISTRIBUTION SYSTEM	DS	06/12/2003	XYLENE, ORTHO	0.0013	MG/L
LITCHFIELD	COMMUNITY	CIRCLE DRIVE WATER COMPANY	CT0740021	ENTRY POINT-WELLS #1 & #2	SS	03/26/2003	TETRACHLOROETHYLENE	0.0006	MG/L
LITCHFIELD	COMMUNITY	CIRCLE DRIVE WATER COMPANY	CT0740021	ENTRY POINT-WELLS #1 & #2	SS	05/13/2003	TETRACHLOROETHYLENE	0.0007	MG/L
LITCHFIELD	COMMUNITY	CIRCLE DRIVE WATER COMPANY	CT0740021	ENTRY POINT-WELLS #1 & #2	SS	07/02/2003	TETRACHLOROETHYLENE	0.0006	MG/L
LITCHFIELD	COMMUNITY	VANDERPOEL CIVIC ASSOCIATION	CT0745111	ENTRY POINT	SS	02/24/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00064	MG/L
LITCHFIELD	COMMUNITY	VANDERPOEL CIVIC ASSOCIATION	CT0745111	ENTRY POINT	SS	02/24/2003	TOLUENE	0.00060	MG/L
MADISON	NON TRAN NON COMM	15 ORCHARD PARK INDUSTRIAL AREA	CT0769113	ENTRY POINT	SS	03/17/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0006	MG/L
MADISON	NON TRAN NON COMM	NORTH MADISON CONGREGATIONAL CHURCH	CT0769143	BETWEEN GAC FILTERS	SS	03/05/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0075	MG/L
MADISON	NON TRAN NON COMM	NORTH MADISON CONGREGATIONAL CHURCH	CT0769143	BETWEEN GAC FILTERS	SS	06/10/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0132	MG/L
MADISON	NON TRAN NON COMM	NORTH MADISON CONGREGATIONAL CHURCH	CT0769143	ENTRY POINT	SS	06/10/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0054	MG/L
MADISON	NON TRAN NON COMM	SUMMER HILL NURSERIES	CT0760104	ENTRY POINT	SS	06/05/2003	TOLUENE	0.0025	MG/L
MADISON	NON TRAN NON COMM	TEMPLE BETH TIKVAH NURSERY SCHOOL	CT0769073	ENTRY POINT	SS	04/28/2003	P-DICHLOROENZENE	0.0008	MG/L
MADISON	NON TRAN NON COMM	TEMPLE BETH TIKVAH NURSERY SCHOOL	CT0769073	ENTRY POINT	SS	08/27/2003	P-DICHLOROENZENE	0.0006	MG/L
MANCHESTER	NON TRAN NON COMM	BIRCH MOUNTAIN DAY SCHOOL	CT0779073	ENTRY POINT	SS	07/15/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0016	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	04/25/2003	TRICHLOROETHYLENE	0.0017	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	04/25/2003	TETRACHLOROETHYLENE	0.0022	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	05/08/2003	1,1,1-TRICHLOROETHANE	0.0006	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	05/08/2003	TRICHLOROETHYLENE	0.0018	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	05/08/2003	TETRACHLOROETHYLENE	0.003	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	05/22/2003	TRICHLOROETHYLENE	0.0021	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	05/22/2003	TETRACHLOROETHYLENE	0.0024	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	06/03/2003	TETRACHLOROETHYLENE	0.0027	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	06/18/2003	TRICHLOROETHYLENE	0.0015	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	06/18/2003	TETRACHLOROETHYLENE	0.0025	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	07/02/2003	TRICHLOROETHYLENE	0.0021	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	07/02/2003	TETRACHLOROETHYLENE	0.0036	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	07/16/2003	TRICHLOROETHYLENE	0.0021	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	07/16/2003	TETRACHLOROETHYLENE	0.0037	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	07/29/2003	TRICHLOROETHYLENE	0.0018	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	07/29/2003	TETRACHLOROETHYLENE	0.0017	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	08/12/2003	TRICHLOROETHYLENE	0.0012	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	08/12/2003	TETRACHLOROETHYLENE	0.0017	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	08/22/2003	TRICHLOROETHYLENE	0.0013	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	08/22/2003	TETRACHLOROETHYLENE	0.0022	MG/L

Positive Organics for Calendar Year 2003

TOWN	SYSTEM TYPE	SYSTEM NAME	PWSID	FACILITY NAME	FACILITY TYPE	COLLECTION DATE	CHEMICAL	MEASURE	UNIT OF MEASURE
ASHFORD	NON TRAN NON COMM	ASHFORD ELEMENTARY SCHOOL	CT0030152	ENTRY POINT	SS	06/16/2003	TETRACHLOROETHYLENE	0.0016	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	09/09/2003	TRICHLOROETHYLENE	0.0015	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	09/09/2003	TETRACHLOROETHYLENE	0.0021	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	09/24/2003	TRICHLOROETHYLENE	0.0025	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	09/24/2003	TETRACHLOROETHYLENE	0.0044	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	10/07/2003	TRICHLOROETHYLENE	0.0016	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	10/07/2003	TETRACHLOROETHYLENE	0.0030	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	10/21/2003	TRICHLOROETHYLENE	0.0019	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	10/21/2003	TETRACHLOROETHYLENE	0.0035	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	11/04/2003	TRICHLOROETHYLENE	0.0026	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	11/04/2003	TETRACHLOROETHYLENE	0.0041	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	11/18/2003	TRICHLOROETHYLENE	0.0018	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	ENTRY POINT - WELLS 6,7,8	SS	11/18/2003	TETRACHLOROETHYLENE	0.0022	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	NEW STATE RD WELL 6	WL	03/11/2003	TETRACHLOROETHYLENE	0.0018	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	NEW STATE RD WELL 7	WL	03/11/2003	TRICHLOROETHYLENE	0.0027	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	NEW STATE RD WELL 7	WL	03/11/2003	TETRACHLOROETHYLENE	0.0020	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	NEW STATE RD WELL 8	WL	03/11/2003	1,1,1-TRICHLOROETHANE	0.0011	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	NEW STATE RD WELL 8	WL	03/11/2003	TRICHLOROETHYLENE	0.0043	MG/L
MANCHESTER	COMMUNITY	TOWN OF MANCHESTER WATER DEPARTMENT	CT0770021	NEW STATE RD WELL 8	WL	03/11/2003	TETRACHLOROETHYLENE	0.0054	MG/L
MANSFIELD	COMMUNITY	CLUB HOUSE APARTMENTS	CT0780101	ENTRY POINT	SS	02/06/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0012	MG/L
MANSFIELD	COMMUNITY	KNOLLWOOD ACRES APARTMENTS	CT0780051	WELL 5	WL	01/10/2003	TOLUENE	0.00174	MG/L
MANSFIELD	COMMUNITY	KNOLLWOOD ACRES APARTMENTS	CT0780051	WELL 5	WL	02/06/2003	TOLUENE	0.021	MG/L
MANSFIELD	NON TRANSIENT	PUBLIC AMERICA	CT0780424	ENTRY POINT	SS	01/23/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.005	MG/L
MANSFIELD	NON TRANSIENT	PUBLIC AMERICA	CT0780424	ENTRY POINT	SS	01/23/2003	TOLUENE	0.0006	MG/L
MANSFIELD	COMMUNITY	ROSAL APARTMENTS	CT0780271	ENTRY POINT	SS	02/03/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.002	MG/L
MANSFIELD	COMMUNITY	ROSAL APARTMENTS	CT0780271	ENTRY POINT	SS	08/31/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.004	MG/L
MARLBOROUGH	NON TRAN NON COMM	DEP EASTERN DISTRICT HEADQUARTERS	CT0791213	ENTRY POINT	SS	03/26/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.014	MG/L
MARLBOROUGH	NON TRAN NON COMM	DEP EASTERN DISTRICT HEADQUARTERS	CT0791213	ENTRY POINT	SS	08/25/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0088	MG/L
MARLBOROUGH	NON TRAN NON COMM	OLDE MARLBOROUGH VILLAGE #2	CT0791242	ENTRY POINT	SS	06/16/2003	TRICHLOROETHYLENE	0.018	MG/L
MERIDEN	COMMUNITY	BRADLEY HOME	CT0807011	ENTRY POINT	SS	01/13/2003	TRICHLOROETHYLENE	0.001	MG/L
MERIDEN	COMMUNITY	BRADLEY HOME	CT0807011	ENTRY POINT	SS	04/21/2003	TRICHLOROETHYLENE	0.0014	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	LINCOLN WELL	WL	01/02/2003	TRICHLOROETHYLENE	0.0008	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	LINCOLN WELL	WL	01/02/2003	TETRACHLOROETHYLENE	0.027	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	LINCOLN WELL	WL	02/06/2003	TRICHLOROETHYLENE	0.0013	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	LINCOLN WELL	WL	02/06/2003	TETRACHLOROETHYLENE	0.026	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	LINCOLN WELL	WL	06/05/2003	TRICHLOROETHYLENE	0.00053	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	LINCOLN WELL	WL	07/03/2003	TRICHLOROETHYLENE	0.0006	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	LINCOLN WELL	WL	07/03/2003	TETRACHLOROETHYLENE	0.028	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	LINCOLN WELL	WL	08/14/2003	TRICHLOROETHYLENE	0.0007	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	LINCOLN WELL	WL	09/04/2003	TRICHLOROETHYLENE	0.001	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	LINCOLN WELL	WL	09/04/2003	TETRACHLOROETHYLENE	0.041	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	LINCOLN WELL	WL	10/02/2003	TRICHLOROETHYLENE	0.0005	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	LINCOLN WELL	WL	10/02/2003	TRICHLOROETHYLENE	0.0005	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	LINCOLN WELL	WL	10/02/2003	TETRACHLOROETHYLENE	0.029	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	LINCOLN WELL	WL	10/02/2003	TETRACHLOROETHYLENE	0.029	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	LINCOLN WELL	WL	11/06/2003	TRICHLOROETHYLENE	0.0008	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	LINCOLN WELL	WL	11/06/2003	TETRACHLOROETHYLENE	0.03	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	LINCOLN WELL	WL	12/04/2003	TRICHLOROETHYLENE	0.0009	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	LINCOLN WELL	WL	12/04/2003	TETRACHLOROETHYLENE	0.042	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	PLATT LINCOLN TREATMENT STATION	TP	01/02/2003	TETRACHLOROETHYLENE	0.0017	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	PLATT LINCOLN WTP ENTRY POINT	SS	07/03/2003	TETRACHLOROETHYLENE	0.0015	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	PLATT LINCOLN WTP ENTRY POINT	SS	07/10/2003	TETRACHLOROETHYLENE	0.0016	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	PLATT LINCOLN WTP ENTRY POINT	SS	10/02/2003	TETRACHLOROETHYLENE	0.0017	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	PLATT WELL	WL	01/02/2003	TRICHLOROETHYLENE	0.001	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	PLATT WELL	WL	01/02/2003	TETRACHLOROETHYLENE	0.0038	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	PLATT WELL	WL	05/27/2003	TETRACHLOROETHYLENE	0.0019	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	PLATT WELL	WL	07/03/2003	TETRACHLOROETHYLENE	0.0044	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	PLATT WELL	WL	10/02/2003	TRICHLOROETHYLENE	0.0012	MG/L
MERIDEN	COMMUNITY	MERIDEN WATER DIVISION	CT0800011	PLATT WELL	WL	10/02/2003	TETRACHLOROETHYLENE	0.004	MG/L
MIDDLEBURY	NON TRAN NON COMM	MARY I. JOHNSON SCHOOL/ADMIN BUILDING	CT0810052	ENTRY POINT	SS	01/27/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0077	MG/L
MIDDLEBURY	NON TRAN NON COMM	MARY I. JOHNSON SCHOOL/ADMIN BUILDING	CT0810052	ENTRY POINT	SS	04/15/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0053	MG/L
MIDDLEBURY	NON TRAN NON COMM	MARY I. JOHNSON SCHOOL/ADMIN BUILDING	CT0810052	ENTRY POINT	SS	09/09/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0074	MG/L
MIDDLEBURY	NON TRAN NON COMM	MARY I. JOHNSON SCHOOL/ADMIN BUILDING	CT0810052	ENTRY POINT	SS	12/03/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0095	MG/L
MIDDLEBURY	NON TRAN NON COMM	MIDDLEBURY ELEMENTARY SCHOOL	CT0819013	ENTRY POINT	SS	01/27/2003	XYLENE, PARA	0.0009	MG/L
MIDDLEBURY	NON TRAN NON COMM	MIDDLEBURY ELEMENTARY SCHOOL	CT0819013	ENTRY POINT	SS	01/27/2003	XYLENE, META	0.0007	MG/L
MIDDLEBURY	NON TRAN NON COMM	MIDDLEBURY ELEMENTARY SCHOOL	CT0819013	ENTRY POINT	SS	04/15/2003	XYLENE, PARA	0.0016	MG/L
MIDDLEBURY	NON TRAN NON COMM	MIDDLEBURY ELEMENTARY SCHOOL	CT0819013	ENTRY POINT	SS	04/15/2003	ETHYLBENZENE	0.0006	MG/L
MIDDLEBURY	NON TRAN NON COMM	MIDDLEBURY ELEMENTARY SCHOOL	CT0819013	ENTRY POINT	SS	04/15/2003	XYLENE, META	0.0012	MG/L
MIDDLEBURY	NON TRAN NON COMM	MIDDLEBURY ELEMENTARY SCHOOL	CT0819013	ENTRY POINT	SS	04/15/2003	XYLENE, ORTHO	0.0007	MG/L
MIDDLEBURY	NON TRAN NON COMM	MIDDLEBURY ELEMENTARY SCHOOL	CT0819013	ENTRY POINT	SS	09/09/2003	XYLENE, PARA	0.0010	MG/L
MIDDLEBURY	NON TRAN NON COMM	MIDDLEBURY ELEMENTARY SCHOOL	CT0819013	ENTRY POINT	SS	09/09/2003	XYLENE, META	0.0006	MG/L
MIDDLEFIELD	NON TRAN NON COMM	LYMAN ORCHARD COUNTRY FARMS COMPLEX	CT0829023	ENTRY POINT	SS	03/17/2003	P-DICHLOROBENZENE	0.0006	MG/L
MIDDLEFIELD	NON TRAN NON COMM	LYMAN ORCHARD COUNTRY FARMS COMPLEX	CT0829023	ENTRY POINT	SS	10/13/2003	P-DICHLOROBENZENE	0.0006	MG/L
MIDDLEFIELD	NON TRAN NON COMM	THE ROGERS MANUFACTURING COMPANY	CT0820072	ENTRY POINT	SS	10/27/2003	O-DICHLOROBENZENE	0.0011	MG/L
MIDDLETOWN	NON TRAN NON COMM	PRATT & WHITNEY	CT0830032	COMBINED RAW WATER DISCHARGE	SS	03/05/2003	1,1,1-TRICHLOROETHANE	0.00087	MG/L
MIDDLETOWN	NON TRAN NON COMM	PRATT & WHITNEY	CT0830032	COMBINED RAW WATER DISCHARGE	SS	03/05/2003	TRICHLOROETHYLENE	0.00636	MG/L
MIDDLETOWN	NON TRAN NON COMM	PRATT & WHITNEY	CT0830032	COMBINED RAW WATER DISCHARGE	SS	06/04/2003	1,1,1-TRICHLOROETHANE	0.00581107	MG/L
MIDDLETOWN	NON TRAN NON COMM	PRATT & WHITNEY	CT0830032	COMBINED RAW WATER DISCHARGE	SS	06/04/2003	TRICHLOROETHYLENE	0.02296	MG/L

Positive Organics for Calendar Year 2003

TOWN	SYSTEM TYPE	SYSTEM NAME	PWSID	FACILITY NAME	FACILITY TYPE	COLLECTION DATE	CHEMICAL	MEASURE	UNIT OF MEASURE
ASHFORD	NON TRAN NON COMM	ASHFORD ELEMENTARY SCHOOL	CT0030152	ENTRY POINT	SS	06/16/2003	TETRACHLOROETHYLENE	0.0016	MG/L
MIDDLETOWN	NON TRAN NON COMM	PRATT & WHITNEY	CT0830032	ENTRY POINT	SS	03/05/2003	CHLOROMETHANE	0.01013	MG/L
MIDDLETOWN	NON TRAN NON COMM	PRATT & WHITNEY	CT0830032	ENTRY POINT	SS	03/05/2003	CARBON TETRACHLORIDE	0.00285	MG/L
MIDDLETOWN	NON TRAN NON COMM	PRATT & WHITNEY	CT0830032	ENTRY POINT	SS	05/07/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0008	MG/L
MIDDLETOWN	NON TRAN NON COMM	PRATT & WHITNEY	CT0830032	ENTRY POINT	SS	05/07/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0008	MG/L
MIDDLETOWN	NON TRAN NON COMM	PRATT & WHITNEY	CT0830032	WELL 7	WL	11/05/2003	1,1,1-TRICHLOROETHANE	0.00283	MG/L
MIDDLETOWN	NON TRAN NON COMM	PRATT & WHITNEY	CT0830032	WELL 7	WL	11/05/2003	TRICHLOROETHYLENE	0.01488	MG/L
MONROE	NON TRAN NON COMM	CORNELL-CARR	CT0850352	ENTRY POINT	SS	06/02/2003	TOLUENE	0.0024	MG/L
MONROE	NON TRAN NON COMM	CORNELL-CARR	CT0850352	ENTRY POINT	SS	12/03/2003	TOLUENE	0.00648	MG/L
MONTVILLE	COMMUNITY	FREEDOM VILLAGE ELDERLY HOUSING	CT0866301	ENTRY POINT	SS	03/20/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0023	MG/L
MONTVILLE	NON TRAN NON COMM	LEONARD J.TYL MIDDLE SCHOOL	CT0869073	ENTRY POINT	SS	05/29/2003	MONOCHLOROBENZENE	0.0025	MG/L
MONTVILLE	COMMUNITY	VILLAGE APARTMENTS	CT0867031	ENTRY POINT	SS	03/25/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0007	MG/L
MORRIS	NON TRAN NON COMM	WHITE FLOWER FARM	CT0870344	ENTRY POINT	SS	05/15/2003	1,2-DICHLOROPROPANE	0.00433	MG/L
NEW FAIRFIELD	COMMUNITY	AQUARIAN WATER CO OF CT-BALL POND SYS	CT0910011	ENTRY POINT-BIGGS	SS	01/16/2003	TRICHLOROETHYLENE	0.0006	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	CHRISTIAN DAY NURSERY SCHOOL	CT0915213	ENTRY POINT	SS	08/18/2003	NAPHTHALENE	0.00016	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	CONSOLIDATED SCHOOL	CT0915053	ENTRY POINT	SS	05/14/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00513	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	CONSOLIDATED SCHOOL	CT0915053	ENTRY POINT	SS	09/04/2003	1,1,1-TRICHLOROETHANE	0.00163	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	DRUCK, INC. (4 DUNHAM DR.)	CT0910522	BETWEEN GAC FILTERS	SS	03/04/2003	1,1,1-TRICHLOROETHANE	0.00879	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	DRUCK, INC. (4 DUNHAM DR.)	CT0910522	BETWEEN GAC FILTERS	SS	09/12/2003	1,1-DICHLOROETHANE	0.00231	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	DRUCK, INC. (4 DUNHAM DR.)	CT0910522	ENTRY POINT	SS	06/11/2003	1,1-DICHLOROETHANE	0.00198	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	DRUCK, INC. (4 DUNHAM DR.)	CT0910522	ENTRY POINT	SS	06/11/2003	1,1,1-TRICHLOROETHANE	0.0117	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	DRUCK, INC. (4 DUNHAM DR.)	CT0910522	WELL	WL	06/11/2003	1,1-DICHLOROETHYLENE	0.00908	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	DRUCK, INC. (4 DUNHAM DR.)	CT0910522	WELL	WL	06/11/2003	1,1-DICHLOROETHANE	0.00206	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	DRUCK, INC. (4 DUNHAM DR.)	CT0910522	WELL	WL	06/11/2003	1,1,1-TRICHLOROETHANE	0.0298	MG/L
NEW FAIRFIELD	NON TRANSIENT	FIELDSTONE COMMONS	CT0910554	WELL	WL	10/22/2003	TETRACHLOROETHYLENE	0.00158	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	HERITAGE PLAZA	CT0915103	BETWEEN GAC FILTERS	SS	03/04/2003	CIS-1,2-DICHLOROETHYLENE	0.0009	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	HERITAGE PLAZA	CT0915103	BETWEEN GAC FILTERS	SS	03/04/2003	TETRACHLOROETHYLENE	0.0055	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	HERITAGE PLAZA	CT0915103	BETWEEN GAC FILTERS	SS	07/24/2003	TETRACHLOROETHYLENE	0.0007	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	HERITAGE PLAZA	CT0915103	BETWEEN GAC FILTERS	SS	10/02/2003	TETRACHLOROETHYLENE	0.0011	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	HERITAGE PLAZA	CT0915103	ENTRY POINT	SS	07/24/2003	TETRACHLOROETHYLENE	0.0013	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	HERITAGE PLAZA	CT0915103	ENTRY POINT	SS	10/02/2003	TETRACHLOROETHYLENE	0.0011	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	HERITAGE PLAZA	CT0915103	WELL 1	WL	04/22/2003	TETRACHLOROETHYLENE	0.0318	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	HERITAGE PLAZA	CT0915103	WELL 2	WL	04/22/2003	TETRACHLOROETHYLENE	0.0008	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	HERITAGE PLAZA	CT0915103	WELL 3	WL	04/22/2003	TETRACHLOROETHYLENE	0.018	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	NEW FAIRFIELD HIGH/MIDDLE SCHOOL	CT0910532	ENTRY POINT	SS	05/23/2003	TOLUENE	0.0024	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	NEW FAIRFIELD HIGH/MIDDLE SCHOOL	CT0910532	ENTRY POINT	SS	08/12/2003	TETRACHLOROETHYLENE	0.00116	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	NEW FAIRFIELD SHOPPING CENTER, LLC	CT0910262	BETWEEN GAC FILTERS	SS	03/04/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0132	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	NEW FAIRFIELD SHOPPING CENTER, LLC	CT0910262	BETWEEN GAC FILTERS	SS	03/04/2003	CIS-1,2-DICHLOROETHYLENE	0.0008	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	NEW FAIRFIELD SHOPPING CENTER, LLC	CT0910262	BETWEEN GAC FILTERS	SS	03/04/2003	TETRACHLOROETHYLENE	0.0008	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	NEW FAIRFIELD SHOPPING CENTER, LLC	CT0910262	BETWEEN GAC FILTERS	SS	10/02/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0085	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	NEW FAIRFIELD SHOPPING CENTER, LLC	CT0910262	BETWEEN GAC FILTERS	SS	10/02/2003	TETRACHLOROETHYLENE	0.0007	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	NEW FAIRFIELD SHOPPING CENTER, LLC	CT0910262	ENTRY POINT	SS	03/31/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0122	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	NEW FAIRFIELD SHOPPING CENTER, LLC	CT0910262	ENTRY POINT	SS	06/17/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0089	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	NEW FAIRFIELD SHOPPING CENTER, LLC	CT0910262	ENTRY POINT	SS	06/17/2003	TETRACHLOROETHYLENE	0.0008	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	NEW FAIRFIELD SHOPPING CENTER, LLC	CT0910262	ENTRY POINT	SS	07/24/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0108	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	NEW FAIRFIELD SHOPPING CENTER, LLC	CT0910262	ENTRY POINT	SS	07/24/2003	TETRACHLOROETHYLENE	0.0008	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	NEW FAIRFIELD SHOPPING CENTER, LLC	CT0910262	ENTRY POINT	SS	10/02/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0038	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	NEW FAIRFIELD SHOPPING CENTER, LLC	CT0910262	WELL #1	WL	04/22/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0162	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	NEW FAIRFIELD SHOPPING CENTER, LLC	CT0910262	WELL #1	WL	04/22/2003	TRICHLOROETHYLENE	0.0012	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	NEW FAIRFIELD SHOPPING CENTER, LLC	CT0910262	WELL #1	WL	04/22/2003	TETRACHLOROETHYLENE	0.0133	MG/L
NEW FAIRFIELD	NON TRAN NON COMM	NEW FAIRFIELD TOWN HALL	CT0910502	ENTRY POINT	SS	05/22/2003	TETRACHLOROETHYLENE	0.0007	MG/L
NEW MILFORD	COMMUNITY	UNITED WATER CT, INC.-NEW MILFORD SYSTEM	CT0960011	WELLS #2 AND #3 TP ENTRY POINT	SS	07/17/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0027	MG/L
NEWTOWN	NON TRANSIENT	PROPERTY AT 115 CHURCH HILL ROAD	CT0970424	DISTRIBUTION SYSTEM	DS	10/03/2003	CIS-1,2-DICHLOROETHYLENE	0.00543	MG/L
NEWTOWN	NON TRANSIENT	PROPERTY AT 115 CHURCH HILL ROAD	CT0970424	DISTRIBUTION SYSTEM	DS	10/03/2003	TRICHLOROETHYLENE	0.00189	MG/L
NEWTOWN	NON TRANSIENT	PROPERTY AT 115 CHURCH HILL ROAD	CT0970424	DISTRIBUTION SYSTEM	DS	10/03/2003	TETRACHLOROETHYLENE	0.0363	MG/L
NEWTOWN	NON TRANSIENT	THE MONA LISA	CT0970304	ENTRY POINT	SS	04/09/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0034	MG/L
NORTH BRANFORD	NON TRAN NON COMM	ACES COLLABORATIVE MAGNET SCHOOL	CT0990723	ENTRY POINT	SS	02/26/2003	TOLUENE	0.024	MG/L
NORTH BRANFORD	NON TRAN NON COMM	ACES COLLABORATIVE MAGNET SCHOOL	CT0990723	ENTRY POINT	SS	05/15/2003	TOLUENE	0.0132	MG/L
NORTH BRANFORD	NON TRAN NON COMM	ACES COLLABORATIVE MAGNET SCHOOL	CT0990723	ENTRY POINT	SS	08/14/2003	TOLUENE	0.0155	MG/L
NORTH BRANFORD	NON TRAN NON COMM	ACES COLLABORATIVE MAGNET SCHOOL	CT0990723	ENTRY POINT	SS	10/30/2003	TOLUENE	0.0050	MG/L
NORTH STONINGTON	NON TRAN NON COMM	TINACO PLAZA, LLC	CT1020092	BETWEEN GAC FILTERS	SS	04/01/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.018	MG/L
NORTH STONINGTON	NON TRAN NON COMM	TINACO PLAZA, LLC	CT1020092	BETWEEN GAC FILTERS	SS	05/21/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.038	MG/L
NORTH STONINGTON	NON TRAN NON COMM	TINACO PLAZA, LLC	CT1020092	BETWEEN GAC FILTERS	SS	07/14/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.028	MG/L
NORTH STONINGTON	NON TRAN NON COMM	TINACO PLAZA, LLC	CT1020092	ENTRY POINT	SS	11/05/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.021	MG/L
NORTH STONINGTON	NON TRAN NON COMM	TINACO PLAZA, LLC	CT1020092	WELL 1	WL	01/16/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.029	MG/L
NORTH STONINGTON	NON TRAN NON COMM	TINACO PLAZA, LLC	CT1020092	WELL 1	WL	03/24/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.035	MG/L
NORWALK	COMMUNITY	NORWALK FIRST TAXING DISTRICT	CT1030011	RAW WELLFIELD ENTRY POINT	SS	05/07/2003	TRICHLOROETHYLENE	0.0007	MG/L
OLD LYME	NON TRAN NON COMM	EASTPORT - WEST 2	CT1059193	ENTRY POINT	SS	05/01/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.011	MG/L
OLD LYME	NON TRAN NON COMM	EASTPORT - WEST 2	CT1059193	ENTRY POINT	SS	07/09/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.011	MG/L
OLD LYME	NON TRAN NON COMM	EASTPORT - WEST 2	CT1059193	ENTRY POINT	SS	07/09/2003	XYLENE, PARA	0.0008	MG/L
OLD LYME	NON TRAN NON COMM	EASTPORT - WEST 2	CT1059193	ENTRY POINT	SS	07/09/2003	TOLUENE	0.008	MG/L
OLD LYME	NON TRAN NON COMM	EASTPORT - WEST 2	CT1059193	ENTRY POINT	SS	07/09/2003	ETHYLBENZENE	0.001	MG/L
OLD LYME	NON TRAN NON COMM	EASTPORT - WEST 2	CT1059193	ENTRY POINT	SS	07/09/2003	XYLENE, ORTHO	0.0056	MG/L
OLD LYME	NON TRAN NON COMM	EASTPORT - WEST 2	CT1059193	WELL #2 - FIRE SYSTEM SUPPLY	WL	11/19/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.005	MG/L

Positive Organics for Calendar Year 2003

TOWN	SYSTEM TYPE	SYSTEM NAME	PWSID	FACILITY NAME	FACILITY TYPE	COLLECTION DATE	CHEMICAL	MEASURE	UNIT OF MEASURE
ASHFORD	NON TRAN NON COMM	ASHFORD ELEMENTARY SCHOOL	CT0030152	ENTRY POINT	SS	06/16/2003	TETRACHLOROETHYLENE	0.0016	MG/L
OLD LYME	NON TRAN NON COMM	LYME ACADEMY OF FINE ARTS	CT1059043	ENTRY POINT	SS	07/11/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0089	MG/L
OLD LYME	NON TRAN NON COMM	LYME ACADEMY OF FINE ARTS	CT1059043	ENTRY POINT	SS	10/08/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00097	MG/L
OLD LYME	NON TRAN NON COMM	LYME ACADEMY OF FINE ARTS	CT1059043	ENTRY POINT	SS	12/17/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0057	MG/L
OLD LYME	COMMUNITY	MIAMI BEACH WATER COMPANY	CT1051021	DRILLED WELL ENTRY POINT #1	SS	05/27/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0008	MG/L
OLD LYME	NON TRAN NON COMM	OLD LYME MARKETPLACE	CT1059013	ENTRY POINT	SS	04/21/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0019	MG/L
OLD LYME	NON TRAN NON COMM	OLD LYME MARKETPLACE	CT1059013	ENTRY POINT	SS	07/08/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.001	MG/L
OLD LYME	NON TRANSIENT	OLD LYME TEXACO	CT1050364	TREATMENT PLANT	TP	07/17/2003	NAPHTHALENE	0.0005	MG/L
OLD LYME	NON TRANSIENT	OLD LYME TEXACO	CT1050364	TREATMENT PLANT	TP	07/17/2003	TOLUENE	0.0098	MG/L
PLAINFIELD	COMMUNITY	HARRINGTON MOBILE HOME PARK	CT1091011	ENTRY POINT	SS	05/12/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0018	MG/L
PLAINFIELD	NON TRAN NON COMM	HYDRO CONDUIT - WAUREGAN	CT1091102	ENTRY POINT	SS	08/12/2003	TOLUENE	0.00053	MG/L
PLAINFIELD	NON TRAN NON COMM	HYDRO CONDUIT - WAUREGAN	CT1091102	WELL #3	WL	08/12/2003	TOLUENE	0.00053	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	ENTRY POINT-WOODFORD AVE WELLS 2A,4A,5&7	SS	02/26/2003	1,1,1-TRICHLOROETHANE	0.00056	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	ENTRY POINT-WOODFORD AVE WELLS 2A,4A,5&7	SS	05/27/2003	1,1,1-TRICHLOROETHANE	0.000608	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	ENTRY POINT-WOODFORD AVE WELLS 2A,4A,5&7	SS	08/27/2003	1,1,1-TRICHLOROETHANE	0.00065595	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	ENTRY POINT-WOODFORD AVE WELLS 2A,4A,5&7	SS	11/19/2003	1,1,1-TRICHLOROETHANE	0.00054	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 3	WL	02/26/2003	CIS-1,2-DICHLOROETHYLENE	0.00154	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 3	WL	02/26/2003	1,1,1-TRICHLOROETHANE	0.0013	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 3	WL	02/26/2003	TRICHLOROETHYLENE	0.00139	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 3	WL	02/26/2003	TETRACHLOROETHYLENE	0.00753	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 3	WL	05/27/2003	CIS-1,2-DICHLOROETHYLENE	0.00123	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 3	WL	05/27/2003	1,1,1-TRICHLOROETHANE	0.001255	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 3	WL	05/27/2003	TRICHLOROETHYLENE	0.001178	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 3	WL	05/27/2003	1,1,2-TRICHLOROETHANE	0.0006	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 3	WL	05/27/2003	TETRACHLOROETHYLENE	0.006725	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 3	WL	08/27/2003	CIS-1,2-DICHLOROETHYLENE	0.00109723	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 3	WL	08/27/2003	1,1,1-TRICHLOROETHANE	0.00150753	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 3	WL	08/27/2003	TRICHLOROETHYLENE	0.00111307	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 3	WL	08/27/2003	TETRACHLOROETHYLENE	0.00770824	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 3	WL	11/19/2003	CIS-1,2-DICHLOROETHYLENE	0.00123	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 3	WL	11/19/2003	1,1,1-TRICHLOROETHANE	0.00114	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 3	WL	11/19/2003	TRICHLOROETHYLENE	0.00107	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 3	WL	11/19/2003	TETRACHLOROETHYLENE	0.00621	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 6	WL	02/26/2003	CIS-1,2-DICHLOROETHYLENE	0.00553	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 6	WL	02/26/2003	TRICHLOROETHYLENE	0.01018	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 6	WL	02/26/2003	TETRACHLOROETHYLENE	0.00069	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 6	WL	05/27/2003	CIS-1,2-DICHLOROETHYLENE	0.00526	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 6	WL	05/27/2003	TRICHLOROETHYLENE	0.008751	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 6	WL	05/27/2003	TETRACHLOROETHYLENE	0.00138	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 6	WL	08/27/2003	CIS-1,2-DICHLOROETHYLENE	0.0041732	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 6	WL	08/27/2003	1,1,1-TRICHLOROETHANE	0.00063	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 6	WL	08/27/2003	TRICHLOROETHYLENE	0.00710541	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 6	WL	08/27/2003	TETRACHLOROETHYLENE	0.0032505	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 6	WL	11/19/2003	CIS-1,2-DICHLOROETHYLENE	0.00397	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 6	WL	11/19/2003	TRICHLOROETHYLENE	0.0057	MG/L
PLAINVILLE	COMMUNITY	VALLEY WATER SYSTEMS, INC.	CT1100011	JOHNSON WELL 6	WL	11/19/2003	TETRACHLOROETHYLENE	0.00255	MG/L
PLYMOUTH	NON TRAN NON COMM	ISELI CO	CT1110192	BETWEEN GAC FILTERS	SS	07/25/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0013	MG/L
PLYMOUTH	NON TRAN NON COMM	ISELI CO	CT1110192	BETWEEN GAC FILTERS	SS	07/25/2003	TETRACHLOROETHYLENE	0.00096	MG/L
PLYMOUTH	NON TRAN NON COMM	ISELI CO	CT1110192	BETWEEN GAC FILTERS	SS	10/21/2003	DICHLOROMETHANE	0.00069	MG/L
PLYMOUTH	NON TRAN NON COMM	ISELI CO	CT1110192	PW2 WELL	WL	10/21/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0026	MG/L
PLYMOUTH	NON TRAN NON COMM	ISELI CO	CT1110192	PW2 WELL	WL	10/21/2003	TETRACHLOROETHYLENE	0.00092	MG/L
PLYMOUTH	NON TRANSIENT	JEHOVAHS WITNESSES	CT1110094	ENTRY POINT	SS	03/11/2003	METHYL TERT-BUTYL ETHER (MTBE)	1.90	MG/L
POMFRET	NON TRAN NON COMM	FIBEROPTICS TECHNOLOGY (OLD)	CT1120443	ENTRY POINT	SS	12/10/2003	NAPHTHALENE	0.00084	MG/L
POMFRET	NON TRAN NON COMM	LOOS & CO - WELL #1	CT1120422	ENTRY POINT	SS	09/03/2003	1,1-DICHLOROETHYLENE	0.0027	MG/L
POMFRET	NON TRAN NON COMM	LOOS & CO - WELL #1	CT1120422	ENTRY POINT	SS	09/03/2003	1,1-DICHLOROETHANE	0.00072	MG/L
POMFRET	NON TRANSIENT	LOOS & CO. (LASHING WIRE BLDG.) - WELL 2	CT1120314	WELL #2	WL	02/04/2003	1,1-DICHLOROETHYLENE	0.0021	MG/L
PRESTON	NON TRAN NON COMM	PRESTON VETERANS MEMORIAL SCHOOL	CT1149033	ENTRY POINT	SS	03/25/2003	TOLUENE	0.0038	MG/L
RIDGEFIELD	NON TRAN NON COMM	CREATIVE CHILDRENS KORNER	CT1180432	ENTRY POINT	SS	09/04/2003	DIBROMOMETHANE	0.79	MG/L
RIDGEFIELD	NON TRAN NON COMM	NORCO, INC.	CT1180362	BETWEEN GAC FILTERS	SS	03/21/2003	1,2-DICHLOROETHANE	0.0009	MG/L
RIDGEFIELD	NON TRAN NON COMM	RIDGEFIELD EUROPEAN MOTORS	CT1180322	ENTRY POINT	SS	02/13/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.052	MG/L
RIDGEFIELD	NON TRAN NON COMM	RIDGEFIELD EUROPEAN MOTORS	CT1180322	ENTRY POINT	SS	06/02/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.153	MG/L
RIDGEFIELD	NON TRAN NON COMM	RIDGEFIELD EUROPEAN MOTORS	CT1180322	ENTRY POINT	SS	08/19/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.850	MG/L
RIDGEFIELD	NON TRAN NON COMM	RIDGEFIELD EUROPEAN MOTORS	CT1180322	ENTRY POINT	SS	12/10/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.740	MG/L
RIDGEFIELD	NON TRAN NON COMM	RIDGEFIELD EUROPEAN MOTORS	CT1180322	WELL	WL	06/02/2003	CIS-1,2-DICHLOROETHYLENE	0.0007	MG/L
RIDGEFIELD	NON TRAN NON COMM	RIDGEFIELD EUROPEAN MOTORS	CT1180322	WELL	WL	06/02/2003	BENZENE	0.002	MG/L
RIDGEFIELD	NON TRAN NON COMM	ULLMAN DEVICES (MAIN BUILDING)	CT1180342	BETWEEN GAC FILTERS	SS	06/18/2003	1,1,1-TRICHLOROETHANE	0.00144	MG/L
RIDGEFIELD	NON TRAN NON COMM	ULLMAN DEVICES (MAIN BUILDING)	CT1180342	COMBINED RAW WATER DISCHARGE	SS	06/18/2003	1,1-DICHLOROETHANE	0.00055	MG/L
RIDGEFIELD	NON TRAN NON COMM	ULLMAN DEVICES (MAIN BUILDING)	CT1180342	COMBINED RAW WATER DISCHARGE	SS	06/18/2003	1,1,1-TRICHLOROETHANE	0.00163	MG/L
RIDGEFIELD	NON TRAN NON COMM	ULLMAN DEVICES (MAIN BUILDING)	CT1180342	COMBINED RAW WATER DISCHARGE	SS	06/18/2003	TRICHLOROETHYLENE	0.00155	MG/L
RIDGEFIELD	NON TRAN NON COMM	ULLMAN DEVICES (MAIN BUILDING)	CT1180342	ENTRY POINT	SS	10/01/2003	1,1-DICHLOROETHANE	0.000934	MG/L
RIDGEFIELD	NON TRAN NON COMM	ULLMAN DEVICES (MAIN BUILDING)	CT1180342	ENTRY POINT	SS	10/01/2003	1,1,1-TRICHLOROETHANE	0.00601	MG/L
RIDGEFIELD	NON TRAN NON COMM	ULLMAN DEVICES (MAIN BUILDING)	CT1180342	ENTRY POINT	SS	10/01/2003	TRICHLOROETHYLENE	0.00312	MG/L
RIDGEFIELD	NON TRAN NON COMM	ULLMAN DEVICES (MAIN BUILDING)	CT1180342	GAC FILTERS	TP	02/21/2003	1,1,1-TRICHLOROETHANE	0.00164	MG/L
SALEM	COMMUNITY	CRYSTAL LAKE ASSOCIATES-73	CT1210051	ENTRY POINT	SS	05/01/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0016	MG/L
SALEM	COMMUNITY	CRYSTAL LAKE CONDOMINIUMS	CT1210021	ENTRY POINT	SS	07/16/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0015	MG/L
SALEM	COMMUNITY	SALEM MANOR CONDOMINIUMS, SYSTEM #1	CT1210011	ENTRY POINT SYSTEM #2	SS	09/28/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00073	MG/L
SALEM	NON TRAN NON COMM	SALEM TOWN CENTER LLC	CT1219093	BETWEEN GAC FILTERS	SS	04/14/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.015	MG/L

Positive Organics for Calendar Year 2003

TOWN	SYSTEM TYPE	SYSTEM NAME	PWSID	FACILITY NAME	FACILITY TYPE	COLLECTION DATE	CHEMICAL	MEASURE	UNIT OF MEASURE
ASHFORD	NON TRAN NON COMM	ASHFORD ELEMENTARY SCHOOL	CT0030152	ENTRY POINT	SS	06/16/2003	TETRACHLOROETHYLENE	0.0016	MG/L
SALEM	NON TRAN NON COMM	SALEM TOWN CENTER LLC	CT1219093	BETWEEN GAC FILTERS	SS	07/28/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.002	MG/L
SALEM	NON TRAN NON COMM	SALEM TOWN CENTER LLC	CT1219093	WELL #2 (NEW WELL)	WL	04/14/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.037	MG/L
SALISBURY	COMMUNITY	AQUARION WATER CO OF CT-SALISBURY SYS	CT1220011	LAKEVILLE WELL #2A	WL	12/05/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0391	MG/L
SALISBURY	COMMUNITY	AQUARION WATER CO OF CT-SALISBURY SYS	CT1220011	LAKEVILLE WELL #2A	WL	12/05/2003	N-BUTYLBENZENE	0.0009	MG/L
SALISBURY	COMMUNITY	AQUARION WATER CO OF CT-SALISBURY SYS	CT1220011	SALISBURY WELL A	WL	02/11/2003	TETRACHLOROETHYLENE	0.0016	MG/L
SALISBURY	COMMUNITY	AQUARION WATER CO OF CT-SALISBURY SYS	CT1220011	SALISBURY WELL A	WL	05/09/2003	TETRACHLOROETHYLENE	0.002	MG/L
SALISBURY	COMMUNITY	AQUARION WATER CO OF CT-SALISBURY SYS	CT1220011	SALISBURY WELL A	WL	08/05/2003	TETRACHLOROETHYLENE	0.0018	MG/L
SALISBURY	COMMUNITY	AQUARION WATER CO OF CT-SALISBURY SYS	CT1220011	SALISBURY WELL B	WL	02/11/2003	TETRACHLOROETHYLENE	0.003	MG/L
SALISBURY	COMMUNITY	AQUARION WATER CO OF CT-SALISBURY SYS	CT1220011	SALISBURY WELL B	WL	05/09/2003	TETRACHLOROETHYLENE	0.0029	MG/L
SALISBURY	COMMUNITY	AQUARION WATER CO OF CT-SALISBURY SYS	CT1220011	SALISBURY WELL B	WL	08/05/2003	TETRACHLOROETHYLENE	0.0028	MG/L
SALISBURY	COMMUNITY	AQUARION WATER CO OF CT-SALISBURY SYS	CT1220011	SALISBURY WELL C	WL	02/11/2003	TETRACHLOROETHYLENE	0.0018	MG/L
SALISBURY	COMMUNITY	AQUARION WATER CO OF CT-SALISBURY SYS	CT1220011	SALISBURY WELL C	WL	05/09/2003	TETRACHLOROETHYLENE	0.0021	MG/L
SALISBURY	COMMUNITY	AQUARION WATER CO OF CT-SALISBURY SYS	CT1220011	SALISBURY WELL C	WL	08/05/2003	TETRACHLOROETHYLENE	0.0017	MG/L
SALISBURY	COMMUNITY	AQUARION WATER CO OF CT-SALISBURY SYS	CT1220011	SALISBURY WELL D	WL	02/11/2003	TETRACHLOROETHYLENE	0.0009	MG/L
SALISBURY	COMMUNITY	AQUARION WATER CO OF CT-SALISBURY SYS	CT1220011	SALISBURY WELL D	WL	05/09/2003	TETRACHLOROETHYLENE	0.0015	MG/L
SALISBURY	COMMUNITY	AQUARION WATER CO OF CT-SALISBURY SYS	CT1220011	SALISBURY WELL D	WL	08/05/2003	TETRACHLOROETHYLENE	0.0006	MG/L
SHARON	COMMUNITY	SHARON RIDGE APARTMENTS	CT1250021	ENTRY POINT	SS	01/09/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0049	MG/L
SHARON	COMMUNITY	SHARON RIDGE APARTMENTS	CT1250021	ENTRY POINT	SS	05/05/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0123	MG/L
SHARON	COMMUNITY	SHARON RIDGE APARTMENTS	CT1250021	ENTRY POINT	SS	08/04/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0039	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	DISTRIBUTION SYSTEM	DS	06/05/2003	TETRACHLOROETHYLENE	0.0007	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	DISTRIBUTION SYSTEM	DS	06/05/2003	TETRACHLOROETHYLENE	0.0006	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	DISTRIBUTION SYSTEM	DS	07/17/2003	1,2-DICHLOROPROPANE	0.0018	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	DISTRIBUTION SYSTEM	DS	07/17/2003	1,2-DICHLOROPROPANE	0.0016	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	DISTRIBUTION SYSTEM	DS	07/17/2003	TETRACHLOROETHYLENE	0.0009	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	DISTRIBUTION SYSTEM	DS	07/17/2003	TETRACHLOROETHYLENE	0.0007	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	DISTRIBUTION SYSTEM	DS	09/11/2003	1,2-DICHLOROPROPANE	0.0014	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	DISTRIBUTION SYSTEM	DS	09/11/2003	TETRACHLOROETHYLENE	0.0015	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	DISTRIBUTION SYSTEM	DS	09/11/2003	TETRACHLOROETHYLENE	0.0015	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	WELL #2 TP ENTRY POINT	SS	07/02/2003	1,2-DICHLOROPROPANE	0.0033	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	WELL #2 TP ENTRY POINT	SS	07/15/2003	1,2-DICHLOROPROPANE	0.0031	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	WELL #2 TP ENTRY POINT	SS	07/29/2003	1,2-DICHLOROPROPANE	0.003	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	WELL #2 TP ENTRY POINT	SS	09/09/2003	1,2-DICHLOROPROPANE	0.0035	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	WELL #2 TP ENTRY POINT	SS	12/08/2003	1,2-DICHLOROPROPANE	0.0048	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	WELL #5	WL	06/10/2003	1,2-DICHLOROPROPANE	0.0061	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	WELL #5	WL	07/02/2003	1,2-DICHLOROPROPANE	0.0061	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	WELL #5	WL	07/10/2003	1,2-DICHLOROPROPANE	0.0058	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	WELL #5	WL	07/15/2003	1,2-DICHLOROPROPANE	0.0059	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	WELL #5	WL	07/23/2003	1,2-DICHLOROPROPANE	0.0056	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	WELL #5	WL	07/29/2003	1,2-DICHLOROPROPANE	0.0057	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	WELL #5	WL	08/12/2003	1,2-DICHLOROPROPANE	0.0066	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	WELL #5	WL	09/09/2003	1,2-DICHLOROPROPANE	0.0064	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	WELL #5	WL	12/08/2003	1,2-DICHLOROPROPANE	0.0091	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	WELL #5 TP ENTRY POINT	SS	07/02/2003	1,2-DICHLOROPROPANE	0.0033	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	WELL #5 TP ENTRY POINT	SS	07/10/2003	1,2-DICHLOROPROPANE	0.0032	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	WELL #5 TP ENTRY POINT	SS	07/15/2003	1,2-DICHLOROPROPANE	0.0031	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	WELL #5 TP ENTRY POINT	SS	07/29/2003	1,2-DICHLOROPROPANE	0.003	MG/L
SIMSBURY	COMMUNITY	AQUARION WATER CO OF CT-SIMSBURY SYSTEM	CT1280021	WELL #5 TP ENTRY POINT	SS	09/09/2003	1,2-DICHLOROPROPANE	0.0035	MG/L
SOUTH WINDSOR	NON TRAN NON COMM	MITCHELL ASSOCIATES	CT1320042	ENTRY POINT	SS	06/02/2003	1,2-DICHLOROPROPANE	0.00054	MG/L
SOUTHINGTON	COMMUNITY	SOUTHINGTON WATER DEPARTMENT	CT1310011	ENTRY POINT - WELL 2	SS	03/13/2003	TETRACHLOROETHYLENE	0.0014	MG/L
SOUTHINGTON	COMMUNITY	SOUTHINGTON WATER DEPARTMENT	CT1310011	WELL 2	WL	06/25/2003	TETRACHLOROETHYLENE	0.0046	MG/L
SOUTHINGTON	COMMUNITY	SOUTHINGTON WATER DEPARTMENT	CT1310011	WELL 2	WL	08/14/2003	TETRACHLOROETHYLENE	0.005	MG/L
STAFFORD	NON TRAN NON COMM	MCDONALDS RESTAURANT	CT1340302	ENTRY POINT	SS	07/16/2003	NAPHTHALENE	0.0023	MG/L
STAFFORD	NON TRAN NON COMM	MCDONALDS RESTAURANT	CT1340302	ENTRY POINT	SS	07/16/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0024	MG/L
STAFFORD	NON TRAN NON COMM	WILLINGTON NAMEPLATE, INC.	CT1341313	ENTRY POINT	SS	11/28/2003	TOLUENE	0.0045	MG/L
STAMFORD	NON TRAN NON COMM	CHURCH OF THE HOLY SPIRIT	CT1355043	ENTRY POINT	SS	01/27/2003	METHYL TERT-BUTYL ETHER (MTBE)	1.20	MG/L
STONINGTON	NON TRAN NON COMM	BRUSTOLON BUICK PONTIAC INC	CT1370152	ENTRY POINT	SS	01/15/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0013	MG/L
STONINGTON	NON TRAN NON COMM	BRUSTOLON BUICK PONTIAC INC	CT1370152	ENTRY POINT	SS	01/15/2003	TOLUENE	0.004	MG/L
STONINGTON	NON TRAN NON COMM	BRUSTOLON BUICK PONTIAC INC	CT1370152	ENTRY POINT	SS	04/09/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0013	MG/L
TOLLAND	NON TRAN NON COMM	70 MERROW ROAD (TOLLAND SUBWAY PLAZA)	CT1429173	ENTRY POINT	SS	04/15/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0013	MG/L
TOLLAND	NON TRAN NON COMM	MEETING HOUSE COMMONS	CT1429033	ENTRY POINT	SS	06/03/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0096	MG/L
TORRINGTON	NON TRANSIENT	TORRINGTON PIZZA PALACE	CT1430814	ENTRY POINT	SS	06/17/2003	CARBON TETRACHLORIDE	0.0009	MG/L
VERNON	COMMUNITY	VERNON VILLAGE INC.	CT1463011	ENTRY POINT - WELL 1	SS	06/03/2003	TRICHLOROETHYLENE	0.0006	MG/L
VERNON	COMMUNITY	VERNON VILLAGE INC.	CT1463011	WELL 3	WL	06/03/2003	TRICHLOROETHYLENE	0.016	MG/L
VERNON	COMMUNITY	VERNON VILLAGE INC.	CT1463011	WELL 3	WL	06/03/2003	TETRACHLOROETHYLENE	0.0089	MG/L
WALLINGFORD	NON TRAN NON COMM	KIDDIE KORNER NURSERY SCHOOL	CT1480152	ENTRY POINT	SS	10/28/2003	TRICHLOROETHYLENE	0.0025	MG/L
WALLINGFORD	NON TRAN NON COMM	TILCON CONNECTICUT INC. - WALLINGFORD	CT1489013	ENTRY POINT	SS	07/21/2003	1,1-DICHLOROETHYLENE	0.0029	MG/L
WALLINGFORD	NON TRAN NON COMM	TILCON CONNECTICUT INC. - WALLINGFORD	CT1489013	ENTRY POINT	SS	07/21/2003	1,1,1-TRICHLOROETHANE	0.0022	MG/L
WALLINGFORD	NON TRAN NON COMM	TILCON CONNECTICUT INC. - WALLINGFORD	CT1489013	ENTRY POINT	SS	10/13/2003	1,1-DICHLOROETHYLENE	0.0031	MG/L
WALLINGFORD	NON TRAN NON COMM	TILCON CONNECTICUT INC. - WALLINGFORD	CT1489013	ENTRY POINT	SS	10/13/2003	1,1-DICHLOROETHANE	0.0046	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STR W #3 FINISHED (GREENSAND)	SS	08/27/2003	CIS-1,2-DICHLOROETHYLENE	0.0007	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STR W #3 FINISHED (GREENSAND)	SS	08/27/2003	1,1-DICHLOROETHYLENE	0.0006	MG/L

Positive Organics for Calendar Year 2003

TOWN	SYSTEM TYPE	SYSTEM NAME	PWSID	FACILITY NAME	FACILITY TYPE	COLLECTION DATE	CHEMICAL	MEASURE	UNIT OF MEASURE
ASHFORD	NON TRAN NON COMM	ASHFORD ELEMENTARY SCHOOL	CT0030152	ENTRY POINT	SS	06/16/2003	TETRACHLOROETHYLENE	0.0016	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STR W #3 FINISHED (GREENSAND)	SS	08/27/2003	1,1-DICHLOROETHANE	0.0008	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STR W #3 FINISHED (GREENSAND)	SS	08/27/2003	1,1,1-TRICHLOROETHANE	0.0016	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STR W #3 FINISHED (GREENSAND)	SS	08/27/2003	TRICHLOROETHYLENE	0.0015	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STR W #3 FINISHED (GREENSAND)	SS	10/14/2003	CIS-1,2-DICHLOROETHYLENE	0.0005	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STR W #3 FINISHED (GREENSAND)	SS	10/14/2003	1,1-DICHLOROETHANE	0.0006	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STR W #3 FINISHED (GREENSAND)	SS	10/14/2003	1,1,1-TRICHLOROETHANE	0.001	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STR W #3 FINISHED (GREENSAND)	SS	10/14/2003	TRICHLOROETHYLENE	0.0012	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	02/24/2003	CIS-1,2-DICHLOROETHYLENE	0.0011	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	02/24/2003	1,1-DICHLOROETHANE	0.0009	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	02/24/2003	1,1,1-TRICHLOROETHANE	0.0014	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	02/24/2003	TRICHLOROETHYLENE	0.0033	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	02/24/2003	TRICHLOROETHYLENE	0.003	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	05/05/2003	CIS-1,2-DICHLOROETHYLENE	0.001	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	05/05/2003	1,1-DICHLOROETHANE	0.0009	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	05/05/2003	1,1,1-TRICHLOROETHANE	0.0015	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	05/05/2003	TRICHLOROETHYLENE	0.0027	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	05/05/2003	TRICHLOROETHYLENE	0.0028	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	09/29/2003	CIS-1,2-DICHLOROETHYLENE	0.0006	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	09/29/2003	1,1-DICHLOROETHYLENE	0.0004	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	09/29/2003	1,1-DICHLOROETHANE	0.0009	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	09/29/2003	1,1,1-TRICHLOROETHANE	0.0015	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	09/29/2003	TRICHLOROETHYLENE	0.0025	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	11/10/2003	CIS-1,2-DICHLOROETHYLENE	0.0009	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	11/10/2003	1,1-DICHLOROETHYLENE	0.0007	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	11/10/2003	1,2-DICHLOROETHANE	0.0012	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	11/10/2003	1,1,1-TRICHLOROETHANE	0.0025	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #2	WL	11/10/2003	TRICHLOROETHYLENE	0.0028	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #3	WL	04/21/2003	1,1,1-TRICHLOROETHANE	0.0007	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #3	WL	04/21/2003	TRICHLOROETHYLENE	0.0009	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #3	WL	08/27/2003	CIS-1,2-DICHLOROETHYLENE	0.0006	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #3	WL	08/27/2003	1,1-DICHLOROETHYLENE	0.0005	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #3	WL	08/27/2003	1,1-DICHLOROETHANE	0.0007	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #3	WL	08/27/2003	1,1,1-TRICHLOROETHANE	0.0014	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #3	WL	08/27/2003	TRICHLOROETHYLENE	0.0013	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #3	WL	10/14/2003	1,1-DICHLOROETHYLENE	0.0003	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #3	WL	10/14/2003	1,1-DICHLOROETHANE	0.0005	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #3	WL	10/14/2003	1,1,1-TRICHLOROETHANE	0.0009	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELL #3	WL	10/14/2003	TRICHLOROETHYLENE	0.001	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELLS #2 & #3 ENTRY POINT	SS	04/21/2003	1,1,1-TRICHLOROETHANE	0.0007	MG/L
WALLINGFORD	COMMUNITY	WALLINGFORD WATER DEPARTMENT	CT1480011	OAK STREET WELLS #2 & #3 ENTRY POINT	SS	04/21/2003	TRICHLOROETHYLENE	0.0009	MG/L
WESTON	NON TRAN NON COMM	WESTON SHOPPING CENTER ASSOCIATES, LLC	CT1570152	BETWEEN GAC FILTERS	SS	02/26/2003	1,1-DICHLOROETHANE	0.005	MG/L
WESTON	NON TRAN NON COMM	WESTON SHOPPING CENTER ASSOCIATES, LLC	CT1570152	BETWEEN GAC FILTERS	SS	08/18/2003	TETRACHLOROETHYLENE	0.0005	MG/L
WESTON	NON TRAN NON COMM	WESTON SHOPPING CENTER ASSOCIATES, LLC	CT1570152	BETWEEN GAC FILTERS	SS	11/24/2003	1,1-DICHLOROETHANE	0.0006	MG/L
WESTON	NON TRAN NON COMM	WESTON SHOPPING CENTER ASSOCIATES, LLC	CT1570152	BETWEEN GAC FILTERS	SS	11/24/2003	TETRACHLOROETHYLENE	0.0059	MG/L
WESTON	NON TRAN NON COMM	WESTON SHOPPING CENTER ASSOCIATES, LLC	CT1570152	ENTRY POINT	SS	11/24/2003	1,1-DICHLOROETHANE	0.0005	MG/L
WESTON	NON TRAN NON COMM	WESTON SHOPPING CENTER ASSOCIATES, LLC	CT1570152	WELL	WL	02/26/2003	TRICHLOROETHYLENE	0.0012	MG/L
WESTON	NON TRAN NON COMM	WESTON SHOPPING CENTER ASSOCIATES, LLC	CT1570152	WELL	WL	02/26/2003	TETRACHLOROETHYLENE	0.3014	MG/L
WESTON	NON TRAN NON COMM	WESTON SHOPPING CENTER ASSOCIATES, LLC	CT1570152	WELL	WL	06/23/2003	1,1-DICHLOROETHANE	0.0005	MG/L
WESTON	NON TRAN NON COMM	WESTON SHOPPING CENTER ASSOCIATES, LLC	CT1570152	WELL	WL	06/23/2003	TRICHLOROETHYLENE	0.0009	MG/L
WESTON	NON TRAN NON COMM	WESTON SHOPPING CENTER ASSOCIATES, LLC	CT1570152	WELL	WL	08/18/2003	TETRACHLOROETHYLENE	0.130	MG/L
WESTON	NON TRAN NON COMM	WESTON SHOPPING CENTER ASSOCIATES, LLC	CT1570152	WELL	WL	11/24/2003	TRICHLOROETHYLENE	0.0009	MG/L
WESTON	NON TRAN NON COMM	WESTON SHOPPING CENTER ASSOCIATES, LLC	CT1570152	WELL	WL	11/24/2003	TETRACHLOROETHYLENE	0.2513	MG/L
WESTPORT	NON TRAN NON COMM	NEWTOWN GROUP PROPERTIES LTD PARTNERSHIP	CT1580003	ENTRY POINT	SS	06/02/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0034	MG/L
WESTPORT	NON TRAN NON COMM	NEWTOWN GROUP PROPERTIES LTD PARTNERSHIP	CT1580003	ENTRY POINT	SS	06/02/2003	TRICHLOROETHYLENE	0.00092	MG/L
WESTPORT	NON TRAN NON COMM	NEWTOWN GROUP PROPERTIES LTD PARTNERSHIP	CT1580003	ENTRY POINT	SS	09/11/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00211	MG/L
WESTPORT	NON TRAN NON COMM	NEWTOWN GROUP PROPERTIES LTD PARTNERSHIP	CT1580003	ENTRY POINT	SS	09/11/2003	TRICHLOROETHYLENE	0.00089	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	DISTRIBUTION SYSTEM	DS	04/07/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.002	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	DISTRIBUTION SYSTEM	DS	07/18/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0035	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	DISTRIBUTION SYSTEM	DS	07/18/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.003	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	ENTRY POINT - DUNKIN DONUTS	SS	07/18/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0046	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	ENTRY POINT - DUNKIN DONUTS	SS	12/03/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.023	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	ENTRY POINT - SLEEP INN	SS	12/03/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0029	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #1	WL	07/18/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0034	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #1	WL	12/03/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0021	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	01/16/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0031	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	02/20/2003	NAPHTHALENE	0.0011	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	02/20/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0343	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	02/20/2003	1,2,4-TRIMETHYLBENZENE	0.0053	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	02/20/2003	1,3,5-TRIMETHYLBENZENE	0.0015	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	02/20/2003	BENZENE	0.0006	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	02/20/2003	ETHYLBENZENE	0.0023	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	02/20/2003	N-PROPYLBENZENE	0.0007	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	03/05/2003	NAPHTHALENE	0.0008	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	03/05/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.031	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	03/05/2003	1,2,4-TRIMETHYLBENZENE	0.0041	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	03/05/2003	1,3,5-TRIMETHYLBENZENE	0.0010	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	03/05/2003	ETHYLBENZENE	0.0017	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	03/05/2003	N-PROPYLBENZENE	0.0005	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	04/07/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.033	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	05/13/2003	NAPHTHALENE	0.0027	MG/L

Positive Organics for Calendar Year 2003

TOWN	SYSTEM TYPE	SYSTEM NAME	PWSID	FACILITY NAME	FACILITY TYPE	COLLECTION DATE	CHEMICAL	MEASURE	UNIT OF MEASURE
ASHFORD	NON TRAN NON COMM	ASHFORD ELEMENTARY SCHOOL	CT0030152	ENTRY POINT	SS	06/16/2003	TETRACHLOROETHYLENE	0.0016	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	05/13/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0317	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	05/13/2003	1,2,4-TRIMETHYLBENZENE	0.0133	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	05/13/2003	1,3,5-TRIMETHYLBENZENE	0.0038	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	05/13/2003	ETHYLBENZENE	0.0047	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	05/13/2003	N-PROPYLBENZENE	0.0010	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	06/12/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.039	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	07/18/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.037	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	10/17/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0258	MG/L
WILLINGTON	NON TRAN NON COMM	TA TRAVEL PLAZA	CT1600513	WELL #2	WL	12/03/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.038	MG/L
WILTON	NON TRANSIENT	DELUCA CENTER	CT1610044	ENTRY POINT	SS	09/16/2003	DIBROMOMETHANE	0.79	MG/L
WINCHESTER	NON TRAN NON COMM	WINCHESTER DOT MAINTENANCE & REPAIR	CT1620162	ENTRY POINT	SS	03/05/2003	TOLUENE	0.002	MG/L
WINCHESTER	NON TRAN NON COMM	WINCHESTER DOT MAINTENANCE & REPAIR	CT1620162	ENTRY POINT	SS	08/11/2003	TOLUENE	0.0014	MG/L
WINDSOR LOCKS	NON TRANSIENT	DONUT KETTLE	CT1650034	ENTRY POINT	SS	02/03/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.002	MG/L
WOLCOTT	COMMUNITY	RSK REALTY 1	CT1669061	ENTRY POINT - WELL #3	SS	02/26/2003	METHYL TERT-BUTYL ETHER (MTBE)	2.50	MG/L
WOODBURY	COMMUNITY	QUASSUK HEIGHTS CONDOMINIUM ASSN	CT1680041	ENTRY POINT 1 - WELLS 1,2,3	SS	04/17/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.007	MG/L
WOODBURY	COMMUNITY	QUASSUK HEIGHTS CONDOMINIUM ASSN	CT1680041	ENTRY POINT 1 - WELLS 1,2,3	SS	08/12/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.0045	MG/L
WOODBURY	COMMUNITY	UNITED WATER CT, INC.-WOODBURY SYSTEM	CT1680011	DISTRIBUTION SYSTEM	DS	01/08/2003	1,1,1-TRICHLOROETHANE	0.0016	MG/L
WOODSTOCK	NON TRAN NON COMM	LINEMASTER SWITCH CORP	CT1690442	BETWEEN GAC FILTERS	SS	06/10/2003	TRICHLOROETHYLENE	0.00037	MG/L
WOODSTOCK	NON TRAN NON COMM	LINEMASTER SWITCH CORP	CT1690442	BETWEEN GAC FILTERS	SS	09/15/2003	TRICHLOROETHYLENE	0.00029	MG/L
WOODSTOCK	NON TRAN NON COMM	LINEMASTER SWITCH CORP	CT1690442	ENTRY POINT	SS	03/17/2003	CHLOROMETHANE	0.00062	MG/L
WOODSTOCK	NON TRAN NON COMM	LINEMASTER SWITCH CORP	CT1690442	ENTRY POINT	SS	06/10/2003	TRICHLOROETHYLENE	0.00027	MG/L
WOODSTOCK	NON TRAN NON COMM	LINEMASTER SWITCH CORP	CT1690442	WELL	WL	06/11/2003	CIS-1,2-DICHLOROETHYLENE	0.007	MG/L
WOODSTOCK	NON TRAN NON COMM	LINEMASTER SWITCH CORP	CT1690442	WELL	WL	06/11/2003	TRICHLOROETHYLENE	0.004	MG/L
WOODSTOCK	NON TRAN NON COMM	LINEMASTER SWITCH CORP	CT1690442	WELL	WL	06/23/2003	CIS-1,2-DICHLOROETHYLENE	0.0078	MG/L
WOODSTOCK	NON TRAN NON COMM	LINEMASTER SWITCH CORP	CT1690442	WELL	WL	06/23/2003	TRANS-1,2-DICHLOROETHYLENE	0.00051	MG/L
WOODSTOCK	NON TRAN NON COMM	LINEMASTER SWITCH CORP	CT1690442	WELL	WL	06/23/2003	TRICHLOROETHYLENE	0.0039	MG/L
WOODSTOCK	NON TRAN NON COMM	LINEMASTER SWITCH CORP	CT1690442	WELL	WL	09/17/2003	CIS-1,2-DICHLOROETHYLENE	0.0098	MG/L
WOODSTOCK	NON TRAN NON COMM	LINEMASTER SWITCH CORP	CT1690442	WELL	WL	09/17/2003	TRANS-1,2-DICHLOROETHYLENE	0.00069	MG/L
WOODSTOCK	NON TRAN NON COMM	LINEMASTER SWITCH CORP	CT1690442	WELL	WL	09/17/2003	TRICHLOROETHYLENE	0.0052	MG/L
WOODSTOCK	NON TRAN NON COMM	WOODSTOCK ELEMENTARY SCHOOL	CT1690262	WELL	WL	06/17/2003	METHYL TERT-BUTYL ETHER (MTBE)	0.00064	MG/L

ATTACHMENT XVI
PUBLIC WATER SYSTEMS TREATING FOR ORGANIC
CHEMICALS DURING 2003

Attachment XVI lists those fifty-one (51) public water supplies now treating for organic contaminants. There are nineteen (19) community supplies and thirty-two (32) non-community supplies in this category.

PUBLIC WATER SYSTEMS TREATING FOR ORGANIC CHEMICALS

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
BETHANY					
	NONNIES DELI	25			
			CIS-1,2-DICHLOROETHYLENE	0.0005	BETWEEN GAC FILTRATION
			METHYL TERT-BUTYL ETHER (MTBE)	0.14	BETWEEN GAC FILTRATION
			METHYL TERT-BUTYL ETHER (MTBE)	0.199	WELL
			METHYL TERT-BUTYL ETHER (MTBE)	0.230	POST GAC TREATMENT
			METHYL TERT-BUTYL ETHER (MTBE)	0.210	BETWEEN GAC FILTRATION
BROOKFIELD					
	20 STATION ROAD - APT BUILDING	27			
			1,2,4-TRICHLOROENZENE	0.0011	WELL 2
			CIS-1,2-DICHLOROETHYLENE	0.0036	WELL 2
			M-DICHLOROENZENE	0.0019	WELL 2
			METHYL TERT-BUTYL ETHER (MTBE)	0.0028	WELL 2
			METHYL TERT-BUTYL ETHER (MTBE)	0.0035	ENTRY POINT
			O-DICHLOROENZENE	0.0016	WELL 2
			P-DICHLOROENZENE	0.0014	WELL 2
			TETRACHLOROETHYLENE	109	WELL 2
			TETRACHLOROETHYLENE	0.160	WELL 2
			TETRACHLOROETHYLENE	107	WELL 2
			TRICHLOROETHYLENE	0.013	WELL 2
	BROOKFIELD CENTER LLC	40			
			METHYL TERT-BUTYL ETHER (MTBE)	0.0018	ENTRY POINT

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
			NAPHTHALENE	0.002	ENTRY POINT
			NAPHTHALENE	0.00085	WELL
			TRICHLOROETHYLENE	0.00079	WELL
	BROOKFIELD SHELL	25			
			METHYL TERT-BUTYL ETHER (MTBE)	0.0007	ENTRY POINT
			METHYL TERT-BUTYL ETHER (MTBE)	0.0004	TREATMENT PLANT
			METHYL TERT-BUTYL ETHER (MTBE)	0.00059	WELL
			METHYL TERT-BUTYL ETHER (MTBE)	0.00052	WELL
			TETRACHLOROETHYLENE	0.001	WELL
			TOLUENE	0.0015	ENTRY POINT
			TOLUENE	0.000069	TREATMENT PLANT
			TOLUENE	0.0011	WELL
			TRICHLOROETHYLENE	0.0016	ENTRY POINT
			TRICHLOROETHYLENE	0.0061	WELL
	CANDLEBROOK VILLAGE	200			
			TETRACHLOROETHYLENE	0.0025	COMBINED RAW WATER DISCHA
			TETRACHLOROETHYLENE	0.0007	BETWEEN GAC FILTERS
	COUNTRY KIDS CLUB	55			
			TETRACHLOROETHYLENE	0.0013	WELL #1
	DORCAL CAOB ASSOCIATES-RADIO SHACK WELI	27			
			CIS-1,2-DICHLOROETHYLENE	0.00247	BETWEEN GAC FILTERS
			CIS-1,2-DICHLOROETHYLENE	0.0101	WELL #3
			CIS-1,2-DICHLOROETHYLENE	0.00095	ENTRY POINT
			CIS-1,2-DICHLOROETHYLENE	0.00575	BETWEEN GAC FILTERS
			CIS-1,2-DICHLOROETHYLENE	0.00705	WELL #3
			CIS-1,2-DICHLOROETHYLENE	0.00124	BETWEEN GAC FILTERS

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
			CIS-1,2-DICHLOROETHYLENE	0.00572	ENTRY POINT
			CIS-1,2-DICHLOROETHYLENE	0.00757	WELL #3
			TETRACHLOROETHYLENE	0.0344	WELL #3
			TETRACHLOROETHYLENE	0.0288	WELL #3
			TETRACHLOROETHYLENE	0.0349	WELL #3
			TETRACHLOROETHYLENE	0.0226	BETWEEN GAC FILTERS
			TETRACHLOROETHYLENE	0.0232	BETWEEN GAC FILTERS
			TETRACHLOROETHYLENE	0.00437	ENTRY POINT
			TETRACHLOROETHYLENE	0.0105	BETWEEN GAC FILTERS
			TRICHLOROETHYLENE	0.0064	WELL #3
			TRICHLOROETHYLENE	0.0051	WELL #3
			TRICHLOROETHYLENE	0.00491	BETWEEN GAC FILTERS
			TRICHLOROETHYLENE	0.0084	WELL #3
			TRICHLOROETHYLENE	0.00213	BETWEEN GAC FILTERS
			TRICHLOROETHYLENE	0.00196	ENTRY POINT
			TRICHLOROETHYLENE	0.0044	BETWEEN GAC FILTERS
	WEBSTER BANK	25			
			METHYL TERT-BUTYL ETHER (MTBE)	0.003	GAC FILTERS
			METHYL TERT-BUTYL ETHER (MTBE)	0.0009	GAC FILTERS
			METHYL TERT-BUTYL ETHER (MTBE)	0.0685	WELL
			TRICHLOROETHYLENE	0.0022	WELL
BURLINGTON					
	BURLINGTON COMMONS	94			
			METHYL TERT-BUTYL ETHER (MTBE)	0.005	WELL
			METHYL TERT-BUTYL ETHER (MTBE)	0.0005	BETWEEN GAC FILTERS
			METHYL TERT-BUTYL ETHER (MTBE)	0.003	WELL

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
			METHYL TERT-BUTYL ETHER (MTBE)	0.006	WELL
			METHYL TERT-BUTYL ETHER (MTBE)	0.005	WELL
			METHYL TERT-BUTYL ETHER (MTBE)	0.0007	BETWEEN GAC FILTERS
			METHYL TERT-BUTYL ETHER (MTBE)	0.0005	WELL
			METHYL TERT-BUTYL ETHER (MTBE)	0.004	WELL
CHESTER					
	AARON MANOR NURSING & REHAB CENTER	93			
			1,2,4-TRIMETHYLBENZENE	0.0016	WELL 5
			1,3,5-TRIMETHYLBENZENE	0.0005	WELL 5
			NAPHTHALENE	0.0013	WELL 5
	GBR SYSTEMS CORPORATION	68			
			TETRACHLOROETHYLENE	0.0048	WELL
COLCHESTER					
	COLCHESTER SEWER & WATER COMMISSION	4500			
			METHYL TERT-BUTYL ETHER (MTBE)	0.0011	CABIN ROAD WTP ENTRY POINT
			METHYL TERT-BUTYL ETHER (MTBE)	1.0	CABIN ROAD WTP ENTRY POINT
			METHYL TERT-BUTYL ETHER (MTBE)	0.0011	CABIN ROAD WTP ENTRY POINT
			TETRACHLOROETHYLENE	0.0007	WELL #4 WTP ENTRY POINT
			TETRACHLOROETHYLENE	0.00071	WELL #4 WTP ENTRY POINT
			TETRACHLOROETHYLENE	0.00077	WELL #4 WTP ENTRY POINT
DANBURY					
	GLOBAL DANBURY - FEDERAL RD	25			
			BROMOMETHANE	0.00076	ENTRY POINT
			BROMOMETHANE	0.00075	ENTRY POINT

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
			BROMOMETHANE	0.00079	BETWEEN GAC FILTERS
			CHLOROMETHANE	0.00067	ENTRY POINT
			CHLOROMETHANE	0.00099	WELL #1
			CHLOROMETHANE	0.00063	WELL #1
			CHLOROMETHANE	0.0008	BETWEEN GAC FILTERS
			METHYL TERT-BUTYL ETHER (MTBE)	0.000103	ENTRY POINT
			METHYL TERT-BUTYL ETHER (MTBE)	0.0011	BETWEEN GAC FILTERS
			TOLUENE	0.02	WELL #1
			TOLUENE	0.0059	BETWEEN GAC FILTERS
			TOLUENE	0.0065	WELL #1
			TOLUENE	0.0017	WELL #1
			TOLUENE	0.00057	ENTRY POINT
			TOLUENE	0.00052	WELL #1
			TOLUENE	0.0022	BETWEEN GAC FILTERS
			TOLUENE	0.0012	ENTRY POINT
			TOLUENE	0.0041	BETWEEN GAC FILTERS
			TOLUENE	0.0018	BETWEEN GAC FILTERS
			TOLUENE	0.032	BETWEEN GAC FILTERS
			TOLUENE	0.0015	ENTRY POINT
			TOLUENE	0.0022	WELL #1
			TOLUENE	0.0013	ENTRY POINT
			TOLUENE	0.0017	WELL #1
			TOLUENE	0.0025	DISTRIBUTION SYSTEM
			TOLUENE	0.0025	WELL #1
			XYLENE, META	0.0012	WELL #1
			XYLENE, META	0.0013	BETWEEN GAC FILTERS
			XYLENE, PARA	0.0013	BETWEEN GAC FILTERS
			XYLENE, PARA	0.0012	WELL #1

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
DARIEN					
	AQUARION WATER CO OF CT-NOROTON SYSTEM	<i>18604</i>			
			CIS-1,2-DICHLOROETHYLENE	0.0016	REWAK WELL
			TETRACHLOROETHYLENE	0.0013	REWAK WELL
			TETRACHLOROETHYLENE	0.0011	REWAK WELL
			TETRACHLOROETHYLENE	0.0014	REWAK WELL
			TETRACHLOROETHYLENE	0.0011	REWAK WELL
			TRICHLOROETHYLENE	0.0005	REWAK WELL
			TRICHLOROETHYLENE	0.0006	REWAK WELL
			TRICHLOROETHYLENE	0.0007	REWAK WELL
			TRICHLOROETHYLENE	0.0007	REWAK WELL
DURHAM					
	DURHAM COMMONS	<i>25</i>			
			METHYL TERT-BUTYL ETHER (MTBE)	5.4	WELL
			METHYL TERT-BUTYL ETHER (MTBE)	0.44	WELL
			METHYL TERT-BUTYL ETHER (MTBE)	0.194	ENTRY POINT
			METHYL TERT-BUTYL ETHER (MTBE)	0.27	GAC FILTRATION
			METHYL TERT-BUTYL ETHER (MTBE)	0.250	WELL
	DURHAM MANUFACTURING	<i>200</i>			
			1,1,1-TRICHLOROETHANE	0.0021	WELL
			1,1-DICHLOROETHANE	0.0019	WELL
			CIS-1,2-DICHLOROETHYLENE	0.037	WELL
			TRICHLOROETHYLENE	0.0022	WELL
			TRICHLOROETHYLENE	0.0016	ENTRY POINT
			TRICHLOROETHYLENE	0.0017	BETWEEN GAC FILTERS

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
	FRANK WARD STRONG SCHOOL	358			
			1,1,1-TRICHLOROETHANE	0.0244	WELL
			1,1,1-TRICHLOROETHANE	0.0318	WELL
			1,1-DICHLOROETHANE	0.0914	WELL
			1,1-DICHLOROETHANE	0.075	WELL
			1,1-DICHLOROETHYLENE	0.0494	WELL
			1,1-DICHLOROETHYLENE	0.0345	WELL
			CIS-1,2-DICHLOROETHYLENE	1.508	WELL
			CIS-1,2-DICHLOROETHYLENE	0.717	WELL
			TETRACHLOROETHYLENE	0.0681	WELL
			TETRACHLOROETHYLENE	0.0402	WELL
			TRANS-1,2-DICHLOROETHYLENE	0.0038	WELL
			TRICHLOROETHYLENE	0.816	WELL
			TRICHLOROETHYLENE	1.573	WELL
			VINYL CHLORIDE	0.0302	WELL
			VINYL CHLORIDE	0.0522	WELL
	LNJS REALTY FAMILY LIMITED PARTNERSHIP	25			
			METHYL TERT-BUTYL ETHER (MTBE)	0.0035	WELL
	TWIN MAPLES NURSING HOME	100			
			1,2-DICHLOROETHANE	0.00062	ENTRY POINT
EAST HAMPTON					
	AMERICAN DISTILLING & MANUFACTURING, INC	55			
			METHYL TERT-BUTYL ETHER (MTBE)	0.002	WELL1
			METHYL TERT-BUTYL ETHER (MTBE)	0.0041	BETWEEN GAC FILTERS
			METHYL TERT-BUTYL ETHER (MTBE)	0.005	BETWEEN GAC FILTERS

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
			METHYL TERT-BUTYL ETHER (MTBE)	0.003	BETWEEN GAC FILTERS
	CL&P EAST HAMPTON SERVICE CTR	<i>80</i>			
			METHYL TERT-BUTYL ETHER (MTBE)	0.00073	WELL #1
	EAST HAMPTON WATER & SEWER AUTHORITY	<i>80</i>			
			CIS-1,2-DICHLOROETHYLENE	0.0047	WELL 1
			CIS-1,2-DICHLOROETHYLENE	0.0054	WELL 1
			METHYL TERT-BUTYL ETHER (MTBE)	1.0	ENTRY POINT
			TETRACHLOROETHYLENE	0.0332	WELL 1
			TETRACHLOROETHYLENE	0.0037	ENTRY POINT
			TETRACHLOROETHYLENE	0.0169	WELL 1
			TRICHLOROETHYLENE	0.0053	WELL 1
			TRICHLOROETHYLENE	0.0075	WELL 1
EAST LYME					
	EAST LYME WATER & SEWER COMMISSION	<i>15245</i>			
			TETRACHLOROETHYLENE	0.0008	WELL 4A WTP ENTRY POINT
			TETRACHLOROETHYLENE	0.001	INDUSTRIAL PARK ROAD WTP EN
			TETRACHLOROETHYLENE	0.0009	WELL 6 WTP ENTRY POINT
	SUNOCO SERVICE STATION #0005-6861	<i>25</i>			
			TOLUENE	0.0028	TREATMENT PLANT
EAST WINDSOR					
	CTWC - NORTHERN REG-WESTERN SYSTEM	<i>77202</i>			
			TRICHLOROETHYLENE	0.0011	ENTRY POINT - WOODLAND PAR
ENFIELD					
	CONNECTICUT CORRECTIONAL INSTITUTE	<i>5186</i>			

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
			TETRACHLOROETHYLENE	13	SOMERS WELL 2
			TETRACHLOROETHYLENE	0.0016	SOMERS WELL 2
			TETRACHLOROETHYLENE	4.2	SOMERS WELL 3
			TETRACHLOROETHYLENE	17.4	SOMERS WELL 2
			TETRACHLOROETHYLENE	3	SOMERS WELL 3
			TETRACHLOROETHYLENE	0.0098	SOMERS WELL 2
			TETRACHLOROETHYLENE	0.0022	SOMERS WELL 3
MADISON					
	NORTH MADISON CONGREGATIONAL CHURCH	<i>29</i>			
			METHYL TERT-BUTYL ETHER (MTBE)	0.0132	BETWEEN GAC FILTERS
			METHYL TERT-BUTYL ETHER (MTBE)	0.0054	ENTRY POINT
			METHYL TERT-BUTYL ETHER (MTBE)	0.0075	BETWEEN GAC FILTERS
MANCHESTER					
	TOWN OF MANCHESTER WATER DEPARTMENT	<i>49500</i>			
			1,1,1-TRICHLOROETHANE	0.0006	ENTRY POINT - WELLS 6,7,8
			1,1,1-TRICHLOROETHANE	0.0011	NEW STATE RD WELL 8
			TETRACHLOROETHYLENE	0.0036	ENTRY POINT - WELLS 6,7,8
			TETRACHLOROETHYLENE	0.0022	ENTRY POINT - WELLS 6,7,8
			TETRACHLOROETHYLENE	0.0044	ENTRY POINT - WELLS 6,7,8
			TETRACHLOROETHYLENE	0.0035	ENTRY POINT - WELLS 6,7,8
			TETRACHLOROETHYLENE	0.0041	ENTRY POINT - WELLS 6,7,8
			TETRACHLOROETHYLENE	0.0017	ENTRY POINT - WELLS 6,7,8
			TETRACHLOROETHYLENE	0.0027	ENTRY POINT - WELLS 6,7,8
			TETRACHLOROETHYLENE	0.0037	ENTRY POINT - WELLS 6,7,8
			TETRACHLOROETHYLENE	0.0022	ENTRY POINT - WELLS 6,7,8
			TETRACHLOROETHYLENE	0.003	ENTRY POINT - WELLS 6,7,8

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
			TETRACHLOROETHYLENE	0.0030	ENTRY POINT - WELLS 6,7,8
			TETRACHLOROETHYLENE	0.0024	ENTRY POINT - WELLS 6,7,8
			TETRACHLOROETHYLENE	0.0017	ENTRY POINT - WELLS 6,7,8
			TETRACHLOROETHYLENE	0.0020	NEW STATE RD WELL 7
			TETRACHLOROETHYLENE	0.0021	ENTRY POINT - WELLS 6,7,8
			TETRACHLOROETHYLENE	0.0022	ENTRY POINT - WELLS 6,7,8
			TETRACHLOROETHYLENE	0.0018	NEW STATE RD WELL 6
			TETRACHLOROETHYLENE	0.0054	NEW STATE RD WELL 8T
			TETRACHLOROETHYLENE	0.0025	ENTRY POINT - WELLS 6,7,8
			TRICHLOROETHYLENE	0.0018	ENTRY POINT - WELLS 6,7,8
			TRICHLOROETHYLENE	0.0017	ENTRY POINT - WELLS 6,7,8
			TRICHLOROETHYLENE	0.0013	ENTRY POINT - WELLS 6,7,8
			TRICHLOROETHYLENE	0.0015	ENTRY POINT - WELLS 6,7,8
			TRICHLOROETHYLENE	0.0021	ENTRY POINT - WELLS 6,7,8
			TRICHLOROETHYLENE	0.0016	ENTRY POINT - WELLS 6,7,8
			TRICHLOROETHYLENE	0.0021	ENTRY POINT - WELLS 6,7,8
			TRICHLOROETHYLENE	0.0018	ENTRY POINT - WELLS 6,7,8
			TRICHLOROETHYLENE	0.0021	ENTRY POINT - WELLS 6,7,8
			TRICHLOROETHYLENE	0.0012	ENTRY POINT - WELLS 6,7,8
			TRICHLOROETHYLENE	0.0019	ENTRY POINT - WELLS 6,7,8
			TRICHLOROETHYLENE	0.0027	NEW STATE RD WELL 7
			TRICHLOROETHYLENE	0.0018	ENTRY POINT - WELLS 6,7,8
			TRICHLOROETHYLENE	0.0025	ENTRY POINT - WELLS 6,7,8
			TRICHLOROETHYLENE	0.0026	ENTRY POINT - WELLS 6,7,8
			TRICHLOROETHYLENE	0.0015	ENTRY POINT - WELLS 6,7,8
			TRICHLOROETHYLENE	0.0043	NEW STATE RD WELL 8

MANSFIELD

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
	PUBLIC AMERICA	<i>25</i>			
			METHYL TERT-BUTYL ETHER (MTBE)	0.005	ENTRY POINT
			TOLUENE	0.0006	ENTRY POINT
	ROSAL APARTMENTS	<i>25</i>			
			METHYL TERT-BUTYL ETHER (MTBE)	0.004	ENTRY POINT
			METHYL TERT-BUTYL ETHER (MTBE)	0.002	ENTRY POINT
MERIDEN					
	MERIDEN WATER DIVISION	<i>60000</i>			
			TETRACHLOROETHYLENE	0.0016	PLATT LINCOLN WTP ENTRY POI
			TETRACHLOROETHYLENE	0.027	LINCOLN WELL
			TETRACHLOROETHYLENE	0.028	LINCOLN WELL
			TETRACHLOROETHYLENE	0.0019	PLATT WELL
			TETRACHLOROETHYLENE	0.0015	PLATT LINCOLN WTP ENTRY POI
			TETRACHLOROETHYLENE	0.029	LINCOLN WELL
			TETRACHLOROETHYLENE	0.004	PLATT WELL
			TETRACHLOROETHYLENE	0.03	LINCOLN WELL
			TETRACHLOROETHYLENE	0.041	LINCOLN WELL
			TETRACHLOROETHYLENE	0.0017	PLATT LINCOLN TREATMENT STA
			TETRACHLOROETHYLENE	0.0044	PLATT WELL
			TETRACHLOROETHYLENE	0.0017	PLATT LINCOLN WTP ENTRY POI
			TETRACHLOROETHYLENE	0.0038	PLATT WELL
			TETRACHLOROETHYLENE	0.029	LINCOLN WELL
			TETRACHLOROETHYLENE	0.026	LINCOLN WELL
			TETRACHLOROETHYLENE	0.042	LINCOLN WELL
			TRICHLOROETHYLENE	0.0005	LINCOLN WELL
			TRICHLOROETHYLENE	0.00053	LINCOLN WELL

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
			TRICHLOROETHYLENE	0.0012	PLATT WELL
			TRICHLOROETHYLENE	0.0006	LINCOLN WELL
			TRICHLOROETHYLENE	0.0005	LINCOLN WELL
			TRICHLOROETHYLENE	0.0013	LINCOLN WELL
			TRICHLOROETHYLENE	0.0008	LINCOLN WELL
			TRICHLOROETHYLENE	0.0007	LINCOLN WELL
			TRICHLOROETHYLENE	0.0009	LINCOLN WELL
			TRICHLOROETHYLENE	0.001	PLATT WELL
			TRICHLOROETHYLENE	0.001	LINCOLN WELL
			TRICHLOROETHYLENE	0.0008	LINCOLN WELL
MIDDLETOWN					
	PRATT & WHITNEY	2800			
			1,1,1-TRICHLOROETHANE	0.00581107	COMBINED RAW WATER DISCHA
			1,1,1-TRICHLOROETHANE	0.00087	COMBINED RAW WATER DISCHA
			1,1,1-TRICHLOROETHANE	0.00283	WELL 7
			CARBON TETRACHLORIDE	0.00285	ENTRY POINT
			CHLOROMETHANE	0.01013	ENTRY POINT
			METHYL TERT-BUTYL ETHER (MTBE)	0.0008	ENTRY POINT
			METHYL TERT-BUTYL ETHER (MTBE)	0.0008	ENTRY POINT
			TRICHLOROETHYLENE	0.02296	COMBINED RAW WATER DISCHA
			TRICHLOROETHYLENE	0.01488	WELL 7
			TRICHLOROETHYLENE	0.00636	COMBINED RAW WATER DISCHA
NEW FAIRFIELD					
	DRUCK, INC. (4 DUNHAM DR.)	30			
			1,1,1-TRICHLOROETHANE	0.00879	BETWEEN GAC FILTERS
			1,1,1-TRICHLOROETHANE	0.0117	ENTRY POINT

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
			1,1,1-TRICHLOROETHANE	0.0298	WELL
			1,1-DICHLOROETHANE	0.00206	WELL
			1,1-DICHLOROETHANE	0.00231	BETWEEN GAC FILTERS
			1,1-DICHLOROETHANE	0.00198	ENTRY POINT
			1,1-DICHLOROETHYLENE	0.00908	WELL
	HERITAGE PLAZA	54			
			CIS-1,2-DICHLOROETHYLENE	0.0009	BETWEEN GAC FILTERS
			TETRACHLOROETHYLENE	0.0318	WELL 1
			TETRACHLOROETHYLENE	0.0007	BETWEEN GAC FILTERS
			TETRACHLOROETHYLENE	0.0011	ENTRY POINT
			TETRACHLOROETHYLENE	0.018	WELL 3
			TETRACHLOROETHYLENE	0.0055	BETWEEN GAC FILTERS
			TETRACHLOROETHYLENE	0.0013	ENTRY POINT
			TETRACHLOROETHYLENE	0.0011	BETWEEN GAC FILTERS
			TETRACHLOROETHYLENE	0.0008	WELL 2
	NEW FAIRFIELD SHOPPING CENTER, LLC	60			
			CIS-1,2-DICHLOROETHYLENE	0.0008	BETWEEN GAC FILTERS
			METHYL TERT-BUTYL ETHER (MTBE)	0.0132	BETWEEN GAC FILTERS
			METHYL TERT-BUTYL ETHER (MTBE)	0.0085	BETWEEN GAC FILTERS
			METHYL TERT-BUTYL ETHER (MTBE)	0.0122	ENTRY POINT
			METHYL TERT-BUTYL ETHER (MTBE)	0.0038	ENTRY POINT
			METHYL TERT-BUTYL ETHER (MTBE)	0.0162	WELL #1
			METHYL TERT-BUTYL ETHER (MTBE)	0.0089	ENTRY POINT
			METHYL TERT-BUTYL ETHER (MTBE)	0.0108	ENTRY POINT
			TETRACHLOROETHYLENE	0.0007	BETWEEN GAC FILTERS
			TETRACHLOROETHYLENE	0.0008	BETWEEN GAC FILTERS
			TETRACHLOROETHYLENE	0.0133	WELL #1

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
			TETRACHLOROETHYLENE	0.0008	ENTRY POINT
			TETRACHLOROETHYLENE	0.0008	ENTRY POINT
			TRICHLOROETHYLENE	0.0012	WELL #1
NORTH STONINGTON					
	TINACO PLAZA, LLC	25			
			METHYL TERT-BUTYL ETHER (MTBE)	0.035	WELL 1
			METHYL TERT-BUTYL ETHER (MTBE)	0.018	BETWEEN GAC FILTERS
			METHYL TERT-BUTYL ETHER (MTBE)	0.028	BETWEEN GAC FILTERS
			METHYL TERT-BUTYL ETHER (MTBE)	0.021	ENTRY POINT
			METHYL TERT-BUTYL ETHER (MTBE)	0.038	BETWEEN GAC FILTERS
			METHYL TERT-BUTYL ETHER (MTBE)	0.029	WELL 1
NORWALK					
	NORWALK FIRST TAXING DISTRICT	45000			
			TRICHLOROETHYLENE	0.0007	RAW WELLFIELD ENTRY POINT
OLD LYME					
	OLD LYME TEXACO	25			
			NAPHTHALENE	0.0005	TREATMENT PLANT
			TOLUENE	0.0098	TREATMENT PLANT
PLAINVILLE					
	VALLEY WATER SYSTEMS, INC.	17500			
			1,1,1-TRICHLOROETHANE	0.00114	JOHNSON WELL 3
			1,1,1-TRICHLOROETHANE	0.00065595	ENTRY POINT-WOODFORD AVE
			1,1,1-TRICHLOROETHANE	0.00150753	JOHNSON WELL 3
			1,1,1-TRICHLOROETHANE	0.00054	ENTRY POINT-WOODFORD AVE

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
			1,1,1-TRICHLOROETHANE	0.000608	ENTRY POINT-WOODFORD AVE
			1,1,1-TRICHLOROETHANE	0.00063	JOHNSON WELL 6
			1,1,1-TRICHLOROETHANE	0.00056	ENTRY POINT-WOODFORD AVE
			1,1,1-TRICHLOROETHANE	0.001255	JOHNSON WELL 3
			1,1,1-TRICHLOROETHANE	0.0013	JOHNSON WELL 3
			1,1,2-TRICHLOROETHANE	0.0006	JOHNSON WELL 3
			CIS-1,2-DICHLOROETHYLENE	0.00109723	JOHNSON WELL 3
			CIS-1,2-DICHLOROETHYLENE	0.00553	JOHNSON WELL 6
			CIS-1,2-DICHLOROETHYLENE	0.00526	JOHNSON WELL 6
			CIS-1,2-DICHLOROETHYLENE	0.00123	JOHNSON WELL 3
			CIS-1,2-DICHLOROETHYLENE	0.00397	JOHNSON WELL 6
			CIS-1,2-DICHLOROETHYLENE	0.00123	JOHNSON WELL 3
			CIS-1,2-DICHLOROETHYLENE	0.00154	JOHNSON WELL 3
			CIS-1,2-DICHLOROETHYLENE	0.0041732	JOHNSON WELL 6
			TETRACHLOROETHYLENE	0.00753	JOHNSON WELL 3
			TETRACHLOROETHYLENE	0.00770824	JOHNSON WELL 3
			TETRACHLOROETHYLENE	0.00255	JOHNSON WELL 6
			TETRACHLOROETHYLENE	0.00138	JOHNSON WELL 6
			TETRACHLOROETHYLENE	0.00621	JOHNSON WELL 3
			TETRACHLOROETHYLENE	0.0032505	JOHNSON WELL 6
			TETRACHLOROETHYLENE	0.0067725	JOHNSON WELL 3
			TETRACHLOROETHYLENE	0.00069	JOHNSON WELL 6
			TRICHLOROETHYLENE	0.00107	JOHNSON WELL 3
			TRICHLOROETHYLENE	0.00139	JOHNSON WELL 3
			TRICHLOROETHYLENE	0.001178	JOHNSON WELL 3
			TRICHLOROETHYLENE	0.008751	JOHNSON WELL 6
			TRICHLOROETHYLENE	0.01018	JOHNSON WELL 6
			TRICHLOROETHYLENE	0.00710541	JOHNSON WELL 6

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
			TRICHLOROETHYLENE	0.0057	JOHNSON WELL 6
			TRICHLOROETHYLENE	0.00111307	JOHNSON WELL 3
PLYMOUTH					
	ISELI CO	<i>80</i>			
			DICHLOROMETHANE	0.00069	BETWEEN GAC FILTERS
			METHYL TERT-BUTYL ETHER (MTBE)	0.0013	BETWEEN GAC FILTERS
			METHYL TERT-BUTYL ETHER (MTBE)	0.0026	PW2 WELL
			TETRACHLOROETHYLENE	0.00092	PW2 WELL
			TETRACHLOROETHYLENE	0.00096	BETWEEN GAC FILTERS
POMFRET					
	LOOS & CO - WELL #1	<i>130</i>			
			1,1-DICHLOROETHANE	0.00072	ENTRY POINT
			1,1-DICHLOROETHYLENE	0.0027	ENTRY POINT
RIDGEFIELD					
	NORCO, INC.	<i>30</i>			
			1,2-DICHLOROETHANE	0.0009	BETWEEN GAC FILTERS
SALEM					
	SALEM TOWN CENTER LLC	<i>30</i>			
			METHYL TERT-BUTYL ETHER (MTBE)	0.002	BETWEEN GAC FILTERS
			METHYL TERT-BUTYL ETHER (MTBE)	0.037	WELL #2 (NEW WELL)
			METHYL TERT-BUTYL ETHER (MTBE)	0.015	BETWEEN GAC FILTERS
SALISBURY					
	AQUARION WATER CO OF CT-SALISBURY SYS	<i>2507</i>			

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
			METHYL TERT-BUTYL ETHER (MTBE)	0.0391	LAKEVILLE WELL #2A
			N-BUTYLBENZENE	0.0009	LAKEVILLE WELL #2A
			TETRACHLOROETHYLENE	0.0021	SALISBURY WELL C
			TETRACHLOROETHYLENE	0.0017	SALISBURY WELL C
			TETRACHLOROETHYLENE	0.0018	SALISBURY WELL A
			TETRACHLOROETHYLENE	0.002	SALISBURY WELL A
			TETRACHLOROETHYLENE	0.0016	SALISBURY WELL A
			TETRACHLOROETHYLENE	0.0009	SALISBURY WELL D
			TETRACHLOROETHYLENE	0.0018	SALISBURY WELL C
			TETRACHLOROETHYLENE	0.0028	SALISBURY WELL B
			TETRACHLOROETHYLENE	0.0015	SALISBURY WELL D
			TETRACHLOROETHYLENE	0.0006	SALISBURY WELL D
			TETRACHLOROETHYLENE	0.003	SALISBURY WELL B
			TETRACHLOROETHYLENE	0.0029	SALISBURY WELL B
SOUTHINGTON					
	SOUTHINGTON WATER DEPARTMENT	<i>40408</i>			
			TETRACHLOROETHYLENE	0.0046	WELL 2
			TETRACHLOROETHYLENE	0.0014	ENTRY POINT - WELL 2
			TETRACHLOROETHYLENE	0.005	WELL 2
VERNON					
	VERNON VILLAGE INC.	<i>430</i>			
			TETRACHLOROETHYLENE	0.0089	WELL 3
			TRICHLOROETHYLENE	0.016	WELL 3
			TRICHLOROETHYLENE	0.0006	ENTRY POINT - WELL 1
WALLINGFORD					

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
WALLINGFORD	WATER DEPARTMENT	39360			
			1,1,1-TRICHLOROETHANE	0.0016	OAK STR W #3 FINISHED (GREEN
			1,1,1-TRICHLOROETHANE	0.0015	OAK STREET WELL #2
			1,1,1-TRICHLOROETHANE	0.0025	OAK STREET WELL #2
			1,1,1-TRICHLOROETHANE	0.0007	OAK STREET WELLS #2 & #3 ENT
			1,1,1-TRICHLOROETHANE	0.0014	OAK STREET WELL #3
			1,1,1-TRICHLOROETHANE	0.0007	OAK STREET WELL #3
			1,1,1-TRICHLOROETHANE	0.0033	OAK STREET WELL #2
			1,1,1-TRICHLOROETHANE	0.0009	OAK STREET WELL #3
			1,1,1-TRICHLOROETHANE	0.001	OAK STR W #3 FINISHED (GREEN
			1,1,1-TRICHLOROETHANE	0.0027	OAK STREET WELL #2
			1,1-DICHLOROETHANE	0.0015	OAK STREET WELL #2
			1,1-DICHLOROETHANE	0.0006	OAK STR W #3 FINISHED (GREEN
			1,1-DICHLOROETHANE	0.0007	OAK STREET WELL #3
			1,1-DICHLOROETHANE	0.0005	OAK STREET WELL #3
			1,1-DICHLOROETHANE	0.0014	OAK STREET WELL #2
			1,1-DICHLOROETHANE	0.0009	OAK STREET WELL #2
			1,1-DICHLOROETHANE	0.0008	OAK STR W #3 FINISHED (GREEN
			1,1-DICHLOROETHYLENE	0.0009	OAK STREET WELL #2
			1,1-DICHLOROETHYLENE	0.0006	OAK STR W #3 FINISHED (GREEN
			1,1-DICHLOROETHYLENE	0.0009	OAK STREET WELL #2
			1,1-DICHLOROETHYLENE	0.0004	OAK STREET WELL #2
			1,1-DICHLOROETHYLENE	0.0007	OAK STREET WELL #2
			1,1-DICHLOROETHYLENE	0.0003	OAK STREET WELL #3
			1,1-DICHLOROETHYLENE	0.0005	OAK STREET WELL #3
			1,2-DICHLOROETHANE	0.0012	OAK STREET WELL #2
			CIS-1,2-DICHLOROETHYLENE	0.0005	OAK STR W #3 FINISHED (GREEN

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
			CIS-1,2-DICHLOROETHYLENE	0.0006	OAK STREET WELL #3
			CIS-1,2-DICHLOROETHYLENE	0.0006	OAK STREET WELL #2
			CIS-1,2-DICHLOROETHYLENE	0.0011	OAK STREET WELL #2
			CIS-1,2-DICHLOROETHYLENE	0.001	OAK STREET WELL #2
			CIS-1,2-DICHLOROETHYLENE	0.0009	OAK STREET WELL #2
			CIS-1,2-DICHLOROETHYLENE	0.0007	OAK STR W #3 FINISHED (GREEN
			TRICHLOROETHYLENE	0.0009	OAK STREET WELLS #2 & #3 ENT
			TRICHLOROETHYLENE	0.0009	OAK STREET WELL #3
			TRICHLOROETHYLENE	0.0028	OAK STREET WELL #2
			TRICHLOROETHYLENE	0.0015	OAK STR W #3 FINISHED (GREEN
			TRICHLOROETHYLENE	0.001	OAK STREET WELL #3
			TRICHLOROETHYLENE	0.0013	OAK STREET WELL #3
			TRICHLOROETHYLENE	0.0028	OAK STREET WELL #2
			TRICHLOROETHYLENE	0.0012	OAK STR W #3 FINISHED (GREEN
			TRICHLOROETHYLENE	0.0025	OAK STREET WELL #2
			TRICHLOROETHYLENE	0.003	OAK STREET WELL #2
WESTON					
	WESTON SHOPPING CENTER ASSOCIATES, LLC	65			
			1,1-DICHLOROETHANE	0.0006	BETWEEN GAC FILTERS
			1,1-DICHLOROETHANE	0.0005	WELL
			1,1-DICHLOROETHANE	0.005	BETWEEN GAC FILTERS
			1,1-DICHLOROETHANE	0.0005	ENTRY POINT
			TETRACHLOROETHYLENE	0.3014	WELL
			TETRACHLOROETHYLENE	0.0005	BETWEEN GAC FILTERS
			TETRACHLOROETHYLENE	0.130	WELL
			TETRACHLOROETHYLENE	0.2513	WELL
			TETRACHLOROETHYLENE	0.0059	BETWEEN GAC FILTERS

<i>TOWN</i>	<i>SYSTEM NAME</i>	<i>POPULATION</i>	<i>CONTAMINANT</i>	<i>LEVEL (ppb)</i>	<i>FACILITY</i>
			TRICHLOROETHYLENE	0.0009	WELL
			TRICHLOROETHYLENE	0.0009	WELL
			TRICHLOROETHYLENE	0.0012	WELL
WOODBURY					
	UNITED WATER CT, INC.-WOODBURY SYSTEM	<i>2260</i>			
			1,1,1-TRICHLOROETHANE	0.0016	DISTRIBUTION SYSTEM
WOODSTOCK					
	LINEMASTER SWITCH CORP	<i>170</i>			
			CHLOROMETHANE	0.00062	ENTRY POINT
			CIS-1,2-DICHLOROETHYLENE	0.0078	WELL
			CIS-1,2-DICHLOROETHYLENE	0.007	WELL
			CIS-1,2-DICHLOROETHYLENE	0.0098	WELL
			TRANS-1,2-DICHLOROETHYLENE	0.00051	WELL
			TRANS-1,2-DICHLOROETHYLENE	0.00069	WELL
			TRICHLOROETHYLENE	0.0039	WELL
			TRICHLOROETHYLENE	0.0052	WELL
			TRICHLOROETHYLENE	0.004	WELL
			TRICHLOROETHYLENE	0.00027	ENTRY POINT
			TRICHLOROETHYLENE	0.00029	BETWEEN GAC FILTERS
			TRICHLOROETHYLENE	0.00037	BETWEEN GAC FILTERS
	WOODSTOCK ELEMENTARY SCHOOL	<i>636</i>			
			METHYL TERT-BUTYL ETHER (MTBE)	0.00064	WELL

ATTACHMENT XVII

CARCINOGEN RANKING OF ORGANIC CHEMICALS PRESENT IN CONNECTICUT PUBLIC WATER SUPPLIES

The scheme historically used by the U.S. Environmental Protection Agency for categorizing organic chemicals according to their carcinogenic potential is as follows:

- ?? Group A: Human Carcinogen: Sufficient evidence in epidemiologic studies to support casual association between exposure and cancer.
- ?? Group B: Probable Human Carcinogen: Limited evidence in epidemiologic studies (Group B1) and/or sufficient evidence from animal studies (Group B2).
- ?? Group C: Possible Human Carcinogen: Limited evidence from animal studies and inadequate or no data in humans.
- ?? Group D: Not Classifiable: Inadequate or no human and animal evidence of carcinogenicity.
- ?? Group E: No Evidence of Carcinogenicity for Humans: No evidence of carcinogenicity in at least two adequate animal tests in different species or inadequate epidemiologic and animal studies.

Attachment XVII lists all organic chemicals detected in Connecticut public water supplies by carcinogenic classification from A to E.

<u>COMPOUND</u>	<u>CLASSIFICATION*</u>
Benzene	A
Bromodichloromethane	B2
Bromoform	
Bromomethane	
Butyl benzene, n	-
Carbon tetrachloride	B2
Chlorodibromomethane	
Chloroform	B2
Chloromethane	C
Dibromomethane	
Dichlorobenzene, p	
Dichloroethane (1,1)	C
Dichloroethane (1,2)	B2
Dichloroethylene (cis-1,2)	
Dichloroethylene (trans-1,2)	
Dichloroethylene (1,1)	C
Dichloromethane	B2
Dichloropropane (1,2)	B2
Dichloropropane (2,2)	
Ethylbenzene	D
Methyl tert butyl ether (MTBE)	C
Monochlorobenzene	
Naphthalene	C
Styrene	C
Tetrachloroethylene	C
Toluene	D
Trichloroethane (1,1,1)	D
Trichloroethane (1,1,2)	C
Trichloroethylene	B2
Trichloropropane (1,2,3)	B2
Trimethylbenzene (1,2,4)	-
Trimethylbenzene (1,3,5)	-
Vinyl Chloride	A
Xylenes, m	
Xylenes, o	
Xylenes, p	

*Refer to Section XVII, p. 10, for classification definitions.