



Stage 2 Disinfection Byproducts Rule

Christopher Roy
Supervising Sanitary Engineer
CT DPH Drinking Water Section
Information Systems Unit

Annual Technical Conference and Vendor Exposition
February 23, 2011

Stage 2 Disinfectant and Disinfection Byproducts Rule

- IDSE Reports received and under review
- Maximum Contaminant Levels have not changed
- Compliance will be based on a Locational Running Annual Average (LRAA)
- Compliance Monitoring Requirements

Schedule	Population	Start Date
1	>= 100,000	4/1/2012
2	50,000-99,999	10/1/2010
3	10,000-49,999	10/1/2013
4	< 10,000	10/1/2013

- Systems that received IDSE waivers and 40/30 Certifications will be required to submit compliance monitoring plans
- Schedules, Fact Sheets, Forms and links to additional information are available on the DWS website