

# MARCH 2009 - MONTHLY RESERVOIR STATUS SUMMARY

(Percent Usable Storage)

Utility Name	Current Month	Monthly Average	% of Normal	Monthly Low on Record	Period of Record	Status or Comments
Aquarion Water Co of CT-Greenwich System	95.7	94	102	44	1962 - 2009	No Restrictions
Aquarion Water Co of CT-Main System*	99.7	98	102	71	1966 - 2009	No Restrictions
Aquarion Water Co of CT-Mystic*	100	99	101	87	1984 - 2009	No Restrictions
Aquarion Water Co of CT-Norfolk System	100	100	100	95	1983 - 2009	No Restrictions
Aquarion Water Co of CT-Salisbury Sys*	100	100	101	90	1983 - 2009	No Restrictions
Aquarion Water Co of CT-Stamford*	94.9	90	106	51	1967 - 2009	No Restrictions
Bethel Water Dept*	100	98	102	86	1984 - 2009	No Restrictions
Bristol Water Department*	98.8	96	103	67	1968 - 2009	No Restrictions
Connecticut Valley Hospital	100	90	111	0	1999 - 2009	No Restrictions
CTWC - Naugatuck Region-Central System*	100	98	102	75	1983 - 2009	No Restrictions
CTWC - Naugatuck Reg-Thomaston System	100	100	100	100	2009 - 2009	No Restrictions
CTWC - Northern Reg-Stafford System	100	100	100	100	1983 - 2009	No Restrictions
CTWC - Northern Reg-Western System*	100	96	105	45	1983 - 2009	No Restrictions
CTWC - Shoreline Region-Chester System*	100	100	100	96	1983 - 2009	No Restrictions
CTWC - Shoreline Region-Guilford System*	100	98	102	74	1983 - 2009	No Restrictions
Danbury Water Dept*	99.8	95	105	60	1977 - 2009	No Restrictions
Groton Utilities	98.9 **	99	100	93	1984 - 2009	No Restrictions
Jewett City Water Company*	100	100	100	88	1983 - 2009	No Restrictions
Manchester Water Department*	105	99	106	91	1981 - 2009	No Restrictions
Meriden Water Division*	99.7	97	103	74	1987 - 2009	No Restrictions
Metropolitan District Commission	99.9	91	110	44	1951 - 2009	No Restrictions
Middletown Water Department*	100	95	105	48	1951 - 2009	No Restrictions
New Britain Water Department	95.6	85	112	46	1971 - 2009	No Restrictions
New London Dept. of Public Utilities	81 **	85	95	54	1971 - 2009	No Restrictions
Norwalk First Taxing District*	100	98	102	81	1979 - 2009	No Restrictions
Norwich Public Utilities*	100	98	102	77	1983 - 2009	No Restrictions
Regional Water Authority*	98	95	104	62	1960 - 2009	No Restrictions
Second Taxing District City of Norwalk	100	96	104	45	1968 - 2009	No Restrictions
Sharon Water & Sewer Commission	100	89	113	0	1999 - 2009	No Restrictions
Southington Water Department*	97	95	102	66	1951 - 2009	No Restrictions
Torrington Water Company	96.6	90	108	38	1964 - 2009	No Restrictions
Wallingford Water Department*	94.3	90	105	73	1982 - 2009	No Restrictions
Waterbury Water Department	90.8 **	98	93	86	1966 - 2009	No Restrictions
Windham Water Works	100	100	100	100	1984 - 2009	No Restrictions
Winsted Water Works	100	100	100	94	1984 - 2009	No Restrictions
<b>Statewide Average:</b>	<b>98.4</b>	<b>95.7</b>	<b>103.0</b>			

\* System uses both groundwater and reservoir supplies.

\*\* Level Below Historical Monthly Average

This Reservoir Status Summary is used to obtain the percent of normal capacity statewide, which is the difference between current reservoir levels and historic monthly average levels. The historic monthly average levels are for the period of record indicated. This statewide percent of normal capacity is then monitored in accordance with the drought trigger indicators in the Connecticut Drought Preparedness and Response Plan.