

# Local Health Department Public Water System Compliance Report

**Old Lyme Health Department**

**Town/District Code** 105    **Full/Part/District** P

**Address**  
52 Lyme Street  
Old Lyme, CT 06371

**Phone** 860-434-1605    **Fax** 860-434-4135    **Web Site**

**Director Name** Dr. Vijay Sikand    **Title** Director of Health    **Email** vjsikand@aol.com

## Violation Summary Report

**Water System Name:** Chadwick Homeowners Assn., Inc.    **Admin Contact:** Mr. Norman Dickson  
**Water System Town:** Old Lyme    **Organization:** Chadwick Homeowners' Assn,In  
**PWS ID/Type:** CT1050011 / C    **Title:** President  
**Population:** 292    **Phone / Ext:** 860-434-7762 /  
**Food Service Establishment?** No    **E-Mail:**  
**Chief Certified Operator(s):** Mr. John F. Sima, III, Certified

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required</i>	<i>Public Notification Received</i>	<i>Water System Facility</i>	<i>Compliance Achieved</i>
CROSS CONNECTION CONTROL	CROSS CONNECTION CONTROL	3/2/2015 -					
<b>Total Violations:</b>							<b>1</b>

**Water System Name:** Bee & Thistle Inn    **Admin Contact:** Ms. Linnea Rufo  
**Water System Town:** Old Lyme    **Organization:** Bee & Thistle Inn  
**PWS ID/Type:** CT1050014 / NC    **Title:** Owner  
**Population:** 25    **Phone / Ext:** 860-434-1667 /  
**Food Service Establishment?** No    **E-Mail:**  
**Chief Certified Operator(s):**

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required</i>	<i>Public Notification Received</i>	<i>Water System Facility</i>	<i>Compliance Achieved</i>
FAILURE TO RESPOND TO SANITARY SURVEY	SANITARY SURVEY	8/20/2011 -	9/26/2011				
MCL (TCR), MONTHLY	COLIFORM (TCR)	8/1/2006 - 8/31/2006	9/14/2006	10/14/2006		DISTRIBUTION SYSTEM	3/31/2007
MCL, AVERAGE	DISTRIBUTION TURBIDITY	7/1/2007 - 9/30/2007	12/5/2007	1/4/2008		Distribution System	9/30/2007
MCL, AVERAGE	DISTRIBUTION TURBIDITY	4/1/2007 - 6/30/2007	7/23/2007	8/22/2007		Distribution System	9/30/2007
MCL, AVERAGE	DISTRIBUTION TURBIDITY	1/1/2007 - 3/31/2007	7/23/2007	8/22/2007		Distribution System	9/30/2007
MCL, AVERAGE	DISTRIBUTION TURBIDITY	7/1/2006 - 9/30/2006	10/16/2006	11/15/2006		Distribution System	12/31/2006

# Local Health Department Public Water System Compliance Report

Total Violations: 6

<b>Water System Name:</b> First Congregational Church of Old Lyme	<b>Admin Contact:</b> Mr. Robert F. McCracken
<b>Water System Town:</b> Old Lyme	<b>Organization:</b> 1St Cong. Church of Old Lyme
<b>PWS ID/Type:</b> CT1050114 / NC	<b>Title:</b> Administrative
<b>Population:</b> 25	<b>Phone / Ext:</b> 860-434-8686 /
<b>Food Service Establishment?</b> No	<b>E-Mail:</b> fccol@snet.net

**Chief Certified Operator(s):**

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required</i>	<i>Public Notification Received</i>	<i>Water System Facility</i>	<i>Compliance Achieved</i>
FAILURE TO RESPOND TO SANITARY SURVEY	SANITARY SURVEY	10/27/2011 -	12/22/2011				1

Total Violations: 1

<b>Water System Name:</b> Florence Griswold Museum	<b>Admin Contact:</b> Mr. Theodore J. Gaffney
<b>Water System Town:</b> Old Lyme	<b>Organization:</b> Florence Griswold Museum
<b>PWS ID/Type:</b> CT1050124 / NC	<b>Title:</b> Facil. Mngr
<b>Population:</b> 25	<b>Phone / Ext:</b> 860-434-5542 / 107
<b>Food Service Establishment?</b> No	<b>E-Mail:</b> TED@FLOGRIS.ORG

**Chief Certified Operator(s):**

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required</i>	<i>Public Notification Received</i>	<i>Water System Facility</i>	<i>Compliance Achieved</i>
CROSS CONNECTION CONTROL	CROSS CONNECTION CONTROL	3/2/2015 -					1

Total Violations: 1

<b>Water System Name:</b> Mile Creek Apartments	<b>Admin Contact:</b> Ms. Carolyn Rablen
<b>Water System Town:</b> Old Lyme	<b>Organization:</b> Mile Creek Apartments
<b>PWS ID/Type:</b> CT1050131 / C	<b>Title:</b> Business Manager
<b>Population:</b> 60	<b>Phone / Ext:</b> 860-887-8344 /
<b>Food Service Establishment?</b> No	<b>E-Mail:</b> czrablen@sbcglobal.net

**Chief Certified Operator(s):** Mr. Donald F. Tapper, Certified

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required</i>	<i>Public Notification Received</i>	<i>Water System Facility</i>	<i>Compliance Achieved</i>
INITIAL/FOLLOW-UP/ROUTINE SOWT M/R (LCR)	LEAD & COPPER RULE	1/1/1994 - 6/30/1994	7/18/1994				1

Total Violations: 1

# Local Health Department

## Public Water System Compliance Report

**Water System Name:** Lyme Regis, Inc.  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1050141 / C  
**Population:** 32  
**Food Service Establishment?** No

**Admin Contact:** Ms. Debbie Unkown\*  
**Organization:** Lyme Regis Inc  
**Title:**  
**Phone / Ext:** /  
**E-Mail:** debbie@dwellescpa.com

**Chief Certified Operator(s):** Mr. Donald F. Tapper, Certified

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required</i>	<i>Public Notification Received</i>	<i>Water System Facility</i>	<i>Compliance Achieved</i>
CROSS CONNECTION CONTROL	CROSS CONNECTION CONTROL	3/2/2012 -					

**Total Violations:** 1

**Water System Name:** Laysville Center Stores  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1050174 / NC  
**Population:** 25  
**Food Service Establishment?** Yes

**Admin Contact:** Mr. Kenneth Coffee  
**Organization:** Coffees Country Market  
**Title:** Owner  
**Phone / Ext:** 860-434-1877 /  
**E-Mail:** ken@coffeescountrymarket.co

**Chief Certified Operator(s):**

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required</i>	<i>Public Notification Received</i>	<i>Water System Facility</i>	<i>Compliance Achieved</i>
PH MON/RPT VIOLATION	PH	8/1/2015 - 8/31/2015	10/26/2015			ENTRY POINT	12/7/2015
PH MON/RPT VIOLATION	PH	7/1/2015 - 7/31/2015	9/17/2015			Entry Point	12/7/2015
PH MON/RPT VIOLATION	PH	11/1/2013 - 11/30/2013	1/21/2014	1/21/2015		Entry Point	
PH MON/RPT VIOLATION	PH	10/1/2013 - 10/31/2013	12/19/2013	12/19/2014		Entry Point	
PH MON/RPT VIOLATION	PH	9/1/2013 - 9/30/2013	10/30/2013	10/30/2014	1/3/2014	Entry Point	
PH MON/RPT VIOLATION	PH	8/1/2013 - 8/31/2013	10/30/2013	10/30/2014	1/3/2014	Entry Point	
PH MON/RPT VIOLATION	PH	7/1/2013 - 7/31/2013	9/25/2013	9/25/2014	1/3/2014	Entry Point	
PH MON/RPT VIOLATION	PH	6/1/2013 - 6/30/2013	8/16/2013	8/16/2014	1/3/2014	Entry Point	
PH MON/RPT VIOLATION	PH	5/1/2013 - 5/31/2013	7/5/2013	7/5/2014	1/3/2014	Entry Point	
PH MON/RPT VIOLATION	PH	4/1/2013 - 4/30/2013	6/19/2013	6/19/2014	1/3/2014	Entry Point	
PH MON/RPT VIOLATION	PH	3/1/2013 - 3/31/2013	5/23/2013	5/23/2014	1/3/2014	Entry Point	
PH MON/RPT VIOLATION	PH	2/1/2013 - 2/28/2013	4/1/2013	4/1/2014	1/3/2014	Entry Point	
PH MON/RPT VIOLATION	PH	9/1/2008 - 9/30/2008	11/21/2008	11/21/2009		Entry Point	10/31/2008
PH MON/RPT VIOLATION	PH	8/1/2008 - 8/31/2008	10/27/2008	10/27/2009		Entry Point	10/31/2008

# Local Health Department

## Public Water System Compliance Report

PH MON/RPT VIOLATION	PH	6/1/2008 - 6/30/2008	8/19/2008	8/19/2009	Entry Point	10/31/2008
PH MON/RPT VIOLATION	pH	5/1/2008 - 5/31/2008	7/8/2008	7/8/2009	Entry Point	10/31/2008
PH MON/RPT VIOLATION	PH	4/1/2008 - 4/30/2008	6/12/2008	6/12/2009	Entry Point	10/31/2008

**Total Violations:** 17

**Water System Name:** Lyme Art Association  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1050184 / NC  
**Population:** 25  
**Food Service Establishment?** No

**Admin Contact:** Mr. Joseph Newman  
**Organization:** Lyme Art Association  
**Title:** Executive Director  
**Phone / Ext:** 860-434-7802 /  
**E-Mail:** joe@lymeartassociation.org

**Chief Certified Operator(s):**

Violation Name (Type)	Analyte / Requirement	Compliance Period	Issue Date	Public Notification		Water System Facility	Compliance Achieved
				Required	Received		
MCL, AVERAGE	DISTRIBUTION COLOR	4/1/2013 - 6/30/2013	9/30/2013	10/30/2013	3/5/2014	Distribution System	
MCL, AVERAGE	DISTRIBUTION TURBIDITY	4/1/2013 - 6/30/2013	9/30/2013	10/30/2013	3/5/2014	Distribution System	
MCL, AVERAGE	DISTRIBUTION TURBIDITY	1/1/2013 - 3/31/2013	5/2/2013	6/1/2013	5/24/2013	Distribution System	
MCL, AVERAGE	DISTRIBUTION COLOR	1/1/2013 - 3/31/2013	5/2/2013	6/1/2013	5/24/2013	Distribution System	
MCL, AVERAGE	DISTRIBUTION TURBIDITY	10/1/2012 - 12/31/2012	2/21/2013	3/23/2013	3/13/2013	Distribution System	
MCL, AVERAGE	DISTRIBUTION COLOR	10/1/2012 - 12/31/2012	2/21/2013	3/23/2013	3/13/2013	Distribution System	
MCL, AVERAGE	DISTRIBUTION COLOR	7/1/2012 - 9/30/2012	11/7/2012	12/7/2012	3/13/2013	Distribution System	
MCL, AVERAGE	DISTRIBUTION TURBIDITY	7/1/2012 - 9/30/2012	11/7/2012	12/7/2012	3/13/2013	Distribution System	

**Total Violations:** 8

**Water System Name:** Old Lyme Inn  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1050244 / NC  
**Population:** 45  
**Food Service Establishment?** Yes

**Admin Contact:** Ms. Christine A Kitchings  
**Organization:** For A Song LLC  
**Title:** Member/Manager  
**Phone / Ext:** 844-265-6197 /  
**E-Mail:**

**Chief Certified Operator(s):**

Violation Name (Type)	Analyte / Requirement	Compliance Period	Issue Date	Public Notification		Water System Facility	Compliance Achieved
				Required	Received		
PUBLIC NOTICE RULE NOT LINKED VIOLATION	PUBLIC NOTICE	3/10/2011 -	3/5/2013				
STATE MONITORING & REPORTING VIOLATION	Physical Parameters	4/1/2011 - 6/30/2011	9/21/2011			Distribution System	

**Total Violations:** 2

# Local Health Department

## Public Water System Compliance Report

**Water System Name:** Old Lyme Library  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1050254 / NC  
**Population:** 25  
**Food Service Establishment?** No

**Admin Contact:** Ms. Mary T. Fiorelli  
**Organization:** Library  
**Title:** Director  
**Phone / Ext:** 860-434-1684 /  
**E-Mail:** mfiorelli@ol.lioninc.org

**Chief Certified Operator(s):**

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required</i>	<i>Public Notification Received</i>	<i>Water System Facility</i>	<i>Compliance Achieved</i>
MONITORING (TCR), ROUTINE MAJOR	COLIFORM (TCR)	4/1/2004 - 6/30/2004	11/2/2004	12/2/2004		DISTRIBUTION SYSTEM	3/31/2005
MONITORING (TCR), ROUTINE MAJOR	COLIFORM (TCR)	1/1/2004 - 3/31/2004	11/2/2004	12/2/2004		DISTRIBUTION SYSTEM	3/31/2005
STATE MONITORING & REPORTING VIOLATION	Physical Parameters	4/1/2004 - 6/30/2004	11/2/2004	11/2/2005		Distribution System	12/31/2004
STATE MONITORING & REPORTING VIOLATION	Physical Parameters	1/1/2004 - 3/31/2004	11/2/2004	11/2/2005		Distribution System	12/31/2004
<b>Total Violations:</b>							<b>4</b>

**Water System Name:** South Shore Landing  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1050344 / NC  
**Population:** 45  
**Food Service Establishment?** No

**Admin Contact:** Ms. Kelly Angelini  
**Organization:** Capitol Holding of Ct, Inc.  
**Title:**  
**Phone / Ext:** 860-434-0222 /  
**E-Mail:**

**Chief Certified Operator(s):**

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required</i>	<i>Public Notification Received</i>	<i>Water System Facility</i>	<i>Compliance Achieved</i>
MCL, AVERAGE	DISTRIBUTION COLOR	10/1/2013 - 12/31/2013	2/14/2014	3/16/2014		Distribution System	
MCL, AVERAGE	DISTRIBUTION COLOR	7/1/2013 - 9/30/2013	1/9/2014	2/8/2014		Distribution System	
MCL, AVERAGE	DISTRIBUTION COLOR	4/1/2013 - 6/30/2013	9/30/2013	10/30/2013		Distribution System	
MCL, AVERAGE	DISTRIBUTION COLOR	7/1/2010 - 9/30/2010	2/25/2011	3/27/2011		Distribution System	12/31/2010
MCL, AVERAGE	DISTRIBUTION COLOR	4/1/2010 - 6/30/2010	7/28/2010	8/27/2010		Distribution System	12/31/2010
MCL, AVERAGE	DISTRIBUTION COLOR	1/1/2010 - 3/31/2010	4/27/2010	5/27/2010		Distribution System	12/31/2010
MCL, AVERAGE	DISTRIBUTION TURBIDITY	10/1/2009 - 12/31/2009	1/26/2010	2/25/2010		Distribution System	3/31/2010
MCL, AVERAGE	DISTRIBUTION COLOR	10/1/2009 - 12/31/2009	1/26/2010	2/25/2010		Distribution System	12/31/2010
MCL, AVERAGE	DISTRIBUTION COLOR	7/1/2009 - 9/30/2009	10/23/2009	11/22/2009		Distribution System	12/31/2010
MCL, AVERAGE	DISTRIBUTION TURBIDITY	7/1/2009 - 9/30/2009	10/23/2009	11/22/2009		Distribution System	3/31/2010
MCL, AVERAGE	DISTRIBUTION TURBIDITY	4/1/2009 - 6/30/2009	8/18/2009	9/17/2009		Distribution System	3/31/2010

# Local Health Department Public Water System Compliance Report

MCL, AVERAGE	DISTRIBUTION COLOR	4/1/2009 - 6/30/2009	8/24/2009	9/23/2009	Distribution System	12/31/2010
MCL, AVERAGE	DISTRIBUTION TURBIDITY	1/1/2009 - 3/31/2009	4/15/2009	5/15/2009	Distribution System	3/31/2010
MCL, AVERAGE	DISTRIBUTION COLOR	1/1/2009 - 3/31/2009	4/15/2009	5/15/2009	Distribution System	12/31/2010
MCL, AVERAGE	DISTRIBUTION TURBIDITY	7/1/2008 - 9/30/2008	10/24/2008	11/23/2008	Distribution System	12/31/2008
MCL, AVERAGE	DISTRIBUTION COLOR	4/1/2008 - 6/30/2008	9/11/2008	10/11/2008	Distribution System	9/30/2008
MCL, SINGLE SAMPLE	DISTRIBUTION COLOR	7/1/2006 - 9/30/2006	10/16/2006	11/15/2006	Distribution System	12/31/2006
MCL, SINGLE SAMPLE	DISTRIBUTION COLOR	10/1/2005 - 12/31/2005	1/5/2006	2/4/2006	Distribution System	3/31/2006
MCL, SINGLE SAMPLE	DISTRIBUTION COLOR	7/1/2005 - 9/30/2005	12/14/2005	1/13/2006	Distribution System	3/31/2006
MCL, SINGLE SAMPLE	DISTRIBUTION COLOR	1/1/2005 - 3/31/2005	4/27/2005	5/27/2005	Distribution System	6/30/2005
PUBLIC NOTICE RULE LINKED TO VIOLATION	PUBLIC NOTICE	1/1/2009 -	3/6/2013			
PUBLIC NOTICE RULE LINKED TO VIOLATION	PUBLIC NOTICE	4/1/2009 -	3/6/2013			
PUBLIC NOTICE RULE LINKED TO VIOLATION	PUBLIC NOTICE	11/23/2009 -	3/6/2013			
PUBLIC NOTICE RULE LINKED TO VIOLATION	PUBLIC NOTICE	2/26/2010 -	3/6/2013			
PUBLIC NOTICE RULE LINKED TO VIOLATION	PUBLIC NOTICE	5/28/2010 -	3/6/2013			
PUBLIC NOTICE RULE LINKED TO VIOLATION	PUBLIC NOTICE	8/28/2010 -	3/6/2013			
PUBLIC NOTICE RULE LINKED TO VIOLATION	PUBLIC NOTICE	3/28/2011 -	3/6/2013			
PUBLIC NOTICE RULE LINKED TO VIOLATION	PUBLIC NOTICE	10/31/2013 -	12/19/2013			
PUBLIC NOTICE RULE LINKED TO VIOLATION	PUBLIC NOTICE	2/9/2014 -	7/9/2014			
PUBLIC NOTICE RULE LINKED TO VIOLATION	PUBLIC NOTICE	3/17/2014 -	7/9/2014			

**Total Violations:** 30

**Water System Name:** 85 Halls Road  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1050364 / NC  
**Population:** 25  
**Food Service Establishment?** No

**Admin Contact:** Mr. Scott Parker  
**Organization:** Cpd Energy Corp  
**Title:** Env & Const. Manager  
**Phone / Ext:** 845-256-0162 /  
**E-Mail:**

**Chief Certified Operator(s):**

Violation Name (Type)	Analyte / Requirement	Compliance Period	Issue Date	Public Notification		Water System Facility	Compliance Achieved
				Required	Received		
MCL (TCR), MONTHLY	COLIFORM (TCR)	10/1/2015 - 12/31/2015	10/26/2015	11/25/2015	12/14/2015	DISTRIBUTION SYSTEM	11/30/2015
PUBLIC NOTICE RULE LINKED TO VIOLATION	PUBLIC NOTICE	12/6/2015 - 12/14/2015					12/14/2015

# Local Health Department Public Water System Compliance Report

Total Violations: 2

**Water System Name:** Old Lyme Fire Dept - Boston Post Rd  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1050404 / NC  
**Population:** 25  
**Food Service Establishment?** No

**Admin Contact:** Mr. Robert Pierson  
**Organization:** Old Lyme Fire Department  
**Title:** Administrative  
**Phone / Ext:** 860-434-0233 /  
**E-Mail:**

**Chief Certified Operator(s):**

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required Received</i>		<i>Water System Facility</i>	<i>Compliance Achieved</i>
FAILURE TO RESPOND TO SANITARY SURVEY	SANITARY SURVEY	10/22/2011 -	12/22/2011				

Total Violations: 1

**Water System Name:** Region 18 Schools - Lyme Street  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1050492 / NTNC  
**Population:** 1102  
**Food Service Establishment?** No

**Admin Contact:** Mr. John A. Rhodes  
**Organization:** Regional School District 18  
**Title:** Dir of Facilities  
**Phone / Ext:** 860-434-8182 /  
**E-Mail:** rhodesj@region18.org

**Chief Certified Operator(s):** Mr. Stuart A. Harkins, Certified

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required Received</i>		<i>Water System Facility</i>	<i>Compliance Achieved</i>
WATER QUALITY PARAMETER M/R (LCR)	Water Quality Parameters	1/1/2005 - 6/30/2005	3/17/2009	3/17/2010	4/7/2009	Entry Point	

Total Violations: 1

**Water System Name:** Boxwood Condominium Association  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1051011 / C  
**Population:** 28  
**Food Service Establishment?** No

**Admin Contact:** Mr. Craig Silver  
**Organization:** Boxwood Condominium Assoc  
**Title:** President  
**Phone / Ext:** 860-434-8319 /  
**E-Mail:** csilver21@yahoo.com

**Chief Certified Operator(s):** Mr. William J. O'shaughnessy,

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required Received</i>		<i>Water System Facility</i>	<i>Compliance Achieved</i>
CROSS CONNECTION CONTROL	CROSS CONNECTION CONTROL	3/2/2014 -	4/25/2014				
FOLLOW-UP OR ROUTINE TAP M/R (LCR)	LEAD & COPPER RULE	1/1/2013 - 12/31/2015	6/30/2016	6/30/2017		DISTRIBUTION SYSTEM	
PH MON/RPT VIOLATION	PH	9/1/2014 - 9/30/2014	11/6/2014	11/6/2015		Entry Point	
PUBLIC NOTICE RULE NOT LINKED VIOLATION	PUBLIC NOTICE	11/7/2015 -	3/2/2016				

Total Violations: 4

# Local Health Department

## Public Water System Compliance Report

**Water System Name:** Miami Beach Water Company  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1051021 / C  
**Population:** 440  
**Food Service Establishment?** No

**Admin Contact:** Mr. Michael Girard  
**Organization:** Miami Beach Water Co.  
**Title:** President  
**Phone / Ext:** 860-434-7562 /  
**E-Mail:** mg7562@sbcglobal.net

**Chief Certified Operator(s):** Mr. John F. Sima, III, Certified

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required</i>	<i>Public Notification Received</i>	<i>Water System Facility</i>	<i>Compliance Achieved</i>
CCR ADEQUACY/AVAILABILITY/CONTENT	CONSUMER CONFIDENCE RULE	8/10/2015 - 11/6/2015	10/28/2015				11/6/2015
CCR ADEQUACY/AVAILABILITY/CONTENT	CONSUMER CONFIDENCE RULE	10/1/2010 -	11/22/2010				
CCR REPORT	CONSUMER CONFIDENCE RULE	7/1/2010 -	11/22/2010				
CROSS CONNECTION CONTROL	CROSS CONNECTION CONTROL	3/2/2015 -					
FOLLOW-UP OR ROUTINE TAP M/R (LCR)	LEAD & COPPER RULE	1/1/2011 - 12/31/2013	5/8/2014	5/8/2015		DISTRIBUTION SYSTEM	
FOLLOW-UP OR ROUTINE TAP M/R (LCR)	LEAD & COPPER RULE	1/1/2005 - 12/31/2007	3/17/2008	3/17/2009		DISTRIBUTION SYSTEM	9/30/2010
MONITORING (TCR), ROUTINE MAJOR	COLIFORM (TCR)	12/1/2007 - 12/31/2007	3/17/2008	4/16/2008		DISTRIBUTION SYSTEM	1/31/2008
MONITORING, ROUTINE (DBP), MAJOR	CHLORINE	7/1/2015 - 7/31/2015	1/7/2016	1/6/2017		DISTRIBUTION SYSTEM	6/30/2014
MONITORING, ROUTINE (DBP), MAJOR	CHLORINE	12/1/2007 - 12/31/2007	3/17/2008	3/17/2009		Distribution System	1/31/2008
MONITORING, ROUTINE MAJOR	COMBINED RADIUM (-226 & -228)	1/1/2004 - 3/31/2004	8/1/2005	8/1/2006		Columbus Wells Entry Point #2	6/30/2004
MONITORING, ROUTINE MAJOR	COMBINED RADIUM (-226 & -228)	1/1/2004 - 3/31/2004	8/1/2005	8/1/2006		Corsino Well Entry Point #3	6/30/2004
MONITORING, ROUTINE MAJOR	COMBINED URANIUM	1/1/2004 - 3/31/2004	8/1/2005	8/1/2006		Drilled Well Entry Point #1	6/30/2004
MONITORING, ROUTINE MAJOR	COMBINED URANIUM	1/1/2004 - 3/31/2004	8/1/2005	8/1/2006		Columbus Wells Entry Point #2	6/30/2004
MONITORING, ROUTINE MAJOR	COMBINED URANIUM	1/1/2004 - 3/31/2004	8/1/2005	8/1/2006		Corsino Well Entry Point #3	6/30/2004
MONITORING, ROUTINE MAJOR	GROSS ALPHA, EXCL. RADON & U	1/1/2004 - 3/31/2004	8/1/2005	8/1/2006		Drilled Well Entry Point #1	6/30/2004
MONITORING, ROUTINE MAJOR	GROSS ALPHA, EXCL. RADON & U	1/1/2004 - 3/31/2004	8/1/2005	8/1/2006		Columbus Wells Entry Point #2	6/30/2004
MONITORING, ROUTINE MAJOR	GROSS ALPHA, EXCL. RADON & U	1/1/2004 - 3/31/2004	8/1/2005	8/1/2006		Corsino Well Entry Point #3	6/30/2004
MONITORING, ROUTINE MAJOR	COMBINED RADIUM (-226 & -228)	1/1/2004 - 3/31/2004	8/1/2005	8/1/2006		Drilled Well Entry Point #1	6/30/2004
NOTIFICATION, PUBLIC (PRE-2003)	LEAD & COPPER RULE	9/1/1994 - 9/30/1994					
PH MON/RPT VIOLATION	PH	7/1/2015 - 7/31/2015	9/17/2015	9/16/2016		Corsino Well Entry Point #3	6/30/2014

# *Local Health Department Public Water System Compliance Report*

PH MON/RPT VIOLATION	PH	6/1/2015 - 6/30/2015	8/4/2015	8/3/2016	Corsino Well Entry Point #3	6/30/2014
PH MON/RPT VIOLATION	PH	4/1/2013 - 4/30/2013	6/19/2013	6/19/2014	Corsino Well Entry Point #3	6/30/2014
PH MON/RPT VIOLATION	PH	2/1/2013 - 2/28/2013	4/1/2013	4/1/2014	Corsino Well Entry Point #3	6/30/2014
PH MON/RPT VIOLATION	PH	2/1/2013 - 2/28/2013	4/1/2013	4/1/2014	Columbus Wells Entry Point #2	6/30/2014
PH MON/RPT VIOLATION	PH	5/1/2012 - 5/31/2012	9/6/2012	9/6/2013	Corsino Well Entry Point #3	6/30/2014
PH MON/RPT VIOLATION	PH	12/1/2011 - 12/31/2011	9/6/2012	9/6/2013	Columbus Wells Entry Point #2	6/30/2014
PH MON/RPT VIOLATION	PH	12/1/2011 - 12/31/2011	9/6/2012	9/6/2013	Corsino Well Entry Point #3	6/30/2014
PH MON/RPT VIOLATION	PH	9/1/2011 - 9/30/2011	9/6/2012	9/6/2013	Columbus Wells Entry Point #2	6/30/2014
PH MON/RPT VIOLATION	PH	9/1/2011 - 9/30/2011	9/6/2012	9/6/2013	Corsino Well Entry Point #3	6/30/2014
PH MON/RPT VIOLATION	PH	7/1/2011 - 7/31/2011	9/6/2012	9/6/2013	Corsino Well Entry Point #3	6/30/2014
PH MON/RPT VIOLATION	PH	6/1/2011 - 6/30/2011	9/6/2012	9/6/2013	Corsino Well Entry Point #3	6/30/2014
PUBLIC NOTICE RULE LINKED TO VIOLATION	PUBLIC NOTICE	5/9/2015 -	6/9/2015			
PUBLIC NOTICE RULE NOT LINKED VIOLATION	PUBLIC NOTICE	9/7/2013 -	12/16/2013			
PUBLIC NOTICE RULE NOT LINKED VIOLATION	PUBLIC NOTICE	4/2/2014 -	7/9/2014			
PUBLIC NOTICE RULE NOT LINKED VIOLATION	PUBLIC NOTICE	5/24/2014 -	7/9/2014			
PUBLIC NOTICE RULE NOT LINKED VIOLATION	PUBLIC NOTICE	6/20/2014 -	7/9/2014			
STATE MONITORING & REPORTING VIOLATION	Physical Parameters	12/1/2007 - 12/31/2007	3/17/2008	3/17/2009	Distribution System	1/31/2008
TREATMENT EFFLUENT MON/RPT VIOLATION	CHLORINE	7/1/2015 - 7/31/2015	9/17/2015	9/16/2016	Corsino Well Entry Point #3	6/30/2014
TREATMENT EFFLUENT MON/RPT VIOLATION	CHLORINE	6/1/2015 - 6/30/2015	8/4/2015	8/3/2016	Corsino Well Entry Point #3	6/30/2014
TREATMENT EFFLUENT MON/RPT VIOLATION	CHLORINE	4/1/2013 - 4/30/2013	6/19/2013	6/19/2014	Corsino Well Entry Point #3	6/30/2014
TREATMENT EFFLUENT MON/RPT VIOLATION	CHLORINE	3/1/2013 - 3/31/2013	5/23/2013	5/23/2014	Corsino Well Entry Point #3	6/30/2014
TREATMENT EFFLUENT MON/RPT VIOLATION	CHLORINE	2/1/2013 - 2/28/2013	4/1/2013	4/1/2014	Columbus Wells Entry Point #2	6/30/2014
TREATMENT EFFLUENT MON/RPT VIOLATION	CHLORINE	2/1/2013 - 2/28/2013	4/1/2013	4/1/2014	Corsino Well Entry Point #3	6/30/2014
TREATMENT EFFLUENT MON/RPT VIOLATION	CHLORINE	9/1/2011 - 9/30/2011	9/6/2012	9/6/2013	Corsino Well Entry Point #3	6/30/2014
TREATMENT EFFLUENT MON/RPT VIOLATION	CHLORINE	9/1/2011 - 9/30/2011	9/6/2012	9/6/2013	Columbus Wells Entry Point #2	6/30/2014

# Local Health Department

## Public Water System Compliance Report

TREATMENT EFFLUENT MON/RPT VIOLATION	CHLORINE	7/1/2011 - 7/31/2011	9/6/2012	9/6/2013	Corsino Well Entry Point #3	6/30/2014
TREATMENT EFFLUENT MON/RPT VIOLATION	CHLORINE	6/1/2011 - 6/30/2011	9/6/2012	9/6/2013	Corsino Well Entry Point #3	6/30/2014
WATER QUALITY PARAMETER M/R (LCR)	LEAD & COPPER RULE	7/10/1994 - 6/30/1994				

**Total Violations:** 48

**Water System Name:** Lymewood Elderly Housing  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1056221 / C  
**Population:** 50  
**Food Service Establishment?** No

**Admin Contact:** Ms. Kathy Murphy  
**Organization:** Lymewood Elderly Housing  
**Title:** President  
**Phone / Ext:** 860-227-1560 /  
**E-Mail:** kmurphy@cbmoves.com

**Chief Certified Operator(s):** Mr. Donald F. Tapper, Certified

Violation Name (Type)	Analyte / Requirement	Compliance Period	Issue Date	Public Notification		Water System Facility	Compliance Achieved
				Required	Received		
CROSS CONNECTION CONTROL	CROSS CONNECTION CONTROL	3/2/2015 -					
MCL, AVERAGE	DISTRIBUTION COLOR	4/1/2011 - 6/30/2011	2/28/2012	3/29/2012	3/18/2012	Distribution System	
MCL, AVERAGE	DISTRIBUTION TURBIDITY	1/1/2011 - 3/31/2011	2/28/2012	3/29/2012	3/12/2012	Distribution System	
MCL, AVERAGE	DISTRIBUTION COLOR	1/1/2011 - 3/31/2011	2/28/2012	3/29/2012	3/14/2012	Distribution System	
MCL, AVERAGE	DISTRIBUTION COLOR	10/1/2010 - 12/31/2010	2/1/2011	3/3/2011	2/14/2011	Distribution System	

**Total Violations:** 5

**Water System Name:** Laurel Heights Association, Inc.  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1056231 / C  
**Population:** 45  
**Food Service Establishment?** No

**Admin Contact:** Mr. Donald F. Tapper  
**Organization:** Mile Creek Apartments  
**Title:** Water Operator  
**Phone / Ext:** 860-434-5334 /  
**E-Mail:** dontapperol@yahoo.com

**Chief Certified Operator(s):**

Violation Name (Type)	Analyte / Requirement	Compliance Period	Issue Date	Public Notification		Water System Facility	Compliance Achieved
				Required	Received		
CROSS CONNECTION CONTROL	CROSS CONNECTION CONTROL	3/2/2015 -					

**Total Violations:** 1

# Local Health Department Public Water System Compliance Report

**Water System Name:** Rye Field Manor Elderly Housing  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1056241 / C  
**Population:** 78  
**Food Service Establishment?** No

**Admin Contact:** Mr. Kim J. Kaiser  
**Organization:** Shoreline Affordable Housing  
**Title:** President  
**Phone / Ext:** 860-434-0526 /  
**E-Mail:**

**Chief Certified Operator(s):** Mr. Steven J. Klobukowski,

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required Received</i>		<i>Water System Facility</i>	<i>Compliance Achieved</i>
CCR REPORT	CONSUMER CONFIDENCE RULE	7/1/2014 - 7/26/2014	1/20/2015				
LEAD CONSUMER NOTICE (LCR)	LEAD & COPPER RULE	12/30/2012 - 2/16/2016					2/16/2016
LEAD CONSUMER NOTICE (LCR)	LEAD & COPPER RULE	12/30/2015 -					
STATE MONITORING & REPORTING VIOLATION	Physical Parameters	6/1/2015 - 6/30/2015	9/24/2015	9/23/2016	11/27/2015	Distribution System	
WATER QUALITY PARAMETER M/R (LCR)	Water Quality Parameters	1/1/2003 - 12/31/2003	4/19/2004	4/19/2005	6/24/2008	Entry Point	

**Total Violations:** 5

**Water System Name:** Old Lyme Marketplace  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1059013 / NTNC  
**Population:** 70  
**Food Service Establishment?** Yes

**Admin Contact:** Mr. Matthew R. Prosser  
**Organization:** Provident Holdings, Inc.  
**Title:** President  
**Phone / Ext:** 203-453-0225 /  
**E-Mail:** Provhold@aol.com

**Chief Certified Operator(s):** Mr. Paul F. Laframboise,

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required Received</i>		<i>Water System Facility</i>	<i>Compliance Achieved</i>
MCL, AVERAGE	CHLORIDE	1/1/2016 - 3/31/2016	4/14/2016	5/14/2016	5/13/2016	ENTRY POINT	
MCL, AVERAGE	CHLORIDE	10/1/2015 - 12/31/2015	12/30/2015	1/29/2016	1/11/2016	ENTRY POINT	
MCL, AVERAGE	CHLORIDE	7/1/2015 - 9/30/2015	9/24/2015	10/24/2015	11/13/2015	Entry Point	
MCL, AVERAGE	CHLORIDE	4/1/2015 - 6/30/2015	6/30/2015	7/30/2015	7/31/2015	Entry Point	
MCL, AVERAGE	CHLORIDE	1/1/2015 - 3/31/2015	4/17/2015	5/17/2015	5/22/2015	Entry Point	
MCL, AVERAGE	CHLORIDE	10/1/2014 - 12/31/2014	1/8/2015	2/7/2015	2/6/2015	Entry Point	
MCL, AVERAGE	CHLORIDE	7/1/2014 - 9/30/2014	9/25/2014	10/25/2014	11/5/2014	Entry Point	
MCL, AVERAGE	CHLORIDE	4/1/2014 - 6/30/2014	5/27/2014	6/26/2014	7/28/2014	Entry Point	
MCL, AVERAGE	CHLORIDE	1/1/2014 - 3/31/2014	3/7/2014	4/6/2014	4/28/2014	Entry Point	
MCL, AVERAGE	CHLORIDE	10/1/2013 - 12/31/2013	11/25/2013	12/25/2013	2/10/2014	Entry Point	

# Local Health Department

## Public Water System Compliance Report

MCL, AVERAGE	CHLORIDE	7/1/2013 - 9/30/2013	10/4/2013	9/25/2013	10/18/2013	Entry Point
MCL, AVERAGE	CHLORIDE	4/1/2013 - 6/30/2013	8/5/2013	9/4/2013	8/28/2013	Entry Point
MCL, AVERAGE	CHLORIDE	1/1/2013 - 3/31/2013	4/4/2013	5/4/2013	4/12/2013	Entry Point
PUBLIC NOTICE RULE LINKED TO VIOLATION	PUBLIC NOTICE	11/4/2015 - 11/13/2015				11/13/2015

**Total Violations: 14**

**Water System Name:** Old Lyme Shopping Center  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1059023 / NTNC  
**Population:** 100  
**Food Service Establishment?** Yes

**Admin Contact:** Ms. Anna Marchetti  
**Organization:** Old Lyme Shopping Center  
**Title:** Owner  
**Phone / Ext:** 914-969-2363 /  
**E-Mail:** Jemma329@aol.com

**Chief Certified Operator(s):**

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required</i>	<i>Public Notification Received</i>	<i>Water System Facility</i>	<i>Compliance Achieved</i>
CROSS CONNECTION CONTROL	CROSS CONNECTION CONTROL	3/2/2010 -	6/16/2010				

**Total Violations: 1**

**Water System Name:** Lyme Academy of Fine Arts  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1059043 / NTNC  
**Population:** 300  
**Food Service Establishment?** No

**Admin Contact:** Mr. Charles Orcutt  
**Organization:** Lyme Academy of Fine Arts  
**Title:** Facilities Director  
**Phone / Ext:** 860-434-5232 / 136  
**E-Mail:**

**Chief Certified Operator(s):** Mr. Carl Suiter, Certified

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required</i>	<i>Public Notification Received</i>	<i>Water System Facility</i>	<i>Compliance Achieved</i>
ACTION LEVEL EXCEEDANCE	COPPER SUMMARY	1/1/2005 - 12/31/2005	11/15/2005	12/15/2005		DISTRIBUTION SYSTEM	6/30/2007
WATER QUALITY PARAMETER M/R (LCR)	Water Quality Parameters	1/1/2005 - 12/31/2005	3/17/2009	3/17/2010	4/1/2009	Entry Point	

**Total Violations: 2**

**Water System Name:** Eastport, LLC  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1059063 / NTNC  
**Population:** 30  
**Food Service Establishment?** No

**Admin Contact:** Ms. Mary Woomer  
**Organization:** Readco LLC  
**Title:** Sen Property Manager  
**Phone / Ext:** 860-434-3611 / 223  
**E-Mail:** mwoomer@readcoholdings.co

**Chief Certified Operator(s):** Mr. Paul F. Laframboise,

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required</i>	<i>Public Notification Received</i>	<i>Water System Facility</i>	<i>Compliance Achieved</i>
------------------------------	------------------------------	--------------------------	-------------------	-------------------------------------	-------------------------------------	------------------------------	----------------------------

# Local Health Department

## Public Water System Compliance Report

FAILURE TO RESPOND TO SANITARY SURVEY    SANITARY SURVEY    12/23/2010 -    2/17/2011  
 SURVEY

**Total Violations: 1**

<b>Water System Name:</b> Learn <b>Water System Town:</b> Old Lyme <b>PWS ID/Type:</b> CT1059073 / NTNC <b>Population:</b> 53 <b>Food Service Establishment?</b> No	<b>Admin Contact:</b> Dr. Eileen S. Howley <b>Organization:</b> Learn <b>Title:</b> Executive Director <b>Phone / Ext:</b> 860-434-4800 / 186 <b>E-Mail:</b> ehowley@learn.k12.ct.us <b>Chief Certified Operator(s):</b> Mr. Brian McNeely, Certified
---	--

Violation Name (Type)	Analyte / Requirement	Compliance Period	Issue Date	Public Notification Required Received		Water System Facility	Compliance Achieved
ACTION LEVEL EXCEEDANCE	COPPER SUMMARY	1/1/2012 - 6/30/2012	2/8/2016	3/9/2016		DISTRIBUTION SYSTEM	5/4/2016
INITIAL/FOLLOW-UP/ROUTINE SOWT M/R (LCR)	LEAD & COPPER RULE	7/1/2012 - 12/31/2012					
LEAD CONSUMER NOTICE (LCR)	LEAD & COPPER RULE	8/1/2012 - 5/4/2016					5/4/2016
OCCT/SOWT RECOMMENDATION/STUDY (LCR)	LEAD & COPPER RULE	1/1/2013 - 5/4/2016			5/4/2016		5/4/2016
PUBLIC NOTICE RULE NOT LINKED VIOLATION	PUBLIC NOTICE	3/10/2016 -	4/11/2016				
WATER QUALITY PARAMETER M/R (LCR)	WQPS - BASIC	1/1/2012 - 6/30/2012				DISTRIBUTION SYSTEM	
WATER QUALITY PARAMETER M/R (LCR)	WQPS - BASIC	1/1/2012 - 6/30/2012				ENTRY POINT	

**Total Violations: 7**

<b>Water System Name:</b> Deep Marine Headquarters <b>Water System Town:</b> Old Lyme <b>PWS ID/Type:</b> CT1059082 / NTNC <b>Population:</b> 50 <b>Food Service Establishment?</b> No	<b>Admin Contact:</b> Mr. Eric Ott <b>Organization:</b> State of Connecticut/Deep <b>Title:</b> Director <b>Phone / Ext:</b> 860-342-2215 / 101 <b>E-Mail:</b> eric.ott@ct.gov <b>Chief Certified Operator(s):</b> Mr. Douglas M. Patterson,
--	---

Violation Name (Type)	Analyte / Requirement	Compliance Period	Issue Date	Public Notification Required Received		Water System Facility	Compliance Achieved
ACTION LEVEL EXCEEDANCE	LEAD SUMMARY	1/1/2015 - 12/31/2015	7/16/2015			DISTRIBUTION SYSTEM	
FOLLOW-UP OR ROUTINE TAP M/R (LCR)	LEAD & COPPER RULE	1/1/2014 - 12/31/2014	4/7/2015	4/6/2016	1/8/2016	DISTRIBUTION SYSTEM	9/30/2015
MCL, AVERAGE	CHLORIDE	1/1/2016 - 3/31/2016	4/14/2016	5/14/2016	5/11/2016	ENTRY POINT	
MCL, AVERAGE	CHLORIDE	10/1/2015 - 12/31/2015	11/23/2015	12/23/2015	12/7/2015	ENTRY POINT	
MCL, AVERAGE	CHLORIDE	7/1/2015 - 9/30/2015	9/24/2015	10/24/2015	10/7/2015	Entry Point	
MCL, AVERAGE	CHLORIDE	4/1/2015 - 6/30/2015	8/19/2015	9/18/2015	8/31/2015	Entry Point	

# *Local Health Department Public Water System Compliance Report*

MCL, AVERAGE	CHLORIDE	1/1/2015 - 3/31/2015	4/17/2015	5/17/2015	1/8/2015	Entry Point
MCL, AVERAGE	CHLORIDE	10/1/2014 - 12/31/2014	1/22/2015	2/21/2015	8/12/2015	Entry Point
MCL, AVERAGE	CHLORIDE	7/1/2014 - 9/30/2014	11/28/2014	12/28/2014	12/26/2014	Entry Point
MCL, AVERAGE	CHLORIDE	4/1/2014 - 6/30/2014	7/24/2014	8/23/2014	9/15/2014	Entry Point
MCL, AVERAGE	CHLORIDE	1/1/2014 - 3/31/2014	4/9/2014	5/9/2014	1/6/2014	Entry Point
MCL, AVERAGE	CHLORIDE	10/1/2013 - 12/31/2013	11/25/2013	12/25/2013	11/6/2013	Entry Point
MCL, AVERAGE	CHLORIDE	7/1/2013 - 9/30/2013	11/25/2013	12/25/2013	11/6/2013	Entry Point
MCL, AVERAGE	CHLORIDE	4/1/2013 - 6/30/2013	8/5/2013	8/5/2014	6/24/2013	Entry Point
MCL, AVERAGE	CHLORIDE	1/1/2013 - 3/31/2013	5/3/2013	6/2/2013	6/4/2012	Entry Point
MCL, AVERAGE	CHLORIDE	10/1/2012 - 12/31/2012	12/31/2012	1/30/2013	12/21/2012	Entry Point
MCL, AVERAGE	CHLORIDE	7/1/2012 - 9/30/2012	10/25/2012			Entry Point
MCL, AVERAGE	CHLORIDE	1/1/2012 - 3/31/2012	7/2/2012	8/1/2012	1/25/2013	Entry Point
MCL, AVERAGE	CHLORIDE	10/1/2011 - 12/31/2011	1/9/2012	2/8/2012	4/2/2013	Entry Point
MCL, AVERAGE	CHLORIDE	7/1/2011 - 9/30/2011	10/26/2011	11/25/2011	6/30/2011	Entry Point
MCL, AVERAGE	CHLORIDE	4/1/2011 - 6/30/2011	8/16/2011	9/15/2011	9/24/2011	Entry Point
MCL, AVERAGE	CHLORIDE	1/1/2011 - 3/31/2011	8/16/2011	9/15/2011	9/25/2011	Entry Point
MCL, AVERAGE	CHLORIDE	10/1/2010 - 12/31/2010	8/16/2011	9/15/2011	9/22/2011	Entry Point
MCL, AVERAGE	CHLORIDE	4/1/2010 - 6/30/2010	5/26/2010	6/25/2010	6/23/2010	Entry Point
MCL, AVERAGE	CHLORIDE	1/1/2010 - 3/31/2010	3/29/2010	4/28/2010	3/29/2010	Entry Point
MCL, AVERAGE	CHLORIDE	10/1/2009 - 12/31/2009	2/17/2010	3/19/2010	9/20/2010	Entry Point
MCL, AVERAGE	CHLORIDE	7/1/2009 - 9/30/2009	9/29/2009	10/29/2009	9/28/2009	Entry Point
MCL, AVERAGE	CHLORIDE	4/1/2009 - 6/30/2009	5/21/2009	6/20/2009	6/25/2009	Entry Point
MCL, AVERAGE	CHLORIDE	1/1/2009 - 3/31/2009	4/30/2009	5/30/2009	12/26/2008	Entry Point
MCL, AVERAGE	CHLORIDE	10/1/2008 - 12/31/2008	12/4/2008	1/3/2009	3/26/2009	Entry Point
MCL, AVERAGE	CHLORIDE	7/1/2008 - 9/30/2008	11/3/2008	12/3/2008	6/26/2008	Entry Point
MCL, AVERAGE	CHLORIDE	4/1/2008 - 6/30/2008	5/19/2008	6/18/2008	3/28/2008	Entry Point
MCL, AVERAGE	CHLORIDE	1/1/2008 - 3/31/2008	5/19/2008	6/18/2008	1/7/2008	Entry Point
MCL, AVERAGE	CHLORIDE	10/1/2007 - 12/31/2007	1/15/2008	2/14/2008	10/1/2007	Entry Point

# Local Health Department Public Water System Compliance Report

MCL, AVERAGE	CHLORIDE	7/1/2007 - 9/30/2007	9/25/2007	10/25/2007	7/3/2007	Entry Point
MCL, AVERAGE	CHLORIDE	4/1/2007 - 6/30/2007	6/27/2007	7/27/2007	4/9/2007	Entry Point
MCL, AVERAGE	CHLORIDE	1/1/2007 - 3/31/2007	3/20/2007	4/19/2007	1/9/2007	Entry Point
MCL, AVERAGE	CHLORIDE	10/1/2006 - 12/31/2006	2/8/2007	3/10/2007	10/10/2006	Entry Point
MCL, AVERAGE	CHLORIDE	7/1/2006 - 9/30/2006	10/10/2006	11/9/2006		Entry Point
MCL, AVERAGE	CHLORIDE	4/1/2006 - 6/30/2006	5/25/2006	6/24/2006	7/3/2006	Entry Point
MCL, AVERAGE	CHLORIDE	1/1/2006 - 3/31/2006	5/25/2006	6/24/2006	7/3/2006	Entry Point
MCL, AVERAGE	CHLORIDE	10/1/2005 - 12/31/2005	1/6/2006	2/5/2006	7/3/2006	Entry Point
MCL, AVERAGE	CHLORIDE	7/1/2005 - 9/30/2005	11/2/2005	12/2/2005	1/25/2006	Entry Point
MCL, AVERAGE	CHLORIDE	4/1/2005 - 6/30/2005	11/2/2005	12/2/2005	1/25/2006	Entry Point
MCL, AVERAGE	CHLORIDE	1/1/2005 - 3/31/2005	11/2/2005	12/2/2005	1/25/2006	Entry Point
MCL, AVERAGE	CHLORIDE	10/1/2004 - 12/31/2004	11/2/2005	12/2/2005	1/25/2006	Entry Point
MCL, AVERAGE	CHLORIDE	7/1/2004 - 9/30/2004	3/23/2005	4/22/2005	4/8/2005	Entry Point
MCL, AVERAGE	CHLORIDE	7/1/2003 - 9/30/2003				Entry Point
MCL, SINGLE SAMPLE	CHLORIDE	4/1/2004 - 6/30/2004	11/2/2005	12/2/2005	1/25/2006	Entry Point
MONITOR GWR TRIGGERED/ADDITIONAL, MAJOR	E. COLI	9/18/2014 - 9/23/2014	11/25/2014	11/25/2015	1/8/2016	Distribution System
PUBLIC NOTICE RULE LINKED TO VIOLATION	PUBLIC NOTICE	11/26/2015 - 1/8/2016				1/8/2016

**Total Violations: 51**

**Water System Name:** Eastport - West  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1059083 / NTNC  
**Population:** 50  
**Food Service Establishment?** No

**Admin Contact:** Ms. Mary Woomer  
**Organization:** Readco LLC  
**Title:** Sen Property Manager  
**Phone / Ext:** 860-434-3611 / 223  
**E-Mail:** mwoomer@readcoholdings.co

**Chief Certified Operator(s):** Mr. Paul F. Laframboise,

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required</i>	<i>Public Notification Received</i>	<i>Water System Facility</i>	<i>Compliance Achieved</i>
PH MON/RPT VIOLATION	PH	12/1/2012 - 12/31/2012	2/19/2013	2/19/2014	3/11/2013	Entry Point	
PH MON/RPT VIOLATION	PH	11/1/2012 - 11/30/2012	1/16/2013	1/16/2014	3/4/2013	Entry Point	
PH MON/RPT VIOLATION	PH	3/1/2011 - 3/31/2011	9/6/2012	9/6/2013	9/28/2012	Entry Point	
PH MON/RPT VIOLATION	PH	2/1/2011 - 2/28/2011	9/6/2012	9/6/2013	9/28/2012	Entry Point	

# Local Health Department

## Public Water System Compliance Report

PH MON/RPT VIOLATION      PH      1/1/2011 - 9/6/2012    9/6/2013    9/28/2012    Entry Point  
 1/31/2011

**Total Violations: 5**

**Water System Name:** Eastport-North

**Admin Contact:** Ms. Mary Woomer

**Water System Town:** Old Lyme

**Organization:** Readco LLC

**PWS ID/Type:** CT1059093 / NTNC

**Title:** Sen Property Manager

**Population:** 100

**Phone / Ext:** 860-434-3611 / 223

**Food Service Establishment?** No

**E-Mail:** mwoomer@readcoholdings.co

**Chief Certified Operator(s):** Mr. Paul F. Laframboise,

Violation Name (Type)	Analyte / Requirement	Compliance Period	Issue Date	Public Notification		Water System Facility	Compliance Achieved
				Required	Received		
FAILURE TO RESPOND TO SANITARY SURVEY	SANITARY SURVEY	12/25/2010 -	2/17/2011				
MCL, AVERAGE	CHLORIDE	1/1/2016 - 3/31/2016	4/14/2016	5/14/2016	5/13/2016	ENTRY POINT	

**Total Violations: 2**

**Water System Name:** Old Lyme Childrens Learning Center, Inc

**Admin Contact:** Miss Alison Zanardi

**Water System Town:** Old Lyme

**Organization:**

**PWS ID/Type:** CT1059103 / NTNC

**Title:** Director

**Population:** 50

**Phone / Ext:** 860-434-1728 / 202

**Food Service Establishment?** No

**E-Mail:** alison\_baasp@comcast.net

**Chief Certified Operator(s):** Mr. Paul F. Laframboise,

Violation Name (Type)	Analyte / Requirement	Compliance Period	Issue Date	Public Notification		Water System Facility	Compliance Achieved
				Required	Received		
FAILURE TO RESPOND TO SANITARY SURVEY	SANITARY SURVEY	10/4/2010 -	12/20/2010				
FAILURE TO RESPOND TO SANITARY SURVEY	SANITARY SURVEY	1/7/2016 -	3/17/2016				
MCL, AVERAGE	DISTRIBUTION TURBIDITY	7/1/2013 - 9/30/2013	1/9/2014	2/8/2014	1/23/2014	Distribution System	
MCL, AVERAGE	DISTRIBUTION TURBIDITY	4/1/2013 - 6/30/2013	9/30/2013	10/30/2013	2/10/2014	Distribution System	
MCL, AVERAGE	DISTRIBUTION COLOR	4/1/2013 - 6/30/2013	9/30/2013	10/30/2013	2/10/2014	Distribution System	
MCL, AVERAGE	DISTRIBUTION TURBIDITY	1/1/2013 - 3/31/2013	5/2/2013	6/1/2013	5/17/2013	Distribution System	
MCL, AVERAGE	DISTRIBUTION TURBIDITY	10/1/2012 - 12/31/2012	2/21/2013	3/23/2013	3/1/2013	Distribution System	
MCL, AVERAGE	DISTRIBUTION TURBIDITY	1/1/2012 - 3/31/2012	5/21/2012	6/20/2012	6/7/2012	Distribution System	
MCL, AVERAGE	DISTRIBUTION TURBIDITY	10/1/2011 - 12/31/2011	2/28/2012	3/29/2012		Distribution System	
MCL, AVERAGE	DISTRIBUTION TURBIDITY	7/1/2011 - 9/30/2011	2/28/2012	3/29/2012	4/20/2012	Distribution System	
MCL, AVERAGE	DISTRIBUTION TURBIDITY	4/1/2011 - 6/30/2011	2/28/2012	3/29/2012	4/19/2012	Distribution System	

# Local Health Department Public Water System Compliance Report

**Total Violations:** 11

**Water System Name:** Saint Anns Church  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1059113 / NC  
**Population:** 25  
**Food Service Establishment?** No

**Admin Contact:** Mr. Richard D. Lamourine  
**Organization:** St. Ann's Episcopal Church  
**Title:** Property Administrat  
**Phone / Ext:** 860-434-1621 /  
**E-Mail:**

**Chief Certified Operator(s):**

Violation Name (Type)	Analyte / Requirement	Compliance Period	Issue Date	Public Notification		Water System Facility	Compliance Achieved
				Required	Received		
FAILURE TO RESPOND TO SANITARY SURVEY	SANITARY SURVEY	9/23/2010 -	10/29/2010				
FAILURE TO RESPOND TO SANITARY SURVEY	SANITARY SURVEY	8/21/2015 -	9/16/2015				
PH MON/RPT VIOLATION	PH	9/1/2015 - 9/30/2015	12/18/2015			ENTRY POINT	4/26/2016
PH MON/RPT VIOLATION	PH	11/1/2014 - 11/30/2014	1/9/2015	1/9/2016		Entry Point	
PH MON/RPT VIOLATION	PH	10/1/2014 - 10/31/2014	1/9/2015	1/9/2016		Entry Point	
PH MON/RPT VIOLATION	PH	7/1/2013 - 7/31/2013	9/25/2013	9/25/2014		Entry Point	
PH MON/RPT VIOLATION	PH	1/1/2013 - 1/31/2013	3/14/2013	3/14/2014		Entry Point	
PH MON/RPT VIOLATION	PH	12/1/2012 - 12/31/2012	2/19/2013	2/19/2014	3/22/2013	Entry Point	
PH MON/RPT VIOLATION	PH	11/1/2012 - 11/30/2012	1/16/2013	1/16/2014	1/25/2013	Entry Point	
PH MON/RPT VIOLATION	PH	10/1/2012 - 10/31/2012	12/18/2012	12/18/2013		Entry Point	
PH MON/RPT VIOLATION	PH	9/1/2012 - 9/30/2012	11/9/2012	11/9/2013		Entry Point	
PH MON/RPT VIOLATION	PH	8/1/2012 - 8/31/2012	10/15/2012	10/15/2013		Entry Point	
PH MON/RPT VIOLATION	PH	7/1/2012 - 7/31/2012	10/15/2012	10/15/2013		Entry Point	
PH MON/RPT VIOLATION	PH	6/1/2012 - 6/30/2012	9/6/2012	9/6/2013	1/9/2013	Entry Point	
PH MON/RPT VIOLATION	PH	5/1/2012 - 5/31/2012	9/6/2012	9/6/2013	1/9/2013	Entry Point	
PH MON/RPT VIOLATION	PH	4/1/2012 - 4/30/2012	9/6/2012	9/6/2013	1/9/2013	Entry Point	
PH MON/RPT VIOLATION	PH	3/1/2012 - 3/31/2012	9/6/2012	9/6/2013	1/9/2013	Entry Point	
PH MON/RPT VIOLATION	PH	2/1/2012 - 2/29/2012	9/6/2012	9/6/2013	1/9/2013	Entry Point	
PH MON/RPT VIOLATION	PH	1/1/2012 - 1/31/2012	9/6/2012	9/6/2013	1/9/2013	Entry Point	
PH MON/RPT VIOLATION	PH	12/1/2011 - 12/31/2011	9/6/2012	9/6/2013	1/9/2013	Entry Point	
PH MON/RPT VIOLATION	PH	11/1/2011 - 11/30/2011	9/6/2012	9/6/2013	1/9/2013	Entry Point	

# Local Health Department Public Water System Compliance Report

PH MON/RPT VIOLATION	PH	10/1/2011 - 10/31/2011	9/6/2012	9/6/2013	1/9/2013	Entry Point
PH MON/RPT VIOLATION	PH	9/1/2011 - 9/30/2011	9/6/2012	9/6/2013	1/9/2013	Entry Point
PH MON/RPT VIOLATION	PH	8/1/2011 - 8/31/2011	9/6/2012	9/6/2013	1/9/2013	Entry Point
PH MON/RPT VIOLATION	PH	7/1/2011 - 7/31/2011	9/6/2012	9/6/2013	1/9/2013	Entry Point
PH MON/RPT VIOLATION	PH	6/1/2011 - 6/30/2011	9/6/2012	9/6/2013	1/9/2013	Entry Point
PH MON/RPT VIOLATION	PH	5/1/2011 - 5/31/2011	9/6/2012	9/6/2013	1/9/2013	Entry Point
PH MON/RPT VIOLATION	PH	4/1/2011 - 4/30/2011	9/6/2012	9/6/2013	1/9/2013	Entry Point
PH MON/RPT VIOLATION	PH	3/1/2011 - 3/31/2011	9/6/2012	9/6/2013	1/9/2013	Entry Point
PUBLIC NOTICE RULE NOT LINKED VIOLATION	PUBLIC NOTICE	10/16/2013 -	12/16/2013			
PUBLIC NOTICE RULE NOT LINKED VIOLATION	PUBLIC NOTICE	11/10/2013 -	12/16/2013			
PUBLIC NOTICE RULE NOT LINKED VIOLATION	PUBLIC NOTICE	12/19/2013 -	8/19/2014			
PUBLIC NOTICE RULE NOT LINKED VIOLATION	PUBLIC NOTICE	3/15/2014 -	7/9/2014			
PUBLIC NOTICE RULE NOT LINKED VIOLATION	PUBLIC NOTICE	9/26/2014 -	11/12/2014			
STATE MONITORING & REPORTING VIOLATION	Physical Parameters	1/1/2011 - 3/31/2011	6/6/2011	6/5/2012	6/14/2011	Distribution System

**Total Violations:** 35

**Water System Name:** Eastport - West 2

**Water System Town:** Old Lyme

**PWS ID/Type:** CT1059193 / NTNC

**Population:** 30

**Food Service Establishment?** No

**Admin Contact:** Ms. Mary Woomer

**Organization:** Readco LLC

**Title:** Sen Property Manager

**Phone / Ext:** 860-434-3611 / 223

**E-Mail:** mwoomer@readcoholdings.co

**Chief Certified Operator(s):** Mr. Paul F. Laframboise,

Violation Name (Type)	Analyte / Requirement	Compliance Period	Issue Date	Public Notification		Water System Facility	Compliance Achieved
				Required	Received		
ACTION LEVEL EXCEEDANCE	LEAD SUMMARY	7/1/2015 - 12/31/2015	1/14/2016			DISTRIBUTION SYSTEM	
ACTION LEVEL EXCEEDANCE	COPPER SUMMARY	7/1/2014 - 12/31/2014	4/22/2015	5/22/2015	5/19/2015	DISTRIBUTION SYSTEM	
PUBLIC EDUCATION (LCR)	LEAD & COPPER RULE	9/9/2015 - 10/30/2015	1/4/2016	1/22/2016	2/12/2016		12/23/2015
WATER QUALITY PARAMETER M/R (LCR)	WQPS - BASIC	7/1/2015 - 12/31/2015	6/27/2016	6/27/2017		DISTRIBUTION SYSTEM	
WATER QUALITY PARAMETER M/R (LCR)	WQPS - BASIC	7/1/2015 - 12/31/2015	6/27/2016	6/27/2017		ENTRY POINT	
WATER QUALITY PARAMETER M/R (LCR)	Water Quality Parameters	7/1/2014 - 12/31/2014	4/27/2015	4/26/2016	6/4/2015	Distribution System	
WATER QUALITY PARAMETER M/R (LCR)	Water Quality Parameters	7/1/2014 - 12/31/2014	4/27/2015	4/26/2016	6/4/2015	Entry Point	

# Local Health Department

## Public Water System Compliance Report

**Total Violations:** 7

**Water System Name:** Lymes' Senior Ctr/Town Woods Park  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1059234 / NC  
**Population:** 25  
**Food Service Establishment?** Yes

**Admin Contact:** Ms. Bonnie A. Reemsnyder  
**Organization:** Town of Old Lyme  
**Title:** First Selectman  
**Phone / Ext:** 860-434-1605 /  
**E-Mail:** breemsnyder@oldlyme-ct.gov

**Chief Certified Operator(s):**

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required</i>	<i>Public Notification Received</i>	<i>Water System Facility</i>	<i>Compliance Achieved</i>
MONITORING (TCR), ROUTINE MINOR	COLIFORM (TCR)	10/1/2015 - 12/31/2015				DISTRIBUTION SYSTEM	3/31/2016

**Total Violations:** 1

**Water System Name:** 34 Lyme Street  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1059244 / NC  
**Population:** 35  
**Food Service Establishment?** Yes

**Admin Contact:** Ms. Angeline P. Reale  
**Organization:** Kallie, LLC  
**Title:** Owner  
**Phone / Ext:** 860-434-6942 /  
**E-Mail:** cashmerecook@gmail.com

**Chief Certified Operator(s):**

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required</i>	<i>Public Notification Received</i>	<i>Water System Facility</i>	<i>Compliance Achieved</i>
FAILURE TO RESPOND TO SANITARY SURVEY	SANITARY SURVEY	2/3/2014 -	3/21/2014				
MONITORING (TCR), ROUTINE MAJOR	COLIFORM (TCR)	10/1/2013 - 12/31/2013	5/8/2014	6/7/2014		DISTRIBUTION SYSTEM	3/31/2014
MONITORING (TCR), ROUTINE MAJOR	COLIFORM (TCR)	7/1/2013 - 9/30/2013	5/8/2014	6/7/2014		DISTRIBUTION SYSTEM	3/31/2014
MONITORING, ROUTINE MAJOR	Nitrate And Nitrite	1/1/2013 - 12/31/2013	5/8/2014	6/7/2014		Entry Point	3/31/2014
PUBLIC NOTICE RULE LINKED TO VIOLATION	PUBLIC NOTICE	6/8/2014 -	7/9/2014				
PUBLIC NOTICE RULE NOT LINKED VIOLATION	PUBLIC NOTICE	2/26/2015 -	4/8/2015				
PUBLIC NOTICE RULE NOT LINKED VIOLATION	PUBLIC NOTICE	5/9/2015 -	6/9/2015				
STATE MONITORING & REPORTING VIOLATION	Physical Parameters	10/1/2013 - 12/31/2013	5/8/2014	5/8/2015		Distribution System	3/31/2014
STATE MONITORING & REPORTING VIOLATION	Physical Parameters	7/1/2013 - 9/30/2013	2/25/2014	2/25/2015		Distribution System	3/31/2014

**Total Violations:** 9

# Local Health Department

## Public Water System Compliance Report

**Water System Name:** Lyme Academy Apartments,LLC  
**Water System Town:** Old Lyme  
**PWS ID/Type:** CT1059251 / C  
**Population:** 48  
**Food Service Establishment?** No

**Admin Contact:** Mr. Philip L Digennaro  
**Organization:** Lyme Academy Apts LLC  
**Title:** Manager/Member  
**Phone / Ext:** 203-365-0577 /  
**E-Mail:**

**Chief Certified Operator(s):** Mr. Carl Suiter, Certified

<i>Violation Name (Type)</i>	<i>Analyte / Requirement</i>	<i>Compliance Period</i>	<i>Issue Date</i>	<i>Public Notification Required</i>	<i>Public Notification Received</i>	<i>Water System Facility</i>	<i>Compliance Achieved</i>
CCR ADEQUACY/AVAILABILITY/CONTENT RULE	CONSUMER CONFIDENCE RULE	8/10/2014 -	1/20/2015				
CCR REPORT	CONSUMER CONFIDENCE RULE	7/1/2014 - 11/25/2014					

**Total Violations:** 2

### Public Water System Roster

#### Old Lyme Health Department

Town/City	PWS ID	PWS Name	Physical Address	PWS Classification	Food Service?
Old Lyme	<b>CT1059244</b>	<b>34 Lyme Street</b>	<b>34 Lyme Street</b>	<b>NC</b>	<b>Yes</b>
	CT1050364	85 Halls Road	85 Halls Road	NC	No
	<b>CT1059254</b>	<b>A. C. Peterson's Drive-In</b>	<b>113 Shore Road</b>	<b>NC</b>	<b>Yes</b>
	CT1050014	Bee & Thistle Inn	100 Lyme Street	NC	No
	<b>CT1050024</b>	<b>Black Hall Club</b>	<b>47-1 Buttonball Road</b>	<b>NC</b>	<b>Yes</b>
	CT1051011	Boxwood Condominium Association	9 Lyme Street	C	No
	CT1050011	Chadwick Homeowners Assn., Inc.		C	No
	CT1059203	Church of Christ The King	1 Mccurdy Road	NC	No
	CT1050752	CTWC - Shoreline Region-Point O Woods		C	No
	CT1050732	CTWC - Shoreline Region-Sound View		C	No
	CT1059082	Deep Marine Headquarters	333 Ferry Road No 2	NTNC	No
	CT1059083	Eastport - West	3 Enterprise Drive	NTNC	No
	CT1059193	Eastport - West 2	5 Enterprise Drive	NTNC	No
	CT1059063	Eastport, LLC	72-4 Mile River Road	NTNC	No
	CT1059093	Eastport-North	6-10 Vista Drive	NTNC	No
	CT1050114	First Congregational Church of Old Lyme	2 Ferry Road	NC	No
	CT1050124	Florence Griswold Museum	96 Lyme Street	NC	No
	<b>CT1059224</b>	<b>Graybill Properties, LLC</b>	<b>11 Hall's Road</b>	<b>NC</b>	<b>Yes</b>
	CT1050144	Hains Park	166 Boston Post Road	NC	No
	CT1056231	Laurel Heights Association, Inc.		C	No
	<b>CT1050174</b>	<b>Laysville Center Stores</b>	<b>167 Boston Post Road</b>	<b>NC</b>	<b>Yes</b>
	CT1059073	Learn	44 Hatchetts Hill Road	NTNC	No
	CT1059251	Lyme Academy Apartments,LLC	77 Lyme Street	C	No
	CT1059043	Lyme Academy of Fine Arts	84 Lyme Street	NTNC	No
	CT1050184	Lyme Art Association	90 Lyme Street	NC	No

# *Local Health Department Public Water System Compliance Report*

## Old Lyme Health Department

Town/City	PWS ID	PWS Name	Physical Address	PWS Classification	Food Service?
	CT1050141	Lyme Regis, Inc.	14 Ferry Road	C	No
	<b>CT1059234</b>	<b>Lymes' Senior Ctr/Town Woods Park</b>	<b>26 Town Woods Road</b>	<b>NC</b>	<b>Yes</b>
	CT1056221	Lymewood Elderly Housing	249 Boston Post Road	C	No
	CT1051021	Miami Beach Water Company		C	No
	CT1050131	Mile Creek Apartments		C	No
	CT1059103	Old Lyme Childrens Learning Center, Inc	57 Lyme Street	NTNC	No
	<b>CT1050224</b>	<b>Old Lyme Country Club House</b>	<b>40 Mccurdy Road</b>	<b>NC</b>	<b>Yes</b>
	CT1059214	Old Lyme Country Club- Pool Cabana	40 Mccurdy Road	NC	No
	CT1059204	Old Lyme Country Club- Tennis Court		NC	No
	CT1050404	Old Lyme Fire Dept - Boston Post Rd	189 Boston Post Road	NC	No
	<b>CT1050244</b>	<b>Old Lyme Inn</b>	<b>85 Lyme Street (route 1)</b>	<b>NC</b>	<b>Yes</b>
	CT1050254	Old Lyme Library	2 Library Lane	NC	No
	<b>CT1059013</b>	<b>Old Lyme Marketplace</b>	<b>90 Halls Road</b>	<b>NTNC</b>	<b>Yes</b>
	<b>CT1050264</b>	<b>Old Lyme Pizza Palace Inc.</b>	<b>264 Shore Road</b>	<b>NC</b>	<b>Yes</b>
	<b>CT1059023</b>	<b>Old Lyme Shopping Center</b>	<b>19 Halls Road</b>	<b>NTNC</b>	<b>Yes</b>
	CT1050492	Region 18 Schools - Lyme Street	69 Lyme Street	NTNC	No
	CT1056241	Rye Field Manor Elderly Housing	1-9 Rye Field Road	C	No
	CT1059113	Saint Anns Church	82 Shore Road	NC	No
	CT1050344	South Shore Landing	230 Shore Road	NC	No
Total Public Water Systems:					44