

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0040442	TALCOTT MOUNTAIN SCIENCE CENTER #1	NTNC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
350 MONTEVIDEO RD			4				
Towns Served: AVON							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19				
Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16				
	10/1/16 - 12/31/16				
	1/1/17 - 3/31/17				
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				
Lead And Copper (PBCU)		5 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30			
	1/1/19 - 12/31/21	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17				
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				
Physical Parameters (PPX)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16				
	10/1/16 - 12/31/16				
Water System Facility: ENTRY POINT (WSF ID: 00700)					
Di(2-Ethylhexyl) - Phthalate (2039)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/16 - 12/31/16				
	1/1/17 - 12/31/17				
	1/1/18 - 12/31/18				
Inorganic Chemicals (IOCS)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/14 - 12/31/16				
	1/1/17 - 12/31/19				
	1/1/20 - 12/31/22				
Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/16 - 12/31/16				
	1/1/17 - 12/31/17				
	1/1/18 - 12/31/18				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0040442	TALCOTT MOUNTAIN SCIENCE CENTER #1	NTNC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
350 MONTEVIDEO RD			4				
Towns Served: AVON							

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
RESPOND TO SANITARY SURVEY	11/13/2011	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2012	
CROSS CONNECTION EXEMPTION	3/1/2020	

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Thallium M&R Violation	1/1/02 - 12/31/04	3	5/2/2006		5/12/2006	
Beryllium M&R Violation	1/1/02 - 12/31/04	3	5/2/2006		5/12/2006	
Antimony M&R Violation	1/1/02 - 12/31/04	3	5/2/2006		5/12/2006	
Sulfate M&R Violation	1/1/02 - 12/31/04	3	5/2/2006		5/12/2006	
Sodium M&R Violation	1/1/02 - 12/31/04	3	5/2/2006		5/12/2006	
Nickel M&R Violation	1/1/02 - 12/31/04	3	5/2/2006		5/12/2006	
Organic Chemicals M&R Violation	10/1/08 - 12/31/08	3	2/27/2010		3/9/2010	
Repeat Total Coliform M&R Violation	10/1/11 - 10/31/11	2	4/20/2012		4/30/2012	
Total Coliform M&R Violation	11/1/11 - 11/30/11	2	4/20/2012		4/30/2012	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Stage 2 Asbestos DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		UPSTREAM	WITHIN 5 SERVICE CON	A			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0040442	TALCOTT MOUNTAIN SCIENCE CENTER #1	NTNC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
350 MONTEVIDEO RD			4				
Towns Served: AVON							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
00700	ENTRY POINT	3	ENTRY POINT	A				
10012	WELL	2	WELL	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)			
Facility Classification: SMALL WATER SYSTEM			
Operator Name	Operator Type	Certification(s)	Certification Expiration
CHOUINARD, THOMAS	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2017

Contact Information

Name		Organization			Job Title		
Mr. Jonathan Craig		Talcott Mountain Science Ctr			Director		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
Montevideo Road					Avon	CT	06001
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-677-8571							

Contact Role(s): **Legal Contact**

Name		Organization			Job Title		
Talcott Mtn Science Ctr							
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
350 Montevideo Rd					Avon	CT	06001
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		

Contact Role(s): **Owner**

Name		Organization			Job Title		
Mr. John Pellino		Talcott Mountain Science Cntr			Associate Director		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
324 Montevideo Road					Avon	CT	06001
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-677-8471	214	860-676-0421			jpellino@tmsc.org		

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0040483	TALCOTT MOUNTAIN SCIENCE CENTER #2	NTNC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
MONTEVIDEO ROAD			1				

Towns Served: AVON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19				
Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16				
	10/1/16 - 12/31/16				
	1/1/17 - 3/31/17				
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
BOYS ROOM (BRF2)	1/1/16 - 12/31/16	8/1-8/31			
	1/1/17 - 12/31/17	8/1-8/31			
	1/1/18 - 12/31/18	8/1-8/31			
Lead And Copper (PBCU)		5 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/15 - 12/31/17	6/1-9/30			
	1/1/18 - 12/31/20	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17				
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				
Physical Parameters (PPX)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16				
	10/1/16 - 12/31/16				
Water System Facility: ENTRY POINT (WSF ID: 00700)					
Di(2-Ethylhexyl) - Phthalate (2039)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	7/1/16 - 9/30/16				
	10/1/16 - 12/31/16				
	1/1/17 - 3/31/17				
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				
Inorganic Chemicals (IOCS)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/14 - 12/31/16				
	1/1/17 - 12/31/19				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0040483	TALCOTT MOUNTAIN SCIENCE CENTER #2	NTNC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
MONTEVIDEO ROAD			1				
Towns Served: AVON							

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/15 - 12/31/17		
	1/1/18 - 12/31/20		

Water System Facility: **WELL (WSF ID: 10014)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL (2)	7/1/16 - 9/30/16		
	10/1/16 - 12/31/16		
	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2005	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	9/1/2016 - 9/30/2016		N
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0040483	TALCOTT MOUNTAIN SCIENCE CENTER #2	NTNC	25	P	GW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
MONTEVIDEO ROAD		1				

Towns Served: AVON

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2005		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		12/1/2016 - 12/31/2016	N
		1/1/2017 - 1/31/2017	
		2/1/2017 - 2/28/2017	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2018	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Chlorine M&R Violation	8/1/12 - 8/31/12	3	10/15/2013		10/25/2013	
Chlorine M&R Violation	7/1/12 - 7/31/12	3	10/15/2013		10/25/2013	
Chlorine M&R Violation	9/1/12 - 9/30/12	3	11/9/2013		11/19/2013	
Disinfectant Byproducts - TTHM & HAA5 M&R Violatio	1/1/15 - 12/31/15	3	12/10/2016		12/20/2016	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper		Stage 2
					Rule	Rule Tier	Asbestos	DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		BRF2	BOYS ROOM	A	Y	N		Y
		BRFA2	BREAK ROOM	A		N		
		DF2	DRINKING FOUNTAIN	A		N		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		GRF2	GIRLS ROOM	A		N		
		OF	OUTSIDE FAUCET	A		N		
UPSTREAM	WITHIN 5 SERVICE CON	A						
00700	ENTRY POINT	3	ENTRY POINT	A				
10014	WELL	2	WELL	A				
1065	WATER TREATMENT PLANT							

Certified Operator Information

Water System Facility: WATER TREATMENT PLANT (WSF ID: 1065)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
CHOUINARD, THOMAS	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2017

Contact Information

Name	Organization	Job Title
Mr. Jonathan Craig	Talcott Mountain Science Ctr	Director

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0040483	TALCOTT MOUNTAIN SCIENCE CENTER #2	NTNC	25	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
MONTEVIDEO ROAD			1					
Towns Served: AVON								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
Montevideo Road						Avon	CT	06001
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-677-8571								
Contact Role(s):		Legal Contact						
Name			Organization			Job Title		
Mr. John Pellino			Talcott Mountain Science Cntr			Associate Director		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
324 Montevideo Road						Avon	CT	06001
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-677-8471	214	860-676-0421			jpellino@tmssc.org			
Contact Role(s):		Administrative Contact						

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0040493	FARMINGTON VALLEY ARC	NTNC	50	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
255 OLD MOUNTAIN ROAD			3				
Towns Served: AVON							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		
	10/1/16 - 12/31/16		
	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		
Lead And Copper (PBCU)	5 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
DISTRIBUTION SYSTEM (4)	1/1/16 - 12/31/18	6/1-9/30	
	1/1/19 - 12/31/21	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		
Physical Parameters (PPX)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		
	10/1/16 - 12/31/16		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/15 - 12/31/17		
	1/1/18 - 12/31/20		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0040493	FARMINGTON VALLEY ARC	NTNC	50	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
255 OLD MOUNTAIN ROAD			3				

Towns Served: AVON

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Pesticides, Herbicides and PCBs-Phase V (SOC5) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/15 - 12/31/17		
	1/1/18 - 12/31/20		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2015	
CROSS CONNECTION SURVEY REPORT	3/1/2018	

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Total Coliform M&R Violation	4/1/04 - 6/30/04	2	1/28/2005		2/7/2005	
Physical Parameters M&R Violation	4/1/04 - 6/30/04	3	12/29/2005		1/8/2006	
Lead and Copper M&R Violation	1/1/10 - 12/31/12	3	4/3/2014		4/13/2014	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10015	WELL	2	WELL	A				
934	FARMINGTON VALLEY ARC PLANT							

Certified Operator Information

Water System Facility: **FARMINGTON VALLEY ARC PLANT (WSF ID: 934)**

Facility Classification: CLASS 1 TREATMENT PLANT

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
WEID, JEREMIAH J.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2018 6/30/2019

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0040493	FARMINGTON VALLEY ARC	NTNC	50	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
255 OLD MOUNTAIN ROAD			3				
Towns Served: AVON							

Contact Information

Name			Organization			Job Title			
Ms. Patricia Maloney			Farmington Valley Arc			Dir. of Res Services			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
P.O. Box 1099						Canton		CT	06019-1099
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-693-6662	106	860-693-8662		860-678-0313					

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule