

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0110011	GRANT HILL ASSOCIATES, INC.	C	97	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			42				

Towns Served: BLOOMFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22				
Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		
	1/1/17 - 3/31/17		Complete		
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				
Lead And Copper (PBCU)		5 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30			
	1/1/19 - 12/31/21	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17		Complete		
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				
Physical Parameters (PPX)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		
Water System Facility: ENTRY POINT (WSF ID: 00700)					
Net Gross Alpha (4000)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete		
	1/1/17 - 12/31/19				
	1/1/20 - 12/31/22				
Uranium (4006)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete		
	1/1/17 - 12/31/19				
	1/1/20 - 12/31/22				
Combined Radium-226/228 (4010)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete		
	1/1/17 - 12/31/19				
	1/1/20 - 12/31/22				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0110011	GRANT HILL ASSOCIATES, INC.	C	97	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			42				

Towns Served: BLOOMFIELD

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Inorganic Chemicals (IOCS)			1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i> <i>Compliance Status</i>
ENTRY POINT (3)		1/1/15 - 12/31/17	
		1/1/18 - 12/31/20	
Nitrate And Nitrite (NOX)			1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i> <i>Compliance Status</i>
ENTRY POINT (3)		1/1/16 - 12/31/16	Complete
		1/1/17 - 12/31/17	Complete
		1/1/18 - 12/31/18	
Pesticides, Herbicides and PCBs-Phase II (SOC2)			1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i> <i>Compliance Status</i>
ENTRY POINT (3)		1/1/14 - 12/31/16	Complete
		1/1/17 - 12/31/19	
		1/1/20 - 12/31/22	
Pesticides, Herbicides and PCBs-Phase V (SOC5)			1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i> <i>Compliance Status</i>
ENTRY POINT (3)		1/1/14 - 12/31/16	Complete
		1/1/17 - 12/31/19	
		1/1/20 - 12/31/22	
Organic Chemicals (VOCS)			1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i> <i>Compliance Status</i>
ENTRY POINT (3)		1/1/15 - 12/31/17	
		1/1/18 - 12/31/20	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2012	
SUBMIT CCR TO THE DEPARTMENT	6/30/2013	
SUBMIT CCR TO THE DEPARTMENT	6/30/2014	
SUBMIT CCR CERTIFICATION FORM	8/9/2014	
SUBMIT CCR CERTIFICATION FORM	8/9/2016	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	
CROSS CONNECTION EXEMPTION	3/1/2020	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier	Stage 2 Asbestos DBPR
00600	DISTRIBUTION SYSTEM	10 OOR	10 OLD ORCHARD RD	A	3	
		11 MRR	11 MAPLE RIDGE RD	A	3	
		12 MRR	12 MAPLE RIDGE ROAD	A	3	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0110011	GRANT HILL ASSOCIATES, INC.	C	97	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		42					

Towns Served: BLOOMFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
		15 OOR	15 OLD ORCHARD RD	A	Y	3	Y	
		4	DISTRIBUTION SYSTEM	A	Y			
		6 OOR	6 OLD ORCHARD RD	A		3		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WHST1	WELL HOUSE TAP	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
147	WELL 1	2	WELL 1	A				
51181	HYDROPNEUMATIC TANK							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
CHOUINARD, THOMAS	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2017

Contact Information

Name		Organization			Job Title		
Mr. Juris Zars		Grant Hill Associates			Treasurer		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
15 Grant Hill Road					Bloomfield	CT	06002
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-242-6798				860-242-6798			

Contact Role(s): **Legal Contact**

Name		Organization			Job Title		
Mr. Timothy M. Keating		Grant Hill Assoc			President		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
13 Grant Hill Rd					Bloomfield	CT	06002
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-547-5000				860-280-5337	keatser@sbcglobal.net		

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0110031	SHARON HEIGHTS WATER ASSOCIATION	C	51	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			30				

Towns Served: BLOOMFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22		
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		Complete
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		
Lead And Copper (PBCU)	5 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30	
	1/1/19 - 12/31/21	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17		Complete
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		
Physical Parameters (PPX)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0110031	SHARON HEIGHTS WATER ASSOCIATION	C	51	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			30				

Towns Served: BLOOMFIELD

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/18		
	1/1/19 - 12/31/21		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		Complete
	1/1/18 - 12/31/18		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2012	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	
CROSS CONNECTION SURVEY REPORT	3/1/2018	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Stage 2 Asbestos DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		SH-12	12 SHARON ROAD	A		2	
		SH-26	26 SHARON ROAD	A	Y	2	
		SH-35	35 SHARON ROAD	A		2	
		SH-42	42 SHARON ROAD	A		2	
		SH-43	43 SHARON ROAD	A		2	
		UPSTREAM	WITHIN 5 SERVICE CON	A			
00700	ENTRY POINT	3	ENTRY POINT	A			
148	WELL 1	2	WELL 1	A			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0110031	SHARON HEIGHTS WATER ASSOCIATION	C	51	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			30				

Towns Served: BLOOMFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
51005	PRESSURE STORAGE							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
CHOUINARD, THOMAS	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2017

Contact Information

Name		Organization		Job Title		
Mr. John Demino		Sharon Heights Water Assn		President		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
		41 Sharon Road		Bloomfield	CT	06002
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-726-9364				860-726-9364	johndemino@comcast.net	

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0110041	ORCHARD HILL ASSOCIATION	C	30	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		11					

Towns Served: BLOOMFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/20				
Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		
	1/1/17 - 3/31/17				
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				
Lead And Copper (PBCU)		5 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/15 - 12/31/17	6/1-9/30			
	1/1/18 - 12/31/20	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17				
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				
Physical Parameters (PPX)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		
Water System Facility: ENTRY POINT (WSF ID: 00700)					
Net Gross Alpha (4000)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/08 - 12/31/16		Complete		
	1/1/17 - 12/31/25				
Uranium (4006)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/08 - 12/31/16		Complete		
	1/1/17 - 12/31/25				
Combined Radium-226/228 (4010)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/08 - 12/31/16		Complete		
	1/1/17 - 12/31/25				
Inorganic Chemicals (IOCS)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/15 - 12/31/17				
	1/1/18 - 12/31/20				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0110041	ORCHARD HILL ASSOCIATION	C	30	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			11				

Towns Served: BLOOMFIELD

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Nitrate And Nitrite (NOX)			
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Pesticides, Herbicides and PCBs-Phase II (SOC2)			1 routine (RT) per three years
ENTRY POINT (3)	1/1/14 - 12/31/16		
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Pesticides, Herbicides and PCBs-Phase V (SOC5)			1 routine (RT) per three years
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Organic Chemicals (VOCS)			1 routine (RT) per three years
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	
CROSS CONNECTION EXEMPTION	3/1/2020	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		OHA-1	1 JUNIPER RD KITCHEN	A	Y	3		
		OHA-10	23 JUNIPER RD KITCH	A	Y	3		
		OHA-11	25 JUNIPER RD KITCH	A	Y	3		
		OHA-2	5 JUNIPER RD KITCHEN	A	Y	N		
		OHA-3	7 JUNIPER RD KITCHEN	A	Y	3		
		OHA-4	9 JUNIPER RD KITCHEN	A	Y	3		
		OHA-5	11 JUNIPER RD KITCH	A	Y	3		
		OHA6	13 JUNIPER RD KITCH	A	Y	3		
		OHA-6	DISTRIBUTION SYSTEM	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0110041	ORCHARD HILL ASSOCIATION	C	30	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		11					

Towns Served: BLOOMFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
		OHA-7	15 JUNIPER RD KITCH	A	Y	3		
		OHA-8	17 JUNIPER RD KITCH	A	Y	3		
		OHA-9	19 JUNIPER RD KITCH	A	Y	3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1759	WELL 1	2	WELL 1	A				
51003	PRESSURE STORAGE							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2018
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2018
LAFRAMBOISE, JEFFREY	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2018
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2017

Contact Information

Name				Organization				Job Title				
Mr. Lois C Godlash								Trustee				
Mailing Address Line One				Mailing Address Line Two				City		State	Zip Code	
11 Juniper Rd								Bloomfield		CT	06002	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address							

Contact Role(s): **Legal Contact, Owner**

Name				Organization				Job Title				
Mr. Kenneth Godlash								Trustee				
Mailing Address Line One				Mailing Address Line Two				City		State	Zip Code	
11 Juniper Rd								Bloomfield		CT	06002	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address							

Contact Role(s): **Legal Contact, Owner**

Name				Organization				Job Title				
Mr. Paul Henzler				Orchard Hill Association				Administrative				
Mailing Address Line One				Mailing Address Line Two				City		State	Zip Code	
15 Juniper Road								Bloomfield		CT	06002	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address							
860-242-3143												

Contact Role(s): **Administrative Contact**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source	
CT0110041	ORCHARD HILL ASSOCIATION	C	30	P	GW	
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
	11					

Towns Served: BLOOMFIELD

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0110051	JUNIPER CLUB INC.	C	104	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			26				

Towns Served: BLOOMFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22				
Total Coliform (3100)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete		
	9/1/16 - 9/30/16		Complete		
	10/1/16 - 10/31/16		Complete		
	11/1/16 - 11/30/16		Complete		
	12/1/16 - 12/31/16		Complete		
	1/1/17 - 1/31/17				
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				
	7/1/17 - 7/31/17				
	8/1/17 - 8/31/17				
Lead And Copper (PBCU)		5 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30			
	1/1/19 - 12/31/21	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 1/31/17				
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				
	7/1/17 - 7/31/17				
	8/1/17 - 8/31/17				
Physical Parameters (PPX)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete		
	9/1/16 - 9/30/16		Complete		
	10/1/16 - 10/31/16		Complete		
	11/1/16 - 11/30/16		Complete		
	12/1/16 - 12/31/16		Complete		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0110051	JUNIPER CLUB INC.	C	104	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			26				

Towns Served: BLOOMFIELD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0110051	JUNIPER CLUB INC.	C	104	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			26				

Towns Served: BLOOMFIELD

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	
CROSS CONNECTION EXEMPTION	3/1/2019	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		J15	15 JUNIPER	A	Y	3		
		J16	16 JUNIPER	A	Y	3		
		J18	18 JUNIPER	A	Y	3		
		J20	20 JUNIPER	A	Y	3	Y	
		R14	14 RUNDLANE	A	Y	3		
		R18	18 RUNDLANE	A	Y	3		
		R19	19 RUNDLANE	A	Y	3		
		R22	22 RUNDLANE	A	Y	3		
		R23	23 RUNDLANE	A	Y	3		
		R27	27 RUNDLANE	A	Y	3		
		R28	28 RUNDLANE	A	Y	3		
		R3	3 RUNDLANE	A	Y	3		
		R30	30 RUNDLANE	A	Y	3		
		R31	31 RUNDLANE	A	Y	3		
		R33	33 RUNDLANE	A	Y	3		
		R34	34 RUNDLANE	A	Y	3		
		R35	35 RUNDLANE	A	Y	3		
		R9	9 RUNDLANE	A	Y	3		
		S515	515 SIMSBURY TPKE	A	Y	3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
154	WELL 2	2	WELL 2	A				
50428	HYDROPNEUMATIC STORAGE							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)			
Facility Classification: SMALL WATER SYSTEM			
<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
CHOQUINARD, THOMAS	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2017
EVON, BRYAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2018

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0110051	JUNIPER CLUB INC.	C	104	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			26				

Towns Served: BLOOMFIELD

Contact Information

Name		Organization		Job Title		
Mr. Jeffrey S. Dawson		Juniper Club Inc				
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
33 Rundelane				Bloomfield	CT	06002
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-888-5860				860-888-5860	falconfitness@aol.com	

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule