

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|--|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

| Asbestos (1094) | | 6 routine (RT) per nine years | | |
|---|--------------------------|--------------------------------------|--------------------------|--|
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> | |
| FIRESTONE (00111) | 1/1/12 - 12/31/20 | | | |
| SAVE THE CHILDREN (00139) | 1/1/12 - 12/31/20 | | | |
| TRUMBULL POLICE (00216) | 1/1/12 - 12/31/20 | | | |
| WHITE HILLS PUMP STATION (00221) | 1/1/12 - 12/31/20 | | | |
| PASTORS WALK (00222) | 1/1/12 - 12/31/20 | | | |
| WEST BRANCH RD SS (00357) | 1/1/12 - 12/31/20 | | | |

| Total Coliform (3100) | | 180 routine (RT) per month | | |
|---|--------------------------|-----------------------------------|--------------------------|--|
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> | |
| Select from Inventory of Active Sampling Points | 8/1/16 - 8/31/16 | | Complete | |
| | 9/1/16 - 9/30/16 | | Complete | |
| | 10/1/16 - 10/31/16 | | Complete | |
| | 11/1/16 - 11/30/16 | | Complete | |
| | 12/1/16 - 12/31/16 | | Complete | |
| | 1/1/17 - 1/31/17 | | | |
| | 2/1/17 - 2/28/17 | | | |
| | 3/1/17 - 3/31/17 | | | |
| | 4/1/17 - 4/30/17 | | | |
| | 5/1/17 - 5/31/17 | | | |
| | 6/1/17 - 6/30/17 | | | |
| | 7/1/17 - 7/31/17 | | | |
| | 8/1/17 - 8/31/17 | | | |

| Disinfectant Byproducts - TTHM & HAA5 (DBP) | | 12 routine (RT) per quarter | | |
|--|--------------------------|------------------------------------|--------------------------|--|
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> | |
| HUNTINGTON RD FS (00016) | 7/1/16 - 9/30/16 | 8/1-8/31 | Complete | |
| | 10/1/16 - 12/31/16 | 11/1-11/30 | Complete | |
| | 1/1/17 - 3/31/17 | 2/1-2/28 | | |
| TEXACO-HOWE AVE (00029) | 4/1/17 - 6/30/17 | 5/1-5/31 | | |
| | 7/1/17 - 9/30/17 | 8/1-8/31 | | |
| | 7/1/16 - 9/30/16 | 8/1-8/31 | Complete | |
| RADD LAUNDROMAT (00030) | 10/1/16 - 12/31/16 | 11/1-11/30 | Complete | |
| | 1/1/17 - 3/31/17 | 2/1-2/28 | | |
| | 4/1/17 - 6/30/17 | 5/1-5/31 | | |
| | 7/1/17 - 9/30/17 | 8/1-8/31 | | |
| | 7/1/16 - 9/30/16 | 8/1-8/31 | Complete | |
| | 10/1/16 - 12/31/16 | 11/1-11/30 | Complete | |
| | 1/1/17 - 3/31/17 | 2/1-2/28 | | |
| | 4/1/17 - 6/30/17 | 5/1-5/31 | | |
| | 7/1/17 - 9/30/17 | 8/1-8/31 | | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|--|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

| Disinfectant Byproducts - TTHM & HAA5 (DBP) | | 12 routine (RT) per quarter | |
|--|--------------------------|------------------------------------|--------------------------|
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| | 7/1/17 - 9/30/17 | 8/1-8/31 | |
| LORDSHIP FS (00032) | 7/1/16 - 9/30/16 | 8/1-8/31 | Complete |
| | 10/1/16 - 12/31/16 | 11/1-11/30 | Complete |
| | 1/1/17 - 3/31/17 | 2/1-2/28 | |
| | 4/1/17 - 6/30/17 | 5/1-5/31 | |
| | 7/1/17 - 9/30/17 | 8/1-8/31 | |
| LORD CHAMBERLAIN NC (00037) | 7/1/16 - 9/30/16 | 8/1-8/31 | Complete |
| | 10/1/16 - 12/31/16 | 11/1-11/30 | Complete |
| | 1/1/17 - 3/31/17 | 2/1-2/28 | |
| | 4/1/17 - 6/30/17 | 5/1-5/31 | |
| | 7/1/17 - 9/30/17 | 8/1-8/31 | |
| JACKMAN FS (00210) | 7/1/16 - 9/30/16 | 8/1-8/31 | Complete |
| | 10/1/16 - 12/31/16 | 11/1-11/30 | Complete |
| | 1/1/17 - 3/31/17 | 2/1-2/28 | |
| | 4/1/17 - 6/30/17 | 5/1-5/31 | |
| | 7/1/17 - 9/30/17 | 8/1-8/31 | |
| TRUMBULL POLICE (00216) | 7/1/16 - 9/30/16 | 8/1-8/31 | Complete |
| | 10/1/16 - 12/31/16 | 11/1-11/30 | Complete |
| | 1/1/17 - 3/31/17 | 2/1-2/28 | |
| | 4/1/17 - 6/30/17 | 5/1-5/31 | |
| | 7/1/17 - 9/30/17 | 8/1-8/31 | |
| GULF HUNTINGTON (00218) | 7/1/16 - 9/30/16 | 8/1-8/31 | Complete |
| | 10/1/16 - 12/31/16 | 11/1-11/30 | Complete |
| | 1/1/17 - 3/31/17 | 2/1-2/28 | |
| | 4/1/17 - 6/30/17 | 5/1-5/31 | |
| | 7/1/17 - 9/30/17 | 8/1-8/31 | |
| WHITE HILLS PUMP STATION (00221) | 7/1/16 - 9/30/16 | 8/1-8/31 | Complete |
| | 10/1/16 - 12/31/16 | 11/1-11/30 | Complete |
| | 1/1/17 - 3/31/17 | 2/1-2/28 | |
| | 4/1/17 - 6/30/17 | 5/1-5/31 | |
| | 7/1/17 - 9/30/17 | 8/1-8/31 | |
| PASTORS WALK (00222) | 7/1/16 - 9/30/16 | 8/1-8/31 | Complete |
| | 10/1/16 - 12/31/16 | 11/1-11/30 | Complete |
| | 1/1/17 - 3/31/17 | 2/1-2/28 | |
| | 4/1/17 - 6/30/17 | 5/1-5/31 | |
| | 7/1/17 - 9/30/17 | 8/1-8/31 | |
| GETTY MOHEGAN RD (01161) | 7/1/16 - 9/30/16 | 8/1-8/31 | Complete |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|-------------------------------------|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

| Disinfectant Byproducts - TTHM & HAA5 (DBP) | | 12 routine (RT) per quarter | |
|--|--------------------------|------------------------------------|--------------------------|
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| | 10/1/16 - 12/31/16 | 11/1-11/30 | Complete |
| | 1/1/17 - 3/31/17 | 2/1-2/28 | |
| | 4/1/17 - 6/30/17 | 5/1-5/31 | |
| | 7/1/17 - 9/30/17 | 8/1-8/31 | |
| LIBRARY 2455 MADISON (01172) | 7/1/16 - 9/30/16 | 8/1-8/31 | Complete |
| | 10/1/16 - 12/31/16 | 11/1-11/30 | Complete |
| | 1/1/17 - 3/31/17 | 2/1-2/28 | |
| | 4/1/17 - 6/30/17 | 5/1-5/31 | |
| | 7/1/17 - 9/30/17 | 8/1-8/31 | |

| Lead And Copper (PBCU) | | 50 routine (RT) per three years | |
|---|--------------------------|--|--------------------------|
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| Select from Inventory of Active Sampling Points | 1/1/16 - 12/31/18 | 6/1-9/30 | |
| | 1/1/19 - 12/31/21 | 6/1-9/30 | |

| Physical Parameters (PPS) | | 180 routine (RT) per month | |
|---|--------------------------|-----------------------------------|--------------------------|
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| Select from Inventory of Active Sampling Points | 1/1/17 - 1/31/17 | | |
| | 2/1/17 - 2/28/17 | | |
| | 3/1/17 - 3/31/17 | | |
| | 4/1/17 - 4/30/17 | | |
| | 5/1/17 - 5/31/17 | | |
| | 6/1/17 - 6/30/17 | | |
| | 7/1/17 - 7/31/17 | | |
| | 8/1/17 - 8/31/17 | | |

| Physical Parameters (PPX) | | 180 routine (RT) per month | |
|---|--------------------------|-----------------------------------|--------------------------|
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| Select from Inventory of Active Sampling Points | 8/1/16 - 8/31/16 | | Complete |
| | 9/1/16 - 9/30/16 | | Complete |
| | 10/1/16 - 10/31/16 | | Complete |
| | 11/1/16 - 11/30/16 | | Complete |
| | 12/1/16 - 12/31/16 | | Complete |

Water System Facility: **TRAP FALLS WTP ENTRY POINT (WSF ID: 00700)**

| Net Gross Alpha (4000) | | 1 routine (RT) per nine years | |
|---|--------------------------|--------------------------------------|--------------------------|
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - TRAP FALLS (3) | 1/1/08 - 12/31/16 | | Complete |
| | 1/1/17 - 12/31/25 | | |

| Uranium (4006) | | 1 routine (RT) per nine years | |
|---|--------------------------|--------------------------------------|--------------------------|
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|-------------------------------------|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: TRAP FALLS WTP ENTRY POINT (WSF ID: 00700)

Uranium (4006) 1 routine (RT) per nine years

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| EP - TRAP FALLS (3) | 1/1/08 - 12/31/16 | | Complete |
| | 1/1/17 - 12/31/25 | | |

Combined Radium-226/228 (4010) 1 routine (RT) per nine years

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| EP - TRAP FALLS (3) | 1/1/08 - 12/31/16 | | Complete |
| | 1/1/17 - 12/31/25 | | |

Inorganic Chemicals (IOCS) 1 routine (RT) per year

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| EP - TRAP FALLS (3) | 1/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 12/31/17 | | |
| | 1/1/18 - 12/31/18 | | |

Nitrate And Nitrite (NOX) 1 routine (RT) per year

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| EP - TRAP FALLS (3) | 1/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 12/31/17 | | |
| | 1/1/18 - 12/31/18 | | |

Pesticides, Herbicides and PCBs-Phase II (SOC2) 2 routine (RT) per three years

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| EP - TRAP FALLS (3) | 1/1/16 - 12/31/18 | | |
| | 1/1/19 - 12/31/21 | | |

Pesticides, Herbicides and PCBs-Phase V (SOC5) 2 routine (RT) per three years

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| EP - TRAP FALLS (3) | 1/1/16 - 12/31/18 | | |
| | 1/1/19 - 12/31/21 | | |

Organic Chemicals (VOCS) 1 routine (RT) per year

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| EP - TRAP FALLS (3) | 1/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 12/31/17 | | |
| | 1/1/18 - 12/31/18 | | |

Water System Facility: EASTON WTP ENTRY POINT (WSF ID: 00701)

Net Gross Alpha (4000) 1 routine (RT) per nine years

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| EP - EASTON (3) | 1/1/08 - 12/31/16 | | Complete |
| | 1/1/17 - 12/31/25 | | |

Uranium (4006) 1 routine (RT) per nine years

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| EP - EASTON (3) | 1/1/08 - 12/31/16 | | Complete |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|-------------------------------------|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: **EASTON WTP ENTRY POINT (WSF ID: 00701)**

| | |
|---|--|
| Uranium (4006) | 1 routine (RT) per nine years |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period Collection Period Compliance Status</i> |
| | 1/1/17 - 12/31/25 |

| | |
|---|--|
| Combined Radium-226/228 (4010) | 1 routine (RT) per nine years |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period Collection Period Compliance Status</i> |
| EP - EASTON (3) | 1/1/08 - 12/31/16 1/1/17 - 12/31/25 Complete |

| | |
|---|---|
| Inorganic Chemicals (IOCS) | 1 routine (RT) per year |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period Collection Period Compliance Status</i> |
| EP - EASTON (3) | 1/1/16 - 12/31/16 1/1/17 - 12/31/17 1/1/18 - 12/31/18 Complete |

| | |
|---|---|
| Nitrate And Nitrite (NOX) | 1 routine (RT) per year |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period Collection Period Compliance Status</i> |
| EP - EASTON (3) | 1/1/16 - 12/31/16 1/1/17 - 12/31/17 1/1/18 - 12/31/18 Complete |

| | |
|--|--|
| Pesticides, Herbicides and PCBs-Phase II (SOC2) | 2 routine (RT) per three years |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period Collection Period Compliance Status</i> |
| EP - EASTON (3) | 1/1/16 - 12/31/18 1/1/19 - 12/31/21 |

| | |
|---|--|
| Pesticides, Herbicides and PCBs-Phase V (SOC5) | 2 routine (RT) per three years |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period Collection Period Compliance Status</i> |
| EP - EASTON (3) | 1/1/16 - 12/31/18 1/1/19 - 12/31/21 |

| | |
|---|---|
| Organic Chemicals (VOCS) | 1 routine (RT) per year |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period Collection Period Compliance Status</i> |
| EP - EASTON (3) | 1/1/16 - 12/31/16 1/1/17 - 12/31/17 1/1/18 - 12/31/18 Complete |

Water System Facility: **HEMLOCKS WTP ENTRY POINT (WSF ID: 00702)**

| | |
|---|--|
| Net Gross Alpha (4000) | 1 routine (RT) per nine years |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period Collection Period Compliance Status</i> |
| EP - HEMLOCKS (3) | 1/1/08 - 12/31/16 1/1/17 - 12/31/25 Complete |

| | |
|---|--|
| Uranium (4006) | 1 routine (RT) per nine years |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period Collection Period Compliance Status</i> |
| EP - HEMLOCKS (3) | 1/1/08 - 12/31/16 1/1/17 - 12/31/25 Complete |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|-------------------------------------|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: **HEMLOCKS WTP ENTRY POINT (WSF ID: 00702)**

| Combined Radium-226/228 (4010) | 1 routine (RT) per nine years | | |
|--|---------------------------------------|--------------------------|--------------------------|
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - HEMLOCKS (3) | 1/1/08 - 12/31/16 | | Complete |
| | 1/1/17 - 12/31/25 | | |
| Inorganic Chemicals (IOCS) | 1 routine (RT) per year | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - HEMLOCKS (3) | 1/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 12/31/17 | | |
| | 1/1/18 - 12/31/18 | | |
| Nitrate And Nitrite (NOX) | 1 routine (RT) per year | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - HEMLOCKS (3) | 1/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 12/31/17 | | |
| | 1/1/18 - 12/31/18 | | |
| Pesticides, Herbicides and PCBs-Phase II (SOC2) | 2 routine (RT) per three years | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - HEMLOCKS (3) | 1/1/16 - 12/31/18 | | |
| | 1/1/19 - 12/31/21 | | |
| Pesticides, Herbicides and PCBs-Phase V (SOC5) | 2 routine (RT) per three years | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - HEMLOCKS (3) | 1/1/16 - 12/31/18 | | |
| | 1/1/19 - 12/31/21 | | |
| Organic Chemicals (VOCS) | 1 routine (RT) per year | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - HEMLOCKS (3) | 1/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 12/31/17 | | |
| | 1/1/18 - 12/31/18 | | |

Water System Facility: **WESTPORT WELLFIELD TP ENTRY POINT (WSF ID: 00704)**

| Net Gross Alpha (4000) | 1 routine (RT) per nine years | | |
|---|--------------------------------------|--------------------------|--------------------------|
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - WESTPORT (3) | 1/1/08 - 12/31/16 | | Complete |
| | 1/1/17 - 12/31/25 | | |
| Uranium (4006) | 1 routine (RT) per nine years | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - WESTPORT (3) | 1/1/08 - 12/31/16 | | Complete |
| | 1/1/17 - 12/31/25 | | |
| Combined Radium-226/228 (4010) | 1 routine (RT) per nine years | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - WESTPORT (3) | 1/1/08 - 12/31/16 | | Complete |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|-------------------------------------|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: WESTPORT WELLFIELD TP ENTRY POINT (WSF ID: 00704)

| | | | |
|---|--------------------------------------|--------------------------|--------------------------|
| Combined Radium-226/228 (4010) | 1 routine (RT) per nine years | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| | 1/1/17 - 12/31/25 | | |

| | | | |
|---|---------------------------------------|--------------------------|--------------------------|
| Inorganic Chemicals (IOCS) | 1 routine (RT) per three years | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - WESTPORT (3) | 1/1/15 - 12/31/17 | | |
| | 1/1/18 - 12/31/20 | | |

| | | | |
|---|--------------------------------|--------------------------|--------------------------|
| Nitrate And Nitrite (NOX) | 1 routine (RT) per year | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - WESTPORT (3) | 1/1/16 - 12/31/16 | | |
| | 1/1/17 - 12/31/17 | | |
| | 1/1/18 - 12/31/18 | | |

| | | | |
|--|---------------------------------------|--------------------------|--------------------------|
| Pesticides, Herbicides and PCBs-Phase II (SOC2) | 2 routine (RT) per three years | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - WESTPORT (3) | 1/1/14 - 12/31/16 | | |
| | 1/1/17 - 12/31/19 | | |
| | 1/1/20 - 12/31/22 | | |

| | | | |
|---|---------------------------------------|--------------------------|--------------------------|
| Pesticides, Herbicides and PCBs-Phase V (SOC5) | 2 routine (RT) per three years | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - WESTPORT (3) | 1/1/14 - 12/31/16 | | |
| | 1/1/17 - 12/31/19 | | |
| | 1/1/20 - 12/31/22 | | |

| | | | |
|---|--------------------------------|--------------------------|--------------------------|
| Organic Chemicals (VOCS) | 1 routine (RT) per year | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - WESTPORT (3) | 1/1/16 - 12/31/16 | | |
| | 1/1/17 - 12/31/17 | | |
| | 1/1/18 - 12/31/18 | | |

Water System Facility: COLEYTOWN WELLFIELD TP ENTRY POINT (WSF ID: 00705)

| | | | |
|---|--------------------------------------|--------------------------|--------------------------|
| Net Gross Alpha (4000) | 1 routine (RT) per nine years | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - COLEYTOWN (3) | 1/1/08 - 12/31/16 | | |
| | 1/1/17 - 12/31/25 | | |

| | | | |
|---|--------------------------------------|--------------------------|--------------------------|
| Uranium (4006) | 1 routine (RT) per nine years | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - COLEYTOWN (3) | 1/1/08 - 12/31/16 | | |
| | 1/1/17 - 12/31/25 | | |

| | | | |
|---|--------------------------------------|--------------------------|--------------------------|
| Combined Radium-226/228 (4010) | 1 routine (RT) per nine years | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - COLEYTOWN (3) | 1/1/08 - 12/31/16 | | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|--|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: **COLEYTOWN WELLFIELD TP ENTRY POINT (WSF ID: 00705)**

| Combined Radium-226/228 (4010) | 1 routine (RT) per nine years | | |
|--|---------------------------------------|--------------------------|--------------------------|
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| | 1/1/17 - 12/31/25 | | |
| Inorganic Chemicals (IOCS) | 1 routine (RT) per three years | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - COLEYTOWN (3) | 1/1/15 - 12/31/17 | | |
| | 1/1/18 - 12/31/20 | | |
| Nitrate And Nitrite (NOX) | 1 routine (RT) per year | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - COLEYTOWN (3) | 1/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 12/31/17 | | |
| | 1/1/18 - 12/31/18 | | |
| Pesticides, Herbicides and PCBs-Phase II (SOC2) | 2 routine (RT) per three years | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - COLEYTOWN (3) | 1/1/16 - 12/31/18 | | |
| | 1/1/19 - 12/31/21 | | |
| Pesticides, Herbicides and PCBs-Phase V (SOC5) | 2 routine (RT) per three years | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - COLEYTOWN (3) | 1/1/16 - 12/31/18 | | |
| | 1/1/19 - 12/31/21 | | |
| Organic Chemicals (VOCS) | 1 routine (RT) per year | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| EP - COLEYTOWN (3) | 1/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 12/31/17 | | |
| | 1/1/18 - 12/31/18 | | |

Water System Facility: **TRAP FALLS WATER TREATMENT PLANT (WSF ID: 14)**

| Total Organic Carbon (2920) | 1 routine (RT) per month | | |
|---|---------------------------------|--------------------------|--------------------------|
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| CFE - TRAP FALLS (5) | 8/1/16 - 8/31/16 | | Complete |
| | 9/1/16 - 9/30/16 | | Complete |
| | 10/1/16 - 10/31/16 | | Complete |
| | 11/1/16 - 11/30/16 | | Complete |
| | 12/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 1/31/17 | | |
| | 2/1/17 - 2/28/17 | | |
| | 3/1/17 - 3/31/17 | | |
| | 4/1/17 - 4/30/17 | | |
| | 5/1/17 - 5/31/17 | | |
| | 6/1/17 - 6/30/17 | | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|--|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: TRAP FALLS WATER TREATMENT PLANT (WSF ID: 14)

| | | | |
|---|--------------------------|---------------------------------|--------------------------|
| Total Organic Carbon (2920) | | 1 routine (RT) per month | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| | 7/1/17 - 7/31/17 | | |
| | 8/1/17 - 8/31/17 | | |

Water System Facility: EASTON WATER TREATMENT PLANT (WSF ID: 15)

| | | | |
|---|--------------------------|---------------------------------|--------------------------|
| Total Organic Carbon (2920) | | 1 routine (RT) per month | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| CFE - EASTON TP (5) | 8/1/16 - 8/31/16 | | Complete |
| | 9/1/16 - 9/30/16 | | Complete |
| | 10/1/16 - 10/31/16 | | Complete |
| | 11/1/16 - 11/30/16 | | Complete |
| | 12/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 1/31/17 | | |
| | 2/1/17 - 2/28/17 | | |
| | 3/1/17 - 3/31/17 | | |
| | 4/1/17 - 4/30/17 | | |
| | 5/1/17 - 5/31/17 | | |
| | 6/1/17 - 6/30/17 | | |
| | 7/1/17 - 7/31/17 | | |
| | 8/1/17 - 8/31/17 | | |

Water System Facility: HEMLOCKS RESERVOIR (WSF ID: 2009)

| | | | |
|---|--------------------------|-----------------------------------|--------------------------|
| Color (1905) | | 1 routine (RT) per quarter | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| HEMLOCKS RESERVOIR (1) | 1/1/17 - 3/31/17 | | |

| | | | |
|---|--------------------------|---------------------------------|--------------------------|
| Total Alkalinity (1927) | | 1 routine (RT) per month | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| HEMLOCKS RESERVOIR (1) | 8/1/16 - 8/31/16 | | Complete |
| | 9/1/16 - 9/30/16 | | Complete |
| | 10/1/16 - 10/31/16 | | Complete |
| | 11/1/16 - 11/30/16 | | Complete |
| | 12/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 1/31/17 | | |
| | 2/1/17 - 2/28/17 | | |
| | 3/1/17 - 3/31/17 | | |
| | 4/1/17 - 4/30/17 | | |
| | 5/1/17 - 5/31/17 | | |
| | 6/1/17 - 6/30/17 | | |
| | 7/1/17 - 7/31/17 | | |
| | 8/1/17 - 8/31/17 | | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|--|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: **HEMLOCKS RESERVOIR (WSF ID: 2009)**

| Total Organic Carbon (2920) | | 1 routine (RT) per month | |
|---|--------------------------|-----------------------------------|--------------------------|
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| HEMLOCKS RESERVOIR (1) | 8/1/16 - 8/31/16 | | Complete |
| | 9/1/16 - 9/30/16 | | Complete |
| | 10/1/16 - 10/31/16 | | Complete |
| | 11/1/16 - 11/30/16 | | Complete |
| | 12/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 1/31/17 | | |
| | 2/1/17 - 2/28/17 | | |
| | 3/1/17 - 3/31/17 | | |
| | 4/1/17 - 4/30/17 | | |
| | 5/1/17 - 5/31/17 | | |
| | 6/1/17 - 6/30/17 | | |
| | 7/1/17 - 7/31/17 | | |
| | 8/1/17 - 8/31/17 | | |
| Total Coliform (3100) | | 1 routine (RT) per quarter | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| HEMLOCKS RESERVOIR (1) | 7/1/16 - 9/30/16 | | Complete |
| | 10/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 3/31/17 | | |
| | 4/1/17 - 6/30/17 | | |
| | 7/1/17 - 9/30/17 | | |
| LT2 - Cryptosporidium, Turbidity & E. coli (LT2) | | 1 routine (RT) per month | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| HEMLOCKS RESERVOIR (1) | 8/1/16 - 8/31/16 | 8/1-8/5 | Complete |
| | 9/1/16 - 9/30/16 | 9/5-9/9 | Complete |
| | 10/1/16 - 10/31/16 | 10/3-10/7 | Complete |
| | 11/1/16 - 11/30/16 | 10/31-11/4 | Complete |
| | 12/1/16 - 12/31/16 | 12/5-12/9 | Complete |
| | 1/1/17 - 1/31/17 | 1/2-1/6 | |
| | 2/1/17 - 2/28/17 | 2/6-2/10 | |
| | 3/1/17 - 3/31/17 | 3/6-3/10 | |
| Raw Water Physical Parameters (PHYR) | | 1 routine (RT) per quarter | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| HEMLOCKS RESERVOIR (1) | 7/1/16 - 9/30/16 | | Complete |
| | 10/1/16 - 12/31/16 | | Complete |
| Surface Water Inorganic Chemicals (RIOIC) | | 1 routine (RT) per year | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| HEMLOCKS RESERVOIR (1) | 1/1/16 - 12/31/16 | | Complete |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|-------------------------------------|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: HEMLOCKS RESERVOIR (WSF ID: 2009)

Surface Water Inorganic Chemicals (RIOCI) 1 routine (RT) per year

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| | 1/1/17 - 12/31/17 | | |
| | 1/1/18 - 12/31/18 | | |

Surface Water Color and Turbidity (RPPS) 1 routine (RT) per quarter

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| HEMLOCKS RESERVOIR (1) | 4/1/17 - 6/30/17 | | |
| | 7/1/17 - 9/30/17 | | |

Surface Water Pesticides (RSOC) 1 routine (RT) per year

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| HEMLOCKS RESERVOIR (1) | 1/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 12/31/17 | | |
| | 1/1/18 - 12/31/18 | | |

Water System Facility: EASTON LAKE RESERVOIR (WSF ID: 2013)

Color (1905) 1 routine (RT) per quarter

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| EASTON LAKE RES (1) | 1/1/17 - 3/31/17 | | |

Total Alkalinity (1927) 1 routine (RT) per month

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| EASTON LAKE RES (1) | 8/1/16 - 8/31/16 | | Complete |
| | 9/1/16 - 9/30/16 | | Complete |
| | 10/1/16 - 10/31/16 | | Complete |
| | 11/1/16 - 11/30/16 | | Complete |
| | 12/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 1/31/17 | | |
| | 2/1/17 - 2/28/17 | | |
| | 3/1/17 - 3/31/17 | | |
| | 4/1/17 - 4/30/17 | | |
| | 5/1/17 - 5/31/17 | | |
| | 6/1/17 - 6/30/17 | | |
| | 7/1/17 - 7/31/17 | | |
| | 8/1/17 - 8/31/17 | | |

Total Organic Carbon (2920) 1 routine (RT) per month

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| EASTON LAKE RES (1) | 8/1/16 - 8/31/16 | | Complete |
| | 9/1/16 - 9/30/16 | | Complete |
| | 10/1/16 - 10/31/16 | | Complete |
| | 11/1/16 - 11/30/16 | | Complete |
| | 12/1/16 - 12/31/16 | | Complete |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|-------------------------------------|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: **EASTON LAKE RESERVOIR (WSF ID: 2013)**

| Total Organic Carbon (2920) | | 1 routine (RT) per month | | |
|---|--------------------------|-----------------------------------|--------------------------|--|
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> | |
| | 1/1/17 - 1/31/17 | | | |
| | 2/1/17 - 2/28/17 | | | |
| | 3/1/17 - 3/31/17 | | | |
| | 4/1/17 - 4/30/17 | | | |
| | 5/1/17 - 5/31/17 | | | |
| | 6/1/17 - 6/30/17 | | | |
| | 7/1/17 - 7/31/17 | | | |
| | 8/1/17 - 8/31/17 | | | |
| Total Coliform (3100) | | 1 routine (RT) per quarter | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> | |
| EASTON LAKE RES (1) | 7/1/16 - 9/30/16 | | Complete | |
| | 10/1/16 - 12/31/16 | | Complete | |
| | 1/1/17 - 3/31/17 | | | |
| | 4/1/17 - 6/30/17 | | | |
| | 7/1/17 - 9/30/17 | | | |
| LT2 - Cryptosporidium, Turbidity & E. coli (LT2) | | 1 routine (RT) per month | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> | |
| EASTON LAKE RES (1) | 8/1/16 - 8/31/16 | 8/1-8/5 | Complete | |
| | 9/1/16 - 9/30/16 | 9/5-9/9 | Complete | |
| | 10/1/16 - 10/31/16 | 10/3-10/7 | Complete | |
| | 11/1/16 - 11/30/16 | 10/31-11/4 | Complete | |
| | 12/1/16 - 12/31/16 | 12/5-12/9 | Complete | |
| | 1/1/17 - 1/31/17 | 1/2-1/6 | | |
| | 2/1/17 - 2/28/17 | 2/6-2/10 | | |
| | 3/1/17 - 3/31/17 | 3/6-3/10 | | |
| Raw Water Physical Parameters (PHYR) | | 1 routine (RT) per quarter | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> | |
| EASTON LAKE RES (1) | 7/1/16 - 9/30/16 | | Complete | |
| | 10/1/16 - 12/31/16 | | Complete | |
| Surface Water Inorganic Chemicals (RIOCI) | | 1 routine (RT) per year | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> | |
| EASTON LAKE RES (1) | 1/1/16 - 12/31/16 | | Complete | |
| | 1/1/17 - 12/31/17 | | | |
| | 1/1/18 - 12/31/18 | | | |
| Surface Water Color and Turbidity (RPPS) | | 1 routine (RT) per quarter | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> | |
| EASTON LAKE RES (1) | 4/1/17 - 6/30/17 | | | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | |
|----------------------------------|--|----------------|------------|------------|----------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW |
| Local Address (where applicable) | Service Connections | Residential | Commercial | Industrial | Combined |
| | | 91,895 | 1 | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: EASTON LAKE RESERVOIR (WSF ID: 2013)

Surface Water Color and Turbidity (RPPS) 1 routine (RT) per quarter

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| | 7/1/17 - 9/30/17 | | |

Surface Water Pesticides (RSOC) 1 routine (RT) per year

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| EASTON LAKE RES (1) | 1/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 12/31/17 | | |
| | 1/1/18 - 12/31/18 | | |

Water System Facility: TRAP FALLS RESERVOIR (WSF ID: 2016)

Color (1905) 1 routine (RT) per quarter

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| TRAP FALLS RESERVOIR (1) | 1/1/17 - 3/31/17 | | |

Total Alkalinity (1927) 1 routine (RT) per month

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| TRAP FALLS RESERVOIR (1) | 8/1/16 - 8/31/16 | | Complete |
| | 9/1/16 - 9/30/16 | | Complete |
| | 10/1/16 - 10/31/16 | | Complete |
| | 11/1/16 - 11/30/16 | | Complete |
| | 12/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 1/31/17 | | |
| | 2/1/17 - 2/28/17 | | |
| | 3/1/17 - 3/31/17 | | |
| | 4/1/17 - 4/30/17 | | |
| | 5/1/17 - 5/31/17 | | |
| | 6/1/17 - 6/30/17 | | |
| | 7/1/17 - 7/31/17 | | |
| | 8/1/17 - 8/31/17 | | |

Total Organic Carbon (2920) 1 routine (RT) per month

| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
|---|--------------------------|--------------------------|--------------------------|
| TRAP FALLS RESERVOIR (1) | 8/1/16 - 8/31/16 | | Complete |
| | 9/1/16 - 9/30/16 | | Complete |
| | 10/1/16 - 10/31/16 | | Complete |
| | 11/1/16 - 11/30/16 | | Complete |
| | 12/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 1/31/17 | | |
| | 2/1/17 - 2/28/17 | | |
| | 3/1/17 - 3/31/17 | | |
| | 4/1/17 - 4/30/17 | | |
| | 5/1/17 - 5/31/17 | | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|-------------------------------------|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: TRAP FALLS RESERVOIR (WSF ID: 2016)

| Total Organic Carbon (2920) | 1 routine (RT) per month | | |
|---|-----------------------------------|--------------------------|--------------------------|
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| | 6/1/17 - 6/30/17 | | |
| | 7/1/17 - 7/31/17 | | |
| | 8/1/17 - 8/31/17 | | |
| Total Coliform (3100) | 1 routine (RT) per quarter | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| TRAP FALLS RESERVOIR (1) | 7/1/16 - 9/30/16 | | Complete |
| | 10/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 3/31/17 | | |
| | 4/1/17 - 6/30/17 | | |
| | 7/1/17 - 9/30/17 | | |
| LT2 - Cryptosporidium, Turbidity & E. coli (LT2) | 1 routine (RT) per month | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| TRAP FALLS RESERVOIR (1) | 8/1/16 - 8/31/16 | 8/1-8/5 | Complete |
| | 9/1/16 - 9/30/16 | 9/5-9/9 | Complete |
| | 10/1/16 - 10/31/16 | 10/3-10/7 | Complete |
| | 11/1/16 - 11/30/16 | 10/31-11/4 | Complete |
| | 12/1/16 - 12/31/16 | 12/5-12/9 | Complete |
| | 1/1/17 - 1/31/17 | 1/2-1/6 | |
| | 2/1/17 - 2/28/17 | 2/6-2/10 | |
| | 3/1/17 - 3/31/17 | 3/6-3/10 | |
| Raw Water Physical Parameters (PHYR) | 1 routine (RT) per quarter | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| TRAP FALLS RESERVOIR (1) | 7/1/16 - 9/30/16 | | Complete |
| | 10/1/16 - 12/31/16 | | Complete |
| Surface Water Inorganic Chemicals (RIOCI) | 1 routine (RT) per year | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| TRAP FALLS RESERVOIR (1) | 1/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 12/31/17 | | |
| | 1/1/18 - 12/31/18 | | |
| Surface Water Color and Turbidity (RPPS) | 1 routine (RT) per quarter | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| TRAP FALLS RESERVOIR (1) | 4/1/17 - 6/30/17 | | |
| | 7/1/17 - 9/30/17 | | |
| Surface Water Pesticides (RSOC) | 1 routine (RT) per year | | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| TRAP FALLS RESERVOIR (1) | 1/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 12/31/17 | | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|--|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: **TRAP FALLS RESERVOIR (WSF ID: 2016)**

| | | | |
|---|--------------------------|--------------------------------|--------------------------|
| Surface Water Pesticides (RSOC) | | 1 routine (RT) per year | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| | 1/1/18 - 12/31/18 | | |

Water System Facility: **HEMLOCKS WATER TREATMENT PLANT (WSF ID: 21)**

| | | | |
|---|--------------------------|---------------------------------|--------------------------|
| Total Organic Carbon (2920) | | 1 routine (RT) per month | |
| <i>Sampling Point (Sampling Point ID)</i> | <i>Monitoring Period</i> | <i>Collection Period</i> | <i>Compliance Status</i> |
| CFE - HEMLOCKS TP (5) | 8/1/16 - 8/31/16 | | Complete |
| | 9/1/16 - 9/30/16 | | Complete |
| | 10/1/16 - 10/31/16 | | Complete |
| | 11/1/16 - 11/30/16 | | Complete |
| | 12/1/16 - 12/31/16 | | Complete |
| | 1/1/17 - 1/31/17 | | |
| | 2/1/17 - 2/28/17 | | |
| | 3/1/17 - 3/31/17 | | |
| | 4/1/17 - 4/30/17 | | |
| | 5/1/17 - 5/31/17 | | |
| | 6/1/17 - 6/30/17 | | |
| | 7/1/17 - 7/31/17 | | |
| | 8/1/17 - 8/31/17 | | |

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **TRAP FALLS WTP ENTRY POINT (WSFID: 00700)**

| | | | |
|-----------------------------|--|---------------------------|---------------------------|
| Analyte | Monitoring Requirement (Summary Type) | Operating Limit | Samples Req/Month |
| pH | Entry Point pH Monitoring (PHRD) | Minimum: 6.4 PH | Daily |
| Start Date: 9/1/2003 | Compliance History: | Operating Limit | Monitoring |
| | Monitoring Period | Compliance Status: | Compliance Status: |
| | 8/1/2016 - 8/31/2016 | | N |
| | 9/1/2016 - 9/30/2016 | | N |
| | 10/1/2016 - 10/31/2016 | | N |
| | 11/1/2016 - 11/30/2016 | | N |
| | 12/1/2016 - 12/31/2016 | | |
| | 1/1/2017 - 1/31/2017 | | |

Water System Facility: **EASTON WTP ENTRY POINT (WSFID: 00701)**

| | | | |
|-----------------------------|--|---------------------------|---------------------------|
| Analyte | Monitoring Requirement (Summary Type) | Operating Limit | Samples Req/Month |
| pH | Entry Point pH Monitoring (PHRD) | Minimum: 6.4 PH | Daily |
| Start Date: 9/1/2003 | Compliance History: | Operating Limit | Monitoring |
| | Monitoring Period | Compliance Status: | Compliance Status: |
| | 8/1/2016 - 8/31/2016 | | N |
| | 9/1/2016 - 9/30/2016 | | N |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|--|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Water System Facility: **EASTON WTP ENTRY POINT (WSFID: 00701)**

| Analyte | Monitoring Requirement (Summary Type) | Operating Limit | Samples Req/Month |
|-----------------------------|---------------------------------------|----------------------------|--------------------------------------|
| pH | Entry Point pH Monitoring (PHRD) | Minimum: 6.4 PH | Daily |
| Start Date: 9/1/2003 | | Compliance History: | Operating Limit |
| | | Monitoring Period | Monitoring Compliance Status: |
| | | 10/1/2016 - 10/31/2016 | N |
| | | 11/1/2016 - 11/30/2016 | N |
| | | 12/1/2016 - 12/31/2016 | |
| | | 1/1/2017 - 1/31/2017 | |

Water System Facility: **HEMLOCKS WTP ENTRY POINT (WSFID: 00702)**

| Analyte | Monitoring Requirement (Summary Type) | Operating Limit | Samples Req/Month |
|-----------------------------|---------------------------------------|----------------------------|--------------------------------------|
| pH | Entry Point pH Monitoring (PHRD) | Minimum: 6.4 PH | Daily |
| Start Date: 9/1/2003 | | Compliance History: | Operating Limit |
| | | Monitoring Period | Monitoring Compliance Status: |
| | | 8/1/2016 - 8/31/2016 | N |
| | | 9/1/2016 - 9/30/2016 | N |
| | | 10/1/2016 - 10/31/2016 | N |
| | | 11/1/2016 - 11/30/2016 | N |
| | | 12/1/2016 - 12/31/2016 | |
| | | 1/1/2017 - 1/31/2017 | |

Water System Facility: **WESTPORT WELLFIELD TP ENTRY POINT (WSFID: 00704)**

| Analyte | Monitoring Requirement (Summary Type) | Operating Limit | Samples Req/Month |
|-----------------------------|--|----------------------------|--------------------------------------|
| Fluoride | Entry Point Fluoride Monitoring (FLRD) | Average: 1.2 MG/L | Daily |
| Start Date: 7/1/2003 | | Compliance History: | Operating Limit |
| | | Monitoring Period | Monitoring Compliance Status: |
| | | 8/1/2016 - 8/31/2016 | N |
| | | 9/1/2016 - 9/30/2016 | N |
| | | 10/1/2016 - 10/31/2016 | N |
| | | 11/1/2016 - 11/30/2016 | N |
| | | 12/1/2016 - 12/31/2016 | |
| | | 1/1/2017 - 1/31/2017 | |

Water System Facility: **COLEYTOWN WELLFIELD TP ENTRY POINT (WSFID: 00705)**

| Analyte | Monitoring Requirement (Summary Type) | Operating Limit | Samples Req/Month |
|-----------------------------|---------------------------------------|----------------------------|--------------------------------------|
| pH | Entry Point pH Monitoring (PHRD) | Minimum: 6.4 PH | Daily |
| Start Date: 7/1/2003 | | Compliance History: | Operating Limit |
| | | Monitoring Period | Monitoring Compliance Status: |
| | | 8/1/2016 - 8/31/2016 | N |
| | | 9/1/2016 - 9/30/2016 | N |
| | | 10/1/2016 - 10/31/2016 | N |
| | | 11/1/2016 - 11/30/2016 | N |
| | | 12/1/2016 - 12/31/2016 | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|--|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Water System Facility: **COLEYTOWN WELLFIELD TP ENTRY POINT (WSFID: 00705)**

| Analyte | Monitoring Requirement (Summary Type) | Operating Limit | Samples Req/Month |
|-----------------------------|---------------------------------------|----------------------------|---------------------------|
| pH | Entry Point pH Monitoring (PHRD) | Minimum: 6.4 PH | Daily |
| Start Date: 7/1/2003 | | Compliance History: | Operating Limit |
| | | Monitoring Period | Compliance Status: |
| | | 1/1/2017 - 1/31/2017 | |

Water System Facility: **TRAP FALLS WATER TREATMENT PLANT (WSFID: 14)**

| Analyte | Monitoring Requirement (Summary Type) | Operating Limit | Samples Req/Month |
|-----------------------------|---------------------------------------|----------------------------|---------------------------|
| Turbidity | CFE Maximum Turbidity (MAXT) | Maximum: 1 NTU | 186 |
| Start Date: 1/1/2002 | | Compliance History: | Monitoring |
| | | Monitoring Period | Compliance Status: |
| | | 8/1/2016 - 8/31/2016 | Y |
| | | 9/1/2016 - 9/30/2016 | Y |
| | | 10/1/2016 - 10/31/2016 | N |
| | | 11/1/2016 - 11/30/2016 | N |
| | | 12/1/2016 - 12/31/2016 | |
| | | 1/1/2017 - 1/31/2017 | |

Water System Facility: **EASTON WATER TREATMENT PLANT (WSFID: 15)**

| Analyte | Monitoring Requirement (Summary Type) | Operating Limit | Samples Req/Month |
|-----------------------------|---------------------------------------|----------------------------|---------------------------|
| Turbidity | CFE Maximum Turbidity (MAXT) | Maximum: 1 NTU | 186 |
| Start Date: 1/1/2002 | | Compliance History: | Monitoring |
| | | Monitoring Period | Compliance Status: |
| | | 8/1/2016 - 8/31/2016 | Y |
| | | 9/1/2016 - 9/30/2016 | N |
| | | 10/1/2016 - 10/31/2016 | N |
| | | 11/1/2016 - 11/30/2016 | N |
| | | 12/1/2016 - 12/31/2016 | |
| | | 1/1/2017 - 1/31/2017 | |

Water System Facility: **HEMLOCKS WATER TREATMENT PLANT (WSFID: 21)**

| Analyte | Monitoring Requirement (Summary Type) | Operating Limit | Samples Req/Month |
|-----------------------------|---------------------------------------|----------------------------|---------------------------|
| Turbidity | CFE Maximum Turbidity (MAXT) | Maximum: 1 NTU | 186 |
| Start Date: 1/1/2002 | | Compliance History: | Monitoring |
| | | Monitoring Period | Compliance Status: |
| | | 8/1/2016 - 8/31/2016 | Y |
| | | 9/1/2016 - 9/30/2016 | Y |
| | | 10/1/2016 - 10/31/2016 | N |
| | | 11/1/2016 - 11/30/2016 | N |
| | | 12/1/2016 - 12/31/2016 | |
| | | 1/1/2017 - 1/31/2017 | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|--|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Other Compliance Schedules

| Compliance Schedule Activity | Due Date | Achieved Date |
|---------------------------------|-----------|---------------|
| CROSS CONNECTION SURVEY REPORT | 3/1/2016 | |
| RESPOND TO SANITARY SURVEY | 9/24/2016 | 9/23/2016 |
| WATERSHED SURVEY REPORT | 3/1/2017 | |
| SUBMIT CCR TO THE DEPARTMENT | 6/30/2017 | |
| SUBMIT CCR CERTIFICATION FORM | 8/9/2017 | |
| LT2 - SUBMIT BIN CLASSIFICATION | 9/30/2017 | |
| LT2 - SUBMIT BIN CLASSIFICATION | 9/30/2017 | |
| LT2 - SUBMIT BIN CLASSIFICATION | 9/30/2017 | |

Water System Facility and Sampling Point Inventory

| Water System Facility ID | Water System Facility | Sampling Point ID | Sampling Point Description | Status | Total Coliform Rule | Lead and Copper Rule Tier | Asbestos | Stage 2 DBPR |
|--------------------------|-------------------------------------|-------------------|----------------------------|--------|---------------------|---------------------------|----------|--------------|
| 00500 | TRAP FALLS WASH WATER RETURN | 1 | SAMPLE TAP | A | | | | |
| 00501 | TRAP FALLS WW RETURN/RAW MIX | 1 | SAMPLE TAP | A | | | | |
| 00502 | EASTON WASH WATER RETURN | 1 | SAMPLE TAP | A | | | | |
| 00503 | EASTON WW RETURN/RAW MIX | 1 | SAMPLE TAP | A | | | | |
| 00504 | HEMLOCKS WASH WATER RETURN | 1 | SAMPLE TAP | A | | | | |
| 00505 | HEMLOCKS WW RETURN/RAW MIX | 1 | SAMPLE TAP | A | | | | |
| 00506 | COLEYTOWN WELLFIELD RAW SAMPLE TAP | 00351 | COLEY WELLS RAW TAP | A | | | | |
| | | 2 | RAW | A | | | | |
| 00507 | HOUSATONIC WELLFIELD RAW SAMPLE TAP | 2 | RAW | A | | | | |
| 00508 | WESTPORT WELLFIELD RAW SAMPLE TAP | 2 | RAW | A | | | | |
| 00600 | DISTRIBUTION SYSTEM | 4 | 149 Boston Ave Two F | A | Y | | | |
| | | 00014 | IRVING B&B | A | Y | | | |
| | | 00016 | HUNTINGTON RD FS | A | Y | | | Y |
| | | 00019 | BRINSMADE PS | A | Y | | | |
| | | 00022 | UNITED METHODIST HO | A | Y | | | |
| | | 00024 | CUMBERLAND FARMS | A | Y | | | |
| | | 00025 | TRAP FALLS TANK | A | Y | | | |
| | | 00029 | TEXACO-HOWE AVE | A | Y | | | Y |
| | | 00030 | RADD LAUNDROMAT | A | Y | | | Y |
| | | 00031 | CITGO STRATFORD AVE | I | Y | | | |
| 00032 | LORDSHIP FS | A | Y | | | Y | | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|--|--|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |
| Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON | | | | | | | |

Water System Facility and Sampling Point Inventory

| Water System Facility ID | Water System Facility | Sampling Point ID | Sampling Point Description | Status | Total Coliform Rule | Lead and Copper Rule Tier | Asbestos | Stage 2 DBPR |
|--------------------------|-----------------------|-------------------|----------------------------|--------|---------------------|---------------------------|----------|--------------|
| | | 00035 | TEXACO WHITE PLAINS | A | Y | | | |
| | | 00037 | LORD CHAMBERLAIN NC | A | Y | | | Y |
| | | 00038 | ST CATHERINE CHURCH | A | Y | | | |
| | | 00039 | GULF MAIN STREET | I | Y | | | |
| | | 00111 | FIRESTONE | A | Y | | Y | |
| | | 00112 | VILLA CAR WASH | A | Y | | | |
| | | 00113 | KELLY TIRES | I | Y | | | |
| | | 00115 | WOOD AVE FS | A | Y | | | |
| | | 00116 | EVERS FS | A | Y | | | |
| | | 00117 | SOUTHPORT FS | A | Y | | | |
| | | 00118 | GETTY POST ROAD | A | Y | | | |
| | | 00120 | CLARENCE ST POLICE | I | Y | | | |
| | | 00121 | SUNOCO GRASMERE | A | Y | | | |
| | | 00122 | RUSSELL CHEVROLET | A | Y | | | |
| | | 00123 | CONGRESS FS | A | Y | | | |
| | | 00125 | ROUTE 33 PS | A | Y | | | |
| | | 00126 | BELDEN HILL PS | A | Y | | | |
| | | 00128 | MOBIL TUNXIS | I | Y | | | |
| | | 00134 | BROOKSIDE PS | A | Y | | | |
| | | 00135 | MERRIT PARKWAY INN | A | Y | | | |
| | | 00137 | PARK AVE MARKET | A | Y | | | |
| | | 00139 | SAVE THE CHILDREN | A | Y | | Y | |
| | | 00210 | JACKMAN FS | A | Y | | | Y |
| | | 00211 | MOBIL STRATFIELD | A | Y | | | |
| | | 00212 | JEFFERSON PS | A | Y | | | |
| | | 00213 | MONROE PS | A | Y | | | |
| | | 00214 | MADISON FIRE STATION | I | | | | |
| | | 00216 | TRUMBULL POLICE | A | Y | | Y | Y |
| | | 00218 | GULF HUNTINGTON | A | Y | | | Y |
| | | 00220 | BIRCHBANK PS | A | Y | | | |
| | | 00221 | WHITE HILLS PUMP STA | A | Y | | Y | Y |
| | | 00222 | PASTORS WALK | A | Y | | Y | Y |
| | | 00228 | MEANS BROOK HL | A | Y | | | |
| | | 00229 | BEECHMONT FS | A | Y | | | |
| | | 00231 | BUCK HILL P.S. | A | Y | | | |
| | | 00232 | NORTH END SEN CTR | I | Y | | | |
| | | 00236 | EDISON RD SS | A | Y | | | |
| | | 00237 | TRUMBULL ANIMAL HOS | A | Y | | | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|--|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Water System Facility and Sampling Point Inventory

| Water System Facility ID | Water System Facility | Sampling Point ID | Sampling Point Description | Status | Total Coliform Rule | Lead and Copper Rule Tier | Asbestos | Stage 2 DBPR |
|--------------------------|-----------------------|-------------------|----------------------------|--------|---------------------|---------------------------|----------|--------------|
| | | 00238 | BIRCHBANK SAMPLE STA | A | Y | | | |
| | | 00239 | AWC MONROE OFFICE | A | Y | | | |
| | | 00343 | CANNONDALE P.S. | A | Y | | | |
| | | 00344 | MEADOWRIDGE TNK PS | A | Y | | | |
| | | 00357 | WEST BRANCH RD SS | A | Y | | | Y |
| | | 01130 | GAMBRO MADISON AV | A | Y | | | |
| | | 01135 | GAMBRO BPT AVE | A | Y | | | |
| | | 01149 | AWC OPERATIONS CTR | A | Y | | | |
| | | 01158 | NORTH ST PS WSTPORT | A | Y | | | |
| | | 01159 | SUNOCO MADISON AVE | A | Y | | | |
| | | 01160 | ELVIRAS DELI WPT | A | Y | | | |
| | | 01161 | GETTY MOHEGAN RD | A | Y | | | Y |
| | | 01162 | SHELTON POLICE | A | Y | | | |
| | | 01163 | SHELTON PARTY WORL | I | Y | | | |
| | | 01164 | BPT - HEALTH DEPT | I | Y | | | |
| | | 01165 | OPTIMUS HEALTH-BPT | A | Y | | N | |
| | | 01166 | TWO FOLD LAUNDRY | A | Y | | | |
| | | 01167 | CURRAN VOLKSWAGEN | A | Y | | | |
| | | 01168 | FITNESS 4000 | I | Y | | | Y |
| | | 01169 | COMPARE FOODS | A | Y | | | |
| | | 01170 | BUDDHIST TEMPLE | A | Y | | | |
| | | 01171 | NEWFIELD LIBRARY BPT | A | Y | | | |
| | | 01172 | LIBRARY 2455 MADISON | A | Y | | | Y |
| | | 01173 | BRIDGEPORT FD | A | Y | | | |
| | | 01174 | 1 CANAL ST WSPT | A | Y | | | |
| | | 01179 | 1 CANAL ST WSPT | A | Y | | | |
| | | 4 | GENERIC DISTRIBUTION | A | Y | | | |
| | | DOWNSTREAM | WITHIN 5 SERVICE CON | A | | | | |
| | | MS1 | 140 MAIN STREET, MON | A | Y | | | |
| | | PB102 | 205 FULLING MLL FFLD | A | | | 1 | |
| | | PB104 | 32 BRIDGET FFLD | A | | | 1 | |
| | | PB108 | 83 GRIST MLL SOPORT | A | | | 1 | |
| | | PB112 | 20 BEAGLING HL FFLD | A | | | 1 | |
| | | PB115 | 13 FAR MILL MONROE | A | | | 1 | |
| | | PB117 | 42 HIGHFIELD MONROE | A | | | 1 | |
| | | PB119 | 80 FIELDROCK MONROE | A | | | 1 | |
| | | PB120 | 19 FAR MILL MONROE | A | | | 1 | |
| | | PB131 | 147 CROSS HL MONROE | A | | | 1 | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|--|--|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |
| Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON | | | | | | | |

Water System Facility and Sampling Point Inventory

| Water System Facility ID | Water System Facility | Sampling Point ID | Sampling Point Description | Status | Total Coliform Rule | Lead and Copper Rule Tier | Asbestos | Stage 2 DBPR |
|--------------------------|-----------------------|-------------------|----------------------------|--------|---------------------|---------------------------|----------|--------------|
| | | PB134 | 30 NELSON BR MONROE | A | | 1 | | |
| | | PB139 | 87 RUGBY SHELTON | A | | 1 | | |
| | | PB143 | 63 PR WENONAH SHEL | A | | 1 | | |
| | | PB144 | 2 JODIE SHELTON | A | | 1 | | |
| | | PB147 | 32 MULBERRY SHELTON | A | | 1 | | |
| | | PB148 | 27 BIG HORN SHELTON | A | | 1 | | |
| | | PB156 | 52 GINA STFD | A | | 1 | | |
| | | PB157 | 395 OAK RIDGE STFD | A | | 1 | | |
| | | PB159 | 120 FAIRCHILD STFD | A | | 1 | | |
| | | PB161 | 930 BEAVER DAM STFD | A | | 1 | | |
| | | PB163 | 400 BRINSMAYD STFD | A | | 1 | | |
| | | PB164 | 1053 CUTSPRING STFD | A | | 1 | | |
| | | PB165 | 260 ASHWOOD STFD | A | | 1 | | |
| | | PB168 | 88 CALHOUN TRUMBULL | A | | 1 | | |
| | | PB172 | 10 DOE HOLLOW TRUMBL | A | | 1 | | |
| | | PB173 | 51 OCTOBER TRUMBULL | A | | 1 | | |
| | | PB176 | 3 IVYWOOD TRUMBULL | A | | 1 | | |
| | | PB208 | 98 PRICE BPT | A | | 1 | | |
| | | PB218 | 291 WOODSTOCK STFD | A | | 1 | | |
| | | PB225 | 37 EAST STREET | A | Y | 1 | | |
| | | PB235 | 896 NICHOLS STFD | A | | 1 | | |
| | | PB238 | 56 VAN STFD | A | | 1 | | |
| | | PB239 | 16 BROOKLAWN PKWY | A | Y | 1 | | |
| | | PB245 | 301 ROWLAND FFLD | A | | 1 | | |
| | | PB259 | 2020 HUNTINGTON TRUM | A | | 1 | | |
| | | PB261 | 1997 HUNTINGTON TRUM | A | | 1 | | |
| | | PB262 | 2078 HUNTINGTON TRU | A | | 3 | | |
| | | PB265 | 232 NORTH ST | A | Y | 1 | | |
| | | PB268 | 46 BENSON FFLD | A | | 1 | | |
| | | PB269 | 54 BROOKFIELD FFLD | A | | 1 | | |
| | | PB284 | 26 ESSEX FFLD | A | | 1 | | |
| | | PB286 | 258 FAIRVIEW FFLD | A | | 1 | | |
| | | PB291 | 178 JACKMAN FFLD | A | | 1 | | |
| | | PB314 | 121 CHALMERS BPT | A | | 1 | | |
| | | PB326 | 7 MEADOWVIEW DRIVE | A | Y | 1 | | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|--|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Water System Facility and Sampling Point Inventory

| Water System Facility ID | Water System Facility | Sampling Point ID | Sampling Point Description | Status | Total Coliform Rule | Lead and Copper Rule Tier | Asbestos | Stage 2 DBPR |
|--------------------------|------------------------------------|-------------------|----------------------------|--------|---------------------|---------------------------|----------|--------------|
| | | PB327 | 6 TODDS WAY WSPT | A | | 3 | | |
| | | PB341 | 84 ELLIOTT STFD | A | | 1 | | |
| | | PB343 | 66 NEWTOWN STFD | A | | 1 | | |
| | | PB345 | PB345 - 42 PAULINE S | A | Y | | | |
| | | PB357 | 605 BROOKLAWN FFLD | A | | 1 | | |
| | | PB359 | 239 COLONY FFLD | A | | 1 | | |
| | | PB360 | 17 EASTLAWN FFLD | A | | 1 | | |
| | | PB363 | 289 FAIRVIEW FFLD | A | | 1 | | |
| | | PB368 | 43 BROOKVIEW FFLD | A | | 1 | | |
| | | PB374 | 72 NEWMAN FFLD | A | | 1 | | |
| | | PB420 | 316 ORCHARD HL FFLD | A | | 1 | | |
| | | PB5844 | 111 EUERLE STREET | A | Y | 3 | | |
| | | PB6287 | 61 ARDEN TRUM | A | | 1 | | |
| | | PB6315 | 24 CRESCENT STREET | A | Y | 1 | | |
| | | PB6323 | 72 UNIVERSITY DR | A | Y | 3 | | |
| | | PB6335 | 4582 MADISON AVE | A | Y | 3 | | |
| | | PB6336 | 855 STRATFORD RD | A | Y | 3 | | |
| | | PB6849 | 501 BIRRPIGJS FF;D | A | Y | 3 | | |
| | | PB6886 | 1999 N BENSON FFLD | A | Y | 1 | | |
| | | PB6887 | 9 SPRUCEWOOD WSPT | A | Y | 3 | | |
| | | PB7515 | 68 LADY SLIPPER DRIV | A | Y | 3 | | |
| | | PB7516 | 31 HORSE STABLE | A | Y | 3 | | |
| | | PB7517 | 20 ELDERBERRY LANE | A | Y | 3 | | |
| | | PB86 | 135 CLOVERHILL BPT | A | | 1 | | |
| | | PB91 | 1229 WOOD BPT | A | | 1 | | |
| | | PB91 - | PB91 - 1229 WOOD AVE | A | Y | | | |
| | | PB98 | 165 POLK BPT | A | | 1 | | |
| | | PB98 - | PB98 - 165 POLK ST B | A | Y | | | |
| | | UPSTREAM | WITHIN 5 SERVICE CON | A | | | | |
| 00700 | TRAP FALLS WTP ENTRY POINT | 3 | EP - TRAP FALLS | A | | | | |
| 00701 | EASTON WTP ENTRY POINT | 3 | EP - EASTON | A | | | | |
| 00702 | HEMLOCKS WTP ENTRY POINT | 3 | EP - HEMLOCKS | A | | | | |
| 00704 | WESTPORT WELLFIELD TP ENTRY POINT | 3 | EP - WESTPORT | A | | | | |
| 00705 | COLEYTOWN WELLFIELD TP ENTRY POINT | 3 | EP - COLEYTOWN | A | | | | |
| 14 | TRAP FALLS WATER TREATMENT PLANT | 5 | CFE - TRAP FALLS | A | | | | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|--|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Water System Facility and Sampling Point Inventory

| Water System Facility ID | Water System Facility | Sampling Point ID | Sampling Point Description | Status | Total Coliform Rule | Lead and Copper Rule Tier | Asbestos | Stage 2 DBPR |
|--------------------------|---------------------------------------|-------------------|----------------------------|--------|---------------------|---------------------------|----------|--------------|
| 1428 | WESTPORT WELL #3 | 2 | WESTPORT WELL #3 | A | | | | |
| 1430 | WESTPORT WELL #4 | 2 | WESTPORT WELL #4 | A | | | | |
| 1431 | WESTPORT WELL #5 | 2 | WESTPORT WELL #5 | A | | | | |
| 1432 | COLEYTOWN WELL #1 | 2 | COLEYTOWN WELL #1 | A | | | | |
| 1433 | COLEYTOWN WELL #2 | 2 | COLEYTOWN WELL #2 | A | | | | |
| 15 | EASTON WATER TREATMENT PLANT | 5 | CFE - EASTON TP | A | | | | |
| 16 | WESTPORT WELLFIELD TREATMENT PLANT | | | | | | | |
| 1641 | WESTPORT WELL #7 | 2 | WESTPORT WELL #7 | A | | | | |
| 17 | COLEYTOWN WELLFIELD TREATMENT PLANT | | | | | | | |
| 2009 | HEMLOCKS RESERVOIR | 1 | HEMLOCKS RESERVOIR | A | | | | |
| 2010 | ASPETUCK RESERVOIR | 1 | RESERVOIR | A | | | | |
| 2011 | SAUGATUCK RESERVOIR | 1 | RESERVOIR | A | | | | |
| 2012 | MOREHOUSE BROOK DIVERSION | 1 | RESERVOIR | A | | | | |
| 2013 | EASTON LAKE RESERVOIR | 1 | EASTON LAKE RES | A | | | | |
| 2014 | WEST PEQUONNOCK DIVERSION | 1 | RESERVOIR | A | | | | |
| 2015 | BOYS HALFWAY RIVER DIVERSION | 1 | RESERVOIR | A | | | | |
| 2016 | TRAP FALLS RESERVOIR | 1 | TRAP FALLS RESERVOIR | A | | | | |
| 2017 | MEANS BROOK RESERVOIR | 1 | RESERVOIR | A | | | | |
| 2018 | FAR MILL RESERVOIR | 1 | RESERVOIR | A | | | | |
| 21 | HEMLOCKS WATER TREATMENT PLANT | 5 | CFE - HEMLOCKS TP | A | | | | |
| 30015 | TRAP FALLS RESERVOIR INTAKE | | | | | | | |
| 30016 | HEMLOCKS RESERVOIR INTAKE | | | | | | | |
| 30017 | EASTON LAKE RESERVOIR INTAKE | | | | | | | |
| 49055 | WILTON ROAD PUMP STATION | | | | | | | |
| 50059 | INTERCONNECTION-NORWALK 1ST-MURRAY ST | | | | | | | |
| 50061 | INTERCONNECTION-NORWALK 1ST-COUNTY ST | | | | | | | |
| 53332 | MEANS BROOK PUMP STATION | | | | | | | |
| 53334 | WHITE HILLS PUMP STATION | | | | | | | |
| 53336 | WHITE HILLS STORAGE TANK | | | | | | | |
| 53338 | MONROE CENTRE STORAGE TANK | | | | | | | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|--|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Water System Facility and Sampling Point Inventory

| <i>Water System Facility ID</i> | <i>Water System Facility</i> | <i>Sampling Point ID</i> | <i>Sampling Point Description</i> | <i>Status</i> | <i>Total Coliform Rule</i> | <i>Lead and Copper Rule Tier</i> | <i>Asbestos</i> | <i>Stage 2 DBPR</i> |
|---------------------------------|---|--------------------------|-----------------------------------|---------------|----------------------------|----------------------------------|-----------------|---------------------|
| 53340 | MONROE CENTRE PUMP STATION | | | | | | | |
| 53342 | PASTORS WALK STORAGE TANK | | | | | | | |
| 53344 | PASTORS WALK PUMP STATION | | | | | | | |
| 53346 | NORTH AVENUE PUMP STATION | | | | | | | |
| 53348 | NORTH AVENUE STORAGE TANK | | | | | | | |
| 53350 | BELDEN HILL PUMP STATION | | | | | | | |
| 53352 | BELDEN HILL STORAGE TANK - EAST | | | | | | | |
| 53354 | BELDEN HILL STORAGE TANK - WEST | | | | | | | |
| 53356 | CANNONDALE BOOSTER STATION | | | | | | | |
| 53358 | MEADOW RIDGE PUMP STATION | | | | | | | |
| 53360 | MEADOW RIDGE STORAGE TANK | | | | | | | |
| 53362 | TRAP FALLS WTP STORAGE TANK | | | | | | | |
| 53364 | NICHOLS PUMP STATION | | | | | | | |
| 53366 | NICHOLS ELEVATED STORAGE TANK | | | | | | | |
| 53368 | BRINSMAD PUMP STATION | | | | | | | |
| 53370 | BRINSMAD STORAGE TANK | | | | | | | |
| 53372 | ORONOQUE PUMP STATION | | | | | | | |
| 53374 | TUNXIS HILL PUMP STATION | | | | | | | |
| 53376 | BROOKSIDE PUMP STATION | | | | | | | |
| 53378 | GREENFIELD ELEVATED STORAGE TANK | | | | | | | |
| 53380 | SAMP MORTAR PUMP STATION | | | | | | | |
| 53382 | BUCK HILL PUMP STATION | | | | | | | |
| 53384 | TASHUA HILLS PUMP STATION | | | | | | | |
| 53386 | TASHUA HILLS STORAGE TANK | | | | | | | |
| 53388 | JEFFERSON STREET PUMP STATION | | | | | | | |
| 53390 | FAIRCHILD WHEELER ELEVATED STORAGE TANK | | | | | | | |
| 53392 | PINE STREET ELEVATED STORAGE TANK | | | | | | | |
| 53394 | EASTON STORAGE TANK - NORTH | | | | | | | |
| 53396 | EASTON STORAGE TANK - SOUTH | | | | | | | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|-------------------------------------|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Water System Facility and Sampling Point Inventory

| Water System Facility ID | Water System Facility | Sampling Point ID | Sampling Point Description | Status | Total Coliform Rule | Lead and Copper Rule Tier | Asbestos | Stage 2 DBPR |
|--------------------------|-------------------------------------|-------------------|----------------------------|--------|---------------------|---------------------------|----------|--------------|
| 53398 | EASTON WTP RAW WATER PUMP STATION | | | | | | | |
| 53402 | TRAP FALLS WTP CLEARWELL | | | | | | | |
| 53404 | 490 TRAP FALLS PUMP STATION | | | | | | | |
| 53412 | HEMLOCKS WTP CLEARWELL | | | | | | | |
| 53414 | HEMLOCKS WTP STORAGE TANK | | | | | | | |
| 53416 | HEMLOCKS WTP RAW WATER PUMP STATION | | | | | | | |
| 53418 | HEMLOCKS WTP HIGH LIFT PUMP STATION | | | | | | | |
| 59992 | MATTHEWS BOOSTER PUMP STATION | | | | | | | |

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 3 DISTRIBUTION SYSTEM

| Operator Name | Operator Type | Certification(s) | Certification Expiration |
|------------------------|-------------------|---|--------------------------|
| PLAVNICKY, JOHN C. | CHIEF OPERATOR | DISTRIBUTION SYSTEM OPERATOR - CLASS III | 6/30/2018 |
| HILDRED, JR., ALAN | ASSIGNED OPERATOR | DISTRIBUTION SYSTEM OPERATOR - CLASS III | 6/30/2019 |
| BYRON, ROY | ASSIGNED OPERATOR | DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV | 12/31/2017 12/31/2019 |
| TORRES, JR., MIGUEL | ASSIGNED OPERATOR | DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV | 12/31/2017 12/31/2019 |
| ANDERSON, JOHN K. | ASSIGNED OPERATOR | DISTRIBUTION SYSTEM OPERATOR - CLASS III | 6/30/2019 |
| CHAPMAN, RICHARD A. | ASSIGNED OPERATOR | WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III | 6/30/2019 6/30/2018 |
| ULBRICK, FRED | ASSIGNED OPERATOR | DISTRIBUTION SYSTEM OPERATOR - CLASS III | 12/31/2019 |
| LEONE, GARY J. | ASSIGNED OPERATOR | DISTRIBUTION SYSTEM OPERATOR - CLASS III | 12/31/2018 |
| CARSWELL, JEFF | ASSIGNED OPERATOR | DISTRIBUTION SYSTEM OPERATOR - CLASS III | 6/30/2017 |
| FABSO, CHARLES P. | ASSIGNED OPERATOR | DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV | 12/31/2017 12/31/2019 |
| CRELAN, STACY | ASSIGNED OPERATOR | DISTRIBUTION SYSTEM OPERATOR - CLASS III | 6/30/2017 |
| BURKE, JONATHAN | ASSIGNED OPERATOR | WATER TREATMENT PLANT OPERATOR - CLASS II | 9/30/2019 |
| KAMINSKI, GARY S. | ASSIGNED OPERATOR | WATER TREATMENT PLANT OPERATOR - CLASS IV | 12/31/2017 |
| GARDNER, GREGORY L. | ASSIGNED OPERATOR | DISTRIBUTION SYSTEM OPERATOR - CLASS III | 6/30/2019 |
| METZ, ERIC J. | ASSIGNED OPERATOR | DISTRIBUTION SYSTEM OPERATOR - CLASS III | 6/30/2019 |
| VIZCARRONDO, CARLOS J. | ASSIGNED OPERATOR | DISTRIBUTION SYSTEM OPERATOR - CLASS III | 6/30/2017 |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

| | | | | | | | |
|----------------------------------|--|---------------------|-------------|------------|----------------|----------|--------------|
| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source | | |
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW | | |
| Local Address (where applicable) | | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
| | | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Certified Operator Information

Water System Facility: TRAP FALLS WATER TREATMENT PLANT (WSF ID: 14)

Facility Classification: CLASS 4 TREATMENT PLANT

| Operator Name | Operator Type | Certification(s) | Certification Expiration |
|---------------------|-------------------|---|--------------------------|
| FABSO, CHARLES P. | CHIEF OPERATOR | DISTRIBUTION SYSTEM OPERATOR - CLASS III | 12/31/2017 |
| | | WATER TREATMENT PLANT OPERATOR - CLASS IV | 12/31/2019 |
| TORRES, JR., MIGUEL | ASSIGNED OPERATOR | DISTRIBUTION SYSTEM OPERATOR - CLASS III | 12/31/2017 |
| | | WATER TREATMENT PLANT OPERATOR - CLASS IV | 12/31/2019 |
| CHAPMAN, RICHARD A. | ASSIGNED OPERATOR | DISTRIBUTION SYSTEM OPERATOR - CLASS III | 6/30/2018 |
| | | WATER TREATMENT PLANT OPERATOR - CLASS IV | 6/30/2019 |
| CAVERLY, DONISE | ASSIGNED OPERATOR | WATER TREATMENT PLANT OPERATOR - CLASS IV | 12/31/2018 |
| LIBERANTE, MICHAEL | ASSIGNED OPERATOR | WATER TREATMENT PLANT OPERATOR - CLASS IV | 12/31/2017 |
| GORMAN, TERENCE | ASSIGNED OPERATOR | WATER TREATMENT PLANT OPERATOR - CLASS IV | 12/31/2018 |
| KAMINSKI, GARY S. | ASSIGNED OPERATOR | WATER TREATMENT PLANT OPERATOR - CLASS IV | 12/31/2017 |
| MALANCA, DANTE A. | ASSIGNED OPERATOR | DISTRIBUTION SYSTEM OPERATOR - CLASS III | 6/30/2017 |
| | | WATER TREATMENT PLANT OPERATOR - CLASS IV | 3/31/2017 |

Water System Facility: EASTON WATER TREATMENT PLANT (WSF ID: 15)

Facility Classification: CLASS 4 TREATMENT PLANT

| Operator Name | Operator Type | Certification(s) | Certification Expiration |
|--------------------|-------------------|---|--------------------------|
| WELSH, JOE | CHIEF OPERATOR | WATER TREATMENT PLANT OPERATOR - CLASS IV | 6/30/2018 |
| LIBERANTE, MICHAEL | ASSIGNED OPERATOR | WATER TREATMENT PLANT OPERATOR - CLASS IV | 12/31/2017 |
| KAMINSKI, GARY S. | ASSIGNED OPERATOR | WATER TREATMENT PLANT OPERATOR - CLASS IV | 12/31/2017 |

Water System Facility: WESTPORT WELLFIELD TREATMENT PLANT (WSF ID: 16)

Facility Classification: CLASS 2 TREATMENT PLANT

| Operator Name | Operator Type | Certification(s) | Certification Expiration |
|---------------------|----------------|---|--------------------------|
| TORRES, JR., MIGUEL | CHIEF OPERATOR | DISTRIBUTION SYSTEM OPERATOR - CLASS III | 12/31/2017 |
| | | WATER TREATMENT PLANT OPERATOR - CLASS IV | 12/31/2019 |

Water System Facility: COLEYTOWN WELLFIELD TREATMENT PLANT (WSF ID: 17)

Facility Classification: CLASS 2 TREATMENT PLANT

| Operator Name | Operator Type | Certification(s) | Certification Expiration |
|---------------------|----------------|---|--------------------------|
| TORRES, JR., MIGUEL | CHIEF OPERATOR | DISTRIBUTION SYSTEM OPERATOR - CLASS III | 12/31/2017 |
| | | WATER TREATMENT PLANT OPERATOR - CLASS IV | 12/31/2019 |

Water System Facility: HEMLOCKS WATER TREATMENT PLANT (WSF ID: 21)

Facility Classification: CLASS 4 TREATMENT PLANT

| Operator Name | Operator Type | Certification(s) | Certification Expiration |
|-------------------|-------------------|---|--------------------------|
| BYRON, ROY | CHIEF OPERATOR | WATER TREATMENT PLANT OPERATOR - CLASS IV | 12/31/2019 |
| | | DISTRIBUTION SYSTEM OPERATOR - CLASS III | 12/31/2017 |
| SCALES, GEORGE M. | ASSIGNED OPERATOR | WATER TREATMENT PLANT OPERATOR - CLASS IV | 12/31/2017 |
| | | DISTRIBUTION SYSTEM OPERATOR - CLASS III | 6/30/2018 |
| WELSH, JOE | ASSIGNED OPERATOR | WATER TREATMENT PLANT OPERATOR - CLASS IV | 6/30/2018 |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

| PWS ID | PWS Name | Classification | Population | Owner Type | Primary Source |
|-----------|-------------------------------------|----------------|------------|------------|----------------|
| CT0150011 | AQUARION WATER CO OF CT-MAIN SYSTEM | C | 351,756 | P | SW |

| Local Address (where applicable) | Service Connections | Residential | Commercial | Industrial | Combined | Agricultural |
|----------------------------------|---------------------|-------------|------------|------------|----------|--------------|
| | | 91,895 | 1 | | | |

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

Certified Operator Information

Water System Facility: **HEMLOCKS WATER TREATMENT PLANT (WSF ID: 21)**

Facility Classification: CLASS 4 TREATMENT PLANT Certification

| Operator Name | Operator Type | Certification(s) | Certification Expiration |
|-----------------|-------------------|---|--------------------------|
| FAUSTIN, JOSEPH | ASSIGNED OPERATOR | WATER TREATMENT PLANT OPERATOR - CLASS IV | 12/31/2019 |

Contact Information

| Name | Organization | Job Title |
|-------------------|------------------------|----------------|
| Mr. John P. Walsh | Aquarion Water Company | Vice President |

| Mailing Address Line One | Mailing Address Line Two | City | State | Zip Code |
|--------------------------|--------------------------|------------|-------|----------|
| 600 Lindley Street | | Bridgeport | CT | 06606 |

| Business Phone | Extension | Fax | Mobile Phone | Emergency Phone | Email Address |
|----------------|-----------|--------------|--------------|-----------------|--------------------------|
| 203-337-5852 | | 203-337-5839 | | 781-413-6175 | jwalsh@aquarionwater.com |

Contact Role(s): **Administrative Contact, Legal Contact**

- Please note the following:**
1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
 2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
 3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule