

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS	C	6,324	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,711	152	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/20				
Total Coliform (3100)		7 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete		
	9/1/16 - 9/30/16		Complete		
	10/1/16 - 10/31/16		Complete		
	11/1/16 - 11/30/16		Complete		
	12/1/16 - 12/31/16		Complete		
	1/1/17 - 1/31/17		Complete		
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				
	7/1/17 - 7/31/17				
	8/1/17 - 8/31/17				
Disinfectant Byproducts - TTHM & HAA5 (DBP)		2 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
126 PWDR MILL RD,CAN (5054)	7/1/16 - 9/30/16	7/1-7/31	Complete		
	10/1/16 - 12/31/16	10/1-10/31	Complete		
	1/1/17 - 3/31/17	1/1-1/31			
	4/1/17 - 6/30/17	4/1-4/30			
133 RIVER RD, COLL (5058)	7/1/17 - 9/30/17	7/1-7/31			
	7/1/16 - 9/30/16	7/1-7/31	Complete		
	10/1/16 - 12/31/16	10/1-10/31	Complete		
	1/1/17 - 3/31/17	1/1-1/31			
	4/1/17 - 6/30/17	4/1-4/30			
	7/1/17 - 9/30/17	7/1-7/31			
Lead And Copper (PBCU)		20 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30			
	1/1/19 - 12/31/21	6/1-9/30			
Physical Parameters (PPS)		7 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 1/31/17		Complete		
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS	C	6,324	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,711	152	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	7 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Physical Parameters (PPX)	7 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete

Water System Facility: **ENTRY POINT-FILTER PLANT (WSF ID: 00700)**

Net Gross Alpha (4000)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		

Uranium (4006)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		

Combined Radium-226/228 (4010)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		

Inorganic Chemicals (IOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/16 - 12/31/16		
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS	C	6,324	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,711	152	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Monitoring Requirements

Water System Facility: **ENTRY POINT-FILTER PLANT (WSF ID: 00700)**

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Water System Facility: **COLLINSVILLE WTP (WSF ID: 114)**

Total Organic Carbon (2920) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CFE- COLLINSVILLE TP (5)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: **MDC NEPAUG RESERVOIR (WSF ID: 2129)**

Total Alkalinity (1927) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
NEPAUG RESERVOIR (1)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS	C	6,324	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,711	152	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Monitoring Requirements

Water System Facility: MDC NEPAUG RESERVOIR (WSF ID: 2129)

Total Organic Carbon (2920)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
NEPAUG RESERVOIR (1)	8/1/16 - 8/31/16		Complete	
	9/1/16 - 9/30/16		Complete	
	10/1/16 - 10/31/16		Complete	
	11/1/16 - 11/30/16		Complete	
	12/1/16 - 12/31/16			
	1/1/17 - 1/31/17			
	2/1/17 - 2/28/17			
	3/1/17 - 3/31/17			
	4/1/17 - 4/30/17			
	5/1/17 - 5/31/17			
	6/1/17 - 6/30/17			
	7/1/17 - 7/31/17			
	8/1/17 - 8/31/17			
E. Coli (3014)		1 routine (RT) per two weeks		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
NEPAUG RESERVOIR (1)	9/23/16 - 10/6/16	10/3-10/7	Complete	
	10/7/16 - 10/20/16	10/17-10/21	Complete	
	10/21/16 - 11/3/16	10/31-11/4	Complete	
	11/4/16 - 11/17/16	11/14-11/18	Complete	
	11/18/16 - 12/1/16	11/28-12/2	Complete	
	12/2/16 - 12/15/16	12/12-12/16	Complete	
	12/16/16 - 12/29/16	12/26-12/30	Complete	
	12/30/16 - 1/12/17	1/9-1/13		
	1/13/17 - 1/26/17	1/23-1/27		
Total Coliform (3100)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
NEPAUG RESERVOIR (1)	7/1/16 - 9/30/16		Complete	
Raw Water Physical Parameters (PHYR)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
NEPAUG RESERVOIR (1)	7/1/16 - 9/30/16		Complete	
	10/1/16 - 12/31/16		Complete	
Surface Water Inorganic Chemicals (RIOC)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
NEPAUG RESERVOIR (1)	1/1/16 - 12/31/16			
	1/1/17 - 12/31/17			
	1/1/18 - 12/31/18			
Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS	C	6,324	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,711	152	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Monitoring Requirements

Water System Facility: **MDC NEPAUG RESERVOIR (WSF ID: 2129)**

Surface Water Color and Turbidity (RPPS) 1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
NEPAUG RESERVOIR (1)	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Surface Water Pesticides (RSOC) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
NEPAUG RESERVOIR (1)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT-FILTER PLANT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
Start Date: 1/1/2004	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2016 - 8/31/2016		N
	9/1/2016 - 9/30/2016		N
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N
	12/1/2016 - 12/31/2016		
	1/1/2017 - 1/31/2017		

Water System Facility: **COLLINSVILLE WTP (WSFID: 114)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2004	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2016 - 8/31/2016	Y	Y
	9/1/2016 - 9/30/2016	Y	N
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N
	12/1/2016 - 12/31/2016		
	1/1/2017 - 1/31/2017		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2017	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	3/31/2017	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
LT2 - SUBMIT SOURCE MONITORING PLAN	7/1/2017	6/30/2016

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS	C	6,324	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,711	152	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT CCR CERTIFICATION FORM	8/9/2017	

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Total Coliform M&R Violation	1/1/11 - 3/31/11	3	6/13/2012		6/23/2012	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		5050	113 HCKLBRY HIL COL	A	Y			
		5051	104 MAIN ST CANTON	A	Y			
		5053	103 DEEPWOOD DR.	A	Y			
		5054	126 PWDR MILL RD,CAN	A	Y			Y
		5055	CANTON COMMONS,RT44	A	Y			
		5056	7 CEMETARY RD, COL	A	Y			
		5057	178 KINGSWOOD DR,COL	A	Y			
		5058	133 RIVER RD, COLL	A				Y
		50801	5 BRKVIEW CRCL,CAN	A		2		
		50802	3 WHIRLING DUN COL	A		2		
		50803	9 WHIRLING DUN COL	A		2		
		50804	23 WICKHAMS FANCY	A		2		
		50805	37 WICKHAMS FANCY	A		2		
		50806	39 WICKHAMS FANCY	A		2		
		50807	44 WICKHAMS FANCY	A		2		
		50808	3 BROOKVIEW CIR,CAN	A		2		
		50809	6 BROOKVIEW CIR, CAN	A		2		
		50810	18 BROOKVIEW CIR,CAN	A		2		
		50811	14 WICKHAMS FANCY	A		2		
		50812	29 WICKHAMS FANCY	A		2		
		50813	33 WICKHAMS FANCY	A		2		
		50814	35 WICKHAMS FANCY	A		2		
		50815	50 WICKHAMS FANCY	A		2		
		50816	52 WICKHAMS FANCY	A		2		
		50817	59 WICKHAMS FANCY	A		2		
		50818	62 WICKHAMS FANCY	A		2		
		50819	1 WHIRLING DUN COL	A		2		
		50820	4 CAMILLE LN	A		2		
		50821	9 CAMILLE LN	A		2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS	C	6,324	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,711	152	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
		50822	100 WINTERBOURNE LN	A		2		
		50823	116 WINTERBOURNE LN	A		2		
		50824	118 WINTERBOURNE LN	A		2		
		50825	126 WINTERBOURNE LN	A		2		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT-FILTER PLANT	3	ENTRY POINT-FILTER P	A				
114	COLLINSVILLE WTP	5	CFE- COLLINSVILLE TP	A				
2129	MDC NEPAUG RESERVOIR	1	NEPAUG RESERVOIR	A				
30019	MDC NEPAUG RESERVOIR	1	NEPAUG RES INTAKE	A				
37292	CTWC HUCKLEBERRY HILL TANK							
49477	CEMETARY ROAD PUMP STATION							
52174	WTP CLEARWELLS							
52176	WTP STANDPIPE							
58936	INTERCONNECTION - AVON WATER CO							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
ROBOTHAM, JR., PAUL C.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
RUZBASAN, STEPHEN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2018
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
PEIL, THEODORE W.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
RUOT, DAVID A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2017
CORBETT, PATRICK M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2018
REYNOLDS, REED M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019

Water System Facility: COLLINSVILLE WTP (WSF ID: 114)

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BARAL, JR, RAYMOND E.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2017
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2019
PRATT, STEPHEN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS	C	6,324	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,711	152	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Certified Operator Information

Water System Facility: **COLLINSVILLE WTP (WSF ID: 114)**

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
DESCHAMPS, WILLIAM A.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2018
PECTO, WILLIAM T.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2018
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2019
SMITH, MICHAEL J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2019
NELL, SCOTT	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019
AUDET, JOSEPH R.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2018
NEGRELLI, SUSAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2018
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2017
ROGERS, SCOTT K.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR IN TRAINING	6/30/2019
RANDALL, DANIEL J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2017

Contact Information

Name		Organization			Job Title	
Mr. Reed M. Reynolds		Connecticut Water Company			Superintendent	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
		19 Executive Drive		Farmington	CT	06032
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-664-6241		860-673-3740		860-286-5700	rreynolds@ctwater.com	

Contact Role(s): **Administrative Contact**

Name		Organization			Job Title	
Mr. Eric W. Thornburg		Connecticut Water Company			President/Ceo	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
93 West Main Street				Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
800-428-6008		860-669-9326		800-286-3985	ethornburg@ctwater.com	

Contact Role(s): **Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0231011	298-302 ALBANY TURNPIKE	C	28	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
298-302 ALBANY TURNPIKE			10				

Towns Served: CANTON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/10 - 12/31/18				
Total Coliform (3100)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete		
	9/1/16 - 9/30/16		Complete		
	10/1/16 - 10/31/16		Complete		
	11/1/16 - 11/30/16		Complete		
	12/1/16 - 12/31/16		Complete		
	1/1/17 - 1/31/17				
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				
	7/1/17 - 7/31/17				
	8/1/17 - 8/31/17				
Lead And Copper (PBCU)		5 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/16	6/1-9/30	Complete		
	1/1/17 - 12/31/19	6/1-9/30			
	1/1/20 - 12/31/22	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 1/31/17				
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				
	7/1/17 - 7/31/17				
	8/1/17 - 8/31/17				
Physical Parameters (PPX)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete		
	9/1/16 - 9/30/16		Complete		
	10/1/16 - 10/31/16		Complete		
	11/1/16 - 11/30/16		Complete		
	12/1/16 - 12/31/16		Complete		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0231011	298-302 ALBANY TURNPIKE	C	28	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
298-302 ALBANY TURNPIKE			10				

Towns Served: CANTON

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT-WELL #1 (3)	1/1/14 - 12/31/16		Complete	
	1/1/17 - 12/31/19			
	1/1/20 - 12/31/22			
Uranium (4006)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT-WELL #1 (3)	1/1/14 - 12/31/16		Complete	
	1/1/17 - 12/31/19			
	1/1/20 - 12/31/22			
Combined Radium-226/228 (4010)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT-WELL #1 (3)	1/1/14 - 12/31/16		Complete	
	1/1/17 - 12/31/19			
	1/1/20 - 12/31/22			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT-WELL #1 (3)	1/1/16 - 12/31/18			
	1/1/19 - 12/31/21			
Nitrate And Nitrite (NOX)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT-WELL #1 (3)	1/1/16 - 12/31/16		Complete	
	1/1/17 - 12/31/17			
	1/1/18 - 12/31/18			
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT-WELL #1 (3)	1/1/14 - 12/31/16	1/1-12/31	Waiver	
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT-WELL #1 (3)	1/1/17 - 12/31/19			
	1/1/20 - 12/31/22			
Organic Chemicals (VOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT-WELL #1 (3)	1/1/16 - 12/31/18			
	1/1/19 - 12/31/21			

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2010	
CROSS CONNECTION EXEMPTION	3/1/2012	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2012	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0231011	298-302 ALBANY TURNPIKE	C	28	P	GW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
298-302 ALBANY TURNPIKE		10				

Towns Served: CANTON

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2013	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2013	
SUBMIT CCR TO THE DEPARTMENT	6/30/2016	
SUBMIT CCR CERTIFICATION FORM	8/9/2016	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2016	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Repeat Total Coliform M&R Violation	10/1/10 - 10/31/10	2	4/16/2011		4/26/2011	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT-WELL #1	A				
1848	WELL #1	2	WELL #1	A				
44836	WELL 1 PRESSURE TANK							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
BEEMAN, ROBERT A.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2018
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2018
		WATER TREATMENT PLANT OPERATOR IN TRAINING	12/31/2018

Contact Information

Name	Organization	Job Title				
Mr. Matthew Schoenhardt	Watsul Associates, LLC	Manager				
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
PO Box 912				Canton	CT	06019
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-543-4005		860-543-4005	860-543-4005	860-543-4005	mfschoenhardt@juno.com	
Contact Role(s): Administrative Contact, Legal Contact, Owner						

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source	
CT0231011	298-302 ALBANY TURNPIKE	C	28	P	GW	
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
298-302 ALBANY TURNPIKE		10				

Towns Served: CANTON

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule