

**CONNECTICUT DEPARTMENT OF PUBLIC HEALTH - DRINKING WATER SECTION
WATER QUALITY MONITORING SCHEDULE**

NEIPSIC WOODS WATER ASSOCIATION

Town: GLASTONBURY

PWS ID: CT0540021

PWS Classification: Community

Population: 92

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)			
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	6/1/14 - 6/30/14		Complete
	7/1/14 - 7/31/14		Complete
	8/1/14 - 8/31/14		Complete
	9/1/14 - 9/30/14		Complete
	10/1/14 - 10/31/14		Complete
	11/1/14 - 11/30/14		
	12/1/14 - 12/31/14		
	1/1/15 - 1/31/15		
	2/1/15 - 2/28/15		
	3/1/15 - 3/31/15		
	4/1/15 - 4/30/15		
	5/1/15 - 5/31/15		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/13	6/1-9/30	Complete
Lead And Copper (PBCU)		5 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/14 - 6/30/14		
	7/1/14 - 12/31/14		
	1/1/15 - 6/30/15		
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	6/1/14 - 6/30/14		Complete
	7/1/14 - 7/31/14		Complete
	8/1/14 - 8/31/14		Complete
	9/1/14 - 9/30/14		Complete
	10/1/14 - 10/31/14		Complete
	11/1/14 - 11/30/14		
	12/1/14 - 12/31/14		
	1/1/15 - 1/31/15		
	2/1/15 - 2/28/15		
	3/1/15 - 3/31/15		
	4/1/15 - 4/30/15		

NOTE: The information contained in this "Water Quality Monitoring Schedule" has been provided to assist owners and operators of public water systems with the water quality monitoring requirements of RCSA Section 19-13-B102. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**CONNECTICUT DEPARTMENT OF PUBLIC HEALTH - DRINKING WATER SECTION
WATER QUALITY MONITORING SCHEDULE**

NEIPSIC WOODS WATER ASSOCIATION

Town: GLASTONBURY

PWS ID: CT0540021

PWS Classification: Community

Population: 92

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)			
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/15 - 5/31/15		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		
	1/1/17 - 12/31/19		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		
	1/1/17 - 12/31/19		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		
	1/1/17 - 12/31/19		
Inorganic Chemicals (IOC1)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/13 - 12/31/15		
	1/1/16 - 12/31/18		
Nitrate And Nitrite (NOX)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/14 - 6/30/14		Complete
	7/1/14 - 9/30/14		Complete
	10/1/14 - 12/31/14		Complete
	1/1/15 - 3/31/15		
	4/1/15 - 6/30/15		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		
	1/1/17 - 12/31/19		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		
	1/1/17 - 12/31/19		

NOTE: The information contained in this "Water Quality Monitoring Schedule" has been provided to assist owners and operators of public water systems with the water quality monitoring requirements of RCSA Section 19-13-B102. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**CONNECTICUT DEPARTMENT OF PUBLIC HEALTH - DRINKING WATER SECTION
WATER QUALITY MONITORING SCHEDULE**

NEIPSIC WOODS WATER ASSOCIATION

Town: GLASTONBURY

PWS ID: CT0540021

PWS Classification: Community

Population: 92

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOC1)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/13 - 12/31/13		Complete
	1/1/14 - 12/31/14		Complete
	1/1/15 - 12/31/15		

Monthly Compliance Reminder

Where routine nitrate or nitrite sampling results exceed the MCL, the system shall take a confirmation sample within 24 hours of receiving notification of the results and contact the Department. Systems unable to comply with the 24-hour sampling requirement shall immediately provide Public Notification and analyze a confirmation sample within two (2) weeks of receiving notification of the results. Compliance determination is based on the average of the initial and confirmation sampling results for each sampling point. (RCSA 19-13-B102(e)(7)(P))

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

<i>Analyte</i>	<i>Monitoring Requirement (Summary Type)</i>	<i>Operating Limit</i>	<i>Samples Req/Month</i>
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	4
<i>Start Date:</i> 3/1/2009		<u>Compliance History:</u>	<u>Operating Limit Compliance:</u>
		<u>Monitoring Period</u>	<u>Monitoring Compliance:</u>
		6/1/2014 - 6/30/2014	Y
		7/1/2014 - 7/31/2014	Y
		8/1/2014 - 8/31/2014	Y
		9/1/2014 - 9/30/2014	Y
		10/1/2014 - 10/31/2014	
		11/1/2014 - 11/30/2014	

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT CCR TO THE DEPARTMENT	6/30/2014	6/30/2014
SUBMIT CCR CERTIFICATION FORM	8/9/2014	6/30/2014
SWTS 2: DWS TREATMENT DETERMINATION	9/30/2014	
CROSS CONNECTION EXEMPTION	3/1/2015	
CCTS 2: DWS REVIEW OF PROPOSED OCCT	3/31/2015	

Public Notification Requirements

Monitoring and Reporting Violations (Mon)

<i>Analyte / Analyte Group (Code)</i>	<i>Monitoring Period</i>	<i>Violation Tier</i>	<i>Public Notification Required</i>	<i>Public Notification Performed</i>	<i>Certification Due</i>	<i>Certification Received</i>
Water Quality Parameters (WQP1)	1/1/11 - 12/31/13	3		9/9/2015	9/19/2015	
Water Quality Parameters (WQP1)	1/1/11 - 12/31/13	3		9/9/2015	9/19/2015	
Lead and Copper (5000)	10/1/13 - 3/31/14	3		9/9/2015	9/19/2015	

NOTE: The information contained in this "Water Quality Monitoring Schedule" has been provided to assist owners and operators of public water systems with the water quality monitoring requirements of RCSA Section 19-13-B102. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**CONNECTICUT DEPARTMENT OF PUBLIC HEALTH - DRINKING WATER SECTION
WATER QUALITY MONITORING SCHEDULE**

NEIPSIC WOODS WATER ASSOCIATION

Town: GLASTONBURY

PWS ID: CT0540021

PWS Classification: Community

Population: 92

Public Notification Requirements

Treatment Technique Violations (TT)

<i>Analyte / Analyte Group (Code)</i>	<i>Monitoring Period</i>	<i>Violation Tier</i>	<i>Public Notification Required Performed</i>	<i>Certification Due</i>	<i>Certification Received</i>
Lead and Copper (5000)	12/1/13 -	2	10/10/2014	10/20/2014	
Lead and Copper (5000)	4/1/14 -	2	10/10/2014	10/20/2014	

Note: Violation Tier 1: Public Notification required no later than 24 hours after the system learns of the violation.

Violation Tier 2: Public Notification required no later than 30 days after the system learns of the violation.

Violation Tier 3: Public Notification required no later than 365 days after the system learns of the violation.

Public Notification Certification of Compliance is required no later than 10 days after completing the Public Notification Requirements..

Water System Facility Information

Distribution System

DISTRIBUTION SYSTEM - (WSF ID: 00600)

Certified Operator Information

<i>Operator Name</i>	<i>Operator Type Certification(s)</i>	<i>Certification Expiration Date</i>
LABIANCA, MICHAEL	CHIEF OPERATOR	
	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2015
	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2015

Sampling Point Inventory

<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Sampling Point Type</i>	<i>Total Coliform</i>	<i>Lead and Copper Tier</i>	<i>Asbestos</i>	<i>Stage 2 DBPR</i>
4	DISTRIBUTION SYSTEM	A	DS	Y			
NEIP001	89 GOODRICH	P	DS	Y	3		
NEIP002	126 GOODRICH	P	DS	Y	3		
NEIP003	103 GOODRICH	P	DS	Y	3		
NEIP004	20 LINCOLN	P	DS	Y	3		
NEIP005	81 GOODRICH	P	DS	Y	3		
NEIP006	73 GOODRICH	P	DS	Y			
NEIP007	114 GOODRICH	P	DS	Y			
NOR001	MENS SINK	P	DS	Y			

Sampling Station

ENTRY POINT - (WSF ID: 00700)

Sampling Point Inventory

<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Sampling Point Type</i>	<i>Total Coliform</i>	<i>Lead and Copper Tier</i>	<i>Asbestos</i>	<i>Stage 2 DBPR</i>
3	ENTRY POINT	A	EP				

NOTE: The information contained in this "Water Quality Monitoring Schedule" has been provided to assist owners and operators of public water systems with the water quality monitoring requirements of RCSA Section 19-13-B102. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**CONNECTICUT DEPARTMENT OF PUBLIC HEALTH - DRINKING WATER SECTION
WATER QUALITY MONITORING SCHEDULE**

NEIPSIC WOODS WATER ASSOCIATION

Town: GLASTONBURY

PWS ID: CT0540021

PWS Classification: Community

Population: 92

Treatment Plant

NEIPSIC PUMP HOUSE - (WSF ID: 657)

CLASS 1 TREATMENT PLANT

Certified Operator Information

<i>Operator Name</i>	<i>Operator Type Certification(s)</i>	<i>Certification Expiration Date</i>
LABIANCA, MICHAEL	CHIEF OPERATOR	
	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2015
	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2015
RACICOT, JEFF	ASSIGNED OPERATOR	
	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2015

Well

WELL 2 - (WSF ID: 1053)

Sampling Point Inventory

<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Sampling Point Type</i>	<i>Total Coliform</i>	<i>Lead and Copper Tier</i>	<i>Asbestos</i>	<i>Stage 2 DBPR</i>
2	WELL 2	A	RW				

Sampling Point Inventory Key:

Type: DS: Distribution System	LD: Lowest Disinfectant Residual Point in Distribution System	RW: Raw Water Source
EP: Entry Point	MD: Midpoint in Distribution System (Average Residence Time)	PC: Process Control
FC: First Customer	MR: Maximum Residence Time	
Status: A: Active	P: Proposed	I: Inactive

Contact Information

<i>Name</i>	<i>Organization</i>	<i>Address</i>	<i>Phone Email</i>	<i>Fax</i>
GREENBLAT, JEFFREY A. <i>Title:</i> PRESIDENT	NEIPSIC WOODS WATER ASSN	63 GOODRICH ROAD	203-250-5627 jgjiffy@aol.com	203-250-2886
<i>Contact Type:</i> Legal Contact		GLASTONBURY, CT 06033		
Administrative Contact				

The Drinking Water Section requires all Public Water Systems to designate one Administrative Contact and a minimum of one Owner and one Legal Contact. All changes to current contact information shall be reported to the Drinking Water Section on the Contact Information Update form.

Please note the following:

1. All water quality monitoring results submitted to the Drinking Water Section (DWS) must include the information identifying the Water System Facility and the Sampling Point.
2. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample and reported to the DWS, in accordance with RCSA 19-13-B102(e)(7)(A).
3. If a "Seasonal Collection Period" is specified, all water quality samples collected for compliance purposes must be collected during this period (i.e. Total Trihalomethanes, Total Haloacetic Acids, and Lead and Copper requirements).
4. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

NOTE: The information contained in this "Water Quality Monitoring Schedule" has been provided to assist owners and operators of public water systems with the water quality monitoring requirements of RCSA Section 19-13-B102. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

CONNECTICUT DEPARTMENT OF PUBLIC HEALTH - DRINKING WATER SECTION
WATER QUALITY MONITORING SCHEDULE

NEIPSIC WOODS WATER ASSOCIATION

Town: GLASTONBURY

PWS ID: CT0540021

PWS Classification: Community

Population: 92

5. Monthly summaries of chlorine residual, pH, orthophosphates, etc., are due no later than the ninth day of the following month.
6. Any owner or operator of a public water system must maintain records in accordance with the RCSA Section 19-13-B102(l).
7. **Please refer to the "Guide to Water Quality Monitoring Schedules" for more information on the content of this schedule.**

If you have any questions, please contact the Information Systems Unit at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: The information contained in this "Water Quality Monitoring Schedule" has been provided to assist owners and operators of public water systems with the water quality monitoring requirements of RCSA Section 19-13-B102. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.