

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM	C	564	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			188				

Towns Served: GUILFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		2 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete		
Total Haloacetic Acids (2456)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
DOGHOUSE QUIDNET CT (DH-QC)	1/1/16 - 12/31/16	8/1-8/31	Complete		
	1/1/17 - 12/31/17	8/1-8/31			
	1/1/18 - 12/31/18	8/1-8/31			
Total Trihalomethanes (2950)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
DOGHOUSE POLPIS LA (DH-PL)	1/1/16 - 12/31/16	8/1-8/31	Complete		
	1/1/17 - 12/31/17	8/1-8/31			
	1/1/18 - 12/31/18	8/1-8/31			
Total Coliform (3100)		2 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete		
	9/1/16 - 9/30/16		Complete		
	10/1/16 - 10/31/16		Complete		
	11/1/16 - 11/30/16		Complete		
	12/1/16 - 12/31/16		Complete		
	1/1/17 - 1/31/17		Complete		
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				
	7/1/17 - 7/31/17				
	8/1/17 - 8/31/17				
Lead And Copper (PBCU)		10 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30			
	1/1/19 - 12/31/21	6/1-9/30			
Physical Parameters (PPS)		2 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 1/31/17		Complete		
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM	C	564	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			188				

Towns Served: GUILFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)	2 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Physical Parameters (PPX)	2 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete

Water System Facility: LOWER PUMPHOUSE ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		Complete
	1/1/18 - 12/31/18		

Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM	C	564	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			188				

Towns Served: GUILFORD

Monitoring Requirements

Water System Facility: LOWER PUMPHOUSE ENTRY POINT (WSF ID: 00700)

Pesticides, Herbicides and PCBs-Phase II (SOC2) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Pesticides, Herbicides and PCBs-Phase V (SOC5) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Water System Facility: ENTRY POINT - UPPER (WSF ID: 00702)

Net Gross Alpha (4000) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Uranium (4006) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		Complete
	1/1/18 - 12/31/18		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM	C	564	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			188				

Towns Served: GUILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT - UPPER (WSF ID: 00702)

Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		Complete
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Water System Facility: WELL 2 (WSF ID: 724)

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: WELL 3 (WSF ID: 725)

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3 (2)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM	C	564	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			188				

Towns Served: GUILFORD

Monitoring Requirements

Water System Facility: **WELL 3 (WSF ID: 725)**

E. Coli (3014)			1 routine (RT) per month
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: **WELL 4 (WSF ID: 726)**

E. Coli (3014)			1 routine (RT) per month
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 4 (2)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: **WELL 5 (WSF ID: 727)**

E. Coli (3014)			1 routine (RT) per month
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 5 (2)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM	C	564	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			188				

Towns Served: GUILFORD

Monitoring Requirements

Water System Facility: **WELL 5 (WSF ID: 727)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: **WELL 4B (WSF ID: 728)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 4B (2)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: **WELL 6 (WSF ID: 729)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 6 (2)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Monthly Water System Facility (WSF) Level Monitoring Requirements

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM	C	564	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			188				

Towns Served: GUILFORD

Water System Facility: LOWER PUMPHOUSE ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 7/1/2013			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2016 - 8/31/2016		N
	9/1/2016 - 9/30/2016		N
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N
	12/1/2016 - 12/31/2016		
	1/1/2017 - 1/31/2017		

Water System Facility: ENTRY POINT - UPPER (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 7/1/2013			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2016 - 8/31/2016		N
	9/1/2016 - 9/30/2016		N
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N
	12/1/2016 - 12/31/2016		
	1/1/2017 - 1/31/2017		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2017	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Chlorine M&R Violation	9/1/15 - 9/30/15	3	12/17/2016		12/27/2016	
Chlorine M&R Violation	9/1/15 - 9/30/15	3	12/17/2016		12/27/2016	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DH-MT	DOGHOUSE MOHAWK TR	A	Y	1	Y	
		DH-PL	DOGHOUSE POLPIS LA	A	Y	1		Y
		DH-QC	DOGHOUSE QUIDNET CT	A	Y	1	Y	Y
		DH-WT	DOGHOUSE WAIWINET	A	Y	1		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM	C	564	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			188				

Towns Served: GUILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
		SP9	BLDG #17 UNIT #13	A	Y			
		UNIT 13	UNIT 13, BLDG 17	A	Y	1		
		UNIT 17	UNIT 117, BLDG 21	A	Y	1		
		UNIT 27	UNIT 27, BLDG 8	A	Y	1		
		UNIT 33	UNIT 33, BLDG 35	A	Y	1		
		UNIT 34	UNIT 34, BLDG 36	A	Y	1	Y	
		UNIT 36	UNIT 36, BLDG 24	A	Y	1	Y	
		UNIT 43	UNIT 43 BLDG 28	A	Y	1		
		UNIT 45	UNIT #45 KITCHEN SIN	A	Y			
		UNIT 48	UNIT 48, BLDG 25	A	Y	1	Y	
		UNIT 49	UNIT 49, BLDG 34	A	Y	1		
		UNIT 50	UNIT 50, BLDG 25	A	Y	1	Y	
		UNIT 54	UNIT 54, BLDG 23	A	Y	1	Y	
		UNIT 56	UNIT 56, BLDG 23	A	Y	1	Y	
		UNIT 7	UNIT 7, BLDG 3	A	Y	1	Y	
		UNIT 74	UNIT 74, BLDG 9	A	Y	1		
		UNIT 76	UNIT 76, BLDG 30	A	Y	1		
		UNIT 80	UNIT 80, BLDG 30	A	Y	1		
		UNIT 84	UNIT 84, BLDG 32	A	Y	1	Y	
		UNIT 97	UNIT 97, BLDG 18	A	Y	1		
		UNIT117	BLDG 21, UNIT 117 UP	A	Y			
		UNIT98	UNIT #98 KITCHEN SIN	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	LOWER PUMPHOUSE ENTRY POINT	3	ENTRY POINT	A				
00702	ENTRY POINT - UPPER	3	ENTRY POINT - UPPER	A				
50065	ATMOSPHERIC TANK - LOWER							
50067	PRESSURE TANK - LOWER							
50069	ATMOSPHERIC TANK - UPPER SYSTEM							
50071	PRESSURE TANK - UPPER SYSTEM							
53224	BOOSTER PUMPING FACILITIES - LOWER							
53232	UPPER PUMPHOUSE BOOSTERS							
58371	UPPER PUMPHOUSE TREATMENT PLANT							
58373	LOWER PUMPHOUSE TREATMENT PLANT							
724	WELL 2	2	WELL 2	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM	C	564	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		188					

Towns Served: GUILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
725	WELL 3	2	WELL 3	A				
726	WELL 4	2	WELL 4	A				
727	WELL 5	2	WELL 5	A				
728	WELL 4B	2	WELL 4B	A				
729	WELL 6	2	WELL 6	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
HARKINS, STUART A.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019 6/30/2019

Water System Facility: **UPPER PUMPHOUSE TREATMENT PLANT (WSF ID: 58371)**

Facility Classification: CLASS 1 UPPER PUMPHOUSE TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
OPERATOR ASSIGNMENT REQUIRE			

Water System Facility: **LOWER PUMPHOUSE TREATMENT PLANT (WSF ID: 58373)**

Facility Classification: CLASS 1 LOWER PUMPHOUSE TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
OPERATOR ASSIGNMENT REQUIRE			

Contact Information

Name		Organization			Job Title		
Mr. William P. Krygier		Empire Property Mgmt. Corp.			Property Manager		
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
625 East Main Street					Branford	CT	06405
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-488-9500		203-488-6290		203-488-6245	correspondence@empirepropertymanagement		

Contact Role(s): **Owner**

Name		Organization			Job Title		
Mr. Paul Mei		Quonnipaug Hills Corporation			President		
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
117 Wauwinet Trail					Guilford	CT	06437
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-457-1938				203-488-9500			

Contact Role(s): **Administrative Contact, Legal Contact**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM	C	564	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			188				

Towns Served: GUILFORD

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0606011	QUONNIPaug HILLS - SECTION I	C	27	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			9				

Towns Served: GUILFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22		

Total Coliform (3100) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Lead And Copper (PBCU) 5 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/16	6/1-9/30	Complete
	1/1/17 - 12/31/19	6/1-9/30	
	1/1/20 - 12/31/22	6/1-9/30	

Physical Parameters (PPS) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17		Complete
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Physical Parameters (PPX) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Uranium (4006) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
---	--------------------------	--------------------------	--------------------------

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0606011	QUONNIPAUG HILLS - SECTION I	C	27	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		9					

Towns Served: GUILFORD

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/18		
	1/1/19 - 12/31/21		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		Complete
	1/1/18 - 12/31/18		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		Complete
	1/1/18 - 12/31/18		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2017	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0606011	QUONNIPAUG HILLS - SECTION I	C	27	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		9					

Towns Served: GUILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
			QH001 UNIT 1 KITCHEN	A	Y	3		
			QH002 UNIT 2 KITCHEN	A	Y	3		
			QH003 UNIT 3 KITCHEN	A	Y	3		
			QH004 UNIT 4 KITCHEN	A	Y	3		
			QH005 UNIT 5 KITCHEN	A	Y	3		
			QH006 UNIT 6 KITCHEN	A	Y	3		
			QH007 UNIT 7 KITCHEN	A	Y	3		
			QH008 UNIT 8 KITCHEN	A	Y	3		
			QH009 UNIT 9 KITCHEN	A	Y	3		
	QH010 PUMP ROOM	A			3			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
52340	PRESSURE STORAGE							
52342	ATMOSPHERIC STORAGE							
730	WELL 1	2	WELL 1	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
HARKINS, STUART A.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019

Contact Information

Name		Organization			Job Title	
Mr. William P. Krygier		Empire Property Mgmt. Corp.			Property Manager	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
625 East Main Street				Branford	CT	06405
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-488-9500		203-488-6290		203-488-6245	correspondence@empirepropertymanagement	
Contact Role(s): Administrative Contact						

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0606011	QUONNIPAUG HILLS - SECTION I	C	27	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
		9						
Towns Served: GUILFORD								
Name			Organization			Job Title		
Mr. Paul Mei			Quonnipaug Hills Corporation			President		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
117 Wauwinet Trail						Guilford	CT	06437
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-457-1938				203-488-9500				
Contact Role(s): Legal Contact								
Name			Organization			Job Title		
625 Partners LLC								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
115 Boston Post Rd						Madison	CT	06443
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
Contact Role(s): Owner								
Please note the following:								
<ol style="list-style-type: none"> 1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample. 2. If a Collection Period is specified, all water quality samples must be collected during the specified period. 3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule. 								

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		13,257	1,462	38	

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/20		
Total Coliform (3100)	40 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		
Disinfectant Byproducts - TTHM & HAA5 (DBP)	4 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
KELSEYTOWN PUMP STAT (1045)	7/1/16 - 9/30/16	9/1-9/30	Complete
	10/1/16 - 12/31/16	12/1-12/31	Complete
	1/1/17 - 3/31/17	3/1-3/31	
	4/1/17 - 6/30/17	6/1-6/30	
	7/1/17 - 9/30/17	9/1-9/30	
WESTBROOK FIRE DEPT (1046)	7/1/16 - 9/30/16	9/1-9/30	Complete
	10/1/16 - 12/31/16	12/1-12/31	Complete
	1/1/17 - 3/31/17	3/1-3/31	
	4/1/17 - 6/30/17	6/1-6/30	
	7/1/17 - 9/30/17	9/1-9/30	
CTWC OFFICE, 93WMAIN (1054)	7/1/16 - 9/30/16	9/1-9/30	Complete
	10/1/16 - 12/31/16	12/1-12/31	Complete
	1/1/17 - 3/31/17	3/1-3/31	
	4/1/17 - 6/30/17	6/1-6/30	
	7/1/17 - 9/30/17	9/1-9/30	
LAGASSE SV, 2051 BPR (1058)	7/1/16 - 9/30/16	9/1-9/30	Complete
	10/1/16 - 12/31/16	12/1-12/31	Complete
	1/1/17 - 3/31/17	3/1-3/31	
	4/1/17 - 6/30/17	6/1-6/30	
	7/1/17 - 9/30/17	9/1-9/30	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Lead And Copper (PBCU) 30 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/15 - 12/31/17	6/1-9/30	
	1/1/18 - 12/31/20	6/1-9/30	

Physical Parameters (PPS) 40 routine (RT) per month

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Physical Parameters (PPX) 40 routine (RT) per month

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete

Water System Facility: **CLINTON WELL WTP ENTRY POINT (WSF ID: 00701)**

Net Gross Alpha (4000) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-CLINTON WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Uranium (4006) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-CLINTON WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-CLINTON WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-CLINTON WELL TP (3)	1/1/15 - 12/31/17		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: CLINTON WELL WTP ENTRY POINT (WSF ID: 00701)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/18 - 12/31/20		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-CLINTON WELL TP (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		Complete
	1/1/18 - 12/31/18		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-CLINTON WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-CLINTON WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-CLINTON WELL TP (3)	7/1/16 - 9/30/16		Complete
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Water System Facility: FIVE FIELDS WELL WTP ENTRY POINT (WSF ID: 00702)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **FIVE FIELDS WELL WTP ENTRY POINT (WSF ID: 00702)**

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/15 - 12/31/17		Complete
	1/1/18 - 12/31/20		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		Complete
	1/1/18 - 12/31/18		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		Complete
	1/1/18 - 12/31/18		

Water System Facility: **GUILFORD WELL WTP ENTRY POINT (WSF ID: 00703)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **GUILFORD WELL WTP ENTRY POINT (WSF ID: 00703)**

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/15 - 12/31/17		
	1/1/18 - 12/31/20		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Water System Facility: **MACKENZIE WTP ENTRY POINT (WSF ID: 00704)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MACKENZIE WTP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MACKENZIE WTP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MACKENZIE WTP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **MACKENZIE WTP ENTRY POINT (WSF ID: 00704)**

Inorganic Chemicals (IOCS) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-MACKENZIE WTP (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Nitrate And Nitrite (NOX) 1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-MACKENZIE WTP (3)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		
	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Pesticides, Herbicides and PCBs-Phase II (SOC2) 2 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-MACKENZIE WTP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Pesticides, Herbicides and PCBs-Phase V (SOC5) 2 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-MACKENZIE WTP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-MACKENZIE WTP (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		Complete
	1/1/18 - 12/31/18		

Water System Facility: **PINEWOOD WELL WTP ENTRY POINT (WSF ID: 00705)**

Net Gross Alpha (4000) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-PINEWOOD WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Uranium (4006) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-PINEWOOD WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
------------------------------------	-------------------	-------------------	-------------------

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **PINEWOOD WELL WTP ENTRY POINT (WSF ID: 00705)**

Combined Radium-226/228 (4010) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINEWOOD WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Inorganic Chemicals (IOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINEWOOD WELL TP (3)	1/1/15 - 12/31/17		Complete
	1/1/18 - 12/31/20		

Nitrate And Nitrite (NOX) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINEWOOD WELL TP (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) **2 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINEWOOD WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINEWOOD WELL TP (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Water System Facility: **SAYBROOK WELL WTP ENTRY POINT (WSF ID: 00707)**

Net Gross Alpha (4000) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Uranium (4006) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: SAYBROOK WELL WTP ENTRY POINT (WSF ID: 00707)

Gross Beta Particle Activity (4100)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Man-Made Beta Particle & Photon Emitters (4101)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Tritium (4102)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Strontium-90 (4174)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/15 - 12/31/17		Complete
	1/1/18 - 12/31/20		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: SAYBROOK WELL WTP ENTRY POINT (WSF ID: 00707)

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Water System Facility: WEISS WELL WTP ENTRY POINT (WSF ID: 00708)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/15 - 12/31/17		Complete
	1/1/18 - 12/31/20		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Pesticides, Herbicides and PCBs-Phase II (SOC2)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Pesticides, Herbicides and PCBs-Phase V (SOC5)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: WEISS WELL WTP ENTRY POINT (WSF ID: 00708)

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Water System Facility: HOLBROOK WELL WTP ENTRY POINT (WSF ID: 00710)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		
	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Organic Chemicals (VOCS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: HOLBROOK WELL WTP ENTRY POINT (WSF ID: 00710)

Organic Chemicals (VOCS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		
	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Water System Facility: MACKENZIE WATER TREATMENT PLANT (WSF ID: 103)

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CFE - MACKENZIE TP (5)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: CLINTON WELL (WSF ID: 1238)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CLINTON WELL (2)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: WEISS WELL (WSF ID: 1242)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WEISS WELL (2)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		13,257	1,462	38	

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **WEISS WELL (WSF ID: 1242)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: **GUILFORD WELL (WSF ID: 1406)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
GUILFORD WELL (2)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: **PINEWOOD WELL 2 (WSF ID: 1409)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PINEWOOD WELL 2 (2)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **PINEWOOD WELL 2 (WSF ID: 1409)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: **HOLBROOK WELL (WSF ID: 1411)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HOLBROOK WELL (2)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Out of Service
	11/1/16 - 11/30/16		Out of Service
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: **SAYBROOK WELL 1 (WSF ID: 1412)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SAYBROOK WELL 1 (2)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: **FIVE FIELDS WELL 2A (WSF ID: 1963)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
FIVE FIELD WELL NEW (2)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		13,257	1,462	38	

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **FIVE FIELDS WELL 2A (WSF ID: 1963)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: **KELSEYTOWN RESERVOIR (WSF ID: 2082)**

Color (1905)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
KELSEYTOWN RES (1)	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
KELSEYTOWN RES (1)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

2,4-D (2105)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
KELSEYTOWN RES (1)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
KELSEYTOWN RES (1)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **KELSEYTOWN RESERVOIR (WSF ID: 2082)**

Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
KELSEYTOWN RES (1)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		
LT2 - Cryptosporidium, Turbidity & E. coli (LT2)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
KELSEYTOWN RES (1)	9/1/16 - 9/30/16	9/12-9/16	
	10/1/16 - 10/31/16	10/10-10/14	
	11/1/16 - 11/30/16	11/14-11/18	
	12/1/16 - 12/31/16	12/12-12/16	
	1/1/17 - 1/31/17	1/16-1/20	
	2/1/17 - 2/28/17	2/13-2/17	
	3/1/17 - 3/31/17	3/13-3/17	
	4/1/17 - 4/30/17	4/10-4/14	
	5/1/17 - 5/31/17	5/15-5/19	
	6/1/17 - 6/30/17	6/12-6/16	
	7/1/17 - 7/31/17	7/10-7/14	
	8/1/17 - 8/31/17	8/14-8/18	
Raw Water Physical Parameters (PHYR)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
KELSEYTOWN RES (1)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
KELSEYTOWN RES (1)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **KELSEYTOWN RESERVOIR (WSF ID: 2082)**

Surface Water Pesticides (RSOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
KELSEYTOWN RES (1)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **MACKENZIE WATER TREATMENT PLANT (WSFID: 103)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 10/1/2003			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2016 - 8/31/2016	Y	Y
	9/1/2016 - 9/30/2016	Y	Y
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N
	12/1/2016 - 12/31/2016		
	1/1/2017 - 1/31/2017		

Water System Facility: **SAYBROOK WELL TREATMENT PLANT (WSFID: 104)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2016 - 8/31/2016		N
	9/1/2016 - 9/30/2016		N
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N
	12/1/2016 - 12/31/2016		
	1/1/2017 - 1/31/2017		

Water System Facility: **CLINTON WELL TREATMENT PLANT (WSFID: 106)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2016 - 8/31/2016		N
	9/1/2016 - 9/30/2016		N
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N
	12/1/2016 - 12/31/2016		
	1/1/2017 - 1/31/2017		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility: **WEISS WELL TREATMENT PLANT (WSFID: 108)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2016 - 8/31/2016		N
	9/1/2016 - 9/30/2016		N
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N
	12/1/2016 - 12/31/2016		
	1/1/2017 - 1/31/2017		

Water System Facility: **FIVE FIELDS WELL TREATMENT PLANT (WSFID: 109)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2016 - 8/31/2016		N
	9/1/2016 - 9/30/2016		N
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N
	12/1/2016 - 12/31/2016		
	1/1/2017 - 1/31/2017		

Water System Facility: **GUILFORD WELL TREATMENT PLANT (WSFID: 110)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2016 - 8/31/2016		N
	9/1/2016 - 9/30/2016		N
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N
	12/1/2016 - 12/31/2016		
	1/1/2017 - 1/31/2017		

Water System Facility: **PINEWOOD WELL TREATMENT PLANT (WSFID: 111)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2016 - 8/31/2016		N
	9/1/2016 - 9/30/2016		N
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility: **PINEWOOD WELL TREATMENT PLANT (WSFID: 111)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2004		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2016 - 12/31/2016	
		1/1/2017 - 1/31/2017	

Water System Facility: **HOLBROOK WELL TREATMENT PLANT (WSFID: 50317)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 6/1/2005		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Monitoring Compliance Status:
		8/1/2016 - 8/31/2016	N
		9/1/2016 - 9/30/2016	N
		10/1/2016 - 10/31/2016	N
		11/1/2016 - 11/30/2016	N
		12/1/2016 - 12/31/2016	
		1/1/2017 - 1/31/2017	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
WATERSHED SURVEY REPORT	3/1/2017	
CROSS CONNECTION SURVEY REPORT	3/1/2017	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	
LT2 - SUBMIT BIN CLASSIFICATION	3/30/2019	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR	
00600	DISTRIBUTION SYSTEM	1045	KELSEYTOWN PUMP STAT	A	Y			Y	
		1046	WESTBROOK FIRE DEPT	A	Y			Y	
		1050	GUILFORD HESS 1162 B	I	Y				
		1050A	GUILFORD MOBIL 1164	A	Y				
		1051	GFD TIRE, 655 BPR	A	Y				
		1052	HAMMO FORD, 191 BPR	A	Y				
		1053	HENNYPENNY 646 BPR M	A	Y				
		1054	CTWC OFFICE, 93WMAIN	A	Y				Y
		1055	GLNWD MKT, 153 GLWD	A	Y				
		1056	DUNKN DNTS, 215 BPR	A	Y				
		1057	WBK MOBIL, 779 BPR	A	Y				
		1058	LAGASSE SV, 2051 BPR	A	Y				Y
		1059	SAYBRK BSTR 1651 BPR	A	Y				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
		1060	HENNY PENNY 1090 BPR	A	Y			
		1061	CHUCKY STR 685 BPR	A	Y			
		1062	SAYBRK FORD 1 FRD DR	A	Y			
		1063	TOMS SERV	A	Y			
		1064	GRSMN CHV 300 MSX TP	A	Y			
		1065	SACHEM HD TANK	A	Y			
		1066	CLR/PWD RED PIT	A	Y			
		1067	SAYBROOK CONVALESCEN	A	Y			
		1069	DISTRIBUTION SYSTEM	A	Y			
		10801	36 WLDWD DR MAD	A			1	
		10802	15 HIGH ST CLN	A			1	
		10803	125 KELSEYTOWN RD CL	A			2	
		10804	138 N COVE RD OS	A			1	
		10805	110 N COVE RD OS	A			1	
		10806	33 FAIR ST GFD	A			1	
		10807	413 SPNCR PL RD WBK	A			2	
		10808	35 COMMERCE DR CLN	A			1	
		10809	14 BRKSD LN MAD	A			1	
		10810	34 HFD AVE OS	A			1	
		10811	15 PEARL ST GFD	A			2	
		10812	19 FAIR ST GFD	A			1	
		10813	35 SHERWOOD TER OS	A			2	
		10814	95 FAIR ST GFD	A			1	
		10815	412 SCHOOLSIDE GFD	A			2	
		10816	8 PROSPECT ST MAD	A			2	
		10817	25 ELMWOOD ST OSD	A			2	
		10818	23 ARGAIL DR WBK	A			2	
		10819	29 MENNKTSK AVE OS	A			1	
		10820	164 LIL STNRD BCH WB	A			2	
		10821	857 BPR WBK	A			3	
		10822	28 WILLARD AV OS	A			2	
		10823	26 BASSETT LN MD	A			2	
		10824	33 HIGH ST CLN	A			1	
		10825	43 NECK RD MAD	A			1	
		10826	431 SPNCR PL RD WBK	A			2	
		10827	29 IRON WORKS RD CL	A			2	
		10828	32 STATE ST GFD	A			1	
		10829	49 CHURCH ST GFD	A			2	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
		10830	82 HIGHWOODS RD GFD	A		3		
		10831	5 Sandcreek Dr, OS	A	Y			
		10832	29 Sherwood Terr, Sb	A	Y			
		10833	138 N Cove Rd, Sbk	A	Y			
		1095	4 APOGEE LANE WBK	A	Y			
		4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00701	CLINTON WELL WTP ENTRY POINT	3	EP-CLINTON WELL TP	A				
00702	FIVE FIELDS WELL WTP ENTRY POINT	3	EP-FIVE FIELDS WELL	A				
00703	GUILFORD WELL WTP ENTRY POINT	3	EP-GUILFORD WELL TP	A				
00704	MACKENZIE WTP ENTRY POINT	3	EP-MACKENZIE WTP	A				
00705	PINEWOOD WELL WTP ENTRY POINT	3	EP-PINEWOOD WELL TP	A				
00707	SAYBROOK WELL WTP ENTRY POINT	3	EP-SAYBROOK WELL TP	A				
00708	WEISS WELL WTP ENTRY POINT	3	EP-WEISS WELL TP	A				
00710	HOLBROOK WELL WTP ENTRY POINT	3	EP - HOLBROOK WELL W	A				
103	MACKENZIE WATER TREATMENT PLANT	3	EP - MACKENZIE WTP	A				
		5	CFE - MACKENZIE TP	A				
104	SAYBROOK WELL TREATMENT PLANT	3	EP SAYBROOK WELL TP	A				
106	CLINTON WELL TREATMENT PLANT	3	EP - CLINTON WELL TP	A				
108	WEISS WELL TREATMENT PLANT	3	EP WEISS WELL TP	A				
109	FIVE FIELDS WELL TREATMENT PLANT	3	EP - FIVE FIELDS TP	A				
110	GUILFORD WELL TREATMENT PLANT	3	EP -GUILFORD WELL TP	A				
111	PINEWOOD WELL TREATMENT PLANT	3	EP-PINEWOOD WELL TP	A				
1238	CLINTON WELL	2	CLINTON WELL	A				
1242	WEISS WELL	2	WEISS WELL	A				
1406	GUILFORD WELL	2	GUILFORD WELL	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW	
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
1409	PINEWOOD WELL 2	2	PINEWOOD WELL 2	A				
1411	HOLBROOK WELL	2	HOLBROOK WELL	A				
1412	SAYBROOK WELL 1	2	SAYBROOK WELL 1	A				
1963	FIVE FIELDS WELL 2A	2	FIVE FIELD WELL NEW	A				
2081	KILLINGWORTH RESERVOIR	1	RESERVOIR	A				
2082	KELSEYTOWN RESERVOIR	1	KELSEYTOWN RES	A				
30035	KILLINGWORTH RESERVOIR							
30036	KELSYTOWN RESERVOIR							
49760	INTERCONNECTION - RWA							
50317	HOLBROOK WELL TREATMENT PLANT							
50319	CEDAR CREST PUMP STATION							
50321	LONG HILL PUMP STATION							
50323	SAYBROOK PUMP STATION							
50325	BISHOP (LONG HILL) STORAGE TANK							
50327	CLAPBOARD HILL TANK							
50329	OBED HEIGHTS TANK							
50331	SACHEMS HEAD TANK							
50333	WESTBROOK TANK							
52048	MACKENZIE CLEARWELL 1							
52050	MACKENZIE CLEARWELL 2							
52052	CEDAR CREST TANK 1							
52054	CEDAR CREST TANK 2							
52056	KELSEYTOWN PUMP STATION							
52058	MACKENZIE PUMP STATION							
52060	IRON WORKS PUMP STATION							
57299	WESTBROOK LEE TANK							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
ANDREWS, PAUL M.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2018
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
FUNK, CHRISTOPHER B.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
MIEZEJESKI, WALTER B.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2018

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
SUITER, CARL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2018 12/31/2019
KEATING, MICHAEL	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2017
HAUSMAN, BRENT	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2018

Water System Facility: MACKENZIE WATER TREATMENT PLANT (WSF ID: 103)

Facility Classification: CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SCHAFFER, KRISTEN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2018
ANDREWS, PAUL M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2017 12/31/2018
GOTTSCHALL, KIMBERLY A.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2018
CIMINO, ANTHONY	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2018

Water System Facility: SAYBROOK WELL TREATMENT PLANT (WSF ID: 104)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ANDREWS, PAUL M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2017 12/31/2018
FUNK, CHRISTOPHER B.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019 6/30/2019
SUITER, CARL	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2019 12/31/2018

Water System Facility: CLINTON WELL TREATMENT PLANT (WSF ID: 106)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ANDREWS, PAUL M.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2018 6/30/2017
FUNK, CHRISTOPHER B.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019 6/30/2019
SUITER, CARL	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2019 12/31/2018

Water System Facility: WEISS WELL TREATMENT PLANT (WSF ID: 108)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ANDREWS, PAUL M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2017 12/31/2018
FUNK, CHRISTOPHER B.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019 6/30/2019

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Certified Operator Information

Water System Facility: WEISS WELL TREATMENT PLANT (WSF ID: 108)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SUITER, CARL	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2018

Water System Facility: FIVE FIELDS WELL TREATMENT PLANT (WSF ID: 109)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ANDREWS, PAUL M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2018
FUNK, CHRISTOPHER B.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
SUITER, CARL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2018
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2019

Water System Facility: GUILFORD WELL TREATMENT PLANT (WSF ID: 110)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ANDREWS, PAUL M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2018
KING, E. J.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
FUNK, CHRISTOPHER B.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
SUITER, CARL	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2018
GARRITY, MICHAEL H.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2017

Water System Facility: PINWOOD WELL TREATMENT PLANT (WSF ID: 111)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ANDREWS, PAUL M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2018
FUNK, CHRISTOPHER B.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
SUITER, CARL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2018
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2019

Water System Facility: HOLBROOK WELL TREATMENT PLANT (WSF ID: 50317)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ANDREWS, PAUL M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2018
SUITER, CARL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2018

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			13,257	1,462	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Certified Operator Information

Water System Facility: **HOLBROOK WELL TREATMENT PLANT (WSF ID: 50317)**

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2019

Contact Information

Name		Organization			Job Title		
Mr. Craig J. Patla		Connecticut Water Company			Mng of Operations		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
93 West Main Street					Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
800-428-3985	3140	860-669-7899		800-286-5700	cpatla@ctwater.com		

Contact Role(s): **Administrative Contact**

Name		Organization			Job Title		
Mr. Eric W. Thornburg		Connecticut Water Company			President/Ceo		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
93 West Main Street					Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
800-428-6008		860-669-9326		800-286-3985	ethornburg@ctwater.com		

Contact Role(s): **Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule