

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0680011</b>	<b>AQUARION WATER CO OF CT-KENT SYSTEM</b>	<b>C</b>	<b>817</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			250	93	3		

Towns Served: KENT

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>2 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/13 - 12/31/21				
<b>Total Haloacetic Acids (2456)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
59 NORTH MAIN ST. SS (02816)	1/1/16 - 12/31/16	9/8-9/14	Complete		
	1/1/17 - 12/31/17	9/8-9/14			
	1/1/18 - 12/31/18	9/8-9/14			
<b>Total Trihalomethanes (2950)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
PATCO ROUTE 7 (02813)	1/1/16 - 12/31/16	9/8-9/14	Complete		
	1/1/17 - 12/31/17	9/8-9/14			
	1/1/18 - 12/31/18	9/8-9/14			
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete		
	9/1/16 - 9/30/16		Complete		
	10/1/16 - 10/31/16		Complete		
	11/1/16 - 11/30/16		Complete		
	12/1/16 - 12/31/16		Complete		
	1/1/17 - 1/31/17				
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				
	7/1/17 - 7/31/17				
	8/1/17 - 8/31/17				
<b>Lead And Copper (PBCU)</b>		<b>10 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30			
	1/1/19 - 12/31/21	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 1/31/17				
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0680011	AQUARION WATER CO OF CT-KENT SYSTEM	C	817	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			250	93	3		

Towns Served: KENT

### Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Physical Parameters (PPS) 1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

**Physical Parameters (PPX) 1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete

**Water System Facility: WELL #2 TP ENTRY POINT (WSF ID: 00700)**

**Net Gross Alpha (4000) 1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #2 TP (3)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		

**Uranium (4006) 1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #2 TP (3)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		

**Combined Radium-226/228 (4010) 1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #2 TP (3)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		

**Inorganic Chemicals (IOCS) 1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #2 TP (3)	1/1/16 - 12/31/18		
	1/1/19 - 12/31/21		

**Nitrate And Nitrite (NOX) 1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #2 TP (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

**Pesticides, Herbicides and PCBs-Phase II (SOC2) 1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #2 TP (3)	1/1/16 - 12/31/18		
	1/1/19 - 12/31/21		

**Pesticides, Herbicides and PCBs-Phase V (SOC5) 1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #2 TP (3)	1/1/16 - 12/31/18		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0680011	AQUARION WATER CO OF CT-KENT SYSTEM	C	817	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			250	93	3		

Towns Served: KENT

## Monitoring Requirements

**Water System Facility: WELL #2 TP ENTRY POINT (WSF ID: 00700)**

**Pesticides, Herbicides and PCBs-Phase V (SOC5) 1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/19 - 12/31/21		

**Organic Chemicals (VOCS) 1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #2 TP (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

**Water System Facility: WELL #3 TP ENTRY POINT (WSF ID: 00701)**

**Net Gross Alpha (4000) 1 routine (RT) per six years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #3 TP (3)	1/1/14 - 12/31/19		

**Uranium (4006) 1 routine (RT) per six years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #3 TP (3)	1/1/14 - 12/31/19		

**Combined Radium-226/228 (4010) 1 routine (RT) per six years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #3 TP (3)	1/1/14 - 12/31/19		

**Inorganic Chemicals (IOCS) 1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #3 TP (3)	1/1/16 - 12/31/18		
	1/1/19 - 12/31/21		

**Nitrate And Nitrite (NOX) 1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #3 TP (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

**Pesticides, Herbicides and PCBs-Phase II (SOC2) 1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #3 TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

**Pesticides, Herbicides and PCBs-Phase V (SOC5) 1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #3 TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

**Organic Chemicals (VOCS) 1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #3 TP (3)	1/1/16 - 12/31/16		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0680011</b>	<b>AQUARION WATER CO OF CT-KENT SYSTEM</b>	C	817	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			250	93	3		

Towns Served: KENT

### Monitoring Requirements

Water System Facility: **WELL #3 TP ENTRY POINT (WSF ID: 00701)**

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Water System Facility: **WELL #2 (WSF ID: 990)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #2 (2)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Water System Facility: **WELL #3 (WSF ID: 991)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #3 (2)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **WELL #2 TP ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine Residual, Free	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2003	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2016 - 8/31/2016		N
	9/1/2016 - 9/30/2016		N
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N
	12/1/2016 - 12/31/2016		
	1/1/2017 - 1/31/2017		

Water System Facility: **WELL #3 TP ENTRY POINT (WSFID: 00701)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine Residual, Free	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2003	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2016 - 8/31/2016		N
	9/1/2016 - 9/30/2016		N

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0680011</b>	<b>AQUARION WATER CO OF CT-KENT SYSTEM</b>	C	817	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			250	93	3		

Towns Served: KENT

## Water System Facility: WELL #3 TP ENTRY POINT (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine Residual, Free	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2003	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N
	12/1/2016 - 12/31/2016		
	1/1/2017 - 1/31/2017		

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2016	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
00600	DISTRIBUTION SYSTEM	02804	KENT TANKS SS	A	Y			
		02812	KENT FABRICS RT 7	A	Y			
		02813	PATCO ROUTE 7	A	Y			Y
		02815	KENT TANK SS	A	Y			
		02816	59 NORTH MAIN ST. SS	A				Y
		4	DISTRIBUTION SYSTEM	A		Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB5701	46 N MAIN KENT	A				3
		PB5704	92 N MAIN KENT	A				3
		PB5706	10 S MAIN KENT	A				3
		PB5707	41 ELIZABETH STREET	A		Y		3
		PB5708	9 MAPLE ST EXT KENT	A				3
		PB5709	43 MAPLE ST EXT KENT	A				3
		PB5710	30 ELIZBETH KENT	A				3
		PB5836	80 N MAIN #28 KENT	A				3
		PB5966	4 BLUFF KENT	A				3
		PB5967	6 BLUFF KENT	A				3
		PB5968	8 BLUFF KENT	A				3
		PB5969	1 BRIDGE KENT	A				3
		PB5971	52 ELIZABETH KENT	A				3
		PB5972	14 JUDD KENT	A				3
		PB5973	8 JUDD KENT	A				3
		PB6347	19 MAPLE ST	A			Y	3
		PB6348	27 ELIZABETH STREET	A			Y	3

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source	
<b>CT0680011</b>	<b>AQUARION WATER CO OF CT-KENT SYSTEM</b>	<b>C</b>	<b>817</b>	<b>P</b>	<b>GW</b>	
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		250	93	3		

Towns Served: KENT

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
		PB6349	27 LANE STREET	A	Y	3		
		PB7042	23 LANE STREET	A	Y	3		
		PB7043	8 ELIZABETH STREET	A	Y	3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	WELL #2 TP ENTRY POINT	3	EP - WELL #2 TP	A				
00701	WELL #3 TP ENTRY POINT	3	EP - WELL #3 TP	A				
1609	WELL #3 TREATMENT PLANT							
510	WELL #2 TREATMENT PLANT							
56640	CONCRETE ATMOSPHERIC STORAGE TANK							
990	WELL #2	2	WELL #2	A				
991	WELL #3	2	WELL #3	A				

## Certified Operator Information

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Facility Classification:** DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LEONE, GARY J.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2018

**Water System Facility: WELL #2 TREATMENT PLANT (WSF ID: 510)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
TIEDMANN, WERNER W.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2017
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
MUNSON, BRIAN C.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2017
PASSECK, PETER	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2018
FREDERICKS, WILLIAM L.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2017
KUSHWARA, CHRISTOPHER J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2018
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2017

**Water System Facility: WELL #3 TREATMENT PLANT (WSF ID: 1609)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
TIEDMANN, WERNER W.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2017
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
MUNSON, BRIAN C.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2017
PASSECK, PETER	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2018

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0680011</b>	<b>AQUARION WATER CO OF CT-KENT SYSTEM</b>	<b>C</b>	<b>817</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			250	93	3		

Towns Served: KENT

## Certified Operator Information

Water System Facility: **WELL #3 TREATMENT PLANT (WSF ID: 1609)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
FREDERICKS, WILLIAM L.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2017
KUSHWARA, CHRISTOPHER J.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2017
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2018

## Contact Information

Name		Organization		Job Title		
<b>Mr. John P. Walsh</b>		Aquarion Water Company		Vice President		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
600 Lindley Street				Bridgeport	CT	06606
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-337-5852		203-337-5839		781-413-6175	jwalsh@aquarionwater.com	

Contact Role(s): **Administrative Contact, Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0680021	KENT SCHOOL CORP (VALLEY CAMPUS)	C	722	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			22	8			

Towns Served: KENT

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		
<b>Lead And Copper (PBCU)</b>	<b>10 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/16	6/1-9/30	Complete
	1/1/17 - 12/31/19	6/1-9/30	
	1/1/20 - 12/31/22	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		
<b>Physical Parameters (PPX)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0680021	KENT SCHOOL CORP (VALLEY CAMPUS)	C	722	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			22	8			

Towns Served: KENT

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/15 - 12/31/17		Complete
	1/1/18 - 12/31/20		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0680021</b>	<b>KENT SCHOOL CORP (VALLEY CAMPUS)</b>	C	722	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			22	8			

Towns Served: KENT

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
<b>Start Date:</b> 1/1/2003		<b>Compliance History:</b>	<b>Monitoring Compliance Status:</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		8/1/2016 - 8/31/2016	Y
		9/1/2016 - 9/30/2016	N
		10/1/2016 - 10/31/2016	N
		11/1/2016 - 11/30/2016	N
		12/1/2016 - 12/31/2016	
		1/1/2017 - 1/31/2017	

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR CERTIFICATION FORM	8/9/2016	6/22/2016
CROSS CONNECTION SURVEY REPORT	3/1/2017	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
00600	DISTRIBUTION SYSTEM	001	DINING HALL	A	Y	N		
		002	FIELD DORM MENS	A		N		
		003	CASE DORM STAFF BTH	A		N		
		004	ADMIN BLD MENS RM	A		N		
		005	S.H. KITCHEN 4 FL	A		N		
		006	M.D. 1ST SLOP	A		N		
		007	M.D.S. 1ST SLOP	A		N		
		008	N.D. 1ST SLOP	A		N		
		009	SCI LST MENS RM	A		N		
		010	FOLEY MENS ROOM	A		N		
		4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
392	KENT SCHOOL TREATMENT PLANT							
45859	ATMOSPHERIC TANK 1							
45861	ATMOSPHERIC TANK 2							
45863	PRESSURE TANK							
992	WELL 2	2	WELL 2	A				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0680021</b>	<b>KENT SCHOOL CORP (VALLEY CAMPUS)</b>	<b>C</b>	<b>722</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			22	8			

Towns Served: KENT

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
993	WELL 1	2	WELL 1	A				

## Certified Operator Information

Water System Facility: **KENT SCHOOL TREATMENT PLANT (WSF ID: 392)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
TOMLINSON, JONATHAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2017
KNIFFEN, PETER	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2017

## Contact Information

Name		Organization			Job Title		
<b>Mr. Joseph Wolinski</b>		Kent School Corp.			Facilities Director		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
P.O. Box 2006					Kent	CT	06757
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-927-3160		860-927-1376		203-927-4801	WOLINSKI@KENT-SCHOOL.EDU		

Contact Role(s): **Administrative Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0680031</b>	<b>THE MARVELWOOD SCHOOL</b>	C	220	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
476 SKIFF MOUNTAIN RD			8	4			

Towns Served: KENT

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22				
<b>Total Haloacetic Acids (2456)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
SCHOOL HOUSE BATH (MS007)	1/1/16 - 12/31/16	8/1-8/31	Complete		
	1/1/17 - 12/31/17	8/1-8/31			
	1/1/18 - 12/31/18	8/1-8/31			
<b>Total Trihalomethanes (2950)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
FACULTY HOUSE KITCHEN SINK (MS018)	1/1/16 - 12/31/16	8/10-8/16	Complete		
	1/1/17 - 12/31/17	8/10-8/16			
	1/1/18 - 12/31/18	8/10-8/16			
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete		
	9/1/16 - 9/30/16		Complete		
	10/1/16 - 10/31/16		Complete		
	11/1/16 - 11/30/16		Complete		
	12/1/16 - 12/31/16		Complete		
	1/1/17 - 1/31/17				
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				
	7/1/17 - 7/31/17				
	8/1/17 - 8/31/17				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/15 - 12/31/17	6/1-9/30			
	1/1/18 - 12/31/20	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 1/31/17				
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0680031</b>	<b>THE MARVELWOOD SCHOOL</b>	<b>C</b>	<b>220</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
476 SKIFF MOUNTAIN RD			8	4			

Towns Served: KENT

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Physical Parameters (PPS)** **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

**Physical Parameters (PPX)** **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

**Net Gross Alpha (4000)** **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

**Uranium (4006)** **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

**Combined Radium-226/228 (4010)** **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

**Inorganic Chemicals (IOCS)** **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

**Nitrate And Nitrite (NOX)** **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

**Pesticides, Herbicides and PCBs - Phase II & V (SOCS)** **1 (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16	1/1-12/31	Waiver

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0680031</b>	<b>THE MARVELWOOD SCHOOL</b>	<b>C</b>	<b>220</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
476 SKIFF MOUNTAIN RD			8	4			
Towns Served: KENT							

### Monitoring Requirements

#### Water System Facility: ENTRY POINT (WSF ID: 00700)

#### Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

#### Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

#### Water System Facility: WELL 4 (WSF ID: 129)

#### E. Coli (3014) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 4 (2)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
8/1/17 - 8/31/17			

#### Water System Facility: WELL 5 (WSF ID: 130)

#### E. Coli (3014) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 5 (2)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0680031</b>	<b>THE MARVELWOOD SCHOOL</b>	C	220	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
476 SKIFF MOUNTAIN RD			8	4			

Towns Served: KENT

## Monitoring Requirements

Water System Facility: **WELL 5 (WSF ID: 130)**

<b>E. Coli (3014)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	8/1/17 - 8/31/17		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine Residual, Free	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2003	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2016 - 8/31/2016		N
	9/1/2016 - 9/30/2016		N
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N
	12/1/2016 - 12/31/2016		
	1/1/2017 - 1/31/2017		

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2017	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		MS002	SUMMIT DORM	A	Y	2	
		MS003	STERLING DORM	A	Y	2	
		MS004	LAKE DORM	A	Y	2	
		MS005	STAR DORM	A	Y	2	
		MS006	DINING HALL BATHROOM	A	Y	2	
		MS007	SCHOOL HOUSE BATH	A	Y	2	Y
		MS008	GYM GIRLS BATH 1	A	Y	N	
		MS009	KITCHEN HANDWASH SIN	A	Y	2	
		MS010	KITCHEN PREP SINK 1	A	Y	2	
		MS011	KITCHEN PREP SINK 2	A	Y	2	
		MS012	BUSINESS/MED BUILDIN	A	Y	2	
		MS013	SCHOOL HOUSE F BATH	A	Y	2	
		MS014	SCHOOL HOUSE M BATH	A	Y	2	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0680031</b>	<b>THE MARVELWOOD SCHOOL</b>	<b>C</b>	<b>220</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
476 SKIFF MOUNTAIN RD			8	4			
Towns Served: KENT							

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
		MS015	GYM GIRLS BATH 2	A	Y	N		
		MS016	GYM GIRLS LOCKER ROO	A	Y	N		
		MS017	PAC CTR BATH	A	Y	2		
		MS018	FACULTY HOUSE KITCHE	A	Y	2		Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
		MS001	PUMP HOUSE	A				
129	WELL 4	2	WELL 4	A				
130	WELL 5	2	WELL 5	A				
51455	CONCRETE ATMOSPHERIC TANK							
566	WELL 4 & 5 TREATMENT STATION							
59004	PUMP STATION							
59006	BLADDER TANKS							

## Certified Operator Information

**Water System Facility:** WELL 4 & 5 TREATMENT STATION (WSF ID: 566)

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BLACK, RON W.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2017
LORUSSO, LEONARD	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2019
GIORDANO, DAVID S.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2017
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2017

## Contact Information

Name		Organization			Job Title			
<b>Mr. Richard Becker</b>		Marvelwood School			Business Manager			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
476 Skiff Mountain Road						Kent	CT	06757
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-927-2065		860-927-2012			richard.becker@marvelwood.org			
Contact Role(s): <b>Administrative Contact, Legal Contact</b>								

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0680082</b>	<b>SOUTH KENT SCHOOL</b>	<b>C</b>	<b>228</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
40 BULLS BRIDGE RD			42				
Towns Served: KENT							

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/13 - 12/31/21				
<b>Total Haloacetic Acids (2456)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
GARF.UPST.DORM BATH (SKS004)	1/1/16 - 12/31/16	9/1-9/30	Complete		
	1/1/17 - 12/31/17	9/1-9/30			
	1/1/18 - 12/31/18	9/1-9/30			
<b>Total Trihalomethanes (2950)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
FACULTY HOUSE #1 KITCHEN (SKS011)	1/1/16 - 12/31/16	9/1-9/30	Complete		
	1/1/17 - 12/31/17	9/1-9/30			
	1/1/18 - 12/31/18	9/1-9/30			
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete		
	9/1/16 - 9/30/16		Complete		
	10/1/16 - 10/31/16		Complete		
	11/1/16 - 11/30/16				
	12/1/16 - 12/31/16				
	1/1/17 - 1/31/17				
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				
	7/1/17 - 7/31/17				
	8/1/17 - 8/31/17				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/15 - 12/31/17	6/1-9/30			
	1/1/18 - 12/31/20	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 1/31/17				
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0680082</b>	<b>SOUTH KENT SCHOOL</b>	C	228	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
40 BULLS BRIDGE RD			42				

Towns Served: KENT

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Physical Parameters (PPX)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/15 - 12/31/17		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0680082</b>	<b>SOUTH KENT SCHOOL</b>	C	228	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
40 BULLS BRIDGE RD			42				
Towns Served: KENT							

## Monitoring Requirements

Water System Facility: <b>ENTRY POINT (WSF ID: 00700)</b>							
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>				<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
		1/1/18 - 12/31/20					
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>				<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
ENTRY POINT (3)		1/1/15 - 12/31/17					
		1/1/18 - 12/31/20					
<b>Organic Chemicals (VOCS)</b>				<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
ENTRY POINT (3)		1/1/14 - 12/31/16				Complete	
		1/1/17 - 12/31/19					
		1/1/20 - 12/31/22					

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: <b>ENTRY POINT (WSFID: 00700)</b>							
<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>			<b>Samples Req/Month</b>		
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.45 MG/L			Daily		
<b>Start Date:</b> 12/1/2014		<b>Compliance History:</b>		<b>Operating Limit</b>	<b>Monitoring</b>		
		<b>Monitoring Period</b>		<b>Compliance Status:</b>	<b>Compliance Status:</b>		
		8/1/2016 - 8/31/2016			N		
		9/1/2016 - 9/30/2016			N		
		10/1/2016 - 10/31/2016			N		
		11/1/2016 - 11/30/2016			N		
		12/1/2016 - 12/31/2016					
		1/1/2017 - 1/31/2017					

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2011	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2014	
CROSS CONNECTION SURVEY REPORT	3/1/2017	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	

## Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Total Coliform MCL Violation	9/1/14 - 9/30/14	2	11/14/2014		11/24/2014	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Stage 2 Asbestos DBPR</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0680082</b>	<b>SOUTH KENT SCHOOL</b>	<b>C</b>	<b>228</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
40 BULLS BRIDGE RD			42				
Towns Served: KENT							

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		SKS001	MN.BLD.SM KITCH.SINK	A	Y		Y	
		SKS002	MN.BLD.DISH WASH SK.	A	Y			
		SKS003	MN.BLD.BASEM.BATH S.	A	Y			
		SKS004	GARF.UPST.DORM BATH	A	Y	2		Y
		SKS005	BRINGH.LOBBY MENS R.	A	Y			
		SKS006	MCCOUN ART RM.SINK	A	Y	2		
		SKS007	2ND FL.MAINT.SH.SINK	A	Y			
		SKS008	BARTL.DORM BATH SINK	A		2		
		SKS009	GILDER HOUSE	A		2		
		SKS010	WOODWD.D.3RD.FL.BAT H	A		2		
		SKS011	FACULTY HOUSE #1 KIT	A		N		Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
37258	ATMOSPHERIC TANK							
502	WELL #1 TREATMENT PLANT							
59284	HYDROPNEUMATIC CONTACT TANK							
995	WELL #1	2	WELL #1	A				

## Certified Operator Information

**Water System Facility:** WELL #1 TREATMENT PLANT (WSF ID: 502)

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
CARLSON, BRUCE	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2019

## Contact Information

Name		Organization			Job Title	
<b>Mr. Andrew J. Vadnais</b>					Secretary/Headmaster	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
South Kent School		40 Bulls Bridge Road		South Kent	CT	06785
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-927-2000	218			860-927-0054	vadnaisa@southkentschool.org	
Contact Role(s): <b>Administrative Contact, Legal Contact</b>						

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT0680082</b>	<b>SOUTH KENT SCHOOL</b>	<b>C</b>	<b>228</b>	<b>P</b>	<b>GW</b>			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
40 BULLS BRIDGE RD		42						
Towns Served: KENT								
Name			Organization			Job Title		
<b>South Kent School Corporation</b>								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
40 Bulls Bridge Rd						South Kent	CT	06785
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
Contact Role(s): <b>Owner</b>								
Name			Organization			Job Title		
<b>Mr. Jeffrey G. Rosenberg</b>			South Kent School Corp			President		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
40 Bulls Bridge Rd						South Kent	CT	06785
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
Contact Role(s): <b>Owner</b>								
<b>Please note the following:</b>								
1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.								
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.								
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.								

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0681061	KENT SCHOOL (MAINTENANCE WELL)	C	30	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			9	2			

Towns Served: KENT

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete		
	9/1/16 - 9/30/16		Complete		
	10/1/16 - 10/31/16		Complete		
	11/1/16 - 11/30/16		Complete		
	12/1/16 - 12/31/16				
	1/1/17 - 1/31/17				
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				
	7/1/17 - 7/31/17				
	8/1/17 - 8/31/17				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/16	6/1-9/30	Complete		
	1/1/17 - 12/31/19	6/1-9/30			
	1/1/20 - 12/31/22	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 1/31/17				
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				
	7/1/17 - 7/31/17				
	8/1/17 - 8/31/17				
<b>Physical Parameters (PPX)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete		
	9/1/16 - 9/30/16		Complete		
	10/1/16 - 10/31/16		Complete		
	11/1/16 - 11/30/16		Complete		
	12/1/16 - 12/31/16				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0681061	KENT SCHOOL (MAINTENANCE WELL)	C	30	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			9	2			

Towns Served: KENT

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0681061</b>	<b>KENT SCHOOL (MAINTENANCE WELL)</b>	<b>C</b>	<b>30</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			9	2			

Towns Served: KENT

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2013	
SUBMIT CCR CERTIFICATION FORM	8/9/2016	6/22/2016
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2016	
CROSS CONNECTION SURVEY REPORT	3/1/2017	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	001	KITCHENET	A	Y	N		
		002	MENS ROOM	A		N		
		003	WOMENS ROOM	A		N		
		004	SLOP SINK	A		N		
		005	TOMS SHOP	A		N		
		4	GENERIC DISTRIBUTION	A		Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
UPSTREAM	WITHIN 5 SERVICE CON	A						
00700	ENTRY POINT	3	ENTRY POINT	A				
1674	WELL 3	2	WELL 3	A				
45867	BLADDER TANK							
45869	BLADDER TANK 2							

## Certified Operator Information

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Facility Classification:** SMALL WATER SYSTEM

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
TOMLINSON, JONATHAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2017
KNIFFEN, PETER	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2017

## Contact Information

Name		Organization			Job Title		
<b>Mr. Joseph Wolinski</b>		Kent School Corp.			Facilities Director		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
P.O. Box 2006					Kent	CT	06757
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-927-3160		860-927-1376		203-927-4801	WOLINSKI@KENT-SCHOOL.EDU		
Contact Role(s):		<b>Administrative Contact</b>					

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0681061</b>	<b>KENT SCHOOL (MAINTENANCE WELL)</b>	<b>C</b>	<b>30</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			<b>9</b>	<b>2</b>			

Towns Served: KENT

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0688011</b>	<b>BROOKWOODS II</b>	C	120	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
433 KENT CORNWALL RD			31				

Towns Served: KENT

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/13 - 12/31/21				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete		
	9/1/16 - 9/30/16		Complete		
	10/1/16 - 10/31/16		Complete		
	11/1/16 - 11/30/16		Complete		
	12/1/16 - 12/31/16				
	1/1/17 - 1/31/17				
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				
	7/1/17 - 7/31/17				
	8/1/17 - 8/31/17				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/16	6/1-9/30	Complete		
	1/1/17 - 12/31/19	6/1-9/30			
	1/1/20 - 12/31/22	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 1/31/17				
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				
	7/1/17 - 7/31/17				
	8/1/17 - 8/31/17				
<b>Physical Parameters (PPX)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete		
	9/1/16 - 9/30/16		Complete		
	10/1/16 - 10/31/16		Complete		
	11/1/16 - 11/30/16		Complete		
	12/1/16 - 12/31/16				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0688011</b>	<b>BROOKWOODS II</b>	C	120	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
433 KENT CORNWALL RD			31				

Towns Served: KENT

### Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0688011</b>	<b>BROOKWOODS II</b>	<b>C</b>	<b>120</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
433 KENT CORNWALL RD			31				
Towns Served: KENT							

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	
CROSS CONNECTION EXEMPTION	3/1/2020	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		BRO-1	HOUSE 30-SINK	A	Y			
		BRO-2	DISTRIBUTION SAMPLE	A			1	
		BRO-3	HOUSE 3-SINK	A			1	
		BRO-4	HOUSE 12-SINK	A			1	
		BRO-5	HOUSE 16-SINK	A			1	
		BRO-6	HOUSE 20-SINK	A			1	
		BRO-7	HOUSE 23-SINK	A			1	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1672	WELL 1	2	WELL 1	A				
1673	WELL 2	2	WELL 2	A				
44913	ATMOSPHERIC TANK							
44915	HYDROPNEUMATIC TANK							

## Certified Operator Information

<b>Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)</b>			
<b>Facility Classification:</b> SMALL WATER SYSTEM			
<b>Operator Name</b>	<b>Operator Type</b>	<b>Certification(s)</b>	<b>Certification Expiration</b>
TOMASCAK, THOMAS S.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2018
DONECKER, MARK	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2017
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2017

## Contact Information

Name		Organization			Job Title	
<b>Mr. George Bentley</b>		Brookwoods li Association, Inc			Treasurer	
Mailing Address Line One		Mailing Address Line Two			City	State
433 Kent Cornwall Road #23					Kent	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
845-832-6601	18			860-927-4966	treasurer.brookwoods@gmail.com	
Contact Role(s): <b>Administrative Contact</b>						

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT0688011</b>	<b>BROOKWOODS II</b>	<b>C</b>	<b>120</b>	<b>P</b>	<b>GW</b>			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
433 KENT CORNWALL RD			31					
Towns Served: KENT								
Name			Organization			Job Title		
<b>Brookwoods li</b>								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
Emergency Contact						Emergency Contact	CT	06000
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-927-4966								
Contact Role(s): <b>Owner</b>								

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**