

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0760014	CAMP LAURELWOOD	NC	400	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
463 SUMMER HILL ROAD				1			
Towns Served: MADISON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				

Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				

Physical Parameters (PPX)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete		
	1/1/17 - 12/31/17				
	1/1/18 - 12/31/18				

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Physical Parameters M&R Violation	4/1/16 - 6/30/16	3	10/4/2017	11/1/2016	10/14/2017	11/17/2016
Total Coliform M&R Violation	4/1/16 - 6/30/16	3	11/23/2017		12/3/2017	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21322	WELL #2	2	WELL	A				
51858	WELL #3	2	WELL #3	A				
51860	WELL #4	2	WELL #4	A				
51862	WELL #5	2	WELL #5	A				
57515	ATMOSPHERIC STORAGE							

Contact Information

Name	Organization	Job Title
Ms. Ruth Ann Ornstein Msw	Camp Laurelwood	Executive Director

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0760014	CAMP LAURELWOOD	NC	400	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
463 SUMMER HILL ROAD				1				
Towns Served: MADISON								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
463 Summer Hill Road						Madison	CT	06443
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-421-3736		203-421-3570						

Contact Role(s): **Administrative Contact, Legal Contact**

- Please note the following:**
1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
 2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
 3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0760024	CIRCLE PIZZA	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1278 DURHAM ROAD				1			
Towns Served: MADISON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		
	1/1/17 - 3/31/17		Complete		
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				

Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17		Complete		
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				

Physical Parameters (PPX)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete		
	1/1/17 - 12/31/17				
	1/1/18 - 12/31/18				

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Physical Parameters M&R Violation	4/1/04 - 6/30/04	2	11/5/2004		11/15/2004	
Physical Parameters M&R Violation	1/1/04 - 3/31/04	2	11/5/2004		11/15/2004	
Total Coliform M&R Violation	4/1/04 - 6/30/04	2	11/5/2004		11/15/2004	
Total Coliform M&R Violation	1/1/04 - 3/31/04	2	11/5/2004		11/15/2004	
Distribution Color MCL Violation	10/1/04 - 12/31/04	2	4/22/2005		5/2/2005	
Nitrate And Nitrite M&R Violation	1/1/04 - 12/31/04	2	6/25/2005		7/5/2005	
Physical Parameters M&R Violation	7/1/04 - 9/30/04	3	1/10/2006		1/20/2006	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform</i>	<i>Lead and Copper</i>	<i>Stage 2</i>
					<i>Rule</i>	<i>Rule Tier</i>	<i>Asbestos DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		UPSTREAM	WITHIN 5 SERVICE CON	A			
00700	ENTRY POINT	3	ENTRY POINT	A			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0760024	CIRCLE PIZZA	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1278 DURHAM ROAD				1			
Towns Served: MADISON							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
21323	WELL	2	WELL	A				

Contact Information

Name			Organization			Job Title			
Mr. Robert P. Sassi			Circle Pizza			Owner			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
1278 Durham Rd						North Madison		CT	06443
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
				860-663-2694					
Contact Role(s): Administrative Contact, Owner									

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0760034	KLEINS GOLF RANGE	NC	31	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
391 DURHAM ROAD				1			
Towns Served: MADISON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		
	1/1/17 - 3/31/17		Complete		
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				

Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17				
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				

Physical Parameters (PPX)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete		
	1/1/17 - 12/31/17		Complete		
	1/1/18 - 12/31/18				

Water System Facility: DUG WELL (WSF ID: 21324)

E. Coli (3014)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELL (2)	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		
	1/1/17 - 3/31/17		Complete		
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21324	DUG WELL	2	WELL	A				
48154	ULTRAVIOLET DISINFECTION							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0760034	KLEINS GOLF RANGE	NC	31	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
391 DURHAM ROAD				1			
Towns Served: MADISON							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Stage 2 Asbestos DBPR
56262	PRESSURE STORAGE						

Contact Information

Name		Organization			Job Title		
Mr. David Klein		Klein Family Lp			Member		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
391 Durham Road					Madison	CT	06443
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-245-1139			860-908-3176	860-572-9744	dklein@kleinsgolf.com		

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Name		Organization			Job Title		
Kleins Golf Range LLC / Klein Family Lp							
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
391 Durham Road					Madison	CT	06443
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-245-1139							

Contact Role(s): **Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0769153	CHRIST CHAPEL	NC	30	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1185 DURHAM ROAD			1				
Towns Served: MADISON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16			Complete
	10/1/16 - 12/31/16			Complete
	1/1/17 - 3/31/17			
	4/1/17 - 6/30/17			
	7/1/17 - 9/30/17			

Physical Parameters (PPS)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17			
	4/1/17 - 6/30/17			
	7/1/17 - 9/30/17			

Physical Parameters (PPX)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16			Complete
	10/1/16 - 12/31/16			Complete

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/16 - 12/31/16			Complete
	1/1/17 - 12/31/17			
	1/1/18 - 12/31/18			

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION EXEMPTION	3/1/2016	
RESPOND TO SANITARY SURVEY	12/25/2016	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	001	NEW LADIES ROOM	A		2		
		002	NEW MENS ROOM	A		2		
		003	UP STAIRS KIT. SINK	A	Y	2		
		004	DOWNSTAIRS KITCHEN	A		2		
		005	JANITOR CLOSET	A		2		
		4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
UPSTREAM	WITHIN 5 SERVICE CON	A						
00700	ENTRY POINT	3	ENTRY POINT	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0769153	CHRIST CHAPEL	NC	30	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1185 DURHAM ROAD			1				
Towns Served: MADISON							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
1029	CHRIST CHAPEL TREATMENT STATION							
10758	CHRIST CHAPEL WELL	2	CHRIST CHAPEL WELL	A				
50174	BLADDER STORAGE TANK							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)			
Facility Classification: DISTRIBUTION SYSTEM			
Operator Name	Operator Type	Certification(s)	Certification Expiration
BARRIS, DAVID C.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2017
FILANDA, MICHAEL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019

Contact Information

Name		Organization			Job Title		
Lisa Schickler		Christ Chapel			Financial Asst		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
1155 Durham Road					Madison	CT	06443
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-421-4667							
Contact Role(s): Administrative Contact							

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0769204	CHURCH OF LATTER DAY SAINTS, MADISON	NC	172	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
275 WARPAS ROAD				1			
Towns Served: MADISON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		
	1/1/17 - 3/31/17		Complete		
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				

Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17		Complete		
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				

Physical Parameters (PPX)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete		
	1/1/17 - 12/31/17		Complete		
	1/1/18 - 12/31/18				

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage 2 DBPR</i>
00501	WELL #1	2	WELL #1	A				
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
59535	HYDROPNEUMATIC TANK							

Contact Information

Name			Organization			Job Title			
Mr. Roy B. McDaniel			Natural Resources-Special Proj			Manager			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
50 E. North Temple St			12Th Floor			Salt Lake City		UT	84150
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
801-240-4656		801-240-4005			mcdanielrb@ldschurch.org				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0769204	CHURCH OF LATTER DAY SAINTS, MADISON	NC	172	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
275 WARPAS ROAD				1				
Towns Served: MADISON								
Contact Role(s): Legal Contact								
Name			Organization			Job Title		
Mr. William A. Puida			Hartford Connecticut Fm Group			Facility Manager		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
130 South Street						Cromwell	CT	06416
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-635-4035		860-635-4036			puidawa@ldschurch.org			
Contact Role(s): Administrative Contact								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule