

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)	3 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/20		
Total Coliform (3100)	60 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		
Disinfectant Byproducts - TTHM & HAA5 (DBP)	8 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
9 CAMP MEETING RD (BIRCHMTN)	7/1/16 - 9/30/16	7/1-7/31	Complete
	10/1/16 - 12/31/16	10/1-10/31	Complete
	1/1/17 - 3/31/17	1/1-1/31	Complete
	4/1/17 - 6/30/17	4/1-4/30	
77 TOLLAND TPKE (CONYERS)	7/1/17 - 9/30/17	7/1-7/31	
	7/1/16 - 9/30/16	7/1-7/31	Complete
	10/1/16 - 12/31/16	10/1-10/31	Complete
	1/1/17 - 3/31/17	1/1-1/31	Complete
125 SPRING ST (GHWTP)	4/1/17 - 6/30/17	4/1-4/30	
	7/1/17 - 9/30/17	7/1-7/31	
	7/1/16 - 9/30/16	7/1-7/31	Complete
	10/1/16 - 12/31/16	10/1-10/31	Complete
87 HERCULES DRIVE (NIKETYKES)	1/1/17 - 3/31/17	1/1-1/31	Complete
	4/1/17 - 6/30/17	4/1-4/30	
	7/1/17 - 9/30/17	7/1-7/31	
	7/1/16 - 9/30/16	7/1-7/31	Complete
265 E MIDDLE TPKE (POLICEDEPT)	10/1/16 - 12/31/16	10/1-10/31	Complete
	1/1/17 - 3/31/17	1/1-1/31	Complete
	4/1/17 - 6/30/17	4/1-4/30	
	7/1/17 - 9/30/17	7/1-7/31	
	7/1/16 - 9/30/16	7/1-7/31	Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Disinfectant Byproducts - TTHM & HAA5 (DBP)		8 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	10/1/16 - 12/31/16	10/1-10/31	Complete	
	1/1/17 - 3/31/17	1/1-1/31	Complete	
	4/1/17 - 6/30/17	4/1-4/30		
	7/1/17 - 9/30/17	7/1-7/31		
701 PORTER ST (ROCKLEDGE)	7/1/16 - 9/30/16	7/1-7/31	Complete	
	10/1/16 - 12/31/16	10/1-10/31	Complete	
	1/1/17 - 3/31/17	1/1-1/31	Complete	
	4/1/17 - 6/30/17	4/1-4/30		
	7/1/17 - 9/30/17	7/1-7/31		
41 CENTER STREET (TNHALL)	7/1/16 - 9/30/16	7/1-7/31	Complete	
	10/1/16 - 12/31/16	10/1-10/31	Complete	
	1/1/17 - 3/31/17	1/1-1/31	Complete	
	4/1/17 - 6/30/17	4/1-4/30		
	7/1/17 - 9/30/17	7/1-7/31		
20 WOODHAVEN RD (UPGLASTON)	7/1/16 - 9/30/16	7/1-7/31	Complete	
	10/1/16 - 12/31/16	10/1-10/31	Complete	
	1/1/17 - 3/31/17	1/1-1/31	Complete	
	4/1/17 - 6/30/17	4/1-4/30		
	7/1/17 - 9/30/17	7/1-7/31		
Lead And Copper (PBCU)		30 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/15 - 12/31/17	6/1-9/30		
	1/1/18 - 12/31/20	6/1-9/30		
Physical Parameters (PPS)		60 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/17 - 1/31/17		Complete	
	2/1/17 - 2/28/17			
	3/1/17 - 3/31/17			
	4/1/17 - 4/30/17			
	5/1/17 - 5/31/17			
	6/1/17 - 6/30/17			
	7/1/17 - 7/31/17			
	8/1/17 - 8/31/17			
Physical Parameters (PPX)		60 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	9/1/16 - 9/30/16		Complete	
	10/1/16 - 10/31/16		Complete	
	11/1/16 - 11/30/16		Complete	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPX)		60 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
	12/1/16 - 12/31/16		Complete		

Water System Facility: **ENTRY POINT - GLOBE HOLLOW WTP (WSF ID: 00700)**

Bromate (1011)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - GLOBE HOLLOW TP (GHTREAT)	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		
	1/1/17 - 3/31/17		Complete		
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				

Net Gross Alpha (4000)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - GLOBE HOLLOW TP (GHTREAT)	1/1/08 - 12/31/16		Complete		
	1/1/17 - 12/31/25				

Uranium (4006)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - GLOBE HOLLOW TP (GHTREAT)	1/1/08 - 12/31/16		Complete		
	1/1/17 - 12/31/25				

Combined Radium-226/228 (4010)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - GLOBE HOLLOW TP (GHTREAT)	1/1/08 - 12/31/16		Complete		
	1/1/17 - 12/31/25				

Inorganic Chemicals (IOCS)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - GLOBE HOLLOW TP (GHTREAT)	1/1/16 - 12/31/16		Complete		
	1/1/17 - 12/31/17				
	1/1/18 - 12/31/18				

Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - GLOBE HOLLOW TP (GHTREAT)	1/1/16 - 12/31/16		Complete		
	1/1/17 - 12/31/17		Complete		
	1/1/18 - 12/31/18				

Pesticides, Herbicides and PCBs-Phase II (SOC2)		2 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - GLOBE HOLLOW TP (GHTREAT)	1/1/14 - 12/31/16		Complete		
	1/1/17 - 12/31/19				
	1/1/20 - 12/31/22				

Pesticides, Herbicides and PCBs-Phase V (SOC5)		2 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: ENTRY POINT - GLOBE HOLLOW WTP (WSF ID: 00700)

Pesticides, Herbicides and PCBs-Phase V (SOC5) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - GLOBE HOLLOW TP (GHTREAT)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - GLOBE HOLLOW TP (GHTREAT)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		Complete
	1/1/18 - 12/31/18		

Water System Facility: ENTRY POINT - CHARTER OAK - WELL 3 (WSF ID: 00701)

Net Gross Alpha (4000) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHARTER OAK WELL 3 (WELL#3T)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		

Uranium (4006) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHARTER OAK WELL 3 (WELL#3T)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		

Combined Radium-226/228 (4010) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHARTER OAK WELL 3 (WELL#3T)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHARTER OAK WELL 3 (WELL#3T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHARTER OAK WELL 3 (WELL#3T)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		Complete
	1/1/18 - 12/31/18		

Pesticides, Herbicides and PCBs-Phase II (SOC2) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHARTER OAK WELL 3 (WELL#3T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Pesticides, Herbicides and PCBs-Phase V (SOC5) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: ENTRY POINT - CHARTER OAK - WELL 3 (WSF ID: 00701)

Pesticides, Herbicides and PCBs-Phase V (SOC5)	2 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>
<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHARTER OAK WELL 3 (WELL#3T)	1/1/14 - 12/31/16
	1/1/17 - 12/31/19
	1/1/20 - 12/31/22

Organic Chemicals (VOCS)	1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>
<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHARTER OAK WELL 3 (WELL#3T)	1/1/16 - 12/31/16
	1/1/17 - 12/31/17
	1/1/18 - 12/31/18

Water System Facility: ENTRY POINT - CHARTER OAK - WELL 4 (WSF ID: 00702)

Net Gross Alpha (4000)	1 routine (RT) per nine years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>
<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHARTER OAK WELL 4 (WELL#4T)	1/1/08 - 12/31/16
	1/1/17 - 12/31/25

Uranium (4006)	1 routine (RT) per nine years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>
<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHARTER OAK WELL 4 (WELL#4T)	1/1/08 - 12/31/16
	1/1/17 - 12/31/25

Combined Radium-226/228 (4010)	1 routine (RT) per nine years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>
<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHARTER OAK WELL 4 (WELL#4T)	1/1/08 - 12/31/16
	1/1/17 - 12/31/25

Inorganic Chemicals (IOCS)	1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>
<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHARTER OAK WELL 4 (WELL#4T)	1/1/14 - 12/31/16
	1/1/17 - 12/31/19
	1/1/20 - 12/31/22

Nitrate And Nitrite (NOX)	1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>
<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHARTER OAK WELL 4 (WELL#4T)	1/1/16 - 12/31/16
	1/1/17 - 12/31/17
	1/1/18 - 12/31/18

Pesticides, Herbicides and PCBs-Phase II (SOC2)	2 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>
<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHARTER OAK WELL 4 (WELL#4T)	1/1/14 - 12/31/16
	1/1/17 - 12/31/19
	1/1/20 - 12/31/22

Pesticides, Herbicides and PCBs-Phase V (SOC5)	2 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>
<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: ENTRY POINT - CHARTER OAK - WELL 4 (WSF ID: 00702)

Pesticides, Herbicides and PCBs-Phase V (SOC5) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHARTER OAK WELL 4 (WELL#4T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHARTER OAK WELL 4 (WELL#4T)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		Complete
	1/1/18 - 12/31/18		

Water System Facility: ENTRY POINT - LOVE LANE - WELL 5 (WSF ID: 00703)

Dieldrin (2070) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LOVE LANE WELL 5 (WELL#5T)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		Complete
	1/1/18 - 12/31/18		

Net Gross Alpha (4000) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LOVE LANE WELL 5 (WELL#5T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Uranium (4006) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LOVE LANE WELL 5 (WELL#5T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LOVE LANE WELL 5 (WELL#5T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Gross Beta Particle Activity (4100) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LOVE LANE WELL 5 (WELL#5T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Man-Made Beta Particle & Photon Emitters (4101) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LOVE LANE WELL 5 (WELL#5T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: ENTRY POINT - LOVE LANE - WELL 5 (WSF ID: 00703)

Man-Made Beta Particle & Photon Emitters (4101) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		

Tritium (4102) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LOVE LANE WELL 5 (WELL#5T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Strontium-90 (4174) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LOVE LANE WELL 5 (WELL#5T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LOVE LANE WELL 5 (WELL#5T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LOVE LANE WELL 5 (WELL#5T)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		Complete
	1/1/18 - 12/31/18		

Pesticides, Herbicides and PCBs-Phase II (SOC2) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LOVE LANE WELL 5 (WELL#5T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Pesticides, Herbicides and PCBs-Phase V (SOC5) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LOVE LANE WELL 5 (WELL#5T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LOVE LANE WELL 5 (WELL#5T)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		Complete
	1/1/18 - 12/31/18		

Water System Facility: ENTRY POINT - NEW STATE ROAD (WSF ID: 00704)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: **ENTRY POINT - NEW STATE ROAD (WSF ID: 00704)**

Net Gross Alpha (4000)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - NEW STATE ROAD WELLS 6,7,8 (WELL678T)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		
Uranium (4006)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - NEW STATE ROAD WELLS 6,7,8 (WELL678T)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		
Combined Radium-226/228 (4010)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - NEW STATE ROAD WELLS 6,7,8 (WELL678T)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - NEW STATE ROAD WELLS 6,7,8 (WELL678T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - NEW STATE ROAD WELLS 6,7,8 (WELL678T)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		Complete
	1/1/18 - 12/31/18		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - NEW STATE ROAD WELLS 6,7,8 (WELL678T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - NEW STATE ROAD WELLS 6,7,8 (WELL678T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - NEW STATE ROAD WELLS 6,7,8 (WELL678T)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		Complete
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Water System Facility: **ENTRY POINT - PARKER STREET - WELL 10 (WSF ID: 00705)**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: **ENTRY POINT - PARKER STREET - WELL 10 (WSF ID: 00705)**

Dieldrin (2070)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PARKER STREET WELL 10 (WELL#10T)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		Complete
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		
Net Gross Alpha (4000)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PARKER STREET WELL 10 (WELL#10T)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		
Uranium (4006)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PARKER STREET WELL 10 (WELL#10T)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		
Combined Radium-226/228 (4010)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PARKER STREET WELL 10 (WELL#10T)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		
Gross Beta Particle Activity (4100)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PARKER STREET WELL 10 (WELL#10T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Man-Made Beta Particle & Photon Emitters (4101)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PARKER STREET WELL 10 (WELL#10T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Tritium (4102)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PARKER STREET WELL 10 (WELL#10T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Strontium-90 (4174)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PARKER STREET WELL 10 (WELL#10T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: **ENTRY POINT - PARKER STREET - WELL 10 (WSF ID: 00705)**

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PARKER STREET WELL 10 (WELL#10T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PARKER STREET WELL 10 (WELL#10T)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		Complete
	1/1/18 - 12/31/18		

Pesticides, Herbicides and PCBs-Phase II (SOC2) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PARKER STREET WELL 10 (WELL#10T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Pesticides, Herbicides and PCBs-Phase V (SOC5) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PARKER STREET WELL 10 (WELL#10T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PARKER STREET WELL 10 (WELL#10T)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		Complete
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Water System Facility: **ENTRY POINT - PROGRESS DRIVE - WELL 11 (WSF ID: 00706)**

Net Gross Alpha (4000) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PROGRESS DRIVE WELL 11 (WELL#11T)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		

Uranium (4006) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PROGRESS DRIVE WELL 11 (WELL#11T)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		

Combined Radium-226/228 (4010) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PROGRESS DRIVE WELL 11 (WELL#11T)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: **ENTRY POINT - PROGRESS DRIVE - WELL 11 (WSF ID: 00706)**

Gross Beta Particle Activity (4100)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PROGRESS DRIVE WELL 11 (WELL#11T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Man-Made Beta Particle & Photon Emitters (4101)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PROGRESS DRIVE WELL 11 (WELL#11T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Tritium (4102)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PROGRESS DRIVE WELL 11 (WELL#11T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Strontium-90 (4174)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PROGRESS DRIVE WELL 11 (WELL#11T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PROGRESS DRIVE WELL 11 (WELL#11T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PROGRESS DRIVE WELL 11 (WELL#11T)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		Complete
	1/1/18 - 12/31/18		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PROGRESS DRIVE WELL 11 (WELL#11T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PROGRESS DRIVE WELL 11 (WELL#11T)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: ENTRY POINT - PROGRESS DRIVE - WELL 11 (WSF ID: 00706)

Organic Chemicals (VOCS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PROGRESS DRIVE WELL 11 (WELL#11T)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		Complete
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Water System Facility: CHARTER OAK - WELL 4 (WSF ID: 1158)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CHARTER OAK ST WELL (WELL#4R)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: CHARTER OAK - WELL 3 (WSF ID: 1159)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CHARTER OAK ST WELL (WELL#3R)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: LOVE LANE - WELL 5 (WSF ID: 1161)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: **LOVE LANE - WELL 5 (WSF ID: 1161)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LOVE LANE WELL 5 (WELL#5R)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: **NEW STATE ROAD - WELL 8 (WSF ID: 1311)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
NEW STATE RD WELL 8 (WELL#8R)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: **NEW STATE ROAD - WELL 7 (WSF ID: 1312)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
NEW STATE RD WELL 7 (WELL#7R)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: **NEW STATE ROAD - WELL 7 (WSF ID: 1312)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: **NEW STATE ROAD - WELL 6 (WSF ID: 1313)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
NEW STATE RD WELL 6 (WELL#6R)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: **GLOBE HOLLOW WATER TREATMENT PLANT (WSF ID: 135)**

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - GLOBE HOLLOW TP (GHTREAT)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: **PARKER STREET - WELL 10 (WSF ID: 163)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PARKER ST WELL 10 (WELL#10R)	9/1/16 - 9/30/16		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: PARKER STREET - WELL 10 (WSF ID: 163)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: PROGRESS DRIVE - WELL 11 (WSF ID: 176)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PROGRESS DR WELL 11 (WELL#11R)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: GLOBE HOLLOW RESERVOIR (WSF ID: 2125)

Bromide (1004)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (GHRAW)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: **GLOBE HOLLOW RESERVOIR (WSF ID: 2125)**

Bromide (1004)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		
Color (1905)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (GHRW)	1/1/17 - 3/31/17		Complete
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		
Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (GHRW)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		
Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (GHRW)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: **GLOBE HOLLOW RESERVOIR (WSF ID: 2125)**

Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (GHRAW)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		Complete
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		
LT2 - Cryptosporidium, Turbidity & E. coli (LT2)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (GHRAW)	9/1/16 - 9/30/16	9/14-9/18	
	10/1/16 - 10/31/16	10/17-10/21	Complete
	11/1/16 - 11/30/16	11/14-11/18	Complete
	12/1/16 - 12/31/16	12/12-12/16	
	1/1/17 - 1/31/17	1/16-1/20	Complete
	2/1/17 - 2/28/17	2/13-2/17	
	3/1/17 - 3/31/17	3/13-3/17	
	4/1/17 - 4/30/17	4/10-4/14	
	5/1/17 - 5/31/17	5/15-5/19	
	6/1/17 - 6/30/17	6/12-6/16	
	7/1/17 - 7/31/17	7/17-7/21	
	8/1/17 - 8/31/17	8/14-8/18	
Raw Water Physical Parameters (PHYR)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (GHRAW)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
Surface Water Inorganic Chemicals (RIOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (GHRAW)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		
Surface Water Pesticides (RSOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (GHRAW)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Monthly Water System Facility (WSF) Level Monitoring Requirements

--

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Water System Facility: ENTRY POINT - GLOBE HOLLOW WTP (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2002		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		9/1/2016 - 9/30/2016	N
		10/1/2016 - 10/31/2016	N
		11/1/2016 - 11/30/2016	N
		12/1/2016 - 12/31/2016	N
		1/1/2017 - 1/31/2017	
		2/1/2017 - 2/28/2017	

Water System Facility: ENTRY POINT - CHARTER OAK - WELL 3 (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine Residual, Free	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		9/1/2016 - 9/30/2016	N
		10/1/2016 - 10/31/2016	N
		11/1/2016 - 11/30/2016	N
		12/1/2016 - 12/31/2016	N
		1/1/2017 - 1/31/2017	
		2/1/2017 - 2/28/2017	

Water System Facility: ENTRY POINT - CHARTER OAK - WELL 4 (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine Residual, Free	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		9/1/2016 - 9/30/2016	N
		10/1/2016 - 10/31/2016	N
		11/1/2016 - 11/30/2016	N
		12/1/2016 - 12/31/2016	N
		1/1/2017 - 1/31/2017	
		2/1/2017 - 2/28/2017	

Water System Facility: ENTRY POINT - LOVE LANE - WELL 5 (WSFID: 00703)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine Residual, Free	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		9/1/2016 - 9/30/2016	N
		10/1/2016 - 10/31/2016	N
		11/1/2016 - 11/30/2016	N
		12/1/2016 - 12/31/2016	N

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Water System Facility: ENTRY POINT - LOVE LANE - WELL 5 (WSFID: 00703)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine Residual, Free	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	1/1/2017 - 1/31/2017		
	2/1/2017 - 2/28/2017		

Water System Facility: ENTRY POINT - NEW STATE ROAD (WSFID: 00704)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine Residual, Free	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	9/1/2016 - 9/30/2016		N
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N
	12/1/2016 - 12/31/2016		N
	1/1/2017 - 1/31/2017		
	2/1/2017 - 2/28/2017		

Water System Facility: ENTRY POINT - PARKER STREET - WELL 10 (WSFID: 00705)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine Residual, Free	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	9/1/2016 - 9/30/2016		N
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N
	12/1/2016 - 12/31/2016		N
	1/1/2017 - 1/31/2017		
	2/1/2017 - 2/28/2017		

Water System Facility: ENTRY POINT - PROGRESS DRIVE - WELL 11 (WSFID: 00706)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine Residual, Free	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	9/1/2016 - 9/30/2016		N
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N
	12/1/2016 - 12/31/2016		N
	1/1/2017 - 1/31/2017		
	2/1/2017 - 2/28/2017		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Water System Facility: **GLOBE HOLLOW WATER TREATMENT PLANT (WSFID: 135)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		9/1/2016 - 9/30/2016	Y
		10/1/2016 - 10/31/2016	Y
		11/1/2016 - 11/30/2016	Y
		12/1/2016 - 12/31/2016	Y
		1/1/2017 - 1/31/2017	
		2/1/2017 - 2/28/2017	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2011	
WATERSHED SURVEY REPORT	3/1/2017	
CROSS CONNECTION SURVEY REPORT	3/1/2017	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	
LT2 - SUBMIT BIN CLASSIFICATION	3/30/2018	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		AC001	PLYMOUTH LANE	A			Y	
		AC002	GRANDVIEW STREET	A			Y	
		ATLAS	427 HARTFORD ROAD	A	Y		Y	
		BHT	209 BUCKLANDHILLS DR	A	Y			
		BIRCHMTN	9 CAMP MEETING RD	A				Y
		BMP	9 CAMPMEETING ROAD	A	Y			
		BOTSTA	GENERATED BY BATCH	A	Y			
		BRIDLE	BRIDLEPATH LN	A				
		CMPLAINT	GENERATED BY BATCH	A	Y			
		CONYERS	77 TOLLAND TPKE	A				Y
		CRESTFLD	565 VERNON STREET	A				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		FRT	355 FERGUSON RD	A	Y			
		GHWTP	125 SPRING ST	A				Y
		HLND	51 HIGHLAND STREET	A	Y			
		HOSE5	1039 TOLLAND TPKE	A	Y			
		LC001	10 GREENHILL STREET	A			1	
		LC002	106 BRAESIDECRESCENT	A			1	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
		LC003	120 BRAESIDECRESCENT	A		1		
		LC004	134 KNOLLWOOD ROAD	A		1		
		LC005	137 SADDLEHILL ROAD	A		1		
		LC006	146 SADDLEHILL ROAD	A		1		
		LC007	150 BOBBY LANE	A		1		
		LC008	152 SADDLEHILL ROAD	A		1		
		LC009	159 SADDLEHILL ROAD	A		1		
		LC010	176 SADDLEHILL ROAD	A		1		
		LC011	18 MARKWOOD DRIVE	A		1		
		LC012	184 SADDLEHILL ROAD	A		1		
		LC013	185 SADDLEHILL ROAD	A		1		
		LC014	193 SADDLEHILL ROAD	A		1		
		LC015	200 SADDLEHILL ROAD	A		1		
		LC016	207 DARTMOUTH ROAD	A		1		
		LC017	21 MARKWOOD LANE	A		1		
		LC018	222 PARKER STREET	A		1		
		LC019	236 KNOLLWOOD ROAD	A		1		
		LC020	30 PHYLLIS ROAD	A		1		
		LC021	32 BRAESIDE CRESCENT	A		1		
		LC022	33 HAMPTON DRIVE	A		1		
		LC023	34 TONICA SPRING TR	A		1		
		LC024	368 TIMROD ROAD	A		1		
		LC025	40 WESTERLY STREET	A		1		
		LC026	45 KNOLLWOOD ROAD	A		1		
		LC027	46 JOYCE LANE	A		1		
		LC028	50 HAMPTON DRIVE	A		1		
		LC029	51 CHARIS ROAD	A		1		
		LC030	54 SPRING STREET	A		1		
		LC031	60 WESTERLY STREET	A		1		
		LC032	61 KINGSWOOD DRIVE	A		1		
		LC033	75 JOYCE LANE	A		1		
		LC034	79 LOVE LANE	A		1		
		LC035	80 SADDLEHILL ROAD	A		1		
		LC036	83 FLEMING STREET	A		1		
		LC037	85 BUTTERNUT ROAD	A		1		
		LC038	85 ERIE STREET	A		1		
		LC039	89 SADDLEHILL ROAD	A		1		
		LC040	92 SADDLEHILL ROAD	A		1		
		LC041	97 SADDLEHILL ROAD	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
		LC042	78 FARM DRIVE	A		1		
		LC043	124 COMSTOCK ROAD	A		1		
		LC044	160 SADDLEHILL ROAD	A		1		
		LC045	111 SADDLEHILL ROAD	A		1		
		LC046	8 MARKWOOD DRIVE	A		1		
		LC047	49 LOVE LANE	A		1		
		LC048	49 WESTERLY STREET	A		1		
		LC049	85 WESTERLY STREET	A		1		
		LC050	53 WESTERLY STREET	A		1		
		LC051	352 HILLIARD STREET	A		1		
		LC052	285 WOODLAND STREET	A		1		
		LC053	102 SADDLEHILL ROAD	A		1		
		LC054	192 SADDLEHILL ROAD	A		1		
		LC055	56 JOYCE LANE	A		1		
		LC056	73 WESTERLY STREET	A		1		
		LC057	31 LOVE LANE	A		1		
		LC058	61 LOVE LANE	A		1		
		LC059	82 LOOKOUT MOUNTAIN	A		1		
		LC060	315 TIMROD ROAD	A		1		
		LC061	41 TONICA SPRINGS	A		1		
		LC062	162 BOBBY LANE	A		1		
		LC063	38 HAMPTON DRIVE	A		1		
		LC064	58 PILGRIM LANE	A		1		
		LC065	19 EAST ELDRIDGE ST	A		1		
		LC066	81 WESTERLY STREET	A		1		
		LC067	28 CHARIS ROAD	A		1		
		LC068	125 WESTERLY STREET	A		1		
		LC069	16 VIEW STREET	A		1		
		LC070	252 KNOLLWOOD RD	A		1		
		LC071	113 CHESTNUT ST	A		1		
		LYDALLST	500 LYDALL STREET	A	Y			
		NEWMAIN	GENERATED BY BATCH	A	Y			
		NIKETYKES	87 HERCULES DRIVE	A				Y
		OAKLAND	460 OAKLAND STREET	A	Y	N		
		OAKLAND-INA	276 OAKLAND STREET	I	Y			
		POLICEDEPT	265 E MIDDLE TPKE	A				Y
		ROCKLEDGE	701 PORTER ST	A				Y
		SANI	263 OLCOTT STREET	A	Y			
		SENIOR	549 EAST MIDDLE TPKE	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
		TNHALL	41 CENTER STREET	A	Y			Y
		UPGLASTON	20 WOODHAVEN RD	A				Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WELL#5T	GENERATED BY BATCH	A	Y			
		WOODHVN	146 WOODHAVEN GLAST	A	Y			
00700	ENTRY POINT - GLOBE HOLLOW WTP	GHTREAT	EP - GLOBE HOLLOW TP	A				
00701	ENTRY POINT - CHARTER OAK - WELL 3	WELL#3T	EP - CHARTER OAK WEL	A				
00702	ENTRY POINT - CHARTER OAK - WELL 4	WELL#4T	EP - CHARTER OAK WEL	A				
00703	ENTRY POINT - LOVE LANE - WELL 5	WELL#5T	EP - LOVE LANE WELL	A				
00704	ENTRY POINT - NEW STATE ROAD	WELL678T	EP - NEW STATE ROAD	A				
00705	ENTRY POINT - PARKER STREET - WELL 10	WELL#10T	EP - PARKER STREET W	A				
00706	ENTRY POINT - PROGRESS DRIVE - WELL 11	WELL#11T	EP - PROGRESS DRIVE	A				
1048	FERN STREET - WELL 1	2	FERN STREET WELL 1	A				
1158	CHARTER OAK - WELL 4	WELL#4R	CHARTER OAK ST WELL	A				
1159	CHARTER OAK - WELL 3	WELL#3R	CHARTER OAK ST WELL	A				
1161	LOVE LANE - WELL 5	WELL#5R	LOVE LANE WELL 5	A				
1311	NEW STATE ROAD - WELL 8	WELL#8R	NEW STATE RD WELL 8	A				
1312	NEW STATE ROAD - WELL 7	WELL#7R	NEW STATE RD WELL 7	A				
1313	NEW STATE ROAD - WELL 6	WELL#6R	NEW STATE RD WELL 6	A				
135	GLOBE HOLLOW WATER TREATMENT PLANT	GHTREAT	EP - GLOBE HOLLOW TP	A				
136	CHARTER OAK - WELL 3 TREATMENT PLANT	3	EP - WELL 3 TP	A				
137	CHARTER OAK - WELL 4 TREATMENT PLANT	3	EP - WELL 4 TP	A				
138	LOVE LANE - WELL 5 TREATMENT PLANT	3	EP - WELL 5 TP	A				
139	NEW STATE ROAD TREATMENT PLANT	WELL678T	EP - WELLS 6, 7 & 8	A				
141	PARKER STREET - WELL 10 TREATMENT PLANT	3	EP - WELL 10 TP	A				
142	PROGRESS ST - WELL 11 TREATMENT PLANT	3	EP - WELL 11 TP	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
163	PARKER STREET - WELL 10	WELL#10R	PARKER ST WELL 10	A				
176	PROGRESS DRIVE - WELL 11	WELL#11R	PROGRESS DR WELL 11	A				
2121	LYDALL RESERVOIR NO.2	1	RESERVOIR	A				
2122	LYDALL RESERVOIR NO.1	LYDALL	RESERVOIR	A				
2123	PORTER RESERVOIR	PORTER	RESERVOIR	A				
2124	HOWARD RESERVOIR	HOWARD	RESERVOIR	A				
2125	GLOBE HOLLOW RESERVOIR	GHRAW	RESERVOIR	A				
2126	BUCKINGHAM RESERVOIR	BUCK	RESERVOIR	A				
2127	RISLEY RESERVOIR	1	RESERVOIR	A				
30039	GLOBE HOLLOW RESERVOIR							
49429	JC PENNEY STORAGE TANK 1							
49431	JC PENNEY STORAGE TANK 2							
49433	FOREST HILLS STORAGE TANK							
49435	NIKE STORAGE TANK							
49437	BUCKLAND HILLS STORAGE TANK							
49439	ROCKLEDGE STORAGE TANK 1							
49441	ROCKLEDGE STORAGE TANK 2							
49443	LOOKOUT MOUNTAIN STORAGE TANK							
49445	BIRCH MOUNTAIN TANK 1							
49447	BIRCH MOUNTAIN TANK 2							
49449	LYDALL STREET RAW WATER PUMP STATION							
49451	HIGHLAND STREET PUMP STATION							
49453	BIRCH MOUNTAIN PUMP STATION							
53706	UPPER GLASTONBURY BOOSTER STATION							
53708	UPPER GLASTONBURY BOOSTER STATION							
58147	HERCULES DR BOOSTER PUMP STATION							
60400	PARKER STREET WTP CLEARWELL							
60402	NEW STATE RD WTP CLEARWELL							

Certified Operator Information

--

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 3 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
KEARNEY II, PATRICK J.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2017
SIMARD, SCOTT	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2019
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
HOLLISTER, ROGER H.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2017
TAIT, KEVIN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2018
NOSKE, RONALD W.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2017
MADSEN, CRAIG A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2017

Water System Facility: GLOBE HOLLOW WATER TREATMENT PLANT (WSF ID: 135)

Facility Classification: CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SIMARD, SCOTT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2019
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
KEARNEY II, PATRICK J.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2017
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
DEMEO, JOSEPH P.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2019
SYME, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2019
OLSON, JAMES	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2018
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019
MONSEGLO, KENNETH	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2018

Water System Facility: CHARTER OAK - WELL 3 TREATMENT PLANT (WSF ID: 136)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SIMARD, SCOTT	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2019
KEARNEY II, PATRICK J.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2017
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
DEMEO, JOSEPH P.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2019
SYME, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2019
OLSON, JAMES	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2018
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019
MONSEGLO, KENNETH	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2018

Water System Facility: CHARTER OAK - WELL 4 TREATMENT PLANT (WSF ID: 137)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SIMARD, SCOTT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2019

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Certified Operator Information

Water System Facility: CHARTER OAK - WELL 4 TREATMENT PLANT (WSF ID: 137)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
KEARNEY II, PATRICK J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2017 12/31/2017
DEMEO, JOSEPH P.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2019
SYME, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2019
OLSON, JAMES	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019 6/30/2018
MONSEGLO, KENNETH	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2018

Water System Facility: LOVE LANE - WELL 5 TREATMENT PLANT (WSF ID: 138)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SIMARD, SCOTT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2019 12/31/2017
KEARNEY II, PATRICK J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2017 12/31/2017
DEMEO, JOSEPH P.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2019
SYME, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2019
OLSON, JAMES	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2018 6/30/2019
SOPER, EDWARD J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
MONSEGLO, KENNETH	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2018

Water System Facility: NEW STATE ROAD TREATMENT PLANT (WSF ID: 139)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SIMARD, SCOTT	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2017 12/31/2019
KEARNEY II, PATRICK J.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017 12/31/2017
DEMEO, JOSEPH P.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2019
SYME, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2019
OLSON, JAMES	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019 6/30/2018
MONSEGLO, KENNETH	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2018

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Certified Operator Information

Water System Facility: PARKER STREET - WELL 10 TREATMENT PLANT (WSF ID: 141)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SIMARD, SCOTT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2019
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
KEARNEY II, PATRICK J.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2017
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
DEMEO, JOSEPH P.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2019
SYME, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2019
OLSON, JAMES	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2018
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019
MONSEGLO, KENNETH	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2018

Water System Facility: PROGRESS ST - WELL 11 TREATMENT PLANT (WSF ID: 142)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SIMARD, SCOTT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2019
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
KEARNEY II, PATRICK J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2017
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2017
DEMEO, JOSEPH P.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2019
SYME, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2019
OLSON, JAMES	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2018
MONSEGLO, KENNETH	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2018

Water System Facility: UPPER GLASTONBURY BOOSTER STATION (WSF ID: 53708)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SIMARD, SCOTT	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2019

Contact Information

Name		Organization			Job Title	
Mr. Patrick J. Kearney II		Town of Manchester Water Dept			Administrator	
Mailing Address Line One		Mailing Address Line Two			City	State
125 Spring Street		P.O. Box 191			Manchester	CT
Zip Code	Business Phone		Extension	Fax	Mobile Phone	Emergency Phone
06045	860-647-3113			860-647-3150		860-647-3111
Email Address						
pkearney@manchesterct.gov						
Contact Role(s): Administrative Contact, Legal Contact						

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770021	MANCHESTER WATER DEPARTMENT	C	51,066	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			14,000	1,090	128		

Towns Served: GLASTONBURY, MANCHESTER, SOUTH WINDSOR, VERNON

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770041	CTWC - REDWOOD FARMS DIVISION	C	424	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			107				

Towns Served: MANCHESTER

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22				
Total Haloacetic Acids (2456)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
50 REDWOOD RD (RED001)	1/1/16 - 12/31/16	8/1-8/31	Complete		
	1/1/17 - 12/31/17	8/1-8/31			
	1/1/18 - 12/31/18	8/1-8/31			
Total Trihalomethanes (2950)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
151 RALPH RD (RED006)	1/1/16 - 12/31/16	8/1-8/31	Complete		
	1/1/17 - 12/31/17	8/1-8/31			
	1/1/18 - 12/31/18	8/1-8/31			
Total Coliform (3100)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	9/1/16 - 9/30/16		Complete		
	10/1/16 - 10/31/16		Complete		
	11/1/16 - 11/30/16		Complete		
	12/1/16 - 12/31/16		Complete		
	1/1/17 - 1/31/17		Complete		
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				
	7/1/17 - 7/31/17				
	8/1/17 - 8/31/17				
Lead And Copper (PBCU)		5 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/15 - 12/31/17	6/1-9/30	Complete		
	1/1/17 - 12/31/19	6/1-9/30			
	1/1/20 - 12/31/22	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 1/31/17		Complete		
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770041	CTWC - REDWOOD FARMS DIVISION	C	424	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			107				

Towns Served: MANCHESTER

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS) **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Physical Parameters (PPX) **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		

Nitrate And Nitrite (NOX) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA) **1 routine (RT) per six years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/19		Complete

Pesticides, Herbicides and PCBs-Phase II (SOC2) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete

Pesticides, Herbicides and PCBs-Phase V (SOC5) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) **1 (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19	1/1-12/31	Waiver

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770041	CTWC - REDWOOD FARMS DIVISION	C	424	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			107				

Towns Served: MANCHESTER

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7 PH	Daily
Start Date: 10/1/2010	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	9/1/2016 - 9/30/2016		N
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N
	12/1/2016 - 12/31/2016		N
	1/1/2017 - 1/31/2017		
	2/1/2017 - 2/28/2017		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2011	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2013	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	
CROSS CONNECTION SURVEY REPORT	3/1/2018	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
90th Percentile Copper Exceedance	1/1/01 - 12/31/03		11/7/2003		11/17/2003	
Total Coliform MCL Violation	12/1/15 - 12/31/15	2	2/10/2016		2/20/2016	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
00600	DISTRIBUTION SYSTEM	1960	DISTRIBUTION SYSTEM	A	Y			
		4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		RED001	50 REDWOOD RD	A	Y	3		Y
		RED002	53 REDWOOD RD	A	Y	3		
		RED003	92 REDWOOD RD	A	Y	3		
		RED004	89 REDWOOD RD	A	Y	3		
		RED005	5 RALPH RD	A	Y	3		
		RED006	151 RALPH RD	A	Y		Y	
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1051	WELL 2	2	WELL 2	A				
1052	WELL 1	2	WELL 1	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0770041	CTWC - REDWOOD FARMS DIVISION	C	424	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			107				

Towns Served: MANCHESTER

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier	Stage 2 Asbestos DBPR
44892	ATMOSPHERIC TANK					
44894	PRESSURE TANK					
52237	REDWOOD FARMS TREATMENT PLANT					
52687	PUMP STATION					

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
MELANSON, STEPHEN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2017
HART, WILLIAM G.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2018
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2017
ROUSSEY, ALFRED E.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019
LABIANCA, MICHAEL	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2018
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2018
BUHLER, BRANT D.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019

Water System Facility: **REDWOOD FARMS TREATMENT PLANT (WSF ID: 52237)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
RACICOT, JEFF	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2018
HART, WILLIAM G.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2018
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2017
LABIANCA, MICHAEL	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2018
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2018

Contact Information

Name		Organization			Job Title	
Mr. Paul C. Lowry		Connecticut Water Company			Superintendent	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
P. O. Box 857				East Windsor	CT	06088
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-292-2809		860-654-1903		800-208-5700	plowry@ctwater.com	
Contact Role(s): Administrative Contact						

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0770041	CTWC - REDWOOD FARMS DIVISION	C	424	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
			107					
Towns Served: MANCHESTER								
Name			Organization			Job Title		
Mr. Eric W. Thornburg			Connecticut Water Company			President/Ceo		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
93 West Main Street						Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
800-428-6008		860-669-9326		800-286-3985	ethornburg@ctwater.com			
Contact Role(s): Legal Contact								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule