Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	**MIDDLETOWN WATER DEPARTMENT**	C	41,019	L	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		10,469			532	

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094) — **1 routine (RT) per nine years**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/20		

Total Coliform (3100) — **50 routine (RT) per month**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
Select from Inventory of Active Sampling Points	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Disinfectant Byproducts - TTHM & HAA5 (DBP) — **4 routine (RT) per quarter**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
MID - WESTFIELD FIRE (70023)	7/1/16 - 9/30/16	7/1-7/31	Complete
	10/1/16 - 12/31/16	10/1-10/31	Complete
	1/1/17 - 3/31/17	1/1-1/31	Complete
	4/1/17 - 6/30/17	4/1-4/30	
	7/1/17 - 9/30/17	7/1-7/31	
MID - AEROSPACE TECH (70025)	7/1/16 - 9/30/16	7/1-7/31	Complete
	10/1/16 - 12/31/16	10/1-10/31	Complete
	1/1/17 - 3/31/17	1/1-1/31	Complete
	4/1/17 - 6/30/17	4/1-4/30	
	7/1/17 - 9/30/17	7/1-7/31	
MID - TOWER ROAD SS (70027)	7/1/16 - 9/30/16	7/1-7/31	Complete
	10/1/16 - 12/31/16	10/1-10/31	Complete
	1/1/17 - 3/31/17	1/1-1/31	Complete
	4/1/17 - 6/30/17	4/1-4/30	
	7/1/17 - 9/30/17	7/1-7/31	
909 MIDDLE STREET (70122)	7/1/16 - 9/30/16	7/1-7/31	Complete
	10/1/16 - 12/31/16	10/1-10/31	Complete
	1/1/17 - 3/31/17	1/1-1/31	Complete
	4/1/17 - 6/30/17	4/1-4/30	
	7/1/17 - 9/30/17	7/1-7/31	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	**MIDDLETOWN WATER DEPARTMENT**	C	41,019	L	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		10,469			532	

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Lead And Copper (PBCU) — **30 routine (RT) per three years**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30	
	1/1/19 - 12/31/21	6/1-9/30	

Physical Parameters (PPS) — **50 routine (RT) per month**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
Select from Inventory of Active Sampling Points	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Physical Parameters (PPX) — **50 routine (RT) per month**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
Select from Inventory of Active Sampling Points	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete

Water System Facility: **CHARLES B. BACON WATER TREATMENT PLANT (WSF ID: 161)**

Total Organic Carbon (2920) — **1 routine (RT) per month**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
EP -CHARLES B. BACON (70201)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Net Gross Alpha (4000) — **1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
EP -CHARLES B. BACON (70201)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	**MIDDLETOWN WATER DEPARTMENT**	C	41,019	L	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		10,469			532	

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Monitoring Requirements

Water System Facility: **CHARLES B. BACON WATER TREATMENT PLANT (WSF ID: 161)**

Uranium (4006)			**1 routine (RT) per three years**
Sampling Point (Sampling Point ID)	***Monitoring Period***	***Collection Period***	***Compliance Status***
EP -CHARLES B. BACON (70201)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)			**1 routine (RT) per three years**
Sampling Point (Sampling Point ID)	***Monitoring Period***	***Collection Period***	***Compliance Status***
EP -CHARLES B. BACON (70201)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Gross Beta Particle Activity (4100)			**1 routine (RT) per three years**
Sampling Point (Sampling Point ID)	***Monitoring Period***	***Collection Period***	***Compliance Status***
EP -CHARLES B. BACON (70201)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Man-Made Beta Particle & Photon Emitters (4101)			**1 routine (RT) per three years**
Sampling Point (Sampling Point ID)	***Monitoring Period***	***Collection Period***	***Compliance Status***
EP -CHARLES B. BACON (70201)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Tritium (4102)			**1 routine (RT) per three years**
Sampling Point (Sampling Point ID)	***Monitoring Period***	***Collection Period***	***Compliance Status***
EP -CHARLES B. BACON (70201)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Strontium-90 (4174)			**1 routine (RT) per three years**
Sampling Point (Sampling Point ID)	***Monitoring Period***	***Collection Period***	***Compliance Status***
EP -CHARLES B. BACON (70201)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)			**1 routine (RT) per year**
Sampling Point (Sampling Point ID)	***Monitoring Period***	***Collection Period***	***Compliance Status***
EP -CHARLES B. BACON (70201)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		
Nitrate And Nitrite (NOX)			**1 routine (RT) per year**
Sampling Point (Sampling Point ID)	***Monitoring Period***	***Collection Period***	***Compliance Status***
EP -CHARLES B. BACON (70201)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	**MIDDLETOWN WATER DEPARTMENT**	C	41,019	L	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		10,469			532	

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Monitoring Requirements

Water System Facility: **CHARLES B. BACON WATER TREATMENT PLANT (WSF ID: 161)**

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) — **2 routine (RT) per three years**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
EP -CHARLES B. BACON (70201)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) — **1 routine (RT) per year**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
EP -CHARLES B. BACON (70201)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Water System Facility: **JOHN S. ROTH WATER TREATMENT PLANT (WSF ID: 162)**

Net Gross Alpha (4000) — **1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
EP - JOHN S. ROTH TP (70202)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Uranium (4006) — **1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
EP - JOHN S. ROTH TP (70202)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010) — **1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
EP - JOHN S. ROTH TP (70202)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Inorganic Chemicals (IOCS) — **1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
EP - JOHN S. ROTH TP (70202)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Nitrate And Nitrite (NOX) — **1 routine (RT) per year**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
EP - JOHN S. ROTH TP (70202)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) — **2 routine (RT) per three years**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
EP - JOHN S. ROTH TP (70202)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	**MIDDLETOWN WATER DEPARTMENT**	C	41,019	L	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		10,469			532	

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Monitoring Requirements

Water System Facility: **JOHN S. ROTH WATER TREATMENT PLANT (WSF ID: 162)**

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) — **2 routine (RT) per three years**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) — **1 routine (RT) per year**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
EP - JOHN S. ROTH TP (70202)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Water System Facility: **MOUNT HIGBY RESERVOIR #1 (WSF ID: 2148)**

Color (1905) — **1 routine (RT) per quarter**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
MOUNT HIGBY RES (70301)	1/1/17 - 3/31/17		Complete
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Total Alkalinity (1927) — **1 routine (RT) per month**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
MOUNT HIGBY RES (70301)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Total Organic Carbon (2920) — **1 routine (RT) per month**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
MOUNT HIGBY RES (70301)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	**MIDDLETOWN WATER DEPARTMENT**	C	41,019	L	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		10,469			532	

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Monitoring Requirements

Water System Facility: **MOUNT HIGBY RESERVOIR #1 (WSF ID: 2148)**

Total Organic Carbon (2920) — **1 routine (RT) per month**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Total Coliform (3100) — **1 routine (RT) per quarter**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
MOUNT HIGBY RES (70301)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

LT2 - Cryptosporidium, Turbidity & E. coli (LT2) — **1 routine (RT) per month**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
MOUNT HIGBY RES (70301)	9/1/16 - 9/30/16	9/12-9/16	Complete
	10/1/16 - 10/31/16	10/10-10/14	
	11/1/16 - 11/30/16	11/28-12/2	Complete
	12/1/16 - 12/31/16	12/12-12/16	Complete
	1/1/17 - 1/31/17	1/16-1/20	Complete
	2/1/17 - 2/28/17	2/13-2/17	
	3/1/17 - 3/31/17	3/13-3/17	
	4/1/17 - 4/30/17	4/10-4/14	
	5/1/17 - 5/31/17	5/15-5/19	
	6/1/17 - 6/30/17	6/12-6/16	
	7/1/17 - 7/31/17	7/10-7/14	
	8/1/17 - 8/31/17	8/14-8/18	

Raw Water Physical Parameters (PHYR) — **1 routine (RT) per quarter**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
MOUNT HIGBY RES (70301)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete

Surface Water Inorganic Chemicals (RIOC) — **1 routine (RT) per year**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
MOUNT HIGBY RES (70301)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Surface Water Pesticides (RSOC) — **1 routine (RT) per year**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
MOUNT HIGBY RES (70301)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	**MIDDLETOWN WATER DEPARTMENT**	C	41,019	L	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		10,469			532	

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **CHARLES B. BACON WATER TREATMENT PLANT (WSFID: 161)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186

Start Date: 1/1/2002

Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
9/1/2016 - 9/30/2016	Y	Y
10/1/2016 - 10/31/2016	Y	Y
11/1/2016 - 11/30/2016		N
12/1/2016 - 12/31/2016	Y	Y
1/1/2017 - 1/31/2017		
2/1/2017 - 2/28/2017		

Water System Facility: **JOHN S. ROTH WATER TREATMENT PLANT (WSFID: 162)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily

Start Date: 10/1/2005

Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
9/1/2016 - 9/30/2016		N
10/1/2016 - 10/31/2016	Y	Y
11/1/2016 - 11/30/2016		N
12/1/2016 - 12/31/2016		N
1/1/2017 - 1/31/2017		
2/1/2017 - 2/28/2017		

Other Compliance Schedules

Compliance Schedule Activity	*Due Date*	*Achieved Date*
WATERSHED SURVEY REPORT	3/1/2017	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	
CROSS CONNECTION SURVEY REPORT	3/1/2018	
LT2 - SUBMIT BIN CLASSIFICATION	3/30/2019	

Water System Facility and Sampling Point Inventory

Water System Facility ID	*Water System Facility*	*Sampling Point ID*	*Sampling Point Description*	*Status*	*Total Coliform Rule*	*Lead and Copper Rule Tier*	*Asbestos*	*Stage 2 DBPR*
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		70023	MID - WESTFIELD FIRE	A	Y			Y
		70025	MID - AEROSPACE TECH	A	Y			Y
		70027	MID - TOWER ROAD SS	A	Y			Y
		70101	10 WESLYAN HILL	A	Y			
		70102	299 WADSWORTH	A	Y			
		70103	70 MAYNARD ST.	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	**MIDDLETOWN WATER DEPARTMENT**	C	41,019	L	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		10,469			532	

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Water System Facility and Sampling Point Inventory

Water System Facility ID	*Water System Facility*	*Sampling Point ID*	*Sampling Point Description*	*Status*	*Total Coliform Rule*	*Lead and Copper Rule Tier*	*Asbestos*	*Stage 2 DBPR*
		70104	99 SPRUCE ST.	A	Y			
		70105	KAPLAN ST.	A	Y			
		70106	207 WESTFIELD ST	A	Y			
		70107	222 MAIN ST.	A	Y			
		70108	533 MAIN ST.	A	Y		Y	
		70108A	MID - GENERAL LOCATI	A	Y			
		70108B	MID - GENERAL LOCATI	A	Y			
		70109	169 CROSS ST.	A	Y			
		70109A	MID - GENERAL LOCATI	A	Y			
		70109B	MID - GENERAL LOCATI	A	Y			
		70110	100 RIVER RD.	A	Y			
		70111	222 COUNTRY CLUB	I	Y			
		70112	245 DEKOVEN DR.	A	Y			
		70114	245 MAIN, CROMWE	A	Y			
		70115	15 IND. PARK PLAC	A	Y			
		70115A	MID - GENERAL LOCATI	A	Y			
		70115A ADJ	MID - GENERAL LOCATI	A	Y			
		70115B	MID - GENERAL LOCATI	A	Y			
		70115B ADJ	MID - GENERAL LOCATI	A	Y			
		70116	919 MIDDLE ST.	I	Y			Y
		70117	218 SMITH	I	Y		Y	
		70118	60 DANIELS	A	Y			
		70119	445 RANDOLH	A	Y			
		70119A	MID- 445 RANDOLPH AD	A	Y			
		70119B	MID- 445 RANDOLPH AD	A	Y			
		70120	217 SMITH STREET	A	Y		Y	
		70122	909 MIDDLE STREET	A	Y			Y
		70123	300 COUNTRY CLUB RD	A	Y			
		ADDITIONAL1	390 RIDGE RD.	A	Y			
		ADDITIONAL2	370 HUNTING HILL AVE	A	Y			
		ADDITIONAL3	311 HUNTING HILL AVE	A	Y			
		ADDITIONAL4	66 SPRING ST.	A	Y			
		ADDITIONAL5	1 WILDERMANS WAY	A	Y			
		CL001	66 VALLEY DR.	A		1		
		CL002	107 RIDGE RD.	A		3		
		CL003	122 WESTWOOD LN	A		1		
		CL004	17 COLES	A		1		
		CL005	46 TAVERN CIRCLE	A		1		
		CL006	256 BRUSH HILL	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	**MIDDLETOWN WATER DEPARTMENT**	C	41,019	L	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		10,469			532	

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Water System Facility and Sampling Point Inventory

Water System Facility ID	*Water System Facility*	*Sampling Point ID*	*Sampling Point Description*	*Status*	*Total Coliform Rule*	*Lead and Copper Rule Tier*	*Asbestos*	*Stage 2 DBPR*
		CL007	45 SNOW RIDGE	A		3		
		CL008	27 VALLEY DR.	A		1		
		CL009	311 LONG LANE	A		1		
		CL010	30 ANDERSON RD.	A		3		
		CL011	22 PHEDON PARKWAY	A		3		
		CL012	250 HUNTING HILL	A		3		
		CL013	288 PROUT HILL RD	A		1		
		CL014	9 MCCORMICK LN.	A		1		
		CL015	151 WESTWOOD LN	A		1		
		CL016	260 MERIDEN RD.	A		3		
		CL017	100 HIGH VIEW TER	A		3		
		CL018	112 MCCORMICK	A		3		
		CL019	500 HUNTING HILL	A		3		
		CL020	650 RIDGE RD.	A		3		
		CL021	10 LITTLE RIVER	A		3		
		CL022	207 CIMARRON RD.	A		1		
		CL023	95 BAILEY RD	A		3		
		CL024	43 HUNTING HILL AVE	A		3		
		CL025	8 HEMLOCK PL	A		3		
		CL026	11 LITTLE RIVER	A		3		
		CL027	70 BIRCHWOOD DR	A		3		
		CL028	85 SISK ST.	A		3		
		CL029	266 PROUT HILL RD	A		3		
		CL030	230 RIDGEWOOD RD	A		3		
		CL031	66 VALLEY DR.	A		1		
		CL032	107 RIDGE RD.	A		3		
		CL033	122 WESTWOOD LN	A		1		
		CL034	17 COLES	A		1		
		CL035	46 TAVERN CIRCLE	A		1		
		CL036	256 BRUSH HILL	A		1		
		CL037	45 SNOW RIDGE	A		3		
		CL038	27 VALLEY DR.	A		1		
		CL039	311 LONG LANE	A		1		
		CL040	30 ANDERSON RD.	A		3		
		CL041	22 PHEDON PARKWAY	A		3		
		CL042	250 HUNTING HILL	A		3		
		CL043	288 PROUT HILL RD	A		1		
		CL044	9 MCCORMICK LN.	A		1		
		CL045	151 WESTWOOD LN	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	**MIDDLETOWN WATER DEPARTMENT**	C	41,019	L	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		10,469			532	

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Water System Facility and Sampling Point Inventory

Water System Facility ID	*Water System Facility*	*Sampling Point ID*	*Sampling Point Description*	*Status*	*Total Coliform Rule*	*Lead and Copper Rule Tier*	*Asbestos*	*Stage 2 DBPR*
		CL046	260 MERIDEN RD.	A		3		
		CL047	100 HIGH VIEW TER	A		3		
		CL048	112 MCCORMICK	A		3		
		CL049	500 HUNTING HILL	A		3		
		CL050	650 RIDGE RD.	A		3		
		CL051	10 LITTLE RIVER	A		3		
		CL052	207 CIMARRON RD.	A		1		
		CL053	95 BAILEY RD	A		3		
		CL054	43 HUNTING HILL AVE	A		3		
		CL055	8 HEMLOCK PL	A		3		
		CL056	11 LITTLE RIVER	A		3		
		CL057	70 BIRCHWOOD DR	A		3		
		CL058	85 SISK ST.	A		3		
		CL059	266 PROUT HILL RD	A		3		
		CL060	230 RIDGEWOOD RD	A		3		
		CL061	11 MAPLE PL.	A				
		CL062	94 CHESTNUT ST	A				
		CL063	177 RIDGE RD.	A				
		CL064	24 SHELLEY DR.	A				
		CL065	45 GOWINN RD.	A				
		CL066	67 MARGARITE RD	A				
		CL067	65 MURRAY ST.	A				
		CL068	36 DEWEY ST.	A				
		CL069	11 CRESCENT DR.	A				
		CL070	36 SCENIC VIEW DR	A				
		CL071	1 RED BLUE RD.	A				
		CL072	26 HOTCHKISS RD.	A				
		CL073	10 STONYCREST ST.	A				
		CL074	5 FITH AVE.	A				
		CL075	3 MCKENZIE CIRCLE	A				
		CL076	30 SILVER ST.	A				
		CL077	49 LEE ST.	A				
		CL078	101 OLD MILL RD.	A				
		CL079	65 BARBARA RD.	A				
		CL080	265 BARBARA RD.	A				
		CL081	75 WESTMONT DR	A				
		CL082	68 MILITARY RD.	A				
		CL083	95 SOUTH FRONT ST	A				
		CL084	55 DOROTHY DR.	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	**MIDDLETOWN WATER DEPARTMENT**	C	41,019	L	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		10,469			532	

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Water System Facility and Sampling Point Inventory

Water System Facility ID	*Water System Facility*	*Sampling Point ID*	*Sampling Point Description*	*Status*	*Total Coliform Rule*	*Lead and Copper Rule Tier*	*Asbestos*	*Stage 2 DBPR*
		CL085	390 PINE ST.	A				
		CL086	188 FOWLER AVE	A				
		CL087	38 MEADOWOOD DR	A				
		CL088	34 PLUMB RD.	A				
		CL089	20 NORTH VIEW DR	A				
		CL090	3 OAK RIDGE DR.	A				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	CHARLES B. BACON WTP ENTRY POINT	3	EP-CHARLES B. BACON	A				
00701	JOHN S. ROTH WTP ENTRY POINT	3	EP- JOHN S. ROTH WTP	A				
1217	JOHN S ROTH WELL #1	2	JOHN S ROTH WELL #1	A				
1218	JOHN S ROTH WELL #2A	2	JOHN S ROTH WELL #2A	A				
1219	JOHN S ROTH WELL #3	2	JOHN S ROTH WELL #3	A				
1220	JOHN S ROTH WELL #4A	2	JOHN S ROTH WELL #4A	A				
1221	JOHN S ROTH WELL #5	2	JOHN S ROTH WELL #5	A				
1222	JOHN S ROTH WELL #6	2	JOHN S ROTH WELL #6	A				
1223	JOHN S ROTH WELL #7	2	JOHN S ROTH WELL #7	A				
1224	JOHN S ROTH WELL #8	2	JOHN S ROTH WELL #8	A				
1225	JOHN S ROTH WELL #9	2	JOHN S ROTH WELL #9	A				
1226	JOHN S ROTH WELL #10	2	JOHN S ROTH WELL #10	A				
161	CHARLES B. BACON WATER TREATMENT PLANT	70201	EP -CHARLES B. BACON	A				
162	JOHN S. ROTH WATER TREATMENT PLANT	70202	EP - JOHN S. ROTH TP	A				
2148	MOUNT HIGBY RESERVOIR #1	70301	MOUNT HIGBY RES	A				
2149	JOHN S ROTH WELLFIELD COMBINED	70302	INF - JOHN S ROTH TP	A				
2155	ADDER RESERVOIR	1	ADDER RESERVOIR	A				
49146	LONG HILL TANK							
49148	LONG HILL PUMP STATION							
49150	WHITE ROAD STORAGE TANK							
49152	POPLAR ROAD PUMP STATION							
49154	RANDOLPH ROAD BOOSTER PUMP STATION							
49158	LAUREL BROOK PUMP STATION							
51946	CHARLES B. BACON CLEARWELL							
51948	JOHN ROTH CLEARWELL							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	**MIDDLETOWN WATER DEPARTMENT**	C	41,019	L	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		10,469			532	

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Water System Facility and Sampling Point Inventory

Water System Facility ID	*Water System Facility*	*Sampling Point ID*	*Sampling Point Description*	*Status*	*Total Coliform Rule*	*Lead and Copper Rule Tier*	*Asbestos*	*Stage 2 DBPR*
51950	MOUNT HIGHBY PUMP STATION							
51952	JOHN ROTH PUMP STATION							
52349	MOUNT HIGBY RESERVOIR #2	1	MH RESERVOIR #2	A				
52351	MOUNT HIGBY RESERVOIR #3	1	MH RESERVOIR #3	A				
52353	CHARLES B. BACON WTP INTAKE							
55711	WASHINGTON STREET PUMP STATION							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	*Operator Type*	*Certification(s)*	*Certification Expiration*
YOUNG, ROBERT J.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019
DARLEY, DAVID	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2018
DARLEY, DEVIN J.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2017
TREVISAN, MICHAEL D.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2017
TETRAULT, THOMAS	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2017
GIULIANO, JUSTIN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2017
SLOAN, JOHN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2018

Water System Facility: **CHARLES B. BACON WATER TREATMENT PLANT (WSF ID: 161)**

Facility Classification: CLASS 4 TREATMENT PLANT

Operator Name	*Operator Type*	*Certification(s)*	*Certification Expiration*
RADOMSKI, FRANK	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
YOUNG, ROBERT J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019
FISCO, DONALD	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2018

Water System Facility: **JOHN S. ROTH WATER TREATMENT PLANT (WSF ID: 162)**

Facility Classification: CLASS 4 TREATMENT PLANT

Operator Name	*Operator Type*	*Certification(s)*	*Certification Expiration*
RADOMSKI, FRANK	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
YOUNG, ROBERT J.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019
FISCO, DONALD	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2018

Contact Information

Name	Organization	Job Title
Mr. Guy Russo	Middletown Water Department	Director

Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	**MIDDLETOWN WATER DEPARTMENT**	C	41,019	L	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		10,469			532	

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

82 Berlin Street		Middletown	CT	06457

Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-638-3510		860-343-8091		860-347-2541	guy.russo@middletownct.gov

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

http://www.ct.gov/dph/publicdrinkingwater

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830021	**CONNECTICUT VALLEY HOSPITAL**	C	2,928	S	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		70				

Towns Served: MIDDLETOWN

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)			**1 routine (RT) per nine years**
Sampling Point (Sampling Point ID)	***Monitoring Period***	***Collection Period***	***Compliance Status***
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/20		Complete

Total Haloacetic Acids (2456)			**1 routine (RT) per quarter**
Sampling Point (Sampling Point ID)	***Monitoring Period***	***Collection Period***	***Compliance Status***
WHITING FORENSIC (CVH08WF)	7/1/16 - 9/30/16	8/1-8/31	Complete
	10/1/16 - 12/31/16	11/1-11/30	Complete
	1/1/17 - 3/31/17	2/1-2/28	
	4/1/17 - 6/30/17	5/1-5/31	
	7/1/17 - 9/30/17	8/1-8/31	

Total Trihalomethanes (2950)			**1 routine (RT) per quarter**
Sampling Point (Sampling Point ID)	***Monitoring Period***	***Collection Period***	***Compliance Status***
RIVERVIEW SCH KITCHEN (CVH20RS)	7/1/16 - 9/30/16	8/1-8/31	Complete
	10/1/16 - 12/31/16	11/1-11/30	Complete
	1/1/17 - 3/31/17	2/1-2/28	
	4/1/17 - 6/30/17	5/1-5/31	
	7/1/17 - 9/30/17	8/1-8/31	

Total Coliform (3100)			**3 routine (RT) per month**
Sampling Point (Sampling Point ID)	***Monitoring Period***	***Collection Period***	***Compliance Status***
Select from Inventory of Active Sampling Points	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Lead And Copper (PBCU)			**10 routine (RT) per three years**
Sampling Point (Sampling Point ID)	***Monitoring Period***	***Collection Period***	***Compliance Status***
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30	
	1/1/19 - 12/31/21	6/1-9/30	

Physical Parameters (PPS)			**3 routine (RT) per month**
Sampling Point (Sampling Point ID)	***Monitoring Period***	***Collection Period***	***Compliance Status***
Select from Inventory of Active Sampling Points	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830021	**CONNECTICUT VALLEY HOSPITAL**	C	2,928	S	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		70				

Towns Served: MIDDLETOWN

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS) — **3 routine (RT) per month**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Physical Parameters (PPX) — **3 routine (RT) per month**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
Select from Inventory of Active Sampling Points	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete

Water System Facility: **CVH WTP ENTRY POINT (WSF ID: 00700)**

Dibromochloropropane (DBCP) (2931) — **1 routine (RT) per quarter**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
CVH WTP ENTRY POINT (3)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Net Gross Alpha (4000) — **1 routine (RT) per nine years**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
CVH WTP ENTRY POINT (3)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		

Uranium (4006) — **1 routine (RT) per nine years**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
CVH WTP ENTRY POINT (3)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		

Combined Radium-226/228 (4010) — **1 routine (RT) per nine years**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
CVH WTP ENTRY POINT (3)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		

Inorganic Chemicals (IOCS) — **1 routine (RT) per year**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
CVH WTP ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Nitrate And Nitrite (NOX) — **1 routine (RT) per year**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830021	**CONNECTICUT VALLEY HOSPITAL**	C	2,928	S	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		70				

Towns Served: MIDDLETOWN

Monitoring Requirements

Water System Facility: **CVH WTP ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX) — **1 routine (RT) per year**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
CVH WTP ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Pesticides, Herbicides and PCBs-Phase II (SOC2) — **1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
CVH WTP ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Pesticides, Herbicides and PCBs-Phase V (SOC5) — **1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
CVH WTP ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) — **1 routine (RT) per year**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
CVH WTP ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Water System Facility: **CVH WATER TREATMENT PLANT (WSF ID: 164)**

Total Organic Carbon (2920) — **1 routine (RT) per month**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
CFE - CVH TP (5)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: **CVH RESERVOIRS #3 & #4 (WSF ID: 2062)**

Total Alkalinity (1927) — **1 routine (RT) per month**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
RESERVOIR (1)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830021	**CONNECTICUT VALLEY HOSPITAL**	C	2,928	S	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		70				

Towns Served: MIDDLETOWN

Monitoring Requirements

Water System Facility: **CVH RESERVOIRS #3 & #4 (WSF ID: 2062)**

Total Alkalinity (1927) — **1 routine (RT) per month**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Total Organic Carbon (2920) — **1 routine (RT) per month**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
RESERVOIR (1)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Total Coliform (3100) — **1 routine (RT) per quarter**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
RESERVOIR (1)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Raw Water Physical Parameters (PHYR) — **1 routine (RT) per quarter**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
RESERVOIR (1)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete

Surface Water Inorganic Chemicals (RIOC) — **1 routine (RT) per year**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
RESERVOIR (1)	1/1/16 - 12/31/16		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830021	**CONNECTICUT VALLEY HOSPITAL**	C	2,928	S	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		70				

Towns Served: MIDDLETOWN

Monitoring Requirements

Water System Facility: **CVH RESERVOIRS #3 & #4 (WSF ID: 2062)**

Surface Water Inorganic Chemicals (RIOC) — **1 routine (RT) per year**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Surface Water Color and Turbidity (RPPS) — **1 routine (RT) per quarter**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
RESERVOIR (1)	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Surface Water Pesticides (RSOC) — **1 routine (RT) per year**

Sampling Point (Sampling Point ID)	*Monitoring Period*	*Collection Period*	*Compliance Status*
RESERVOIR (1)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **CVH WTP ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine Residual, Free	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily

Start Date: 7/1/2003

Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
9/1/2016 - 9/30/2016		N
10/1/2016 - 10/31/2016		N
11/1/2016 - 11/30/2016		N
12/1/2016 - 12/31/2016		N
1/1/2017 - 1/31/2017		
2/1/2017 - 2/28/2017		

Water System Facility: **CVH WATER TREATMENT PLANT (WSFID: 164)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186

Start Date: 1/1/2002

Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
9/1/2016 - 9/30/2016	Y	Y
10/1/2016 - 10/31/2016	Y	Y
11/1/2016 - 11/30/2016	Y	Y
12/1/2016 - 12/31/2016	Y	Y
1/1/2017 - 1/31/2017		
2/1/2017 - 2/28/2017		

Other Compliance Schedules

Compliance Schedule Activity	*Due Date*	*Achieved Date*

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830021	**CONNECTICUT VALLEY HOSPITAL**	C	2,928	S	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		70				

Towns Served: MIDDLETOWN

Other Compliance Schedules

Compliance Schedule Activity	*Due Date*	*Achieved Date*
CROSS CONNECTION SURVEY REPORT	3/1/2017	
WATERSHED SURVEY REPORT	3/1/2017	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
LT2 - SUBMIT SOURCE MONITORING PLAN	7/1/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	

Water System Facility and Sampling Point Inventory

Water System Facility ID	*Water System Facility*	*Sampling Point ID*	*Sampling Point Description*	*Status*	*Total Coliform Rule*	*Lead and Copper Rule Tier*	*Asbestos*	*Stage 2 DBPR*
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		CVH01BH	BATTELL HALL	A	Y	3		
		CVH02RV	RIVERVIEW BLDG#8	A	Y			
		CVH03MH	MERRITT HALL	A	Y	3		
		CVH04JS	CJTS	A				
		CVH05RH	RUSSELL HALL	A		3		
		CVH06EC	EDDY CENTER	A		3		
		CVH07CG	COTTAGE #7	A		3		
		CVH08WF	WHITING FORENSIC	A		3	Y	Y
		CVH09DC	CHILD DAY CARE	A		3		
		CVH10DH	DUTCHER HALL	A		3		
		CVH11SH	SHEW HALL	A		3		
		CVH12CB	COTTER BUILDING	A		3		
		CVH13SP	SHEPHERD HOME	A		3		
		CVH14SC	SUPT. COTTAGE	A		3		
		CVH15GO	GROUNDS OFFICE	A		3		
		CVH16ON	COTTAGE #16	A		3		
		CVH17WH	WOODWARD HALL	A		3		
		CVH18DT	DUTTON HOME	A		3		
		CVH19QW	RIVERVIEW BLDG#4	A		3		
		CVH20RS	RIVERVIEW SCH KITCHE	A		3		Y
		CVH21MA	COTTAGE #31	A		3		
		CVH22BE	COTTAGE #32	A		3		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	CVH WTP ENTRY POINT	3	CVH WTP ENTRY POINT	A				
164	CVH WATER TREATMENT PLANT	5	CFE - CVH TP	A				
2061	CVH RESERVOIR #2	1	RESERVOIR	A				
2062	CVH RESERVOIRS #3 & #4	1	RESERVOIR	A				
2063	CVH RESERVOIR #5	1	RESERVOIR	A				
2064	CVH RESERVOIR #6	1	RESERVOIR	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830021	**CONNECTICUT VALLEY HOSPITAL**	C	2,928	S	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		70				

Towns Served: MIDDLETOWN

Water System Facility and Sampling Point Inventory

Water System Facility ID	*Water System Facility*	*Sampling Point ID*	*Sampling Point Description*	*Status*	*Total Coliform Rule*	*Lead and Copper Rule Tier*	*Asbestos*	*Stage 2 DBPR*
30044	CVH RESERVOIRS #3 & #4							
49793	CVH TREATMENT PLANT STORAGE TANK							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 1 DISTRIBUTION SYSTEM

Operator Name	*Operator Type*	*Certification(s)*	*Certification Expiration*
TURGEON, MICHAEL Y.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2017
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
MROZOWSKI, JOSEPH	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
TIRONE, STEPHEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2017
		WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019

Water System Facility: **CVH WATER TREATMENT PLANT (WSF ID: 164)**

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	*Operator Type*	*Certification(s)*	*Certification Expiration*
TURGEON, MICHAEL Y.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2017
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
MROZOWSKI, JOSEPH	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
TIRONE, STEPHEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2017
		WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019

Contact Information

Name	Organization	Job Title
Ms. Miriam E. Delphin-Rittmon	Dmhas	Commissioner

Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
410 Capitol Avenue	PO Box 341431	Hartford	CT	06134

Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-418-7000				860-418-7000	miriam.delphin-rittmon@ct.gov

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

http://www.ct.gov/dph/publicdrinkingwater

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.