

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,108	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					9,537

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

Monitoring Requirements

Water System Facility: **STEWART WTP BLENDED INFLUENT (WSF ID: 00500)**

Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
STEWART WTP BLENDED INFLUENT (1)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

LT2 - Cryptosporidium, Turbidity & E. coli (LT2)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
STEWART WTP BLENDED INFLUENT (1)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Raw Water Physical Parameters (PHYR)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
STEWART WTP BLENDED INFLUENT (1)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/20		

Total Coliform (3100)	25 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,108	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,537	

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		25 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
	6/1/17 - 6/30/17				
	7/1/17 - 7/31/17				
	8/1/17 - 8/31/17				
Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
NAUGATUCK POLICE DEPT (2061)	7/1/16 - 9/30/16	8/1-8/31	Complete		
	10/1/16 - 12/31/16	11/1-11/30	Complete		
	1/1/17 - 3/31/17	2/1-2/28			
	4/1/17 - 6/30/17	5/1-5/31			
	7/1/17 - 9/30/17	8/1-8/31			
2714 SOUTH MAIN (2150)	7/1/16 - 9/30/16	8/1-8/31	Complete		
	10/1/16 - 12/31/16	11/1-11/30	Complete		
	1/1/17 - 3/31/17	2/1-2/28			
	4/1/17 - 6/30/17	5/1-5/31			
	7/1/17 - 9/30/17	8/1-8/31			
65 TUCKER HILL RD (2156)	7/1/16 - 9/30/16	8/1-8/31	Complete		
	10/1/16 - 12/31/16	11/1-11/30	Complete		
	1/1/17 - 3/31/17	2/1-2/28			
	4/1/17 - 6/30/17	5/1-5/31			
	7/1/17 - 9/30/17	8/1-8/31			
MIDDLEBURY EDGE (2158)	7/1/16 - 9/30/16	8/1-8/31	Complete		
	10/1/16 - 12/31/16	11/1-11/30	Complete		
	1/1/17 - 3/31/17	2/1-2/28			
	4/1/17 - 6/30/17	5/1-5/31			
	7/1/17 - 9/30/17	8/1-8/31			
Lead And Copper (PBCU)		30 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/16	6/1-9/30	Complete		
	1/1/17 - 12/31/19	6/1-9/30			
	1/1/20 - 12/31/22	6/1-9/30			
Physical Parameters (PPS)		25 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 1/31/17		Complete		
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,108	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,537	

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	25 routine (RT) per month
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period Collection Period Compliance Status</i>
	7/1/17 - 7/31/17
	8/1/17 - 8/31/17

Physical Parameters (PPX)	25 routine (RT) per month
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period Collection Period Compliance Status</i>
Select from Inventory of Active Sampling Points	9/1/16 - 9/30/16 Complete
	10/1/16 - 10/31/16 Complete
	11/1/16 - 11/30/16 Complete
	12/1/16 - 12/31/16 Complete

Water System Facility: **STEWART WTP ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)	1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period Collection Period Compliance Status</i>
STEWART ENTRY POINT (3)	1/1/14 - 12/31/16 Complete
	1/1/17 - 12/31/19
	1/1/20 - 12/31/22

Uranium (4006)	1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period Collection Period Compliance Status</i>
STEWART ENTRY POINT (3)	1/1/14 - 12/31/16 Complete
	1/1/17 - 12/31/19
	1/1/20 - 12/31/22

Combined Radium-226/228 (4010)	1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period Collection Period Compliance Status</i>
STEWART ENTRY POINT (3)	1/1/14 - 12/31/16 Complete
	1/1/17 - 12/31/19
	1/1/20 - 12/31/22

Inorganic Chemicals (IOCS)	1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period Collection Period Compliance Status</i>
STEWART ENTRY POINT (3)	1/1/16 - 12/31/16 Complete
	1/1/17 - 12/31/17
	1/1/18 - 12/31/18

Nitrate And Nitrite (NOX)	1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period Collection Period Compliance Status</i>
STEWART ENTRY POINT (3)	1/1/16 - 12/31/16 Complete
	1/1/17 - 12/31/17
	1/1/18 - 12/31/18

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	2 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period Collection Period Compliance Status</i>
STEWART ENTRY POINT (3)	1/1/14 - 12/31/16 Complete
	1/1/17 - 12/31/19

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,108	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,537	

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

Monitoring Requirements

Water System Facility: **STEWART WTP ENTRY POINT (WSF ID: 00700)**

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
STEWART ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Water System Facility: **INDIAN FIELD WELLFIELD ENTRY POINT (WSF ID: 00701)**

Net Gross Alpha (4000) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Uranium (4006) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/15 - 12/31/17		
	1/1/18 - 12/31/20		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
---	--------------------------	--------------------------	--------------------------

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,108	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,537	

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

Monitoring Requirements

Water System Facility: **INDIAN FIELD WELLFIELD ENTRY POINT (WSF ID: 00701)**

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Water System Facility: **MARKS BROOK WELLFIELD ENTRY POINT (WSF ID: 00702)**

Net Gross Alpha (4000)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		Complete
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Uranium (4006)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		Complete
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Combined Radium-226/228 (4010)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		Complete
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,108	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,537	

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

Monitoring Requirements

Water System Facility: MARKS BROOK WELLFIELD ENTRY POINT (WSF ID: 00702)

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		Complete
	1/1/18 - 12/31/18		

Water System Facility: INDIAN FIELDS WELL #1 (WSF ID: 1344)

E. Coli (3014) 1 triggered (TG) per period

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
INDIAN FIELDS WELL #1 (2)	10/5/16 - 10/10/16		

E. Coli (3014) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
INDIAN FIELDS WELL #1 (2)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		Complete
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: INDIAN FIELDS WELL #2 (WSF ID: 1345)

E. Coli (3014) 1 triggered (TG) per period

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
INDIAN FIELDS WELL #2 (2)	10/5/16 - 10/10/16		

E. Coli (3014) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
INDIAN FIELDS WELL #2 (2)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		Complete
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,108	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,537	

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

Monitoring Requirements

Water System Facility: INDIAN FIELDS WELL #2 (WSF ID: 1345)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: MARKS BROOK WELL #1 (WSF ID: 1372)

E. Coli (3014)	1 triggered (TG) per period		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MARKS BROOK WELL #1 (2)	10/5/16 - 10/10/16		Out of Service

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MARKS BROOK WELL #1 (2)	9/1/16 - 9/30/16		Out of Service
	10/1/16 - 10/31/16		Out of Service
	11/1/16 - 11/30/16		Out of Service
	12/1/16 - 12/31/16		Out of Service
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: MARKS BROOK WELL #2 (WSF ID: 1373)

E. Coli (3014)	1 triggered (TG) per period		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MARKS BROOK WELL #2 (2)	10/5/16 - 10/10/16		Out of Service

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MARKS BROOK WELL #2 (2)	9/1/16 - 9/30/16		Out of Service
	10/1/16 - 10/31/16		Out of Service
	11/1/16 - 11/30/16		Out of Service
	12/1/16 - 12/31/16		Out of Service
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,108	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,537	

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

Monitoring Requirements

Water System Facility: **MARKS BROOK WELL #2 (WSF ID: 1373)**

E. Coli (3014) **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: **STEWART WATER TREATMENT PLANT (WSF ID: 172)**

Total Organic Carbon (2920) **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - STEWART TP (5)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: **STRAITSVILLE RESERVOIR (WSF ID: 2095)**

Color (1905) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
STRAITSVILLE RESERVOIR (1)	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Total Alkalinity (1927) **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
STRAITSVILLE RESERVOIR (1)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,108	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,537	

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

Monitoring Requirements

Water System Facility: STRAITSVILLE RESERVOIR (WSF ID: 2095)

Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
STRAITSVILLE RESERVOIR (1)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
STRAITSVILLE RESERVOIR (1)	7/1/16 - 9/30/16		
	10/1/16 - 12/31/16		
	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		
Raw Water Physical Parameters (PHYR)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
STRAITSVILLE RESERVOIR (1)	7/1/16 - 9/30/16		
	10/1/16 - 12/31/16		
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
STRAITSVILLE RESERVOIR (1)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		
Surface Water Pesticides (RSOC)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
STRAITSVILLE RESERVOIR (1)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Monthly Water System Facility (WSF) Level Monitoring Requirements

--

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,108	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,537	

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

Water System Facility: **STEWART WTP ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 7/1/2003		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		9/1/2016 - 9/30/2016	N
		10/1/2016 - 10/31/2016	N
		11/1/2016 - 11/30/2016	N
		12/1/2016 - 12/31/2016	N
		1/1/2017 - 1/31/2017	
		2/1/2017 - 2/28/2017	

Water System Facility: **INDIAN FIELD WELLFIELD ENTRY POINT (WSFID: 00701)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 7/1/2003		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		9/1/2016 - 9/30/2016	N
		10/1/2016 - 10/31/2016	N
		11/1/2016 - 11/30/2016	N
		12/1/2016 - 12/31/2016	N
		1/1/2017 - 1/31/2017	
		2/1/2017 - 2/28/2017	

Water System Facility: **MARKS BROOK WELLFIELD ENTRY POINT (WSFID: 00702)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 7/1/2003		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		9/1/2016 - 9/30/2016	N
		10/1/2016 - 10/31/2016	N
		11/1/2016 - 11/30/2016	N
		12/1/2016 - 12/31/2016	N
		1/1/2017 - 1/31/2017	
		2/1/2017 - 2/28/2017	

Water System Facility: **STEWART WATER TREATMENT PLANT (WSFID: 172)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		9/1/2016 - 9/30/2016	Y
		10/1/2016 - 10/31/2016	Y
		11/1/2016 - 11/30/2016	Y
		12/1/2016 - 12/31/2016	Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,108	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,537	

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

Water System Facility: STEWART WATER TREATMENT PLANT (WSFID: 172)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		1/1/2017 - 1/31/2017	Y
		2/1/2017 - 2/28/2017	Y

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2017	
WATERSHED SURVEY REPORT	3/1/2017	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	
LT2 - SUBMIT BIN CLASSIFICATION	3/30/2019	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
00500	STEWART WTP BLENDED INFLUENT	1	STEWART WTP BLENDED	A				
00600	DISTRIBUTION SYSTEM	2042	PROSPECT TANK	A	Y			
		2050	60 GABRIEL DRIVE	A	Y			
		2050-OLD	18 MAY STREET	I	Y			
		2051	1354 NEW HAVEN RD	A	Y			
		2052	2714 SOUTH MAIN	A	Y			
		2052OLD	2636 S MAIN ST	I	Y			
		2052X	2636 SOUTH MAIN STRE	I	Y			
		2053	41 MAPLE ST	A	Y			
		2054	159 QUINN ST	I	Y			
		2055	250 MEADOW ST	A	Y			
		2056	HORIZON HOMES	A				
		2057	253 PROSPECT ST	A	Y			
		2058	MESHADDOCK PUMP STA	A				
		2059	85 SPRING ROAD	A	Y			
		2059-OLD	MAPLE HILL PUMP STA	I	Y			
		2060	165 TAWNY THRUSH RD	A	Y			
		2061	NAUGATUCK POLICE DEP	A				Y
		20801	165 BEACON HILL COMM	A		N		
		20802	33 COUNTRY HILL RD	A		2		
		20803	173 BEACON HILL COMM	A		N		
		20804	176 BEACON HILL COMM	A		2		
		20805	60 CAMBRIDGE CT	A		N		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,108	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,537	

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
		20806	270 ANDREW AVE	A		3		
		20807	69 CAMBRIDGE CT	A		N		
		20808	205 ANDREW AVE	A		3		
		20809	25 COUNTRY HILL RD	A		2		
		20810	163 BEACON HILL COMM	A		2		
		20811	148 BEACON HILL COMM	A		N		
		20812	169 BEACON HILL COMM	A		N		
		20813	164 BEACON HILL COMM	A		N		
		20814	144 BEACON HILL COMM	A		N		
		20815	167 BEACON HILL COMM	A		2		
		20816	170 BEACON HILL COMM	A		N		
		20817	268 ANDREW AVE	A		3		
		20818	73 COUNTRY HILL RD	A		2		
		20819	91 COUNTRY HILL RD	A		2		
		20820	261 ANDREW AVE	A		3		
		20821	85 COUNTRY HILL RD	A		2		
		20822	67 COUNTRY HILL RD	A		2		
		20823	89 COUNTRY HILL RD	A		2		
		20824	29 CARRIAGE DR	A		1		
		20825	67 CARRIAGE DR	A		1		
		20826	66 CARRIAGE DR	A		1		
		20827	69 CARRIAGE DR	A		1		
		20828	14 CARRIAGE DR	A		1		
		20829	61 CARRIAGE DR	A		1		
		20830	10 CARRIAGE DR	A		1		
		20831	17 CARRIAGE DR	A		1		
		20832	21 AETNA ST	A	Y	2		
		20833	54 CLIFF ST	A	Y	1		
		20834	8 TUDOR LN	A	Y	1		
		20835	3 TUDOR LN	A	Y	1		
		20836	12 TUDOR LN	A	Y	1		
		20837	13 TUDOR LN	A	Y	1		
		20838	14 TUDOR LN	A	Y	1		
		20839	15 TUDOR LN	A	Y	1		
		20840	16 TUDOR LN	A	Y	1		
		20841	18 TUDOR LN	A		1		
		20842	10 TUDOR LN	A	Y	1		
		20843	23 TUDOR LN	A	Y	1		
		20844	25 TUDOR LN	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,108	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,537	

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
		20845	27 TUDOR LN	A	Y	1		
		20846	29 TUDOR LN	A	Y	1		
		20847	33 TUDOR LN	A	Y	1		
		20848	30 TUDOR LN	A	Y	1		
		20849	32 TUDOR LN	A	Y	1		
		20850	24 TUDOR LN	A	Y	1		
		20851	28 TUDOR LN	A	Y	1		
		20852	59 CARRIAGE DR	A	Y	1		
		20853	16 VINCENT PL	A	Y	1		
		20854	14 VINCENT PL	A	Y	1		
		20855	36 CELENTANO DR	A	Y	1		
		20856	34 CELENTANO DR	A	Y	1		
		20857	38 CELENTANO DR	A	Y	1		
		20858	28 CELENTANO DR	A	Y	1		
		20859	101 CELENTANO DR	A	Y	1		
		20860	99 CELENTANO DR	A	Y	1		
		20861	105 CELENTANO DR	A	Y	1		
		20862	107 CELENTANO DR	A	Y	1		
		20863	109 CELENTANO DR	A	Y	1		
		20864	113 CELENTANO DR	A	Y	1		
		20865	115 CELENTANO DR	A	Y	1		
		20866	119 CELENTANO DR	A	Y	1		
		20867	121 CELENTANO DR	A	Y	1		
		20868	40 CELENTANO DR	A	Y	1		
		20869	375 ALLERTON FARMS	A	Y	1		
		20870	379 ALLERTON FARMS	A	Y	1		
		20871	387 ALLERTON FARMS	A	Y	1		
		20872	10 VINCENT PL	A		1		
		20873	12 VINCENT PL	A	Y	1		
		20874	6 VINCENT PL	A	Y	1		
		20875	8 VINCENT PL	A	Y	1		
		20876	203 OSBORN RD	A	Y	1		
		20877	5 VINCENT PL	A	Y	1		
		20878	19 PUTTING GREEN LN	A	Y	1		
		20879	22 PUTTING GREEN LN	A	Y	1		
		20880	27 PUTTING GREEN LN	A	Y	1		
		20881	32 PUTTING GREEN LN	A	Y	1		
		20882	67 PUTTING GREEN LN	A	Y	1		
		20883	185 BLUEBIRD DR	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,108	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,537	

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
		20884	162 BLUEBIRD DR	A	Y	1		
		20885	252 BLUEBIRD DR	A	Y	1		
		20886	248 BLUEBIRD DR	A	Y	1		
		20887	240 BLUEBIRD DR	A	Y	1		
		20888	229 BLUEBIRD DR	A	Y	1		
		20889	225 BLUEBIRD DR	A	Y	1		
		20890	217 BLUEBIRD DR	A	Y	1		
		20891	221 BLUEBIRD DR	A	Y	1		
		20892	209 BLUEBIRD DR	A	Y	1		
		20893	213 BLUEBIRD DR	A	Y	1		
		20894	194 BLUEBIRD DR	A	Y	1		
		20895	198 BLUEBIRD DR	A	Y	1		
		20896	202 BLUEBIRD DR	A	Y	1		
		20897	205 BLUEBIRD DR	A	Y	1		
		20898	209 BLUEBIRD DR	A	Y	1		
		20899	224 BLUEBIRD DR	A	Y	1		
		20900	190 BLUEBIRD DR	A	Y	1		
		20901	197 BLUEBIRD DR	A	Y	1		
		20902	232 BLUEBIRD DR	A	Y	1		
		20903	236 BLUEBIRD DR	A	Y	1		
		20904	237 BLUEBIRD DR	A	Y	1		
		20905	101 BLUEBIRD DR	A	Y	1		
		20906	112 BLUEBIRD DR	A	Y	1		
		20907	118 BLUEBIRD DR	A	Y	1		
		20908	125 BLUEBIRD DR	A	Y	1		
		20909	126 BLUEBIRD DR	A	Y	1		
		20910	131 BLUEBIRD DR	A	Y	1		
		20911	137 BLUEBIRD DR	A	Y	1		
		20912	138 BLUEBIRD DR	A	Y	1		
		2096	NEW MAINS	A	Y			
		2150	2714 SOUTH MAIN	A	Y			Y
		2150X	930 STRAITS TPKE	I	Y	3		Y
		2156	65 TUCKER HILL RD	A	Y			Y
		2157	BLUEBERRY KNOLL	A	Y			
		2158	MIDDLEBURY EDGE	A				Y
		2165	PD 200 SOUTHFORD ROA	A	Y			
		4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,108	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,537	

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
00700	STEWART WTP ENTRY POINT	3	STEWART ENTRY POINT	A				
00701	INDIAN FIELD WELLFIELD ENTRY POINT	3	ENTRY POINT	A				
00702	MARKS BROOK WELLFIELD ENTRY POINT	3	ENTRY POINT	A				
1344	INDIAN FIELDS WELL #1	2	INDIAN FIELDS WELL #	A				
1345	INDIAN FIELDS WELL #2	2	INDIAN FIELDS WELL #	A				
1372	MARKS BROOK WELL #1	2	MARKS BROOK WELL #1	A				
1373	MARKS BROOK WELL #2	2	MARKS BROOK WELL #2	A				
171	MARKS BROOK TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
172	STEWART WATER TREATMENT PLANT	5	EP - STEWART TP	A				
174	INDIAN FIELDS TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
2091	LONG HILL RESERVOIR	1	LONG HILL RESERVOIR	A				
2092	TWITCHELL RESERVOIR	1	RESERVOIR	A				
2093	BEACON VALLEY BROOK DIVERSION	1	RESERVOIR	A				
2094	MOODY RESERVOIR	1	RESERVOIR	A				
2095	STRAITSVILLE RESERVOIR	1	STRAITSVILLE RESERVO	A				
2096	MULBERRY RESERVOIR	1	MULBERRY RESERVOIR	A				
2097	HOPKINS DIVERSION	1	RESERVOIR	A				
2098	UPPER CANDEE RESERVOIR	1	UPPER CANDEE RESERVO	A				
2099	LOWER CANDEE RESERVOIR	1	RESERVOIR	A				
2100	MESHADDOCK BROOK DIVERSION	1	RESERVOIR	A				
30047	MULBERRY RESERVOIR							
30048	TWITCHELL RESERVOIR							
30049	LOWER CANDEE RESERVOIR							
30050	STRAITSVILLE RESERVOIR							
49033	SHADDUCK ROAD BOOSTER PUMP STATION							
49035	FERNDALE TANK							
49333	PROSPECT TANK							
50969	KELLY ROAD PUMP STATION							
50971	HYDROPNEUMATIC TANKS - KELLY RD							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,108	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,537	

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier	Stage 2 Asbestos DBPR
51785	FAWN MEADOW STORAGE TANKS					
52090	LOWER ROAD TANK					
52092	GREAT HILL RD TANK					
52094	CLARK TANK					
52096	HUNTERS MOUNTAIN RD TANK					
52098	MAPLE HILL TANK					
52100	MULBERRY #1 TANK					
52102	MULBERRY #2 TANK					
52104	MESHADDOCK TANK					
52106	STEWART CLEARWELL					
52108	MESHADDOCK PUMP STATION					
52110	HILLSIDE PUMP STATION					
52112	FIRST INDUSTRIAL PARK PUMP STATION					
52114	SECOND INDUSTRIAL PARK PUMP STATION					
52116	OSBORN RD PUMP STATION					
52118	MAPLE HILL PUMP STATION					
52120	SHARON AVE PUMP STATION					
52122	HUNTERS MTN RD PUMP STATION					
52124	PROSPECT PUMP STATION					
52126	STEWART PUMP STATION					
56999	CLARK ROAD PUMP STATION					
59390	TUCKER HILL PUMP STATION					

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
CORBETT, PATRICK M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2018
PEIL, THEODORE W.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
PHIPPS, RYAN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2020
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,108	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,537	

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

Certified Operator Information

Water System Facility: MARKS BROOK TREATMENT STATION (WSF ID: 171)

Facility Classification: CLASS 2 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
CORBETT, PATRICK M.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2018
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
WINSLOW, KEITH	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2017
PEIL, THEODORE W.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
PHIPPS, RYAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2020

Water System Facility: STEWART WATER TREATMENT PLANT (WSF ID: 172)

Facility Classification: CLASS 4 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
KEAN, DANIEL C.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
DOWD, PETER S.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2017
		DISTRIBUTION SYSTEM OPERATOR IN TRAINING	6/30/2017
HINTZ, JONATHAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2018

Water System Facility: INDIAN FIELDS TREATMENT STATION (WSF ID: 174)

Facility Classification: CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
CORBETT, PATRICK M.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2018
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
PEIL, THEODORE W.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
PHIPPS, RYAN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2020
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019

Contact Information

Name		Organization			Job Title	
Mr. Reed M. Reynolds		Connecticut Water Company			Superintendent	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
		19 Executive Drive		Farmington	CT	06032
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-664-6241		860-673-3740		860-286-5700	rreynolds@ctwater.com	

Contact Role(s): **Administrative Contact**

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,108	P	SW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
						9,537		
Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY								
Name			Organization			Job Title		
Mr. Eric W. Thornburg			Connecticut Water Company			President/Ceo		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
93 West Main Street						Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
800-428-6008		860-669-9326		800-286-3985	ethornburg@ctwater.com			
Contact Role(s): Legal Contact								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0880031	IDLEVIEW MOBILE HOME PARK	C	138	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			58				

Towns Served: NAUGATUCK

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/13 - 12/31/21				
Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		
	1/1/17 - 3/31/17				
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				
Lead And Copper (PBCU)		5 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/15 - 12/31/17	6/1-9/30			
	1/1/18 - 12/31/20	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17				
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				
Physical Parameters (PPX)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		
Water System Facility: ENTRY POINT (WSF ID: 00700)					
Net Gross Alpha (4000)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/08 - 12/31/16		Complete		
	1/1/17 - 12/31/25				
Uranium (4006)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/08 - 12/31/16		Complete		
	1/1/17 - 12/31/25				
Combined Radium-226/228 (4010)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/08 - 12/31/16		Complete		
	1/1/17 - 12/31/25				
Inorganic Chemicals (IOCS)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/16 - 12/31/18				
	1/1/19 - 12/31/21				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0880031	IDLEVIEW MOBILE HOME PARK	C	138	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			58				

Towns Served: NAUGATUCK

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	2/7/2017
SUBMIT CCR CERTIFICATION FORM	8/9/2017	
CROSS CONNECTION EXEMPTION	3/1/2021	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		IDLEVIEW001	UNIT #25	A	Y	3		
		IDLEVIEW002	UNIT #14	A		1		
		IDLEVIEW003	UNIT #42	A		3		
		IDLEVIEW004	UNIT #27	A		1		
		IDLEVIEW005	UNIT #24	A		3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
406	WELL #1	2	WELL #1	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0880031	IDLEVIEW MOBILE HOME PARK	C	138	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		58					

Towns Served: NAUGATUCK

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
407	WELL #2	2	WELL #2	A				
423	IDLEVIEW TREATMENT PLANT							
49628	IDLEVIEW PRESSURE TANK							

Certified Operator Information

Water System Facility: **IDLEVIEW TREATMENT PLANT (WSF ID: 423)**

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LEMAY, REALE D.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2017
		WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
KILBOURN, ERIC	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2019

Contact Information

Name		Organization			Job Title		
Ms. Marcia Stemm		Harmony Acres Mobile Home Park			President		
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
68 Cooke Street					Plainville	CT	06062
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-747-6881		860-410-1095		800-822-6690	MHPARKSINC@aol.com		

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule